

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 NYREG 1000-00000-00041111
7 8 9 14 15 25 26 30 57 CAT 58 5

CON'T
01 REPORT SOURCE L05000244012582020882
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
02 On January 25, 1982, due to the events described in LER 82-003, fire watches posted
03 as a result of 8 inoperable fire detection zones were evacuated from site. Therefore
04 these eight zones were inoperable without firewatches which is a violation of a LCO
05 defined in Technical Specification 3.14.1.1a and reportable based on Technical
06 Specification 6.9.2.a(2).

09 SYSTEM CODE AB CAUSE CODE X CAUSE SUBCODE X COMPONENT CODE ZZZZZZ COMP. SUBCODE Z VALVE SUBCODE Z
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER 82 EVENT YEAR 82 SEQUENTIAL REPORT NO. 004 OCCURRENCE CODE 01 REPORT TYPE T REVISION NO. 0
21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN X FUTURE ACTION Z EFFECT ON PLANT Z SHUTDOWN METHOD Z HOURS 0000 ATTACHMENT SUBMITTED Y NPR-4 FORM SUB. N PRIME COMP. SUPPLIER Z COMPONENT MANUFACTURER Z999
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10 The fire watches were evacuated at 1044 hours in accordance with procedure SC-1.5.
11 Following the event, fire watches were returned to the 8 inoperable fire detection
12 zones at 1600 hours.

15 FACILITY STATUS X % POWER 000 OTHER STATUS 30 Site Emergency METHOD OF DISCOVERY Z DISCOVERY DESCRIPTION 32 NA
7 8 9 10 12 13 44 45 46 80

16 ACTIVITY RELEASED Z CONTENT Z AMOUNT OF ACTIVITY 35 NA LOCATION OF RELEASE 36 NA
7 8 9 10 11 44 45 80

17 PERSONNEL EXPOSURES NUMBER 000 TYPE Z DESCRIPTION 39 NA
7 8 9 11 12 13 80

18 PERSONNEL INJURIES NUMBER 000 DESCRIPTION 41 NA
7 8 9 11 12 80

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z DESCRIPTION 43 NA
7 8 9 10 80

20 PUBLICITY ISSUED N DESCRIPTION 45 NA
7 8 9 10 80

8202230442 820208
PDR ADOCK 05000244
S PDR

NRC USE ONLY

GPO 67-925

DATE February 8, 1982

TO Ronald C. Haynes

Attachment to LER 82-004/01T-0
Rochester Gas and Electric Corporation
R. E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

On January 25, 1982 at 0925 hours, an unusual event occurred at Ginna Station which is described in LER 82-003. As a result of this event, a site emergency was declared at 1044 hours which required site evacuation. Fire watch personnel in accordance with plant procedure SC-1.5, step 3.5, were evacuated from site.

Prior to this event, eight (8) fire detection zones were in the inoperable status. Three (3) of these zones were inoperable due to the reasons presented in LER 81-018. The remaining five (5) zones were inoperable due to welding/grinding activities by site construction personnel within the areas protected by these fire detection zones. Fire watches had been posted to these eight (8) zones to satisfy the requirements of Technical Specification 3.14.1.1a.

Following recovery from the event described in LER 82-003, fire watch personnel were returned to the eight (8) inoperable fire detection zones at 1600 hours. Therefore the zones did not have fire watches posted for a total of 5 hours and 16 minutes. The five (5) fire detection zones inoperable due to welding/grinding activities were returned to service and the posted fire watches were removed from the areas.

At no time during this event, was there any need for the use of the eight (8) inoperable fire detection zones or fire suppression systems for these zones.