



LER 82-04

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (Continued)

10 seconds after the loss occurred. This restoration of off-site power came about due to the closing of the Oswego-NMP1 breaker. Subsequently, the diesel generators were secured. The safety concerns of this event were minimal since more than the required number of diesel generators came into operation, and because of the very short length of time (approx. 10 seconds) that off-site power was removed.