

FEB 8 1982

DCS MS-016

Docket Nos. 50-317  
and 50-318

Mr. A. E. Lundvall, Jr.  
Vice President - Supply  
Baltimore Gas & Electric Company  
P. O. Box 1475  
Baltimore, Maryland 21203



Dear Mr. Lundvall:

We have completed our review of the Inservice Test Program (ITP) for the safety-related pumps and valves at Calvert Cliffs Units 1 and 2. The licensee has stated that the ITP for Calvert Cliffs Unit 1 will comply with the requirements of the ASME Boiler and Pressure Vessel Code, Section XI, 1974 Edition, and Addenda through Summer 1975, except as addressed in the enclosed evaluation. This program began on May 8, 1975 and will terminate on May 8, 1985. The licensee has stated that the ITP for Calvert Cliffs Unit 2 will comply with the ASME Boiler and Pressure Vessel Code, Section XI, 1977 Edition, and Addenda through Summer 1978, except as addressed in the enclosed evaluation. This program began on August 1, 1980 and will terminate on April 1, 1987.

The enclosed evaluation of the Calvert Cliffs ITP addresses the code reliefs which have been requested by BG&E.

The NRC has provided the following relief from ASME Boiler and Pressure Vessel Code, Section XI:

- o relief from the observation of certain pump performance parameters since these parameters are not readily observable or are meaningless,
- o relief from pump, high differential pressure alert and action levels in that overly tight levels result in unnecessary pump testing,
- o relief from monthly pump performance tests; safety related pumps are to be run monthly and performance tested quarterly,
- o relief from valve exercising where: (1) if the valve is in its safety-related position and not required to change position for safe shutdown of the plant or following an accident, no valve exercising is required, or (2) if the valve is required to be operated for safe shutdown of the plant or following an accident, alternate testing has been reviewed and found to be acceptable.

OFFICE	.....	.....	.....	.....	.....	.....	.....
SURNAME	8202260319	820208	.....	.....	.....	.....	.....
DATE	PDR	ADOCK	05000317	.....	.....	.....	.....
	P		PDR	.....	.....	.....	.....

The approval of the above relief expires on May 8, 1985 for Calvert Cliffs Unit 1 and April 1, 1987 for Calvert Cliffs Unit 2.

A copy of the Federal Register Notice is also enclosed.

Sincerely,

Original signed by  
Robert A. Clark

Robert A. Clark, Chief  
Operating Reactors Branch #3  
Division of Licensing

Enclosure:  
As stated

cc: See next page

DISTRIBUTION:

Docket File  
NRC PDR  
L PDR  
NSIC  
TERA  
ORB#3 Rdg  
DEisenhut  
JOlshinski  
PMKreutzer-3  
DJaffe  
RAClark  
OELD  
I&e-4  
GDeegan-8  
ACRS-10  
OPA  
Secretariat  
RDiggs  
JHeltemes  
Gray File  
DChaney  
JPage

*no legal objection  
To admit and FR notice  
convey*

*AD, OR, DL  
T. Novak  
1/19/82*

OFFICE	ORB#3:DL	ORB#3:DL	ORB#1:DL	MEB	OELD	ORB#3:DL	MEB
SURNAME	PMKreutzer	DJaffe	DChaney	JPage	RAClark	RAClark	RAClark
DATE	1/21/82	1/13/82	1/19/82	1/15/82	1/21/82	1/19/82	1-19-82



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

DISTRIBUTION:  
Docket File  
ORB#3 Rdg  
PMKreutzer

Docket No. 50-317/318

Docketing and Service Section  
Office of the Secretary of the Commission

SUBJECT: BALTIMORE GAS AND ELECTRIC COMPANY, Calvert Cliffs Nuclear  
Power Plant, Unit Nos. 1 and 2

Two signed originals of the Federal Register Notice identified below are enclosed for your transmittal to the Office of the Federal Register for publication. Additional conformed copies ( 12 ) of the Notice are enclosed for your use.

- ☐ Notice of Receipt of Application for Construction Permit(s) and Operating License(s).
- ☐ Notice of Receipt of Partial Application for Construction Permit(s) and Facility License(s): Time for Submission of Views on Antitrust Matters.
- ☐ Notice of Availability of Applicant's Environmental Report.
- ☐ Notice of Proposed Issuance of Amendment to Facility Operating License.
- ☐ Notice of Receipt of Application for Facility License(s); Notice of Availability of Applicant's Environmental Report; and Notice of Consideration of Issuance of Facility License(s) and Notice of Opportunity for Hearing.
- ☐ Notice of Availability of NRC Draft/Final Environmental Statement.
- ☐ Notice of Limited Work Authorization.
- ☐ Notice of Availability of Safety Evaluation Report.
- ☐ Notice of Issuance of Construction Permit(s).
- ☐ Notice of Issuance of Facility Operating License(s) or Amendment(s).
- ☒ Other: Notice of granting of relief from ASME Section XI Inservice  
Testing Requirements. Referenced documents have been provided  
PDR.

Division of Licensing  
Office of Nuclear Reactor Regulation

Enclosure:  
As Stated

OFFICE	→	ORB#3:DP				
SURNAME	→	PMKreutzer/pn				
DATE	→	2/9/82				