

FEBRUARY 08 1982

DISTRIBUTION:

Docket File  
NRC PDR  
L PDR

TERA  
NSIC  
ORB#4 Rdg  
Deisenhut  
MPadovan  
Ringram  
Hornstein  
EBlackwood

OELD  
AEOD  
IE-3  
ACRS-10  
Gray File

Docket No. 50-312

Mr. J. J. Mattimoe  
Assistant General Manager and  
Chief Engineer  
Sacramento Municipal Utility District  
6201 S Street  
P. O. Box 15830  
Sacramento, California 95813



Dear Mr. Mattimoe:

SUBJECT: PROCEDURES FOR MANUALLY INITIATING HPI FLOW THROUGH THE NORMAL  
MAKE-UP NOZZLE

The Rancho Seco ASLAB, in their memorandum and Order dated October 7, 1981, required the staff's review of your HPI nozzle analysis. As part of this review, we requested additional information in our February 3, 1982 letter. In response to our letter, your February 4, 1982 letter indicated that no additional thermal cycling of the normal make-up nozzle is expected as a result of manually actuated HPI. You subsequently told us by telephone on February 8, 1982 that the source of HPI water when actuated manually is the make-up tank instead of the borated water storage tank normally used for the automatically actuated HPI. In support of the information given to us verbally, please give us a copy of your procedure for manually initiating HPI after a reactor trip. We request your submittal within 15 days of receipt of this letter.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore OMB clearance is not required under P.L. 96-511.

Sincerely,

\*ORIGINAL SIGNED BY  
JOHN F. STOLZ\*

John F. Stolz, Chief  
Operating Reactors Branch #4  
Division of Licensing

cc:  
See next page

OFFICE	ORB#4:DL	C-ORB#4:DL					
SURNAME	MPadovan/cb	JStolz					
	2/8/82	2/8/82					
8203040269 820208 PDR ADOCK 05000312 PDR							
OFFICIAL RECORD COPY							
USGPO: 1981-330-960							



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

February 8, 1982

Docket No. 50-312

Mr. J. J. Mattimoe  
Assistant General Manager and  
Chief Engineer  
Sacramento Municipal Utility District  
6201 S Street  
P. O. Box 15830  
Sacramento, California 95813


Dear Mr. Mattimoe:

SUBJECT: PROCEDURES FOR MANUALLY INITIATING HPI FLOW THROUGH THE NORMAL  
MAKE-UP NOZZLE

The Rancho Seco ASLAB, in their memorandum and Order dated October 7, 1981, required the staff's review of your HPI nozzle analysis. As part of this review, we requested additional information in our February 3, 1982 letter. In response to our letter, your February 4, 1982 letter indicated that no additional thermal cycling of the normal make-up nozzle is expected as a result of manually actuated HPI. You subsequently told us by telephone on February 8, 1982 that the source of HPI water when actuated manually is the make-up tank instead of the borated water storage tank normally used for the automatically actuated HPI. In support of the information given to us verbally, please give us a copy of your procedure for manually initiating HPI after a reactor trip. We request your submittal within 15 days of receipt of this letter.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore OMB clearance is not required under P.L. 96-511.

Sincerely,

  
John F. Stolz, Chief  
Operating Reactors Branch #4  
Division of Licensing

cc:  
See next page

cc w/enclosure(s):

David S. Kaplan, Secretary and  
General Counsel  
6201 S Street  
P. O. Box 15830  
Sacramento, California 95813

Sacramento County  
Board of Supervisors  
827 7th Street, Room 424  
Sacramento, California 95814

Business and Municipal Department  
Sacramento City-County Library  
828 I Street  
Sacramento, California 95814

Regional Radiation Representative  
EPA Region IX  
215 Fremont Street  
San Francisco, California 94111

Mr. Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
Suite 220, 7910 Woodmont Avenue  
Bethesda, Maryland 20814

Thomas Baxter, Esq.  
Shaw, Pittman, Potts & Trowbridge  
1800 M Street, N.W.  
Washington, D. C. 20036

Herbert H. Brown, Esq.  
Lawrence Coe Lanpher, Esq.  
Hill, Christopher and Phillips, P.C.  
1900 M Street, N.W.  
Washington, D. C. 20036

Helen Hubbard  
P. O. Box 63  
Sunol, California 94586

Christopher Ellison, Esq.  
Dian Grueuich, Esq.  
California Energy Commission  
1111 Howe Avenue  
Sacramento, California 95825

Ms. Eleanor Schwartz  
California State Office  
600 Pennsylvania Avenue, S.E., Rm. 201  
Washington, D. C. 20003

Docketing and Service Section  
Office of the Secretary  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Resident Inspector/Rancho Seco  
c/o U. S. N. R. C.  
14410 Twin Cities Road  
Herald, CA 95638

Dr. Richard F. Cole  
Atomic Safety & Licensing Board Panel  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. Frederick J. Shon  
Atomic Safety and Licensing Board  
Panel  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Elizabeth S. Bowers, Esq.  
Chairman, Atomic Safety and  
Licensing Board Panel  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Atomic Safety and Licensing Board  
Panel  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Sacramento Municipal Utility  
District

- 2 -

Atomic Safety and Licensing Appeal  
Board Panel  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. Robert H. Engelken, Regional Administrator  
U. S. Nuclear Regulatory Commission, Region V  
1990 N. California Boulevard, Suite 202  
Walnut Creek, California 94596

Alan S. Rosenthal, Chairman  
Atomic Safety and Licensing  
Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. John H. Buck  
Atomic Safety and Licensing  
Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Christine N. Kohl  
Atomic Safety and Licensing  
Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

California Department of Health  
ATTN: Chief, Environmental  
Radiation Control Unit  
Radiological Health Section  
714 P Street, Room 498  
Sacramento, California 95814