NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: [| | | | |] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Field	Value
Licensee Code (2)	N J O C P 1
License Number (3)	0 0 - 0 0 0 0 0 - 0 0
License Type (4)	4 1 1 1 1
CAT (5)	
Report Source (6)	L
Docket Number (7)	0 5 0 0 0 2 1 9
Event Date (8)	0 1 2 1 8 2
Report Date (9)	0 2 2 2 8 2

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

During surveillance testing, RBCCW Drywell Isolation Valve, V-5-167, failed to fully close. Although one isolation valve failed, the second isolation valve V-5-166 would have isolated the penetration. Due to the above the safety significance of this event is considered minimal.

System Code (11)	Cause Code (12)	Cause Subcode (13)	Component Code (14)	Comp. Subcode (15)	Valve Subcode (16)
S D	X	Z	V A L V O P	A	Z

LER/RO Report Number (17)	Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
	8 2	—	0 0 4	/	0 3	L	—	0

Action Taken (18)	Future Action (19)	Effect on Plant (20)	Shutdown Method (21)	Hours (22)	Attachment Submitted (23)	NPRD-4 Form Sub. (24)	Prime Comp. Supplier (25)	Component Manufacturer (26)
X	X	Z	Z	0 0 0 0	Y	Y	N	L 2 0 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

The cause was attributed to a lack of stem/stem nut lubrication and/or a packing problem. The stem nut, stem and the bearing were lubricated the valve was repacked and the torque switch setting was raised. Lube checks of similar Limitorque valve operators will be incorporated into the PM program.

Facility Status (28)	% Power (29)	Other Status (30)	Method of Discovery (31)	Discovery Description (32)
G	0 0 0	NA	B	Surveillance Test

Activity Released (33)	Content of Release (34)	Amount of Activity (35)	Location of Release (36)
Z	Z	NA	NA

PERSONNEL EXPOSURES

Number (37)	Type (38)	Description (39)
0 0 0	Z	NA

PERSONNEL INJURIES

Number (40)	Description (41)
0 0 0	NA

LOSS OF OR DAMAGE TO FACILITY

Type (42)	Description (43)
Z	NA

PUBLICITY

Issued (44)	Description (45)
N	NA

NRC USE ONLY

8203050340 820222
PDR ADOCK 05000219
S PDR

NAME OF PREPARER: Hamid Pirooz
PHONE: 609-971-4418