

# LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N C B E P 1 2 0 0 - 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5  
7 8 9 14 15 25 26 30 57 CAT 58

CON'T  
0 1 L 6 0 5 0 - 0 3 2 5 7 0 1 1 8 8 2 8 0 2 1 6 8 2 9  
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10  
0 2 | During plant operation, 1B reactor recirculation pump tripped while plant technicians |  
0 3 | were investigating a slight indication variance of ATWS-RPT instrument, 1-B21-LTM- |  
0 4 | N025B-2, to other redundant indications. Following a determination of the cause of |  
0 5 | the trip, the pump was restarted and power was returned to that prior to the trip. |  
0 6 | The pump was out of service for 34 minutes. This event did not affect the health and |  
0 7 | safety of the public. |

0 8 | Technical Specifications 3.4.1.1, 6.9.1.9b | 80

SYSTEM CODE I B 11 CAUSE CODE A 12 CAUSE SUBCODE C 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE T 15 VALVE SUBCODE Z 16  
9 10 11 12 13 18 19 20  
17 LER/RO REPORT NUMBER 8 2 21 22 0 1 1 24 26 27 0 3 28 29 L 30 31 0 32  
ACTION TAKEN X 18 FUTURE ACTION X 19 EFFECT ON PLANT B 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NRPD-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER R 3 6 9 26  
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27  
1 0 | Involved plant technicians used a milliamp meter instead of a DC voltmeter to read |  
1 1 | the N025B-2 output, causing the instrument to drive downscale and trip the pump. |  
1 2 | N025B-2 was determined operable and the pump was restarted. Involved personnel have |  
1 3 | been counseled to utilize correct test equipment and instrument vendor literature |  
1 4 | while troubleshooting instrument problems. | 80

FACILITY STATUS E 28 % POWER 0 9 9 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operational Event 32  
7 8 9 10 12 13 44 45 46 80  
ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36  
7 8 9 10 11 44 45 80  
PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39  
7 8 9 11 12 13 80  
PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41  
7 8 9 11 12 80  
LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
7 8 9 10 80

PUBLICITY N 44 DESCRIPTION 8203080619 820216 45  
ISSUED N 44 PDR ADOCK 05000325 PDR  
7 8 9 10 80  
NAME OF PREPARER M. J. Pastva, Jr. PHONE (919) 457-9521  
80 91