NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01	LICENSEE CODE: N J S G S 2 (2) LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3) LICENSE TYPE: 4 1 1 1 1 (4) CAT (5)
01 CON'T	REPORT SOURCE: L (6) DOCKET NUMBER: 0 5 0 0 0 3 1 1 (7) EVENT DATE: 0 2 1 1 8 2 (8) REPORT DATE: 0 2 2 4 8 2 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On February 11, 1982, in response to the NRC Request for Additional Information on
03 Seismic Qualification of the Auxiliary Feedwater System, it was discovered that the
04 check valves 1AF71 and 1AF72 and associated piping were not seismically analyzed
05 and protected. As per Technical Specification 6.9.1.8.i the NRC Resident Inspector
06 was notified immediatley, with written notification submitted within 24 hours.
07
08

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
C H (11)	B (12)	A (13)	Z Z Z Z Z Z (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 2	—	0 0 7	/	0 1	X	—	1

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
F (18)	X (19)	Z (20)	Z (21)	0 0 0 0	Y (23)	N (24)	N (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 A protective steel structure will be provided off the seismic wall. These new
11 structures will also incorporate seismic guides for additional protection of these
12 valves. DCR 1EC-1404 has been initiated and issued to the Station to make these
13 improvements/enhancements. A Supplemental Report will be submitted upon completion.
14

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
15	E (28)	1 0 0 (29)	N/A	C (31)	Engineering Review

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
16	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
17	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
18	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
19	Z (42)	NA

PUBLICITY

ISSUED DESCRIPTION (45)

20

NRC USE ONLY

8203160411 820308
PDR ADOCK 05000272
S PDR

NAME OF PREPARER Dickey PHONE: 609-935-0998

GPO 917-926