



## Omaha Public Power District

1623 HARNEY • OMAHA, NEBRASKA 68102 • TELEPHONE 536-4000 AREA CODE 402

March 10, 1982  
LIC-82-119



Mr. Robert A. Clark, Chief  
U. S. Nuclear Regulatory Commission  
Office of Nuclear Reactor Regulation  
Division of Licensing  
Operating Reactors Branch No. 3  
Washington, D.C. 20555

Reference: Docket No. 50-285

Dear Mr. Clark:

The Omaha Public Power District's letter dated December 28, 1981 provided an update regarding the District's implementation of TMI Action Plan (NUREG-0737) requirements. Specifically, the letter stated that the Fort Calhoun Station containment hydrogen monitors (Item II.F.1.6) were installed and the calibration of the monitors was to be completed by January 1, 1982, consistent with the Commission's schedule. During the calibration procedure, the hydrogen analyzers were damaged, requiring that they be returned to the vendor for repair. Based upon the vendor's repair schedule, the District expects to have the hydrogen monitors returned, reinstalled, and operational by June 1, 1982. The damage to the Fort Calhoun Station hydrogen monitors has been previously discussed with the District's NRC Project Manager and this letter serves to formally notify the Commission.

Sincerely,

W. C. Jones  
Division Manager  
Production Operations

WCJ/KJM/TLP/RWS:jmm

cc: LeBoeuf, Lamb, Leiby & MacRae  
1333 New Hampshire Avenue, N.W.  
Washington, D.C. 20036

A046  
Silo