

CONFIRMATION OF ACTION LETTER

MAR 11 1982

Docket No. 50-346

Toledo Edison Company
ATTN: Mr. Richard P. Crouse
Vice President
Nuclear
Edison Plaza
300 Madison Avenue
Toledo, OH 43652



Gentlemen:

This refers to the telephone discussions between Mr. R. P. Crouse and Mr. C. E. Norelius and others of this office on March 10, 1982, regarding the potential problem of cracking in the safe end nozzle on the makeup system and the possible wear on the related thermal sleeve at B&W facilities. With regard to this matter we understand that you submitted on March 9, 1982 information to the Office of Nuclear Reactor Regulation justifying continued operation. We also understand that with regard to this problem you will:

1. Shutdown the reactor on March 13, 1982 for a normal refueling outage,
2. Inspect thermal sleeves, gaps, and welds in the safe end nozzle area by RT and special UT using the equivalent procedure/techniques which have been developed for Crystal River and Oconee sites by B&W,
3. Obtain Region III concurrence prior to restart of the reactor from the refueling outage.

Please inform us immediately if your understanding of this matter is different from that stated above.

Is/ for A.B. Davis

8203170324 820311
PDR ADDCK 05000346
P PDR

James G. Keppler
Regional Administrator

cc: T. D. Murray, Station
Superintendent
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
Harold W. Kohn, Power Siting
Commission
Helen W. Evans, State of Ohio
Robert M. Quillin, Ohio Department
of Health

*IEO1
3/16*

OFFICE	RIII	<i>W.H.L.</i>	<i>JS</i>	<i>DM</i>	<i>D</i>	<i>JS</i>	<i>16</i>
SURNAME	Jackiw/Is	Little	Streeter	Notelins	Davis	Keppler	
DATE	3/11/82	3/11/82	3/11	3/11	3/11	3/11	

CONFIRMATION OF ACTION LETTER