

Attachment 1

PROPOSED TECHNICAL SPECIFICATION CHANGE

8203230472 820315  
PDR ADGCK 05000339  
P PDR

condensate and sampling systems where the presence of the radioactive tracer is expected to warrant such controls. VEPCO will take special precautions to minimize radiation exposure and contamination during both the handling of the radioactive tracer prior to injection and the taking of system samples following injection of the tracer. VEPCO will ensure that all regulatory requirements for liquid discharge are met during disposal of all sampling effluents and when reestablishing continuous blowdown from the steam generators after completion of the studies.

- (10) No later than October 11, 1980, VEPCO shall submit a design for the backup overcurrent protection system for containment electrical penetrations for Commission review and approval. The backup system shall be installed and operational prior to resuming power operation following the ~~first~~ <sup>SECOND</sup> refueling outage.
- (11) No later than November 1, 1980, VEPCO shall implement the fire protection modifications as described in the Commission Safety Evaluation Report, "Fire Protection Program for North Anna Power Station, Units 1 and 2", dated February 1979 (see Amendment No. 8 to NPF-4 for the North Anna Power Station, Unit No. 1) except implementation of the modification of the alternate shutdown system shall be implemented no later than April 1, 1981.
- (12) VEPCO shall implement the following modifications related to IE Bulletin 79-27 "Loss of Non-Class IE Instrumentation and Control Power System Bus During Operation" as specified in VEPCO's letters, dated May 30 and July 9, 1980 on the following schedule:
- (a) Prior to startup following the November 1, 1980 outage for Fire Protection Modifications:
- Item 2 - Alternate Feed for Annunciators
  - Item 3, 4, 7 and 8: Alternate Power Supply for Vital SOV and Vital Instrument Panels.
  - Item 9 and 10: Loss of Voltage for Semi-Vital Buses
- (b) Within six months from date of issuance of this license:
- Item 6: Alternate Power to Gaitronics
  - Items 11, 12, 13 and 14: Change to Voltage Indication - 125 VDC Buses
- (c) Prior to startup following the first refueling outage:
- Items 1 and 5: Diverse Power Supply for  $T_h$  and  $T_c$

## ELECTRICAL POWER SYSTEMS

### NORMALLY DE-ENERGIZED POWER CIRCUITS

#### LIMITING CONDITION FOR OPERATION

---

3.8.2.7 All circuits shown in Table 3.8-3 shall be de-energized.

APPLICABILITY: MODES 1, 2, 3, 4

#### ACTION:

With one or more of the circuits shown in Table 3.8-3 energized, de-energize the circuit(s) within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

#### SURVEILLANCE REQUIREMENTS

---

4.8.2.7 At least once per 31 days, when operating in Modes 1-4, verify that all of the circuits in Table 3.8-3 are de-energized by noting the position of the appropriate circuit breakers.

TABLE 3.8-3

NORMALLY DE-ENERGIZED POWER CIRCUITS

<u>Penetration</u>	<u>DEVICE NUMBER AND LOCATION</u>	<u>LOAD</u>
2C-2 2D-2	480 V SWGR 2H Compartment N-16	Refueling and Maintenance Circuit
2F1-2	480 V MCC 2B1-1 Cubicle B4R	Reactor Cavity Manipulator Crane (2-MH-CR-5)
2F1-2	480 V MCC 2B1-1 Cubicle B4L	Fuel Transfer Control Cabinet (2-EI-CB-92)
2F1-2	480 V MCC 2B1-1 Cubicle C2R	RCC Fixture Change (2-RC-R-18)
11A-2	480 V MCC 2C1-1 Cubicle B3	RC Annulus Crane (2-MH-CR-19)
11B-2	480 V MCC 2C2-1 Cubicle A2R	Stud Tensioner, Portable Crane Receptacle
12E-2	480 V MCC 2B1-2 Cubicle C1L	RC Stage Basket
23C-2	480 V MCC 2B1-2 Cubicle A3	RC Polar Crane (2-MH-CR-01)
4A-2	480 V MCC 2H1-2S Cubicle G2	Loop 3 Hot Leg Stop Vv (MOV-2594) *
4A-2	480 V MCC 2H1-2S Cubicle H2	Loop 3 Cold Leg Stop Vv (MOV-2595)*
4B-2	480 V MCC 2H1-2S Cubicle H3	Loop 2 Hot Leg Stop Vv (MOV-2592)*
4B-2	480 V MCC 2H1-2S Cubicle J1	Loop 2 Cold Leg Stop Vv (MOV-2593)*
11A-2	480 V MCC 2H1-2S Cubicle F3	Loop 2 Bypass Stop Vv (MOV-2586)
11B-2	480 V MCC 2H1-2S Cubicle G1	Loop 3 Bypass Stop Vv (MOV-2587)
21E-2	480 V MCC 2H1-2S Cubicle F1	Loop 1 Bypass Stop Vv (MOV-2585)
22B-2	480 V MCC 2H1-2S Cubicle F2	Loop 1 Hot Leg Stop Vv (MOV-2590)*
22B-2	480 V MCC 2H1-2S Cubicle G3	Loop 1 Cold Leg Stop Vv (MOV-2591)*

\* See Special Test Exception 3.10.4

SAFETY EVALUATION  
PROPOSED TECHNICAL SPECIFICATION CHANGE  
TO ELECTRICAL PENETRATION SECONDARY PROTECTION  
NORTH ANNA UNIT 2

Due to both the large quantity of circuits requiring modification and testing, and the physical constraints of working in the electrical penetration area imposed by the number of required design changes to be implemented, completion of the secondary protection installation until the second refueling has been requested. In Section 8.8 of Supplement No. 10 to the North Anna Unit 2 Safety Evaluation Report (attached) the NRC concluded that the design of the primary protection system for the electrical penetrations was acceptable. Based on this evaluation, continued operation of North Anna Unit 2 pending complete installation of secondary protection devices is warranted.

8.8

Overcurrent Protection For Containment Electrical Penetrations

On August 3, 1979 we issued our position requiring containment electrical penetrations to have overcurrent protection that meets the recommendations of Regulatory Guide 1.63, Revision 1 "Electric Penetration Assemblies in Containment Structures for Light-Water-Cooled Nuclear Power Plants." We were subsequently advised that the North Anna Power Station Unit 2 design would not meet the single failure criterion and that some of the primary protective devices would not provide protection over the complete range of faults. Following further discussions with the applicant, we allowed the applicant to use the approach taken on the Diablo Canyon Nuclear Power Station, Units 1 and 2 (Docket Nos. 50-275 and 50-323) for an acceptable design.

The applicant submitted additional information that describes the installed primary overcurrent protection and the modifications to protection of the containment penetrations that carry power, control and instrumentation circuits. This information included listings of the power, control, and instrumentation circuits and their penetrations. Also, for each type of penetration, time-current heating curves that were matched with current-time operation curves for the primary protective devices were provided. A listing was provided giving the maximum available fault currents for each type of penetration. This information shows that the protective devices would operate in sufficient time even when carrying the maximum available fault currents to protect the penetrations from overheating and consequent loss of integrity. We conclude that the primary protection system for the penetrations as described in the submitted information is acceptable.

Our position also states that an acceptable design for the backup overcurrent protection system shall be submitted within six months after the date of licensing. Further, this backup system shall be installed and operational prior to startup following the first refueling outage. The applicant has agreed to comply with these requirements and we find this commitment acceptable. Accordingly, the Technical Specifications will reflect these requirements.

**ELECTRICAL PENETRATION PROTECTION  
CONTROL CIRCUITS  
(PRIMARY AND SECONDARY)**

**NORTH ANNA POWER STATION - UNIT 2  
VIRGINIA ELECTRIC AND POWER COMPANY**



**STONE & WEBSTER ENGINEERING CORPORATION  
BOSTON, MASSACHUSETTS**

JOB ID#	PENETRATION		LOAD	TIME-CURRENT CURVE		PRIMARY PROTECTIVE DEVICE	NOTES & COMMENTS	SECONDARY PROTECTIVE DEVICE	NOTES & COMMENTS
	TYPE	CONDUCTOR		120% SK(C)-	FULL LOAD AMPS				
2F1-2	IC	10-ANG	Fuel Transfer Control Cab (2-EI-CB-92)	IC-1	3.9A	Fuse Busman NON-15A		Fuse Busman NON-15A*	
6B-2	IB	14-ANG	a) Stem Limit Switch (SLS MDV-2865A)	IB-1	175mA	Breaker GE TQB 5A		Breaker GE TE-15A	
			b) Loop 1 Red CYC	IB-2A	300mA	Fuse Busman ABC 10A	See Note "A" below for all circuits with IB-3 time current curve.	Breaker GE TE-15A	
			c) Loop 1 x Conn (MDV-2585)	IB-3	175mA	Fuse Busman NON-15A		Fuse Busman NON-15A	
			d) Hot Leg Isol (MDV-2590)	IB-3	175mA	Fuse Busman NON-15A		Fuse Busman NON-15A	
			e) Cold Leg Isol (MDV-2591)	IB-3	175mA	Fuse Busman NON-15A		Fuse Busman NON-15A	
			f) St. Generator Surface Sample (TV-88212A)	IB-4	447mA	Breaker GE TE 15A		Breaker GE TE-15A*	
			g) Acc TK 1 CD LG (MDV-2865A)	IB-3	175mA	Fuse Busman NON-15A		Fuse Busman NON-15A	
			h) ACC TK 1 CD LG (MDV-2865A)	IB-5	175mA	Fuse Busman ABC 3A		Breaker GE TE-15A	
			i) ACC TK 2 CD LG (MDV-2865B)	IB-3	175mA	Fuse Busman NON-15A		Fuse Busman NON-15A	
			j) Acc TK 2 CD LG (MDV-2865B)	IB-5	175mA	Fuse Busman ABC 3A		Breaker GE TE-15A	
			k) Loop 1 Regen Hx Outlet (HCV-2200A)	IB-5	20mA	Fuse Busman ABC 3A		Breaker GE TE-15A	
			l) Loop 1 Regen Hx Outlet (HCV-2200A)	IB-6	20mA	Breaker GE THED-15A		Breaker GE THED-15A*	
			m) Loop 1 Regen Hx Outlet (HCV-2200A)	IB-2E	20mA	Fuse Busman ABC 10A		Breaker GE THED-15A	
			n) Loop 2 Regen Hx Outlet (HCV-2200B)	IB-5	20mA	Fuse Busman ABC 3A		Breaker GE TE-15A	
			o) Loop 2 Regen Hx Outlet (HCV-2200B)	IB-6	20mA	Breaker GE THED-15A		Breaker GE THED-15A*	
			p) Loop 2 Regen Hx Outlet (HCV-2200B)	IB-2B	20mA	Fuse Busman ABC 10A		Breaker GE THED-15A	
			q) Loop 3 Regen Hx Outlet (HCV-2200C)	IB-5	20mA	Fuse Busman ABC 3A		Breaker GE TE-15A	
			r) Loop 3 Regen Hx Outlet (HCV-2200C)	IB-6	20mA	Breaker GE THED-15A		Breaker GE THED-15A*	
			s) Loop 3 Regen Hx Outlet (HCV-2200C)	IB-2E	20mA	Fuse Busman ABC 10A		Breaker GE THED-15A	
			t) Press to Relief TK (PCV-2455C)	IB-6	54mA	Breaker GE THED-15A		Breaker GE THED-15A*	
			→ u) Loop 1 Recirc Air Coil (TV-CC205A)	IB-1	447mA	Breaker GE TQB 5A		Breaker GE TE-15A	
			→ v) Containment Instr Air (TV-1A201A)	IB-1	447mA	Breaker GE TQB 5A		Breaker GE TE-15A	

\* Proposed Secondary Protection Device. Existing Secondary Device inadequate.

Note A: Primary and secondary protection for all circuits with time current curve IB-3 provided by two Busman Non 15A fuses, one in each leg of the 120 V a-c or 125 V d-c ungrounded circuit. See Sketch No. 1.

→ CIRCUITS REFERENCED IN VEPCO LETTER S.N. 084A



POSITION	PROTECTION		LOAD	TIME-CURRENT CURVE 12050-SK(C)-	FULL LOAD AMPS	PRIMARY PROTECTIVE DEVICE	NOTES & COMMENTS	SECONDARY PROTECTIVE DEVICE	NOTES & COMMENTS
	TYPE	CONDUCTOR							
			w) (Rack 2-108)	IB-2A	380mA	Fuse Busman ABC 10A		Breaker GE TE-15A	
			x) Press to Relief TK. (MOV-2536)	IB-3	140mA	Fuse Busman NON-15A		Fuse Busman NON-15A	
			y) Loop 1 HT LG CON (MOV-2700)	IB-3	178mA	Fuse Busman NON-15A		Fuse Busman NON-15A	
			z) Anc TK 3 Disch (MOV-2700A)	IB-3	178mA	Fuse Busman NON-15A		Fuse Busman NON-15A	
6C-2	IB	14-AMG	a) Rack 2-120	IB-2A	380mA	Fuse Busman ABC 10A		Breaker GE TE-15A	
			b) Loop 2 X Conn (MOV-2586)	IB-3	178mA	Fuse Busman NON-15A		Fuse Busman NON-15A	
			c) Loop 2 Red CKT	IB-2A	300mA	Fuse Busman ABC 10A		Breaker GE TE-15A	
			d) Hot Leg Isol (MOV-2592)	IB-3	178mA	Fuse Busman NON-15A		Fuse Busman NON-15A	
			e) Cold Leg Isol (MOV-2593)	IB-3	178mA	Fuse Busman NON-15A		Fuse Busman NON-15A	
			f) Recirc Spray (2-RS-P-01A VHS SW)	IB-3	132mA	Fuse Busman NON-15A		Fuse Busman NON-15A*	
			g) Air Operated Damper (HV257A)	IB-1	73mA	Breaker GE TQB 5A		Breaker GE TE-15A	
			h) Air Operated Damper (HV257B)	N/R	N/R	Spare		Spare	
			i) Air Operated Damper (HV257C)	IB-1	73mA	Breaker GE TQB 5A		Breaker GE TE-15A	
			j) Cont Vacuum Eject Init (TV-CV200)	IB-1	330mA	Breaker GE TQB 5A		Breaker GE TE-15A	
			k) Loop 2 Recirc Air Coll (TV-CC205B)	IB-1	447mA	Breaker GE TQB 5A		Breaker GE TE-15A	
			l) Loop 3 Recirc Air Coll (TV-CC205C)	IB-1	447mA	Breaker GE TQB 5A		Breaker GE TE-15A	
			m) Press Liquid Space (TV-SS200A)	IB-1	447mA	Breaker GE TQB 5A		Breaker GE TE-15A	
			n) Press Vapor Space (TV-SS201A)	IB-1	447mA	Breaker GE TQB 5A		Breaker GE TE-15A	
			o) Press Liquid Space (TV-SS200A)	IB-1	447mA	Breaker GE TQB 5A		Breaker GE TE-15A	
			p) Press Rel TK Gas Space (TV-SS204A)	IB-1	447mA	Breaker GE TQB 5A		Breaker GE TE-15A	
			q) Prim Cool Hot Leg Hdr (TV-SS206A)	IB-1	447mA	Breaker GE TQB 5A		Breaker GE TE-15A	
			r) RCP SWHI DIS (MOV-2390)	IB-3	174mA	Fuse Busman NON-15A		Fuse Busman NON-15A	

\* Proposed Secondary Protection Device. Existing Secondary Device inadequate.  
See Note A on Page 1 for circuits with time current curve IB-3.

POSITION	PENETRATION		LOAD	TIME-CURRENT CURVE 12050-SX(C)-	FULL LOAD AMPS	PRIMARY PROTECTIVE DEVICE	NOTES & COMMENTS	SECONDARY PROTECTIVE DEVICE	NOTES & COMMENTS
	TYPE	CONDUCTOR							
6B-2	IB	14-AMG	a) Letdown Line Loop 2 (LCV-2460B Lim. Sv.)	IB-5	84mA	Bussman ABC-3A		Breaker GE TK-15A	
			b) Loop 1 RCP Seal Lk Off (RCV-2303A)	IB-7	20mA	GE TEB-10A		Breaker GE TEB-10A*	
			c) Loop 2 RCP Seal Lk Off (RCV-2303B)	IB-7	20mA	GE TEB-10A		Breaker GE TEB-10A*	
			d) Loop 2 Accum Test Line (RCV-2050C)	IB-7	20mA	GE TEB-10A		Breaker GE TEB-10A*	
			e) Loop 2 Accum Test Line (RCV-2050D)	IB-7	20mA	GE TEB-10A		Breaker GE TEB-10A*	
			f) Loop 2 Accum Wk Up Line (RCV-2051B)	IB-7	20mA	GE TEB-10A		Breaker GE TEB-10A*	
			g) Loop 2 Accum Pria XFER (RCV-2052B)	IB-7	20mA	GE TEB-10A		Breaker GE TEB-10A*	
			h) Loop 2 Accum W2 Supply (RCV-2053B)	IB-7	20mA	GE TEB-10A		Breaker GE TEB-10A*	
			i) Loop 2 Stand Pipe Trip (TV-2522B)	IB-7	46mA	GE TEB-10A		Breaker GE TEB-10A*	
			j) Pri Grd Wkr to Rel TK (RCV-2519)	IB-7	20mA	GE TEB-10A		Breaker GE TEB-10A*	
			k) Auxiliary Spray Line (RCV-2311)	IB-7	20mA	GE TEB-10A		Breaker GE TEB-10A*	
			l) PR Rel TK to PO XFER TK (TV-2523)	IB-7	46mA	GE TEB-10A		Breaker GE TEB-10A*	
			m) Loop 1 Letdown Line (LCV-2460A)	IB-7	84mA	GE TEB-10A		Breaker GE TEB-10A*	
			n) Loop 2 Drain Line (RCV-2557B)	IB-7	20mA	GE TEB-10A		Breaker GE TEB-10A*	
			o) Loop 2 FLL Line Header (RCV-2556B)	IB-7	20mA	GE TEB-10A		Breaker GE TEB-10A*	
			p) Letdown Line Loop 2 (LCV-2460B)	IB-7	84mA	GE TEB-10A*			

\*Proposed Secondary Protection Device. Existing Secondary Device inadequate.

POSITION	PRIMARY PROTECTION		LOAD	TIME-CURRENT CURVE		PRIMARY PROTECTIVE DEVICE	NOTES & COMMENTS	SECONDARY PROTECTIVE DEVICE	NOTES & COMMENTS
	TYPE	CONDUCTOR		12050-EX (C)-	FULL LOAD AMPS				
6D-2	IB	14-AMG	a) Loop 3 X Conn (NDV-2587)	IB-3	176mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			b) Loop 3 Red CKT	IB-2A	300mA	Fuse Busman ABC 10A		Breaker GE TE-15A	
			c) Hot Leg Isol (NDV-2594)	IB-3	176mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			d) Cold Leg Isol (NDV-2595)	IB-3	176mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			e) Loop 2 Charging Line (BCV-2310)	IB-7	20mA	Breaker GE TEB-10A		Breaker GE TEB-10A <sup>o</sup>	
			→ f) Neut Shld TK Cool A Inlt (TV-CC207A)	IB-1	330mA	Breaker GE TQB-5A		Breaker GE TE-15A	
			→ g) Neut Shld TK Cool A Outlet (TV-CC208A)	IB-1	330mA	Breaker GE TQB-5A		Breaker GE TE-15A	
			→ h) Neut Shld TK Cool B Inlt (TV-CC207B)	IB-1	330mA	Breaker GE TQB-5A		Breaker GE TE-15A	
			i) Skid Comp A (2-IA-C-02A)	IB-3	935mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			→ j) Neut Shld TK Cool B Otlet (TV-CC208B)	IB-1	330mA	Breaker GE TQB-5A		Breaker GE TE-15A	
			k) Press Bal TK W2 Purge (BCV-2550)	IB-7	20mA	Breaker GE TEB-10A		Breaker GE TEB-10A <sup>o</sup>	
			→ l) Loop 2 Inlet Header (TV-CC206B)	IB-1	330mA	Breaker GE TQB-5A		Breaker GE TE-15A	
			m) MCP Bearing Lift Pp (PS-13-2)	IB-3	38mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			n) MCP Bearing Lift Pp (PS-13-2)	IB-3	6.7A for 4.5 Cycles	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			o) MCP Bearing Lift Pp (PS-14-2)	IB-3	6.7A for 4.5 Cycles	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			p) RACK 2-102	IB-2A	380mA	Fuse Busman ABC 10A		Breaker GE TE-15A	
			→ q) Neutron Shld Cool Make Up (SOV-RS201)	IB-1	330mA	Breaker GE TQB-5A		Breaker GE TE-15A	
→ aa) Neutron Pot Evacuation (2-4D-EM-01)	IB-5	Later	Busman ABC 3A		Breaker GE TE-15A				
11A-2	IC	10-AMG	ab) Skid Comp A (PS-IA213A)	-	-	Internal Annunciator Circuit**			
			a) Steam Gen Blow Down (TV-BD200G)	IC-2	447mA	Breaker GE TQB-5A		Breaker GE TE-15A	
			b) Steam Gen Blow Down (TV-BD200H)	IC-2	447mA	Breaker GE TQB-5A		Breaker GE TE-15A	
→ c) Steam Gen Blow Down (TV-BD200J)	IC-2	447mA	Breaker GE TQB-5A		Breaker GE TE-15A				
11C-2	IC	10-AMG	a) Loop 1 SLS CKTS	IC-3	330mA	Fuse Busman ABC 10A		Breaker GE TE-15A	
			b) RACK 2-106	IC-3	390mA	Fuse Busman ABC 10A		Breaker GE TE-15A	

\*Proposed Secondary Protection Device. Existing Secondary Device Inadequate.  
 \*\*Current limiting to 4 amps.  
 See Note A on Page 1 for circuits with time current curve IB-3.

POSITION	PRIMARY PROTECTION		LOAD	TIME-CURRENT CURVE 12050-SK(C)-	FULL LOAD AMPS	PRIMARY PROTECTIVE DEVICE	NOTES & COMMENTS	SECONDARY PROTECTIVE DEVICE	NOTES & COMMENTS
	TYPE	CONDUCTOR							
11D-2	IC	10-AMG	a) Loop 2 SLS CKTS	IC-3	300mA	Fuse Busman ABC 10A		Breaker GE TE-15A	
			b) RACK 2-117	IC-3	380mA	Fuse Busman ABC 10A		Breaker GE TE-15A	
			c) Press Relief W2 Supply (80V-2455C-3)	IC-4	1.6A	Breaker GE TED-10A		Breaker GE TED-10A*	
11B-2	IC	10-AMG	a) Loop 3 SLS CKTS	IC-3	300mA	Fuse Busman ABC 10A		Breaker GE TE-15A	
			b) RACK 2-103	IC-3	380mA	Fuse Busman ABC 10A		Breaker GE TE-15A	
14B-2	IB	14-AMG	a) Resid Heat Rem Hdr A (TV-88207A, 207B)	IB-4	330mA	Breaker GE TE-15A		Breaker GE TE-15A*	
			b) Resid Heat Rem Hdr B (TV-88207B)	IB-4	330mA	Breaker GE TE-15A		Breaker GE TE-15A*	
			c) Loop 1, 2 S/G Sample Selector (TV-88211A-C)	IB-4	330mA	Breaker GE TE-15A		Breaker GE TE-15A*	
			d) Reactor Leak Det Line (HCV-2544)	IB-7	20mA	Breaker GE TED-10A		Breaker GE TED-10A*	
			→ e) Loop 1 Inlet Header (TV-CC206A)	IB-1	330mA	Breaker GE TQB-5A		Breaker TE-15A	
			→ f) Loop 3 Inlet Header (TV-CC206C)	IB-1	330mA	Breaker GE TQB-5A		Breaker TE-15A	
			g) RCP Bearing Lift Pp (PS-12-2)	IB-3	35mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			h) RWR Return (NDV-CC200A)	IB-3	174mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			i) RWR Return (NDV-CC200B)	IB-3	174mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			a) Loop 1, 2 Prim Cool CLD LG TB-88209A-C	IB-4	330mA	Breaker GE TE-15A		Breaker GE TE-15A*	
			b) Loop 3 Drain Cont V (HCV-2557C)	IB-7	20mA	Breaker GE TED-10A		Breaker GE TED-10A*	
			c) Loop 1 Accum Test Line (HCV-2850A)	IB-7	20mA	Breaker GE TED-10A		Breaker GE TED-10A*	
d) Loop 1 Accum Test Line (HCV-2850B)	IB-7	20mA	Breaker GE TED-10A		Breaker GE TED-10A*				
e) Loop 3 Accum Test Line (HCV-2850E)	IB-7	20mA	Breaker GE TED-10A		Breaker GE TED-10A*				
f) Loop 3 Accum Test Line (HCV-2850F)	IB-7	20mA	Breaker GE TED-10A		Breaker GE TED-10A*				
g) Loop 1 Accum Mkup Line (HCV-2851A)	IB-7	20mA	Breaker GE TED-10A		Breaker GE TED-10A*				
h) Loop 3 Accum Mkup Line (HCV-2851C)	IB-7	20mA	Breaker GE TED-10A		Breaker GE TED-10A*				
i) Loop 1 Accum Prim XFER (HCV-2852A)	IB-7	20mA	Breaker GE TED-10A		Breaker GE TED-10A*				
j) Loop 3 Accum Prim XFER (HCV-2852C)	IB-7	20mA	Breaker GE TED-10A		Breaker GE TED-10A*				

\* Proposed Secondary Protection Device. Existing Secondary Device inadequate.  
See Note A on Page 1 for circuits with time current curve IB-3.

POSITION	PROTECTION		LOAD	TIME-CURRENT CURVE 12050-BK(C)-	FULL LOAD AMPS	PRIMARY PROTECTIVE DEVICE	NOTES & COMMENTS	SECONDARY PROTECTIVE DEVICE	NOTES & COMMENTS
	TYPE	CONDUCTOR							
			k) Loop 1 Accum W2 Supply (HCV-2853A)	IB-7	20mA	Breaker GE TED-10A		Breaker GE TED-10 <sup>W</sup>	
			l) Loop 3 Accum W2 Supply (HCV-2853C)	IB-7	20mA	Breaker GE TED-10A		Breaker GE TED-10 <sup>W</sup>	
			m) Etc Letdown Hx Inlet (HCV-2201)	IB-7	20mA	Breaker GE TED-10A		Breaker GE TED-10 <sup>W</sup>	
			n) Press Rel TK W2 Line (HCV-2898)	IB-7	20mA	Breaker GE TED-10A		Breaker GE TED-10 <sup>W</sup>	
		→	o) Reactor Coolant PP (80V-CC216A)	IB-8	597mA	Breaker W Quik Lag 5A		Breaker GE TE-15A	
		→	p) Reactor Coolant PP (80V-CC216B)	IB-8	597mA	Breaker W Quik Lag 5A		Breaker GE TE-15A	
		→	q) Reactor Coolant PP (80V-CC216C)	IB-8	597mA	Breaker W Quik Lag 5A		Breaker GE TE-15A	
			r) Rel Tank W/D STS Line (HCV-2549)	IB-7	20mA	Breaker GE TED-10A		Breaker GE TED-10 <sup>W</sup>	
			s) Etc Letdown Hx Outlet (HCV-2389)	IB-7	20mA	Breaker GE TED-10A		Breaker GE TED-10 <sup>W</sup>	
			t) RCP Bearing Lift Pp (PS-14-2)	IB-3	38mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			u) Primary Drain Transfer Tk (LS-DG203)	IB-3	123mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			v) Primary Drain Transfer Tk (LS-DG203)	IB-3	123mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			w) RC Purge System Supply (MDV-HV200A)	IB-3	178mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			x) RC Purge System EMI (MDV-HV200C)	IB-3	178mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			y) Cont Cab RAD near 2-RC-P-1A (2-PP-CP-06)	IB-6	5mA	Breaker GE THED-15A		Breaker GE THED-15 <sup>W</sup>	
			z) Cont Cab RAD near 2-RC-P-1B (2-PP-CP-07)	IB-6	5mA	Breaker GE THED-15A		Breaker GE THED-15 <sup>W</sup>	
			aa) Cont Cab RAD near 2-RC-P-1C (2-PP-CP-08)	IB-6	5mA	Breaker GE THED-15A		Breaker GE THED-15 <sup>W</sup>	
19C-2	IB	14-AWG	a) ACC TK 3 CD LG (MDV-2865C)	IB-3	178mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			b) ACC TK 3 CD LG (MDV-2865C)	IB-5	178mA	Fuse Busman ABC 3A		Fuse Busman ABC 3 <sup>W</sup>	
			c) Recirc Spray (2-RS-P-01B V1B SW)	IB-3	132mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			d) Press To Relief TK (PCV-2456)	IB-6	54mA	Breaker GE THED-15A		Breaker GE THED-15 <sup>W</sup>	

\* Proposed Secondary Protection Device. Existing Secondary Device Inadequate.  
See Note A on Page 1 for circuits with time current curve IB-3.



POSITION	PENETRATION		LOAD	T I DGE-CURRENT CURVE 120%0-SK(C)-	FULL LOAD AMPS	PRIMARY PROTECTIVE DEVICE	NOTES & COMMENTS	SECONDARY PROTECTIVE DEVICE	NOTES & COMMENTS
	TYPE	CONDUCTOR							
			e) Elevator	IB-9	Later	Fuse Busman Type AGC-6A		Fuse Busman Type AGC-6A*	
			f) Elevator	IB-9	Later	Fuse Busman Type AGC-6A		Fuse Busman Type AGC-6A*	
			g) Air Operated Damper (HV257B)	IB-1	73mA	Breaker GE TQB 5A		Breaker GE TE-15A	
			h) Air Operated Damper (HV257C)	IB-1	73mA	Breaker GE TQB 5A		Breaker GE TE-15A	
	→		i) RCP Thermal Barrier (TV-CC201B)	IB-1	447mA	Breaker GE TQB 5A		Breaker GE TE-15A	
	→		j) Loop 1 Return Header (TV-CC202B)	IB-1	447mA	Breaker GE TQB 5A		Breaker GE TE-15A	
	→		k) Loop 2 Return Header (TV-CC202D)	IB-1	447mA	Breaker GE TQB 5A		Breaker GE TE-15A	
	→		l) Loop 3 Return Header (TV-CC202F)	IB-1	447mA	Breaker GE TQB 5A		Breaker GE TE-15A	
	→		m) Reac Cont Sump Pp Disch (TV-DA200B)	IB-1	447mA	Breaker GE TQB 5A		Breaker GE TE-15A	
	→		n) Prim Drain XFER LP Dis (TV-DB200B)	IB-1	447mA	Breaker GE TQB 5A		Breaker GE TE-15A	
	→		o) Limit SW ON TV-DM200C (TV-DM200C)	IB-1	447mA	Breaker GE TQB 5A		Breaker GE TE-15A	
			p) Skid Comp B (2-IA-C-02B)	IB-3	935mA	Fuse Busman NOW 15A		Fuse Busman NOW-15A	
			q) Containment Isol (TV-2642)	IB-6	150mA	Breaker GE THED-15A		Breaker GE THED-15A*	
	→		r) Pri Dm XFER TK Vent (TV-VG200B)	IB-1	447mA	Breaker GE TQB-5A		Breaker GE TE-15A	
			s) W2 Supply Line (HCV-2936)	IB-6	20mA	Breaker GE THED-15A		Breaker GE THED-15A*	
			t) Press to Rel TK (MDV-2535)	IB-3	170mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			u) LP 1 HT LG CON (MDV-2701)	IB-3	170mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			v) ACC TK 3 DISCH. (MDV-2720B)	IB-3	170mA	Fuse Busman NOW-15A		Fuse Busman NOW-15A	
			w) Skid Comp B (PL-IA213B)	-	-	Internal Annunciator Circuit**			
19D-2	IB	14-AWG	a) Primary Coolant Hot Leg (TV-SB208A-D)	IB-4	330mA	Breaker GE TE-15A		Breaker GE TE-15A*	
			b) Primary Coolant Hot Leg (TV-SB208A-D)	IB-4	330mA	Breaker GE TE-15A		Breaker GE TE-15A*	
			c) Loop 1 Letdown Line (LCV-2460A Lim. Sw.)	IB-2A	8mA	Busman ABC-3A		Breaker GE TE-15A	
			d) Incore Instr RM Sump (LB-DA20C)	IB-10	8mA	Breaker GE TQB-15A		Breaker GE TQB-15A*	

\* Proposed Secondary Protection Device. Existing Secondary Device inadequate.  
 \*\* Current limiting to 4 amps.  
 See Note A on Page 1 for circuits with time current curve IB-3.

POSITION	PENETRATION		LOAD	TIME-CURRENT CURVE 120%0-SK(C)-	FULL LOAD AMPS	PRIMARY PROTECTIVE DEVICE	NOTES & COMMENTS	SECONDARY PROTECTIVE DEVICE	NOTES & COMMENTS
	TYPE	CONDUCTOR							
			e) Loop 1 Stand Pipe Trip (TV-2522A)	IB-7	46mA	Breaker GE TEB-10A		Breaker GE TEB-10A*	
			f) Loop 3 Stand Pipe Trip (TV-2522C)	IB-7	46mA	Breaker GE TEB-10A		Breaker GE TEB-10A*	
			g) Loop 3 RCP Seal LK-OFF (HCV-2303C)	IB-7	46mA	Breaker GE TEB-10A		Breaker GE TEB-10A*	
			h) Recirc Seal Wtr Outlet (HCV-2307)	IB-7	20mA	Breaker GE TEB-10A		Breaker GE TEB-10A*	
			i) Loop 1 Fill Line Header (HCV-2556A)	IB-7	20mA	Breaker GE TEB-10A		Breaker GE TEB-10A*	
			j) Loop 3 Fill Line Header (HCV-2556C)	IB-7	20mA	Breaker GE TEB-10A		Breaker GE TEB-10A*	
			k) Loop 1 Drain Line (HCV-2557A)	IB-7	20mA	Breaker GE TEB-10A		Breaker GE TEB-10A*	
			l) Elevator	IB-9	Later	Fuse Busman Type AGC 6A		Fuse Busman Type AGC 6A*	
			m) Elevator	IB-9	Later	Fuse Busman Type AGC 6A		Fuse Busman Type AGC 6A*	
			n) Elevator	IB-9	Later	Fuse Busman Type AGC 6A		Fuse Busman Type AGC 6A*	
			o) Elevator	IB-9	Later	Fuse Busman Type AGC 6A		Fuse Busman Type AGC 6A*	
			p) Elevator	IB-9	Later	Fuse Busman Type AGC 6A		Fuse Busman Type AGC 6A*	
			q) Elevator	IB-9	Later	Fuse Busman Type AGC 6A		Fuse Busman Type AGC 6A*	
			r) Elevator	IB-9	Later	Fuse Busman Type AGC 6A		Fuse Busman Type AGC 6A*	
			s) Elevator	IB-9	Later	Fuse Busman Type AGC 6A		Fuse Busman Type AGC 6A*	
			t) RCP Bearing Lift Pp (PS-12-2)	IB-3	6.7A for 4.5 Cycles	Fuse Busman NON 15		Fuse Busman NON 15A	
21B-2	IC	10-AMG →	a) Steam Gen Blowdown (TV-BD200B)	IC-2	447mA	Breaker GE TQB-5A		Breaker GE TE-15A	
		→	b) Steam Gen Blowdown (TV-BD200D)	IC-2	447mA	Breaker GE TQB-5A		Breaker GE TE-15A	
		→	c) Steam Gen Blowdown (TV-BD200F)	IC-2	447mA	Breaker GE TQB-5A		Breaker GE TE-15A	
			d) RC Purge Sys Supply (MOV-HV200B)	N/R	N/R	Spare		Spare	
			e) Mot Oper VV For Contain Supply (MOV-HV200A, MOV-HV200C)	IB-3	178mA	Fuse Busman NON 15A		Fuse Busman NON 15A	
21D-2	IC	10-AMG	a) Press Rel N2 Supply (80V-2456-3)	IC-4	1.6A	Breaker GE TEB-10A		Breaker GE TEB-10A*	

\* Proposed Secondary Protection Device. Existing Secondary Device inadequate. See Note A on Page 1 for circuits with time current curve IB-3.

Page No. Preliminary Item  
 Est. No. J.O. No. 12050  
 Date 9-26-80 By TPC  
 Checked 9-26-80 By TPC  
 Revised  
 Client VEPCO  
 Location  
 Subject TYPICAL ARRANGEMENT 120V A.C. UNGROUNDED CIRCUITS  
 AND 125V D.C. UNGROUNDED CIRCUITS  
 Based on




SKETCH NO. 1

1  
 2  
 3  
 4  
 5  
 6  
 7  
 8  
 9  
 10  
 11  
 12  
 13  
 14  
 15  
 16  
 17  
 18  
 19  
 20  
 21  
 22  
 23  
 24  
 25  
 26  
 27  
 28  
 29  
 30  
 31  
 32  
 33  
 34  
 35  
 36  
 37  
 38  
 39  
 40  
 41  
 42  
 43  
 44  
 45  
 46  
 47  
 48  
 49  
 50



A. GE TGP-5A or TGE-5A  
 B. GE T-15

#14 FEED THRU  
 1) SINGLE SEAL  
 2) TWO SEALS



A. PRIMARY PROTECTION DEVICE CURVE  
 B. SECONDARY PROTECTION DEVICE CURVE  
 C. PENETRATION CURVE (TO 6000 SECONDS BY TEST)  
 D. PENETRATION CONTINUOUS RATING-ALL CONDUCTORS EQUALLY LOADED  
 E. MAX. FAULT CURRENT

NOTE: PER MANUFACTURER "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "D".

NOTE: PER MANUFACTURER WITH 138 CONDUCTORS MAKING 20 AMPS THE REMAINING TWO CONDUCTOR ARE RATED 25 AMPS CONTINUOUSLY

D. PENETRATION CONTINUOUS RATING-CONDUCTORS UNEQUALLY LOADED (SEE NOTE ABOVE)

TIME-CURRENT CHARACTERISTIC CURVES

For \_\_\_\_\_  
 BASIS FOR DATA Standards \_\_\_\_\_  
 1. Tests made at \_\_\_\_\_  
 2. Curves are plotted to \_\_\_\_\_

Time-current in \_\_\_\_\_  
 Date: \_\_\_\_\_  
 p.f. starting at 75C with no initial load

Y-axis is at \_\_\_\_\_  
 Test points so variations should be \_\_\_\_\_

No. 12050-SK(C)-IB-1  
 Date 2/19/80 MPO


REV 1 7/15/82 TPC

AMPERE: 0 20 40 60 80 100 200 400 600 800 1000 2000 4000 6000 8000 10000

- A. PRIMARY PROTECTION DEVICE CURVE
- B. SECONDARY PROTECTION DEVICE CURVE
- C. PENETRATION CURVE (TO 1000 SECONDS BY TEST)
- D. PENETRATION CONTINUOUS RATING - ALL CONDUCTORS EQUALLY LOADED

NOTE: PER MANUFACTURER "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "D".  
E. MAX. FUSE CURRENT

NOTE: PER MANUFACTURER WITH 138 CONDUCTORS SHOWN BY THIS THE EXHIBITED COPY CONDUCTORS ARE RATED 24 AMPS COLLECTIVELY (PENETRATION CONTINUOUS RATING CONDUCTORS, EQUALLY LOADED, SEE NOTE ABOVE)



TIME-CURRENT CHARACTERISTIC CURVES

For \_\_\_\_\_ Fuse Links in \_\_\_\_\_

Basis for Data Standards \_\_\_\_\_ Dated \_\_\_\_\_


1. Tests made at \_\_\_\_\_ Volts a-c at \_\_\_\_\_ p-f., starting at 25°C with no initial load.

2. Curves are plotted to \_\_\_\_\_ Test points so variations should be \_\_\_\_\_

No. 19050-BK(C)-1B-2A

Date 2/19/90 JWP

REV 1 9/15/80 TR



- A. PRIMARY PROTECTION DEVICE CURVE
- B. SECONDARY PROTECTION DEVICE CURVE
- C. PENETRATION CURVE (TO 1000 SECOND BY TEST)
- D. PENETRATION CONTINUOUS RATING-ALL CONDUCTORS EQUALLY LOADED
- NOTE: PER MANUFACTURERS "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "D"
- E. MAX. FAULT CURRENT
- NOTE: PER MANUFACTURER WITH 138 CONDUCTORS SHARING 20 AMPS THE REMAINING TWO CONDUCTOR ARE RATED 25 AMPS CONTINUOUSLY
- D. PENETRATION CONTINUOUS RATING-CONDUCTORS UNEQUALLY LOADED (SEE NOTE ABOVE)

TIME-CURRENT CHARACTERISTIC CURVES

For \_\_\_\_\_ Fuse Links In \_\_\_\_\_

BASIS FOR DATA Standards \_\_\_\_\_ Dated \_\_\_\_\_


1. Tests made at \_\_\_\_\_ Volts a-c at \_\_\_\_\_ p-f, starting at 25C with no initial load

2. Curves are plotted to \_\_\_\_\_ Test points so variations should be \_\_\_\_\_

No. 12050-SK(C)-IB-2B  
 Date 9/15/80 TRC

#14 FEED THRU  
 1) SINGLE SEAL  
 2) TWO SEALS

A BUSSMAN NON - 15A  
 B BUSSMAN NON - 15A



A. PRIMARY PROTECTION DEVICE CURVE  
 B. SECONDARY PROTECTION DEVICE CURVE  
 C. PENETRATION CURVE (TO 1000 SECONDS BY TEST)  
 D. PENETRATION CONTINUOUS RATING - ALL CONDUCTORS EQUALLY LOADED  
 NOTE: PER MANUFACTURER "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "D".  
 E. MAX. FAULT CURRENT

NOTE: PER MANUFACTURER WITH 138 CONDUCTORS (RATING 20 AMPS THE REMAINING TWO CONDUCTORS ARE RATED 25 AMPS CONTINUOUSLY PENETRATION CONTINUOUS RATING - CONDUCTORS UNUSUALLY LOADED - SEE NOTE ABOVE)

TIME-CURRENT CHARACTERISTIC CURVES

For \_\_\_\_\_ Fuse Lin. In \_\_\_\_\_

BASIS FOR DATA Standards \_\_\_\_\_ Dated \_\_\_\_\_

1. Tests made at \_\_\_\_\_ Volts a-c at \_\_\_\_\_ p-f, starting at 25C with no initial load

2. Curves are plotted to \_\_\_\_\_ Test points so variations should be \_\_\_\_\_


No. LR050-SX(C)-IB-3

Date 2/18/80 MKO

REV 1 9/15/80 TK

#14 FEED THRU  
 1) SINGLE SEAL  
 2) TWO SEALS


A GE TE-15A  
 B GE TE-15A



- A. PRIMARY PROTECTION DEVICE CURVE
  - B. SECONDARY PROTECTION DEVICE CURVE
  - C. PENETRATION CURVE (TO 1000 SECONDS BY TEST)
  - D. PENETRATION CONTINUOUS RATING - ALL CONDUCTORS EQUALLY LOADED
- NOTE: PER MANUFACTURER "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "D".
- E. MAX. FAULT CURRENT

NOTE: PER MANUFACTURER WITH 138 CONDUCTORS SHARING 20 AMPS THE REMAINING TWO CONDUCTORS ARE RATED 25 AMPS CONTINUOUSLY

D'. PENETRATION CONTINUOUS RATING-CONDUCTORS UNEQUALLY LOADED (SEE NOTE ABOVE)



TIME-CURRENT CHARACTERISTIC CURVES

For \_\_\_\_\_ Fuse Links In \_\_\_\_\_

BASIS FOR DATA Standards \_\_\_\_\_ Date \_\_\_\_\_

1. Tests made at \_\_\_\_\_ Volts a-c at \_\_\_\_\_ p.f. starting at 25C with no initial load

2. Curves are plotted to \_\_\_\_\_ Test points so variations should be \_\_\_\_\_

No. 12050-SK(C)-IB-4  
 Date 2/12/80 JMD

REV 1 9/15/80 115

#14 FEED THRU  
 1) SINGLE SEAL  
 2) TWO SEALS


A BUSSMAN  
 GE

ABC-3A  
 TE-15A

(D) (C)  
 CURRENT IN AMPERES

A PRIMARY PROTECTION DEVICE CURVE  
 B. SECONDARY PROTECTION DEVICE CURVE  
 C. PENETRATION CURVE (TO 1000 SECONDS BY TEST)  
 D. PENETRATION CONTINUOUS RATING - ALL CONDUCTORS EQUALLY LOADED  
 NOTE: PER MANUFACTURER "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "D".  
 E. MAX. FAULT CURRENT

NOTE: PER MANUFACTURER WITH 136 CONDUCTORS SHARING 25 AMPS PER REMAINING TWO CONDUCTORS ARE RATED 25 AMPS CONTINUOUSLY.  
 D'. PENETRATION CONTINUOUS RATING-CONDUCTORS UNEQUALLY LOADED (SEE NOTE ABOVE)



TIME-CURRENT CHARACTERISTIC CURVES

For \_\_\_\_\_ Fuse Links in \_\_\_\_\_

Basis for Data Standards \_\_\_\_\_ Dated \_\_\_\_\_

1. Tests made at \_\_\_\_\_ Volts a-c at \_\_\_\_\_ p-f., starting at 25C with no initial load


2. Curves are plotted to \_\_\_\_\_ Test points so variations should be \_\_\_\_\_

No. 12050-SK(C)-IB-5  
 Date 2/19/80 WKO

REV 1 9/15/80 TR

#14 FEED THRU  
 1) SINGLE SEAL  
 2) TWO SEALS

A GE THED-15A  
 B GE THED-15A



A PRIMARY PROTECTION DEVICE CURVE  
 B SECONDARY PROTECTION DEVICE CURVE  
 C PENETRATION CURVE (TO 1000 SECONDS BY TEST)  
 D PENETRATION CONTINUOUS RATING - ALL CONDUCTORS EQUALLY LOADED  
 NOTE: PER MANUFACTURER "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "D"  
 E MAX. FAULT CURRENT

NOTE: PER MANUFACTURER WITH 138 CONDUCTORS SHARING 20 AMP THE REMAINING TWO CONDUCTOR ARE RATED BY IAPC CONTINUOUSLY  
 D' PENETRATION CONTINUOUS RATING-CONDUCTORS UNUSUALLY LOADED (SEE NOTE ABOVE)

TIME-CURRENT CHARACTERISTIC CURVES

For \_\_\_\_\_ Fuse Links in \_\_\_\_\_

Basis for Data Standards \_\_\_\_\_ Dated \_\_\_\_\_

1. Tests made at \_\_\_\_\_ Volts a-c at \_\_\_\_\_ p-f, starting at 25C with no initial load

2. Curves are plotted to \_\_\_\_\_ Test points as variations should be \_\_\_\_\_


No. 12057-BK(C)-15-6

Date 2/19/80 WFO

REV 1 9/15/83 IX

A GE TEB-10A  
 B GE TEB-10A

#14 FEED THRU  
 1) SINGLE SEAL  
 2) TWO SEALS



A. PRIMARY PROTECTION DEVICE CURVE  
 B. SECONDARY PROTECTION DEVICE CURVE  
 C. PENETRATION CURVE (TO 1000 SECONDS BY TEST)  
 D. PENETRATION CONTINUOUS RATING - ALL CONDUCTORS EQUALLY LOADED  
 NOTE: PER MANUFACTURER "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "D"  
 E. MAX. FAULT CURRENT

NOTE: PER MANUFACTURER WITH 138 CONDUCTORS SHARING 20 AMPS THE REMAINING TWO CONDUCTORS ARE RATED 25 AMPS CONSEQUENTLY IN PENETRATION CONTINUOUS RATING - CONDUCTORS EQUALLY LOADED (SEE NOTE ABOVE)

TIME-CURRENT CHARACTERISTIC CURVES

For \_\_\_\_\_ Fuse Links In \_\_\_\_\_ Dated \_\_\_\_\_

BASIS FOR DATA Standards \_\_\_\_\_ p-f, starting at 25C with no initial load

1. Tests made at \_\_\_\_\_ Volts a-c at \_\_\_\_\_ Test points as variations should be \_\_\_\_\_

2. Curves are plotted to \_\_\_\_\_


No. 12050-SK(C)-IB-7  
 Date 2/19/80 JMD

REV 1 9/15/80 TR



#14 FEED THRU  
 1) SINGLE SEAL  
 2) TWO SEALS

A W QUIK LAG BRK 5A  
 B GE TE-15A



A. PRIMARY PROTECTION DEVICE CURVE  
 B. SECONDARY PROTECTION DEVICE CURVE  
 C. PENETRATION CURVE (TO 1000 SECONDS BY TEST)  
 D. PENETRATION CONTINUOUS RATING - ALL CONDUCTORS  
 EQUALLY LOADED  
 NOTE: PER MANUFACTURER "C" CONTINUES WITH SAME  
 SLOPE EXHIBITED BETWEEN 500 AND 1000  
 SECONDS UNTIL IT INTERSECTS "D".  
 E. MAX. FAULT CURRENT

NOTE: PER MANUFACTURER WITH 138 CONDUCTORS  
 BEARING 60 AMPERE REMAINING TWO-  
 THIRD RATED BY AMPERE CONDUCTOR  
 PENETRATION CONTINUOUS RATING CONDUCTORS  
 EQUALLY LOADED (SEE NOTE ABOVE)

TIME-CURRENT CHARACTERISTIC CURVES

For \_\_\_\_\_ Fuse Links in \_\_\_\_\_ Dated \_\_\_\_\_

BASIS FOR DATA Standards. \_\_\_\_\_ p-f. starting at 25C with no initial load

1. Tests made at \_\_\_\_\_ Volts a-c at \_\_\_\_\_ Test points so variations should be \_\_\_\_\_


2. Curves are plotted to \_\_\_\_\_

No. 18050-SK(C)-1B-8  
 Date 2/19/80 JLD

*REV 1 9/11/80 TK*

#14 FEED THRU  
 1) SINGLE SEAL  
 2) TWO SEALS

A BUSSMAN AGC 6A  
 B BUSSMAN AGC 6A



- A. PRIMARY PROTECTION DEVICE CURVE
  - B. SECONDARY PROTECTION DEVICE CURVE
  - C. PENETRATION CURVE (TO 1000 SECONDS BY TEST)
  - D. PENETRATION CONTINUOUS RATING - ALL CONDUCTORS EQUALLY LOADED
- NOTE: PER MANUFACTURER "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "D"
- E. MAX. FAULT CURRENT

- NOTE: PER MANUFACTURER WITH 138 CONDUCTORS GRABING 20 AMPERE THE REMAINING TWO CONDUCTORS ARE RATED 25 AMPERE CONTINUOUSLY
- D'. PENETRATION CONTINUOUS RATING-CONDUCTORS UNEQUALLY LOADED (SEE NOTE ABOVE)

TIME-CURRENT CHARACTERISTIC CURVES

For \_\_\_\_\_ Fuse Links In \_\_\_\_\_

BASIS FOR DATA Standards \_\_\_\_\_ Detd \_\_\_\_\_

1. Tests made at \_\_\_\_\_ Volts a-c at \_\_\_\_\_ p-f., starting at 25C with no initial load


2. Curves are plotted to \_\_\_\_\_ Test points so variations should be \_\_\_\_\_

No. 12050-SK(C)-IB-9  
 Date 2/19/80 MJD

RE 1 2/15/80 TX

A GE TQB- 15A  
 B GE TQB- 15A

14 FEET THRU  
 1) SINGLE SEAL  
 2) TWO SEALS



A. PRIMARY PROTECTION DEVICE CURVE  
 B. SECONDARY PROTECTION DEVICE CURVE  
 C. PENETRATION CURVE (TO 1000 SECONDS BY TEST)  
 D. PENETRATION CONTINUOUS RATING - ALL CONDUCTORS EQUALLY LOADED  
 NOTE: PER MANUFACTURER "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "D"  
 E. MAX. FAULT CURRENT  
 NOTE: PER MANUFACTURER WITH 138 CONDUCTORS SHARING 30 AMP EACH REMAINING TWO CONDUCTORS ARE RATED 25 AMPS CONTINUOUSLY  
 D'. PENETRATION CONTINUOUS RATING-CONDUCTORS UNEQUALLY LOADED (SEE NOTE ABOVE)

TIME-CURRENT CHARACTERISTIC CURVES

For \_\_\_\_\_ Fuse Links. In \_\_\_\_\_

Basis for Data Standards \_\_\_\_\_ Dated \_\_\_\_\_

1. Tests made at \_\_\_\_\_ Volts a-c at \_\_\_\_\_ p-f. starting at 25C with no initial load

2. Curves are plotted to \_\_\_\_\_ Test points so variations should be \_\_\_\_\_


No. 12050-SK(C)-IB-10

Date 2/19/80 W40

REV 1 9/15/80 TPC

#10 FEED THRU  
 1) SINGLE SEAL  
 2) TWO SEALS

A BUSSMAN NON-15A  
 B BUSSMAN NON-15A




A. PRIMARY PROTECTION DEVICE CURVE  
 B. SECONDARY PROTECTION DEVICE CURVE  
 C. PENETRATION CURVE (TO 1000 SECONDS BY TEST)  
 D. PENETRATION CONTINUOUS RATING - ALL CONDUCTORS EQUALLY LOADED  
 NOTE: PER MANUFACTURER "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "D".  
 E. MAX. FAULT CURRENT

TIME-CURRENT CHARACTERISTIC CURVES  
 For \_\_\_\_\_ Fuse Links in \_\_\_\_\_  
 Dated \_\_\_\_\_  
 BASIS FOR DATA Standards \_\_\_\_\_  
 1. Tests made at \_\_\_\_\_ Volts a-c at \_\_\_\_\_ p-f., starting at 25C with no initial load  
 2. Curves are plotted to \_\_\_\_\_ Test points so variations should be \_\_\_\_\_  
 No. 12050-SK(C)-IC-1  
 Date 2/19/80 MJO

REV 1 -1/15/80 TPC  
 REV 2 9/22/80 TPC

A GE TQB-5A  
 B GE TE-15A

#10 FEED THRU  
 1) SINGLE SEAL  
 2) TWO SEALS



A. PRIMARY PROTECTION DEVICE CURVE  
 B. SECONDARY PROTECTION DEVICE CURVE  
 C. PENETRATION CURVE (TO 1000 SECONDS BY TEST)  
 D. PENETRATION CONTINUOUS RATING - ALL CONDUCTORS EQUALLY LOADED.  
 NOTE: PER MANUFACTURER "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "D".  
 E. MAX. FAULT CURRENT

TIME-CURRENT CHARACTERISTIC CURVES

For \_\_\_\_\_ Fuse Links in \_\_\_\_\_ Dated \_\_\_\_\_


BASIS FOR DATA Standards \_\_\_\_\_

1. Tests made at \_\_\_\_\_ Volts a-c at \_\_\_\_\_ p-f. starting at 25C with no initial load

2. Curves are plotted to \_\_\_\_\_ Test points so variations should be \_\_\_\_\_

No. 12050-BK(C)-IC-2  
 Date 2/19/80 JAO

Per 9/15/80 R



TIME-CURRENT CHARACTERISTIC CURVES

For \_\_\_\_\_ Fuse Links in \_\_\_\_\_ Dated \_\_\_\_\_

BASIS FOR DATA Standards \_\_\_\_\_

1. Tests made at \_\_\_\_\_ Volts a-c at \_\_\_\_\_ p-f, starting at 25C with no initial load

2. Curves are plotted to \_\_\_\_\_ Test points so variations should be \_\_\_\_\_


No. 12050-BK(C)-1C-3

Date 2/19/80 JMD

REV 1 9/15/80 TX

A GE TEB-10A  
 B GE TEB-10A

#10 FEED THRU  
 1) SINGLE SEAL  
 2) TWO SEALS



TIME-CURRENT CHARACTERISTIC CURVES

For \_\_\_\_\_ Fuse Links in \_\_\_\_\_

Basis for Data Standards \_\_\_\_\_ Dated \_\_\_\_\_

1. Tests made at \_\_\_\_\_ Volts a-c at \_\_\_\_\_ p-f, starting at 25C with no initial load.

2. Curves are plotted to \_\_\_\_\_ Test points so variations should be \_\_\_\_\_

No. 12050-BK(C)-1C-4

Date 2/19/80 JWP

RE: 1 - 1/17/80 TPC