

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 S C N E E 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 56 57

CONT

01 L 0 5 0 0 0 2 6 9 7 0 2 0 9 8 2 0 3 0 9 8 2 9

REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 On February 9, 1982, a steam generator tube leak of approximately 0.11 GPM was

03 indicated by the Condensate Steam Air Ejector Offgas Radiation Monitor. This

04 constitutes an abnormal degradation of the reactor coolant pressure boundary and

05 is reportable pursuant to Technical Specification 6.6.2.1.a(3). Personnel and

06 systems adequately controlled this event and the releases were well within reg-

07 ulatory requirements; thus, the health and safety of the public were not affected

08 by this event.

09 C B 11 E 12 B 13 H T E X C H 14 F 15 Z 16

SYSTEM CODE 9 10 CAUSE CODE 11 12 CAUSE SUBCODE 13 14 COMPONENT CODE 15 16 COMP. SUBCODE 17 18 VALVE SUBCODE 19 20

17 8 2 1 0 0 3 1 0 1 T 0

LER/RO REPORT NUMBER 21 22 EVENT YEAR 23 24 SEQUENTIAL REPORT NO. 25 26 OCCURRENCE CODE 27 28 REPORT TYPE 29 30 REVISION NO. 31 32

B 18 Z 19 A 20 A 21 0 3 8 4 Y 23 N 24 N 25 B 0 1 5 26

ACTION TAKEN 33 34 FUTURE ACTION 35 36 EFFECT ON PLANT 37 38 SHUTDOWN METHOD 39 40 HOURS 41 42 ATTACHMENT SUBMITTED 43 44 NRC-4 FORM NOS. 45 46 PRIME COMP. SUPPLIER 47 48 COMPONENT MANUFACTURER 49 50

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 The apparent cause of the steam generator tube leak was a crack on Tube 74-2.

11 This unit was shut down and cooled down. The leaking tube was stabilized from

12 the top and was explosively plugged from the bottom. Eddy current testing in

13 the lane region showed no tubes unacceptably degraded.

14

15 E 28 1 0 0 29 NA 30 A 31 Operator Observation 32

FACILITY STATUS 33 34 % POWER 35 36 OTHER STATUS 37 38 METHOD OF DISCOVERY 39 40 DISCOVERY DESCRIPTION 41 42

16 M 33 M 34 1.823 C 35 Vent stack to atmos; TB to Keowee tailrace 36

ACTIVITY CONTENT 37 38 AMOUNT OF ACTIVITY 39 40 LOCATION OF RELEASE 41 42

17 0 1 8 37 E 38 Maintenance personnel - 9.27 man-Rem 39

PERSONNEL EXPOSURES 41 42 TYPE 43 44 DESCRIPTION 45 46

18 0 0 0 40 NA 41

PERSONNEL INJURIES 43 44 NUMBER 45 46 DESCRIPTION 47 48

19 Z 42 NA 43

LOSS OF OR DAMAGE TO FACILITY 45 46 TYPE 47 48 DESCRIPTION 49 50

20 NA 45

PUBLICITY 47 48 ISSUED 49 50 DESCRIPTION 51 52

2 8203230515 820309 NA 53 54 55 56 57 58 59 60

PDR ADOCK 05000269 tutzer 704-373-7139

PDR PHONE: