

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 MDC CN 1 2 00 - 000000 - 000 3 41111 4 5
7 8 9 14 15 26 30 57 CAT 58

CON'T
01 REPORT SOURCE L 6 05000317 7 021582 8 031782 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 75 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 0335 during the performance of a routine test it was discovered that
03 #13 Containment Air Cooler Fan could not be stopped r shifted to low
04 speed (LOCA speed) from the Control Room. The cooler was declared in-
05 operable and placed out of service per T.S. 3.6.2.2. The three redundant
06 coolers and the Containment Spray System remained operable during the
07 event. The cooler was returned to service at 0510. Repetitive events:
08 None.

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
S B 11 X 12 Z 13 X X X X X X 14 Z 15 Z 16
7 8 9 10 11 12 13 18 19 20
17 LER-RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
8 2 006 / 03 L 0
21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
Z 18 Z 19 Z 20 Z 21 0000 N 23 N 24 Z 25 Z 999 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Troubleshooting the motor starter relays and the control circuitry re-
11 vealed no apparent cause of problem. No maintenance action was performed
12 as all components worked satisfactorily. The fan is run monthly during
13 surveillance tests and is checked per the preventive maintenance pro-
14 gram, therefore no further preventive action is deemed necessary.

15 FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)
E 28 100 29 NA B 31 Surveillance Test
7 8 9 10 12 13 44 45 46 80

16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
Z 33 Z 34 NA NA
7 8 9 10 11 44 45 80

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
000 37 Z 38 NA
7 8 9 11 12 13 80

18 PERSONNEL INJURIES NUMBER DESCRIPTION (41)
000 40 NA
7 8 9 11 12 80

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)
Z 42 NA
7 8 9 10 80

20 PUBLICITY ISSUED DESCRIBED (44) 8203250182 820317 PDR ADOCK 05000317 PDR
N 44
7 8 9 10 68 69 80

NAME OF PREPARER G.S. Pavis/L.F. Basso

PHONE 301-269-4742/4986