



ARKANSAS POWER & LIGHT COMPANY  
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000  
March 15, 1982

2CAN038201

Director of Nuclear Reactor Regulation  
ATTN: Mr. Robert A. Clark, Chief  
Operating Reactors Branch #3  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555



SUBJECT: Arkansas Nuclear One-Unit 2  
Docket No. 50-368  
License No. NPF-6  
Technical Specification 4.8.1.1.2.c.2  
DG Load Block Timing Surveillance  
(File: 2-1510)

Gentlemen:

In response to your letter dated January 19, 1982, the following is provided.

AP&L cannot be assured of continually being able to meet the requirements of Technical Specification 4.8.1.1.2.c.2 as interpreted in your letter of January 19, 1982. For this reason AP&L plans to re-evaluate the ANO-2 diesel generator loading sequence and the required intervals necessary between loads to maintain adequate voltage and frequency following each load block. Based on this information and the analysis used to develop the component start times for Table 8.3-1 of the ANO-2 FSAR, AP&L will resubmit a proposed change to the Technical Specification 4.8.1.1.2.c.2 which addresses the diesel generator load block timing surveillance test requirement.

We expect to have all needed analyses complete and our proposed Technical Specification to you within the next 90 days.

Very truly yours,

John R. Marshall  
Manager, Licensing

JRM:DEJ:sc

A001  
5/10