



Nebraska Public Power District

GENERAL OFFICE
P.O. BOX 499, COLUMBUS, NEBRASKA 68602-0499
TELEPHONE (402) 564-8561

NLS9000150
April 12, 1990

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Subject: NUREG-0737, Supplement 1 - Regulatory Guide 1.97 Response,
Revision IX

- References:
- 1) Letter from G. A. Trevors to U.S. NRC, dated August 21, 1989, NUREG-0737, Supplement 1 - Regulatory Guide 1.97 Response, Revision VIII
 - 2) Letter from W. O. Long to J. M. Pilant, dated October 27, 1986, Emergency Response Capability - Conformance to Regulatory Guide 1.97, Revision 2

Gentlemen:

Attached is Revision IX of the Regulatory Guide 1.97 (RG 1.97) instrumentation list. The changes between Revision VIII (Reference 1) and Revision IX are identified by revision bars in the right-hand margin. This revision reflects only typographical corrections. The District does not consider any of the changes in Revision IX to impact the favorable safety evaluation report (Reference 2), which found Cooper Nuclear Station to be in compliance with the requirements of RG 1.97.

The purpose of this revision to the RG 1.97 response is to correct typographical errors identified during the NRC Regulatory Guide 1.97 Team Inspection, NRC Inspection Report 90-01.

Should you have any questions regarding this issue, please contact this office.

Sincerely,

G. A. Trevors
Division Manager
Nuclear Support

9004230080 900412
PDR ADOCK 05000298
Q PNU

/jw

Attachment (34 pages)

cc: U.S. Nuclear Regulatory Commission
Region IV - Arlington, TX

NRC Resident Inspector
Cooper Nuclear Station

A003
11

VARIABLE	RANGE REQUIRED IN R.G. 1,97	TYPE- CATEGORY	PURPOSE	COOPER CIC NUMBER	ITEM NO.	INSTALLED RANGE	EO STATUS
<u>Reactivity Control</u>							
Neutron Flux	10% to 100% Full Power (SRM, APRM)	B-1	Function Detection; Accomplishment of Mitigation	SRM's, LPRM's	1-1	10% to 125% Full Power	N/A
Control Rod Position	Full In or Not Full In	B-3	Verification	RPIS	3-1	Full In or Not Full In 0"-144"	N/A
RCS Soluble Boron Concentration (Sample)	0 to 1,000 ppm	B-3	Verification	PASS	3-2	0-1000 PPM Grab Sample	N/A
Coolant Level In Reactor	Bottom of Core Support Plate to Lesser of Top of Vessel or Centerline of Main Steam Line	A-1 B-1	Function Detection; Accomplishment of Mitigation; Long-Term Surveillance	NBI-LT-59A,B,C	1-2	10" - +225"	Qualified
				NBI-LR-85A,B	1-3	(-150" - +60")	Mild Environment
				NBI-LI-85A,B,C	1-4		Mild Environment
				NBI-IE-59A,-91A,B	1-151		Mild Environment
				NBI-SC-59A,B	1-152		Mild Environment
				NBI-LT-92	1-5	160" - +340"	Qualified
				NBI-LI-92	1-6	(0" - +170")	Mild Environment
				NBI-IE-92	- *53		Mild Environment
				NBI-LT-91A,B,C	1-7	-150 - +225"	Qualified
				NBI-LI-91A,B,C	1-8	(-314" - +61")	Mild Environment
				NBI-LR-91A,C	1-154		Mild Environment
				NBI-IE-91A,B	1-155		Mild Environment
				NBI-SC-91A,B	1-156		Mild Environment
BWR Core Thermocouples	200°F to 2300°F		To Provide Diverse Indication of Water Level	None		N/A	N/A

ITEM NO.	SEISMIC STATUS ¹	QA STATUS ²	REDUNDANT ³ CHANNEL	POWER SUPPLY	CR DISPLAY	REQUIRED FOR TSC	REQUIRED FOR EOF	INPUT TO PMIS	DEVIATIONS AND JUSTIFICATIONS
1-1	A	B	Yes*	RPS	Indicators	SRM	SRM Alarm Only	Yes Alarm Only	Implemented as Category 3. SRM's indicate 3 counts per second which meets the lower flux requirement of R.G. 1.97. The District will follow industry development of Category 1 neutron flux instrumentation, evaluate newly developed equipment and install Category 1 instrumentation upon the demonstration of reliable, functional and maintainable equipment.
3-1	N/A	B	N/A	RPS	Indicators	Yes	Yes	Yes	None
3-2	N/A	C	N/A	LPRW2A	None	No	No	No	None
1-2	C	A	Yes	EE-PNL-CCP1A(12)/ EE-PNL-CPP(26)	Indicator/ Recorder	Yes	Yes	Yes	NPPD provides 1E fuel zone water level instrumentation to -150" which is 6" below the bottom of active fuel. NPPD supplies only one qualified channel for the upper water range, from top of fuel (0 inches) to the center of the steam line at +287.5 inches. Reference SEP.
1-3	C	A	Yes						
1-4	C	A	Yes*						
1-151	C	A	Yes						
1-152	C	A	Yes	EE-PNL-CCP1A(12)	Indicator	Yes	Yes	Yes	
1-5	C	A	No						
1-6	C	A	No						
1-153	C	A	No						
1-7	C	A	Yes	EE-PNL-CCP1A(12)/ EE-PNL-CPP(26)	Indicator/ Recorder	Yes	Yes	Yes	
1-8	C	A	Yes						
1-154	C	A	Yes						
1-155	C	A	Yes						
1-156	C	A	Yes						
N/A		N/A	N/A	N/A	N/A	No	No	No	Not implemented. Reference BWROG Position, Appendix A.

VARIABLE	RANGE REQUIRED IN R.G. 1.97	TYPE- CATEGORY	PURPOSE	COOPER CIC NUMBER	ITEM NO.	INSTALLED RANGE	EO STATUS
<u>Maintaining Reactor Coolant System Integrity</u>							
RCS Pressure	0 psia to 1500 psig	A-1	Function Detection; Accomplishment of	NB1-PT-6A,B	1-9	0 - 1500 psig	Qualified
		B-1	Mitigation; Verification	PC-1E-3A,3B	1-10		Mild Environment
		C-1		PC-SC-2A,2B	1-11		Mild Environment
				NB1-PR-2A,2B	1-12		Mild Environment
Drywell Pressure	0 to Design Pressure (D.P. = 56 psig)	A-1	Function Detection; Accomplishment of	PC-PT-512A,B	1-13	-5 - 70 psig	Qualified
		B-1	Mitigation; Verification	PC-1E-5A,B	1-14		Mild Environment
				PC-SC-4A,B	1-15		Mild Environment
				PC-PR-2A,B	1-157		Mild Environment
				PC-PT-4A1,4B2	1-16	0 - 250 psig	Qualified
				PC-1E-3A,3B	1-17		Mild Environment
				PC-SC-3A,3B	1-18		Mild Environment
				PC-PR-1A,1B	1-19		Mild Environment
Drywell Sump Level	Top to Bottom	B-1	Function Detection; Accomplishment of Mitigation; Verification	ANN-ANN-(9-4-1/6-3)	1-20		Mild Environment
				ANN-ANN-(9-4-1/7-3)			
				ANN-ANN-(5-1/5-4)			
<u>Maintaining Containment Integrity</u>							
Primary Containment Pressure	-5 psig to Design Pressure (D.P. = 56 psig)	B-1	Function Detection; Accomplishment of Mitigation; Verification	PC-PT-512A,B	1-21	-5-70 psig	Qualified
				PC-1E-5A,B	1-22		Mild Environment
				PC-SC-4A,B	1-23		Mild Environment
				PC-PR-2A,B	1-158		Mild Environment

ITEM NO.	SEISMIC STATUS ¹	QA STATUS ²	REDUNDANT ³ CHANNEL	POWER SUPPLY	CR DISPLAY	REQUIRED FOR TSC	REQUIRED FOR EDF	INPUT TO PMIS	DEVIATIONS AND JUSTIFICATIONS
1-9	C	A	Yes ^a	EE-PNL-CCP1A(12)/	Recorder	Yes	Yes	Yes	None
1-10	C	A		EE-PNL-CPP(26)	Both				
1-11	C	A			Channels				
1-12	C	A							
1-13	C	A	Yes ^a	EE-PNL-CCP1A(12)/	Recorder	Yes	Yes	Yes	None
1-14	C	A		EE-PNL-CPP(26)	Both				
1-15	C	A			Channels				
1-157	C	A							
1-16	C	A	Yes ^a	EE-PNL-CCP1A(12)/	Recorder	Yes	Yes	Yes	None
1-17	C	A		EE-PNL-CPP(26)	Both				
1-18	C	A			Channels				
1-19	C	A							
1-20		B			Annunciators	Yes	Yes	Yes	Implemented as Category 3. Reference SER.
1-21	C	A	Yes ^a	EE-PNL-CCP1A(12)/	Recorder	Yes	Yes	Yes	None
1-22	C	A		EE-PNL-CPP(26)	Both				
1-23	C	A			Channels				
1-158	C	A							

VARIABLE	RANGE REQUIRED IN R.G. 1.97	TYPE- CATEGORY	PURPOSE	COOPER CIC NUMBER	ITEM NO.	INSTALLED RANGE	EQ STATUS
Primary Containment Isolation Valve Position (Excluding Check Valves)	Closed - Not Closed	B-1	Accomplishment of Isolation	PC-PT-4A1,4B2	1-24	0 - 250 psig	Qualified
				PC-IE-3A,3B	1-25		Mild Environment
				PC-SC-3A,3B	1-26		Mild Environment
				PC-PR-1A,1B	1-27		Mild Environment
				PC-PT-30A,B	1-28	-5 - 70 psig	Qualified
				PC-IE-5A,B	1-29		Mild Environment
				PC-SC-4A,B	1-159		Mild Environment
				PC-PR-2A,B	1-160		Mild Environment
				PC-LMS-237AV(O),(C)	1-30	Closed - Not Closed	Qualified
				PC-AO-237AV	1-31		Mild Environment
				Indicating Lights			
				PC-LMS-238AV(O),(C)	1-32	Closed - Not Closed	Qualified
				PC-AO-238AV	1-33		Mild Environment
				Indicating Lights			
				PC-LMS-243AV(O),(C)	1-34	Closed - Not Closed	Qualified
				PC-AO-243AV	1-35		Mild Environment
				Indicating Lights			
				PC-LMS-244AV(O),(C)	1-36	Closed - Not Closed	Qualified
				PC-AO-244AV	1-37		Mild Environment
				Indicating Lights			
				PC-LMS-245AV(O),(C)	1-38	Closed - Not Closed	Qualified
				PC-AO-245AV	1-39		Mild Environment
				Indicating Lights			
				PC-LMS-246AV(O),(C)	1-40	Closed - Not Closed	Qualified
				PC-AO-246AV	1-41		Mild Environment
				Indicating Lights			
				PC-MO-230MV	1-42	Closed - Not Closed	Qualified
				PC-MO-230MV	1-43		Mild Environment
				Indicating Lights			
				PC-MO-231MV	1-44	Closed - Not Closed	Qualified
				PC-MO-231MV	1-45		Mild Environment
				Indicating Lights			
				PC-MO-232MV	1-46	Closed - Not Closed	Qualified
				PC-MO-232MV	1-47		Mild Environment
				Indicating Lights			
				RW-LMS-A094(O),(C)	1-48	Closed - Not Closed	Qualified
				RW-AO-A094	1-49		Mild Environment
				Indicating Lights			
				RW-LMS-A095(O),(C)	1-50	Closed - Not Closed	Qualified
				RW-AO-A095	1-51		Mild Environment
				Indicating Lights			
				RW-LMS-A082(O),(C)	1-52	Closed - Not Closed	Qualified
				RW-AO-A082	1-53		Mild Environment
				Indicating Lights			
				RW-LMS-A083(O),(C)	1-54	Closed - Not Closed	Qualified
				RW-AO-A083	1-55		Mild Environment
				Indicating Lights			
				PC-MO-233MV	1-56	Closed - Not Closed	Qualified
				PC-MO-233MV	1-57		Mild Environment
				Indicating Lights			
				MS-LMS-A080A,B,C,D (A),(F)	1-58	Closed - Not Closed	Qualified

ITEM NO.	SEISMIC STATUS ¹	QA STATUS ²	REDUNDANT ³ CHANNEL	POWER SUPPLY	CR DISPLAY	REQUIRED FOR TSC	REQUIRED FOR EOP	INPUT TO PMIS	DEVIATIONS AND JUSTIFICATIONS
1-24	C	A	Yes	EE-PNL-CCP1A(12)/	Recorder	Yes	Yes	Yes	
1-25	C	A		EE-PNL-CPP(26)	Both Channels				
1-26	C	A							
1-27	C	A							
1-28	C	A	Yes	EE-PNL-CCP1A(12)/	Recorder	Yes	Yes	Yes	None
1-29	C	A		EE-PNL-CPP (26)	Single Channel				
1-159	C	A							
1-160	C	A							
1-30	C	A	Yes ^a	EE-PNL-CCP1B(7)	Indicator Lights	Yes	Yes	Yes	None
1-31	C	A							
1-32	C	A	Yes ^a	EE-PNL-CCP1B(7)	Indicator Lights	Yes	Yes	Yes	None
1-33	C	A							
1-34	C	A	No ^d	EE-PNL-CCP1A(9)	Indicator Lights	Yes	Yes	Yes	None
1-35	C	A							
1-36	C	A	No ^d	EE-PNL-CCP1A(9)	Indicator Lights	Yes	Yes	Yes	None
1-33	C	A							
1-38	C	A	Yes ^a	EE-PNL-CCP1B(7)	Indicator Lights	Yes	Yes	Yes	None
1-39	C	A							
1-40	C	A	Yes ^a	EE-PNL-CCP1B(7)	Indicator Lights	Yes	Yes	Yes	None
1-41	C	A							
1-42	C	B	Yes ^a	EE-MCC-RA(2A)	Indicator Lights	Yes	Yes	Yes	None
1-43	C	A							
1-44	C	B	Yes ^a	EE-MCC-RA(2B)	Indicator Lights	Yes	Yes	Yes	None
1-45	C	A							
1-46	C	B	Yes ^a	EE-MCC-RA(2C)	Indicator Lights	Yes	Yes	Yes	None
1-47	C	A							
1-48	C	A	Yes ^a	EE-PNL-RPSPP1A(3)	Indicator Lights	Yes	Yes	Yes	None
1-49	C	A							
1-50	C	A	Yes ^a	EE-PNL-RPSPP1B(3)	Indicator Lights	Yes	Yes	Yes	None
1-51	C	A							
1-52	C	A	Yes ^a	EE-PNL-RPSPP1A(3)	Indicator Lights	Yes	Yes	Yes	None
1-53	C	A							
1-54	C	A	Yes ^a	EE-PNL-RPSPP1B(3)	Indicator Lights	Yes	Yes	Yes	None
1-55	C	A							
1-56	C	B	Yes ^a	EE-MCC-RA(2D)	Indicator Lights	Yes	Yes	Yes	None
1-57	C	A							
1-58	C	B	Yes ^a	EE-PNL-AA2(12)	Indicator Lights	Yes	Yes	Yes	None

ITEM NO.	SEISMIC STATUS ¹	QA STATUS ²	REDUNDANT ³ CHANNEL	POWER SUPPLY	CR DISPLAY	REQUIRED FOR TSC	REQUIRED FOR EOF	INPUT TO PMIS	DEVIATIONS AND JUSTIFICATIONS
1-59	C	A							
1-60	C	B	Yes ^a	EE-PNL-BB2(9)	Indicator Lights	Yes	Yes	Yes	None
1-61	C	A							
1-62	C	B	Yes ^a	EE-MCC-R(4C)	Indicator Lights	Yes	Yes	Yes	None
1-63	C	A							
1-64	C	B	Yes ^a	EE-STR-125RX (MD77)	Indicator Lights	Yes	Yes	Yes	None
1-65	C	A							
1-66	C	B	Yes ^a	EE-MCC-R(5A)	Indicator Lights	Yes	Yes	Yes	None
1-67	C	A							
1-68	C	B	Yes ^a	EE-STR-125HPC1 (MD16)	Indicator Lights	Yes	Yes	Yes	None
1-69	C	A							
1-70	C	B	Yes ^a	EE-MCC-Y(10B)	Indicator Lights	Yes	Yes	Yes	None
1-71	C	A							
1-72	C	B	Yes ^a	EE-STR-125RC1C (MD16)	Indicator Lights	Yes	Yes	Yes	None
1-73	C	A							
1-74	C	B	Yes ^a	EE-MCC-K(4C)	Indicator Lights	Yes	Yes	Yes	None
1-75	C	A							
1-76	C	B	Yes ^a	EE-MCC-RA(5B)	Indicator Lights	Yes	Yes	Yes	None
1-77	C	A							
1-78	C	A	Yes ^a	EE-MCC-R(5C)	Indicator Lights	Yes	Yes	Yes	None
1-79	C	A							
1-80	C	B	Yes ^a	EE-STR-125RX (MD18)	Indicator Lights	Yes	Yes	Yes	None
1-81	C	A							
1-82	C	B	Yes ^a	EE-STR-125HPC1 (RHR-MD17)	Indicator Lights	Yes	Yes	Yes	None
1-83	C	A							
1-84	C	B	Yes ^a	EE-MCC-R(7A)	Indicator Lights	Yes	Yes	Yes	None
1-85	C	A							
1-86	C	A	Yes ^b	EE-STR-250 DIVI(MD25A)	Indicator Lights	Yes	Yes	Yes	None
1-87	C	A							
1-88	C	A	Yes ^b	EE-STR-250 DIVII(MD25B)	Indicator Lights	Yes	Yes	Yes	None
1-89	C	A							
1-90	C	B	Yes ^b	EE-MCC-CA(3E)	Indicator Lights	Yes	Yes	Yes	None

VARIABLE	RANGE REQUIRED IN R.G. 1.97	TYPE- CATEGORY	PURPOSE	COOPER CIC NUMBER	ITEM NO.	INSTALLED RANGE	EQ-STATUS
				RHR-MO-M027A Indicating Lights	1-91		Mild Environment
				RHR-MO-M027B Indicating Lights	1-92	Closed - Not Closed	Qualified
				RHR-MO-M027C Indicating Lights	1-93		Mild Environment
				CS-MO-M012A Indicating Lights	1-94	Closed - Not Closed	Qualified
				CS-MO-M012B Indicating Lights	1-95		Mild Environment
				CS-MO-M012C Indicating Lights	1-96	Closed - Not Closed	Qualified
				CS-MO-M012D Indicating Lights	1-97		Mild Environment
				CS-MO-M011A Indicating Lights	1-98	Closed - Not Closed	Qualified
				CS-MO-M011B Indicating Lights	1-99		Mild Environment
				CS-MO-M011C Indicating Lights	1-100	Closed - Not Closed	Qualified
				CS-MO-M011D Indicating Lights	1-101		Mild Environment
				RR-LMS-740AV(D), (C)	1-102	Closed - Not Closed	Qualified
				RR-AO-740AV	1-103		Mild Environment
				RR-LMS-741AV(D), (C)	1-104	Closed - Not Closed	Qualified
				RR-AO-741AV	1-105		Mild Environment
				RHR-MO-M057 Indicating Lights	1-106	Closed - Not Closed	Qualified
				RHR-MO-M057 Indicating Lights	1-107		Mild Environment
				RHR-MO-M067 Indicating Lights	1-108	Closed - Not Closed	Qualified
				RHR-MO-M067 Indicating Lights	1-109		Mild Environment
				ACAD-MO-1301MV Indicating Lights	1-110	Closed - Not Closed	Qualified
				ACAD-MO-1301MV Indicating Lights	1-111		Mild Environment
				ACAD-MO-1302MV Indicating Lights	1-112	Closed - Not Closed	Qualified
				ACAD-MO-1302MV Indicating Lights	1-113		Mild Environment
				ACAD-MO-1303MV Indicating Lights	1-114	Closed - Not Closed	Qualified
				ACAD-MO-1303MV Indicating Lights	1-115		Mild Environment
				ACAD-MO-1304MV Indicating Lights	1-116	Closed - Not Closed	Qualified
				ACAD-MO-1304MV Indicating Lights	1-117		Mild Environment
				ACAD-MO-1305MV Indicating Lights	1-118	Closed - Not Closed	Qualified

ITEM NO.	SEISMIC STATUS ¹	QA STATUS ²	REDUNDANT ³ CHANNEL	POWER SUPPLY	CR DISPLAY	REQUIRED FOR TSC	REQUIRED FOR EDF	INPUT TO PMIS	DEVIATIONS AND JUSTIFICATIONS
1-91	C	A							
1-92	C	B	Yes ^b	EE-MCC-RB(3C)	Indicator Lights	Yes	Yes	Yes	None
1-93	C	A							
1-94	C	A	Yes ^c	EE-MCC-Q(6A)	Indicator Lights	Yes	Yes	Yes	None
1-95	C	A							
1-96	C	A	Yes ^c	EE-MCC-Y(5C)	Indicator Lights	Yes	Yes	Yes	None
1-97	C	A							
1-98	C	A	Yes ^c	EE-MCC-Q(5F)	Indicator Lights	Yes	Yes	Yes	None
1-99	C	A							
1-100	C	A	Yes ^c	EE-MCC-Y(5B)	Indicator Lights	Yes	Yes	Yes	None
1-101	C	A							
1-102	C	A	Yes ^a	EE-PNL-CCP1B(2)	Indicator Lights	Yes	Yes	Yes	None
1-103	C	A							
1-104	C	A	Yes ^a	EE-PNL-CCP1A(2)	Indicator Lights	Yes	Yes	Yes	None
1-105	C	A							
1-106	C	B	Yes ^a	EE-MCC-R(3B)	Indicator Lights	Yes	Yes	Yes	None
1-107	C	A							
1-108	C	B	Yes ^a	EE-PNL-BB3(3)	Indicator Lights	Yes	Yes	Yes	None
1-109	C	A							
1-110	C	C	Yes ^a	EE-MCC-CB(3A)	Indicator Lights	Yes	Yes	Yes	None
1-111	C	A							
1-112	C	C	Yes ^u	EE-PNL-CA(1)	Indicator Lights	Yes	Yes	Yes	None
1-113	C	A							
1-114	C	C	Yes ^a	EE-PNL-CB(1)	Indicator Lights	Yes	Yes	Yes	None
1-115	C	A							
1-116	C	C	Yes ^a	EE-MCC-CA(2A)	Indicator Lights	Yes	Yes	Yes	None
1-117	C	A							
1-118	C	C	Yes ^a	EE-PNL-CB(2)	Indicator Lights	Yes	Yes	Yes	None

VARIABLE	RANGE REQUIRED IN R.C. 1.97	TYPE- CATEGORY	PURPOSE	COOPER CIC NUMBER	ITEM NO.	INSTALLED RANGE	EQ STATUS
				ACAD-MO-1305MV Indicating Lights	1-119		Mild Environment
				ACAD-MO-1306MV	1-120	Closed - Not Closed	Qualified
				ACAD-MO-1306MV Indicating Lights	1-121		Mild Environment
				ACAD-MO-1308MV	1-122	Closed - Not Closed	Qualified
				ACAD-MO-1308MV Indicating Lights	1-123		Mild Environment
				ACAD-MO-1310MV	1-124	Closed - Not Closed	Qualified
				ACAD-MO-1310MV Indicating Lights	1-125		Mild Environment
				ACAD-MO-1311MV	1-126	Closed - Not Closed	Qualified
				ACAD-MO-1311MV Indicating Lights	1-127		Mild Environment
				ACAD-MO-1312MV	1-128	Closed - Not Closed	Qualified
				ACAD-MO-1312MV Indicating Lights	1-129		Mild Environment
<u>Reactor Coolant Pressure Boundary</u>							
Primary Containment Area Radiation	1 R/hr to 10 ⁵ R/hr	C-3	Detection of Breach; Verification	RMA-RE-40A,B RMA-RM-40A,B RMA-10-40A,B (RMA-RR-40 for A & B)	3-3 3-4 3-5 3-6	1R/hr to 10 ⁷ R/hr	N/A N/A N/A
Drywell Drain Sumps Level (Identified and Unidentified Leakage)	Top to Bottom	C-1	Detection of Breach; Accomplishment of Mitigation; Verification Long- Term Surveillance	ANN-ANN-(9-4-1/4-3) ANN-ANN-(9-4-1/5-3) ANN-ANN-(5-1/5-2)	1-130		Mild Environment

ITEM NO.	SEISMIC STATUS ¹	QA STATUS ²	REDUNDANT ³ CHANNEL	POWER SUPPLY	CR DISPLAY	REQUIRED FOR ISC	REQUIRED FOR EOF	INPUT TO PMIS	DEVIATIONS AND JUSTIFICATIONS
1-119	C	A							
1-120	C	C	Yes ^c	EE-MCC-CA(2B)	Indicator Lights	Yes	Yes	Yes	None
1-121	C	A							
1-122	C	C	Yes ^a	EE-PNL-CA(2)	Indicator Lights	Yes	Yes	Yes	None
1-123	C	A							
1-124	C	C	Yes ^a	EE-PNL-CB(3)	Indicator Lights	Yes	Yes	Yes	None
1-125	C	A							
1-126	C	C	Yes ^b	EE-PNL-CA(3)	Indicator Lights	Yes	Yes	Yes	None
1-127	C	A							
1-128	C	C	Yes ^a	EE-MCC-CB(3C)	Indicator Lights	Yes	Yes	Yes	None
1-129	C	A							
3-3	N/A	A	N/A	EE-PNL-CCP1A(19)	Common Recorder	Yes	Yes	Yes	None
3-4	N/A			EE-PNL-CCP1B(1)					
3-5	N/A								
3-6	N/A								
1-130	-	B	-	---	Annunciators	Yes	Yes	Yes	Implemented as Category 3. Reference SER.

VARIABLE	RANGE REQUIRED IN R.G. 1.97	TYPE- CATEGORY	PURPOSE	COOPER CIC NUMBER	ITEM NO.	INSTALLED RANGE	EQ STATUS
Suppression Pool Water Level	Bottom of ECCS Suction Line to 5' Above Normal Water Level	A-1 C-1	Detection of Breach; Accomplishment of Mitigation; Verification Long-Term Surveillance	PC-DP1-3A1,3B2 PC-IE-2A,2B PC-SC-1A,1B PC-LR-1A,1B	1-131 1-132 1-133 1-134	0 - 30' (866' - 896')	Qualified Mild Environment Mild Environment Mild Environment
<u>Containment</u>							
Primary Containment Pressure	-5 psig to 4 Times Design Pressure D.P. = 56 psig	C-1	Detection of Potential for or Actual Breach; Accomplishment of Mitigation	PC-PT-4A1,4B2 PC-IE-3A,3B PC-SC-3A,3B PC-PR-1A,1B	1-135 1-136 1-137 1-138	0 - 250 psia	Qualified Mild Environment Mild Environment Mild Environment
Effluent Radioactivity-Noble Gases	10^{-6} uCi/cc to 10^{-2} uCi/cc	C-2	Indication of Breach	ERP Hi-range Effluent Monitor RMP-RM-3A,B RMP-CBX-(3B-1,2) RMP-CBX-(3A-1,2) RMP-RR-3	 2-1 2-2 2-162 2-163	5×10^{-7} uCi/cc to 1×10^{-5} uCi/cc (Note 4)	 Mild Environment Mild Environment Mild Environment
Containment and Drywell Hydrogen Concentration	0 - 30% (Capability of Operating from -5 psig to Design Pressure)	C-1	Detection of Potential for Breach; Accomplishment of Mitigation	PC-AN-H2/021 PC-AN-H2/0211 PC-R-H21 PC-R-H211	1-139 1-140 1-141 1-142	0-30%	Qualified Qualified Mild Environment Mild Environment
Containment and Drywell Oxygen Concentration (for Inerted Containment Plants)	0 - 10% (Capability of Operating from -5 psig to Design Pressure)	C-1	Detection of Potential for Breach; Accomplishment of Mitigation	PC-AN-H2/021 PC-AN-H2/0211 PC-R-021 PC-R-0211	1-143 1-143 1-144 1-144	0-10% 0-30%	Qualified Qualified Mild Environment Mild Environment
<u>Condensate and Feedwater System</u>							
Main Feedwater Flow	0 - 110% Design Flow (D.F.= 9.52×10^6 lb/hr total, 6.4×10^6 lb/hr per pump)	D-3	Detection of Operation, Analysis of Cooling	RFC-FT-50A,B RFC-ES-93 RFC-SORT-110A,B RFC-FI-89A,B	3-7 3-8 3-9 3-10	0-7.0 x 10^6 lb/hr Per Pump	N/A N/A N/A N/A
Condensate Storage Tank Level	Top to Bottom	D-3	Indication of Available Water for Cooling	CM-LT-5 Computer PT F001 ES-ES-1 CM-LIC-5 CM-LT-680A CM-LI-682	3-11 3-12 3-13 3-14 3-15 3-16	0 - 100% (0' - 40') 0 - 100% (0' - 36')	N/A N/A N/A N/A N/A N/A
Emergency Storage Tank Level	Bottom to Top	D-3	Indication of Available Water for Cooling	CM-LT-681A,B CM-LI-681A,B CM-ES-6	3-17 3-18 3-19	0 - 100% (0 - 16')	N/A N/A N/A

ITEM NO.	SEISMIC STATUS ¹	QA STATUS ²	REDUNDANT ³ CHANNEL	POWER SUPPLY	CR DISPLAY	REQUIRED FOR TSC	REQUIRED FOR EOF	INPUT TO PMIS	DEVIATIONS AND JUSTIFICATIONS
1-131	C	A	Yes	EE-PNL-CCP1A(12)/	Recorder	Yes	Yes	Yes	None
1-132	C	A		EE-PNL-CPP(26)	- Both				
1-133	C	A			Channels				
1-134	C	A							
1-135	C	A	Yes	EE-PNL-CCP1A(12)/	Recorder	Yes	Yes	Yes	None
1-136	C	A		EE-PNL-CPP(26)	- Both				
1-137	C	A			Channels				
1-138	C	A							
			N/A	480 VAC from PPGB1	Recorder and	Yes	Yes	Yes	None
				120 VAC from	Indicator -				
				LPGB1	Single Channel				
2-1	N/A	C							
2-2	N/A	C		EE-PNL-CCP1B(19)					
2-162	N/A	C							
2-163	N/A	C							
1-139	C	A	Yes	EE-PNL-CCP1A(20)	Recorder -	No	No	Yes	None
1-140	C	A		EE-PNL-CCP1B(18)	Both	No	No	Yes	
1-141	C	A		EE-PNL-CCP1A(20)	Channels				
1-142	C	A		EE-PNL-CCP1B(18)					
1-143	C	A	Yes	EE-PNL-CCP1A(20)	Recorder -	Yes	Yes	Yes	None
1-143	C	A		EE-PNL-CCP1B(18)	Both Channels				
1-144	C	A		EE-PNL-CCP1A(20)					
1-144	C	A		EE-PNL-CCP1B(18)					
3-7	N/A	C	N/A	EE-PNL-NBPP(4)	Indicator -	Yes	Yes	Yes	None
3-8	N/A	C		EE-PNL-AA2(2)	Both Channels				
3-9	N/A	C			Recorder -				
3-10	N/A	C			Single Channel				
3-11	N/A	C	N/A	EE-PNL-CCP1A(16)	Indicator -	Yes	Yes	Yes	None
3-12	N/A	C			Single Channel				
3-13	N/A	C							
3-14	N/A	C		EE-PNL-CCP1A(11)					
3-15	N/A	C	N/A	EE-PNL-PPCM1	Indicator -	Yes	Yes	Yes	None
3-16	N/A	C			Single Channel				
3-17	N/A	C	N/A	EE-PNL-CCP1B(12)	Indicator -	Yes	Yes	Yes	None
3-18	N/A	C			Both Channels				
3-19	N/A	C							

VARIABLE	RANGE REQUIRED IN R.C. 1.07	TYPE CATEGORY	PURPOSE	COOPER CIC NUMBER	ITEM NO.	INSTALLED RANGE	EO STATUS
<u>Fuel Cladding</u>							
Radioactivity Concentration or Radiation Level in Circulating Primary Coolant	1/2 Tech Spec Limit to 100 Times Tech Spec Limit	C-1	Detection or Breach	Post-Accident Sample System	1-145	Grab Sample	N/A
<u>Ventilation Systems</u>							
Emergency Ventilation Damper Position	Open - Closed Status	B-2	To Monitor Operation				
				HV-LMS-257AV(O), (C) HV-ADV-257AV Indicating Lights	2-3 2-4	Open-Closed	Mild Environment Mild Environment
				HV-MO-272MV HV-MO-272MV Indicating Lights	2-5 2-6	Open-Closed	Mild Environment Mild Environment
				HV-LMS-259AV(O), (C) HV-ADV-259AV Indicating Lights	2-7 2-8	Open-Closed	Mild Environment Mild Environment
				HV-MO-253MV HV-MO-258MV Indicating Lights	2-9 2-10	Open-Closed	Mild Environment Mild Environment
				HV-MO-260MV HV-MO-260MV Indicating Lights	2-11 2-12	Open-Closed	Mild Environment Mild Environment
				HV-LMS-261AV(O), (C) HV-ADV-261AV Indicating Lights	2-13 2-14	Open-Closed	Mild Environment Mild Environment
				HV-MO-262MV HV-MO-262MV Indicating Lights	2-14S 2-146	Open-Closed	Mild Environment Mild Environment
				HV-MO-264MV HV-MO-264MV Indicating Lights	2-147 2-148	Open-Closed	Mild Environment Mild Environment
				HV-MO-266MV HV-MO-266MV Indicating Lights	2-149 2-150	Open-Closed	Mild Environment Mild Environment
				HV-MO-268MV HV-MO-268MV Indicating Lights	2-151 2-152	Open-Closed	Mild Environment Mild Environment
				HV-LMS-263AV(O), (C) HV-ADV-263AV Indicating Lights	2-153 2-154	Open-Closed	Mild Environment Mild Environment
				HV-LMS-265AV(O), (C) HV-ADV-265AV Indicating Lights	2-155 2-156	Open-Closed	Mild Environment Mild Environment
				HV-LMS-267AV(O), (C) HV-ADV-267AV Indicating Lights	2-157 2-158	Open-Closed	Mild Environment Mild Environment
				HV-LMS-269AV(O), (C) HV-ADV-269AV Indicating Lights	2-159 2-160	Open-Closed	Mild Environment Mild Environment

ITEM NO.	SEISMIC STATUS ¹	OA STATUS ²	REDUNDANT ³ CHANNEL	POWER SUPPLY	CR DISPLAY	REQUIRED FOR TSC	REQUIRED FOR EOF	INPUT TO PMIS	DEVIATIONS AND JUSTIFICATIONS
1-145	None	C	No	LPRW-2A	None	No	No	No	Implemented as Category 3. Reference SER.
2-3	N/A	B	Yes ^a	EE-PNL-CCP1B(16)	Indicator Lights	Yes	Yes	Yes	None
2-4	N/A	B							
2-5	N/A	B	Yes ^a	EE-MCC-RA(3A)	Indicator Lights	Yes	Yes	Yes	
2-6	N/A	B							
2-7	N/A	B	Yes ^a	EE-PNL-CCP1B(16)	Indicator Lights	Yes	Yes	Yes	
2-8	N/A	B							
2-9	N/A	B	Yes ^a	EE-MCC-RA(3B)	Indicator Lights	Yes	Yes	Yes	
2-10	N/A	B							
2-11	N/A	B	Yes ^a	EE-MCC-RA(3C)	Indicator Lights	Yes	Yes	Yes	
2-12	N/A	B							
2-13	N/A	B	Yes ^a	EE-PNL-CCP1B(16)	Indicator Lights	Yes	Yes	Yes	
2-14	N/A	B							
2-145	N/A	B	Yes ^a	EE-MCC-RA(3D)	Indicator Lights	Yes	Yes	Yes	
2-146	N/A	B							
2-147	N/A	B	Yes ^a	EE-MCC-RA(4A)	Indicator Lights	Yes	Yes	Yes	
2-148	N/A	B							
2-149	N/A	B	Yes ^a	EE-MCC-RA(4B)	Indicator Lights	Yes	Yes	Yes	
2-150	N/A	B							
2-151	N/A	B	Yes ^a	EE-MCC-RA(4C)	Indicator Lights	Yes	Yes	Yes	
2-152	N/A	B							
2-153	N/A	B	Yes ^a	EE-PNL-CCP1B(16)	Indicator Lights	Yes	Yes	Yes	
2-154	N/A	B							
2-155	N/A	B	Yes ^a	EE-PNL-CCP1B(16)	Indicator Lights	Yes	Yes	Yes	
2-156	N/A	B							
2-157	N/A	B	Yes ^a	EE-PNL-CCP1B(16)	Indicator Lights	Yes	Yes	Yes	
2-158	N/A	B							
2-159	N/A	B	Yes ^a	EE-PNL-CCP1B(16)	Indicator Lights	Yes	Yes	Yes	
2-160	N/A	B							

VARIABLE	RANGE REQUIRED IN R.G. 1.97	TYPE- CATEGORY	PURPOSE	COOPER CIC NUMBER	ITEM NO.	INSTALLED RANGE	EQ STATUS
<u>Power Supplies</u>							
Status of Standby Power and Other Energy Sources Important to Safety	Plant Specific	D-2	To Monitor System Status	DG-A1-AM11,AM12	2-15	0 - 1200 Amps	Mild Environment
				DG-FQ1-FM2,FM3	2-16	55 - 65 CPS	Mild Environment
				DG-VAR1-VARM8,VARM9	2-17	0 - 7 HVAR	Mild Environment
				DG-V1-VM11,VM12	2-18	0 - 5250 VAC	Mild Environment
				DG-W1-WM1,WM2	2-19	0 - 7 M WATTS	Mild Environment
				EE-CB-4160DG1(EG1)	2-20		Mild Environment
				Current Transformers			
				EE-CB-4160DG1(EG1)	2-21		Mild Environment
				Potential Transformers			
				EE-CB-4160DG2(EG2)	2-22		Mild Environment
				Current Transformers			
				EE-CB-4160DG2(EG2)	2-23		Mild Environment
				Potential Transformers			
				DG-XFMR-Varm8	2-24		Mild Environment
				DG-XFMR-Varm9	2-25		Mild Environment
				EE-XFMR-EG1(RA)	2-26		Mild Environment
				EE-XFMR-EG1(RB)	2-27		Mild Environment
				EE-XFMR-EG1(RC)	2-28		Mild Environment
				EE-XFMR-EG2(RA)	2-29		Mild Environment
				EE-XFMR-EG2(RB)	2-30		Mild Environment
				EE-XFMR-EG2(GC)	2-31		Mild Environment
				IA-PI-606	2-32	0-120 psig	Mild Environment
				ES-ES-1	2-33		Mild Environment
				IA-PI-606	2-34		Mild Environment
				EE-A1-250A1	2-35	200 - 0 Amps 0 - 1000 Amps	Mild Environment

ITEM NO.	SEISMIC STATUS ¹	QA STATUS ²	REDUNDANT ³ CHANNEL	POWER SUPPLY	CR DISPLAY	REQUIRED FOR TSC	REQUIRED FOR EDF	INPUT TO PMIS	DEVIATIONS AND JUSTIFICATIONS
2-15	N/A	B	Yes ^a	DG1 & DG2 PT's & CT's	Indicators - Both Channels	Yes	Yes	Yes	None
2-16	N/A	B	Yes ^a			Yes	Yes	Yes	
2-17	N/A	B	Yes ^a			Yes	Yes	Yes	
2-18	N/A	B	Yes ^a			Yes	Yes	Yes	
2-19	N/A	B	Yes ^a			Yes	Yes	Yes	
2-20	N/A	B				Yes	Yes	Yes	
2-21	N/A	B							
2-22	N/A	B							
2-23	N/A	B							
2-24	N/A	B							
2-25	N/A	B							
2-26	N/A	B							
2-27	N/A	B							
2-28	N/A	B							
2-29	N/A	B							
2-30	N/A	B							
2-31	N/A	B							
2-32	N/A	B	No	ES-ES-1 EE-PNL-CCP1A(16)		Yes	Yes	Yes	None
2-33	N/A	B							
2-34	N/A	B							
2-35	N/A	B	N/A	250 VDC Batt. 1A	Indicator	Yes	Yes	Yes	None

VARIABLE	RANGE REQUIRED IN R.G. 1.97	TYPE CATEGORY	PURPOSE	COOPER CIC NUMBER	ITEM NO.	INSTALLED RANGE	ED STATUS
Primary Containment - Related Systems	0 - 110% Design Flow	D-2	To Monitor Operation	EE-VI-250A1	2-36	0 - 300 Volts	Mild Environment
				EE-AI-250A2	2-37	0 - 300 Amps	Mild Environment
				EE-AI-250B1	2-38	200 - 0 Amps	Mild Environment
				EE-AI-250B2	2-39	0 - 1000 Amps	Mild Environment
				EE-VI-250B1	2-40	0 - 300 Volts	Mild Environment
				EE-AI-125A1	2-41	200 - 0 Amps	Mild Environment
				EE-AI-125A2	2-42	0 - 1000 Amps	Mild Environment
				EE-VI-125A1	2-43	0 - 150 Volts	Mild Environment
				EE-AI-125B1	2-44	200 - Amps	Mild Environment
				EE-AI-125B2	2-45	0 - 1000 Amps	Mild Environment
				EE-VI-125B1	2-46	0 - 150 Volts	Mild Environment
				AC BUS Status	2-47		
				None	2-48	N/A	N/A
				PC-PI-513	2-49	0 - +2.0 psig	Qualified
				PC-R-(RPPG-513)	2-50		Mild Environment
				PC-PI-512A,B	2-51	-5 - 70 psig	Qualified
Suppression Pool Water	Top of Vent to Top of Weir Well	D-2	To Monitor Operation	PC-IE-5A,B	2-52		Mild Environment
				PC-SC-4A,B	2-53		Mild Environment
				PC-PR-2A,B	2-161		Mild Environment
				PC-PI-4A1,4B2	2-54	0 - 250 psig	Qualified
				PC-IE-3A,3B	2-55		Mild Environment
				PC-SC-3A,3B	2-56		Mild Environment
				PC-PR-1A,1B	2-57		Mild Environment
				PC-DPT-3A1,3B2	2-58	0 - 30" (866'-896")	Qualified
				PC-IE-2A,2B	2-59		Mild Environment
				PC-SC-1A,1B	2-60		Mild Environment
				PC-LP-1A,1B	2-61		Mild Environment

ITEM NO.	SEISMIC STATUS ¹	QA STATUS ²	REDUNDANT ³ CHANNEL	POWER SUPPLY	CR DISPLAY	REQUIRED FOR TSC	REQUIRED FOR EQF	INPUT TO PMIS	DEVIATIONS AND JUSTIFICATIONS
2-36	N/A	B	N/A	250 VDC BUS 1A	Indicator	Yes	Yes	Yes	None
2-37	N/A	B	N/A	250 VDC CHG. 1A	Indicator	Yes	Yes	Yes	None
2-38	N/A	B	N/A	250 VDC Batt. 1B	Indicator	Yes	Yes	Yes	None
2-39	N/A	B	N/A	250 VDC CHG. 1B	Indicator	Yes	Yes	Yes	None
2-40	N/A	B	N/A	250 VDC BUS 1B	Indicator	Yes	Yes	Yes	None
2-41	N/A	B	N/A	125 VDC Batt. 1A	Indicator	Yes	Yes	Yes	None
2-42	N/A	B	N/A	125 VDC CHG. 1A	Indicator	Yes	Yes	Yes	None
2-43	N/A	B	N/A	125 VDC BUS 1A	Indicator	Yes	Yes	Yes	None
2-44	N/A	B	N/A	125 VDC Batt. 1B	Indicator	Yes	Yes	Yes	None
2-45	N/A	B	N/A	125 VDC CHG. 1B	Indicator	Yes	Yes	Yes	None
2-46	N/A	B	N/A	125 VDC BUS 1B	Indicator	Yes	Yes	Yes	None
2-47									Not implemented as status can be derived from other sources.
2-48	N/A	N/A	N/A	N/A	N/A	No	No	No	Not implemented. Reference SER.
2-49	N/A	B	N/A	EE-PNL-CCP1A(9)	Recorder - Single Channel	Yes	Yes	Yes	None
2-50	N/A	B							
2-51	N/A	A	N/A	EE-PNL-CCP1A(12)	Recorder	Yes	Yes	Yes	None
2-52	N/A	A		EE-PNL-CPP(26)	Both Channels				
2-53	N/A	A							
2-161	N/A	A							
2-54	N/A	A	N/A	EE-PNL-CCP1A(12)	Recorders - Both Channels	Yes	Yes	Yes	None
2-55	N/A	A		EE-PNL-CPP(26)					
2-56	N/A	A							
2-57	N/A	A							
2-58	N/A	A	N/A	EE-PNL-CCP1A(12)	Recorders - Both Channels	Yes	Yes	Yes	None
2-59	N/A	A		EE-PNL-CPP(26)					
2-60	N/A	A							
2-61	N/A	A							

VARIABLE	RANGE REQUIRED IN R.C. 1.97	TYPE- CATEGORY	PURPOSE	COOPER CIC NUMBER	ITEM NO.	INSTALLED RANGE	EQ STATUS
Suppression Pool Water Temperature	30°F to 230°F	A-1 D-2	To Monitor Operation	PC-TE-1A,B,C,D,E,F,G, H,2A,B,C,D,E,F,G,H PC-TR-24 PC-TR-25	1-146 1-147 1-159	0 - 250°F	Qualified Mild Environment Mild Environment
Drywell Atmospheric	40°F to 440°F	D-2	To Monitor Operation	PC-TE-505A-E PC-R1-505A-E PC-T1-505A-E PC-TE-510A-E PC-R1-510A-E PC-T1-510A-E PC-AM-510A,B,C	2-62 2-63 2-64 2-65 2-66 2-67 2-161	50° - 600°F 50° - 350°F	Qualified Mild Environment Mild Environment Qualified Mild Environment Mild Environment Mild Environment
Drywell Spray Flow	0 to 110% Design Flow	D-2	To Monitor Operation	None	2-68		
<u>Main Steam System</u>							
Main Steamline Isolation Valves Leakage Control System Procedure	0 to 15" of Water 0 to 5 psig	D-2	To Provide Indication of Pressure Boundary Maintenance	N/A to BWR 4	2-69		
Primary System Safety Relief Valve Positions, Including ADS or Pressure in Valve Lines	Closed - Not Closed 0 - 50 psig	D-2	Detection of Accident; Boundary Integrity Indication	MS-PS-300A-K (SRV) MS-T2-112A,B,C (SV) MS-TE-114A,B,C (SV) MS-TR-166	2-70 2-71 2-72 2-73	30 psi (0-30 psi) 0 - 600°F 0 - 600°F	Qualified Qualified Qualified
Isolation Condenser System Shellside Water Level	Top to Bottom	D-2	To Monitor Operation	N/A to CNS	2-74		Mild Environment
Insulation Condenser System Valve Position	Open or Closed	D-2	To Monitor Operation	N/A to CNS	2-75		
RCIC Flow	0 - 110% Design Flow (D.F. = 416 GPM)	D-2	To Monitor Operation	RCIC-F1-78 RCIC-FIC-91 RCIC-SQRT-99	2-76 2-77 2-78	0 - 500 GPM	Qualified Mild Environment Mild Environment

ITEM NO.	SEISMIC STATUS ¹	QA STATUS ²	REDUNDANT ³ CHANNEL	POWER SUPPLY	CR DISPLAY	REQUIRED FOR TSC	REQUIRED FOR EUF	INPUT TO PMIS	DEVIATIONS AND JUSTIFICATIONS
1-146	C	A	Yes	EE-PNL-CCP1A(12) EE-PNL-CPP(26)	Recorder Both Channels	Yes	Yes	Yes	None
1-147	C	A	Yes	EE-PNL-CCP1A(16)					
1-159	C	A	Yes	EE-PNL-CPP(14)					
2-62	N/A	A	N/A	EE-PNL-CCP1A(16)	Indicator - Single Channel	Yes	Yes	Yes	None
2-63	N/A	B							
2-64	N/A	B							
2-65	N/A	A	N/A	EE-PNL-CCP1A(16)	Indicator - Single Channel	Yes	Yes	Yes	Expanded range not implemented. Reference SER.
2-66	N/A	A							
2-67	N/A	B							
2-161	N/A	A							
2-68									Not implemented. Reference SER.
2-69									Not applicable to CNS.
2-70	N/A	B	N/A	EE-PNL-AA2(6)	Indicator Lights	Yes	Yes	Yes	None
2-71	N/A	A	N/A	EE-PNL-CPP(4)	Recorder - Single Channel	Yes	Yes	Yes	
2-72	N/A	A	N/A		Computer Pt.				
2-73	N/A	B	N/A						
2-74									Not applicable to CNS.
2-75									Not applicable to CNS.
2-76	N/A	A	N/A	EE-PNL-NBPP(19)	Indicator -	Yes	Yes	Yes	None
2-77	N/A	B	N/A	9-4(13A-F14)	Single Channel				
2-78	N/A	B	N/A						

VARIABLE	RANGE REQUIRED IN R.O. 1.07	TYPE CATEGORY	PURPOSE	COOPER CIC NUMBER	ITEM NO.	INSTALLED RANGE	EQ STATUS
HPCI Flow	0 - 110% Design Flow (D.F. = 4250 GPM)	D-2	To Monitor Operation	HPCI-FI-B2 HPCI-FIC-108 HPCI-1VTR-119 HPCI-SORT-118	2-79 2-80 2-81 2-82	0 - 5000 GPM	Qualified Wild Environment Wild Environment Wild Environment
Core Spray System Flow	0 - 110% Design Flow (D.F. = 4720 GPM)	D-2	To Monitor Operation	CS-FI-20A-B CS-ES-52A-B CS-FI-50A-B	2-83 2-84 2-85	0 - 6000 GPM	Qualified Wild Environment Wild Environment
LPCI Flow	0 - 110% Design Flow (D.F. = 15,000 GPM)	D-2	To Monitor Operation	RHR-FI-109A-B RHR-ES-145A-B RHR-SORT-134A-B RHR-FI-133A-B	2-86 2-87 2-88 2-89	0 - 20,000 GPM	Qualified Wild Environment Wild Environment Wild Environment
SLCS Flow	0 - 110% Design Flow	D-2	To Monitor Operation	None	2-90		
SLCS Storage Tank Level	Top to Bottom	D-2	To Monitor Operation	SLC-LI-45 SLC-LI-66 SLC-ES-69	2-91 2-92 2-93	0 - 100% Level	Wild Environment Wild Environment Wild Environment
<u>Residual Heat Removal Systems</u>							
RHR System Flow	0 - 110% Design Flow (D.F. = 15,000 GPM)	D-2	To Monitor Operation	RHR-FI-109A-B RHR-ES-145A-B RHR-SORT-134A-B RHR-FI-133A-B	2-94 2-95 2-96 2-97	0 - 20,000 GPM	Qualified Wild Environment Wild Environment Wild Environment
RHR Heat Exchanger Outlet Temperature	40°F to 350°F	D-2	To Monitor Operation	RHR-TE-94C,D RHR-TR-131	2-98 2-99	0 - 600°F	Qualified Wild Environment

ITEM NO.	SEISMIC STATUS ¹	QA STATUS ²	REDUNDANT ³ CHANNEL	POWER SUPPLY	CR DISPLAY	REQUIRED FOR TSC	REQUIRED FOR EDF	INPUT TO PMIS	DEVIATIONS AND JUSTIFICATIONS
2-79	N/A	A	N/A	EE-PNL-B52(1B)	Indicator -	Yes	Yes	Yes	None
2-80	N/A	B	N/A	9-4(23A-F25 & 23A-F26)	Single Channel				
2-81	N/A	B	N/A						
2-82	N/A	B	N/A						
2-83	N/A	A	N/A	EE-PNL-CCP1A(3)	Indicators -	Yes	Yes	Yes	None
2-84	N/A	B	N/A	9-19(14-F52AV)	Double Channel				
2-85	N/A	B	N/A	EE-PNL-CCP(9) 9-18(14A-F3)					
2-86	N/A	A	N/A	EE-PNL-CCP1A(3)	Indicator -	Yes	Yes	Yes	None
2-87	N/A	B	N/A	9-18(14A-F16A)	Double Channel				
2-88	N/A	B	N/A	EE-PNL-CCP1B(3)					
2-89	N/A	B	N/A	9-18(10A-F16B)					
2-90									Not implemented. Reference SER.
2-91	N/A	B	N/A	EE-PNL-CCP(9)	Indicator -	Yes	Yes	Yes	Implemented as Category 3. Reference SER.
2-92	N/A	B	N/A	(11A-F2)	Single Channel				
2-93	N/A	B	N/A						
2-94	N/A	A	N/A	EE-PNL-CCP1A(3)	Indicators -	Yes	Yes	Yes	None
2-95	N/A	B	N/A	EE-PNL-CCP1B(3)	Double Channels				
2-96	N/A	B	N/A						
2-97	N/A	B	N/A						
2-98	N/A	A	N/A	EE-PNL-CCP(4)	Common	Yes	Yes	Yes	None
2-99	N/A	B	N/A		Recorder				

VARIABLE	RANGE REQUIRED IN R.G. 1.97	TYPE- CATEGORY	PURPOSE	COOPER CIC NUMBER	ITEM NO.	INSTALLED RANGE	EO STATUS
<u>Cooling Water System</u>							
Cooling Water Temperature to ESF System Components	40°F to 200°F	D-2	To Monitor Operation	SW-TE-94A,B	2-100	0 - 600°F	N/A
				RHR-TR-131	2-101		Mild Environment
				(RHR Hx Outlet)			
				SW-TE-388A,B	2-102	0°F - 200°F	N/A
				(REC Hx Outlet)			
				SW-TE-390A,B	2-103	0°F - 200°F	N/A
				(RHR Hx Inlet)			
				SW-TE-387A,B	2-104	0°F - 200°F	N/A
(REC Hx Inlet)							
Cooling Water Flow to ESF System Components	0 - 110% Design Flow	D-2	To Monitor Operation	SW-FI-97A,B (RHR Hx)	2-105	0 - 10,000 GPM	Qualified
				RHR-ES-145A,B	2-106		Mild Environment
				SW-SORT-132A,B	2-107		Mild Environment
				SW-FI-132A,B	2-108		Mild Environment
				SW-FI-387A,B (REC Hx)	2-109	0 - 8000 GPM	Qualified
				SW-SORT-387A,B	2-110		Mild Environment
				SW-FI-387A,B	2-111		Mild Environment
				REC-ES-10(A)	2-112		Mild Environment
				REC-ES-9(B)	2-113		Mild Environment
<u>Radwaste Systems</u>							
High Radioactivity Liquid Tank Level	Top to Bottom	D-3	To Monitor Operation	RW-LT-420	3-20	0 - 100%	N/A
				(FLR DRN COLL TK)			
				RW-LT-369	3-21	0 - 100%	N/A
			(WASTE COLL TK)				
<u>Containment Radiation</u>							
Primary Containment Area Radiation High Range	1R/hr to 10 ⁷ R/hr	E-1	Detection of Significant Releases; Release Assessment; Long-Term Surveillance Emergency Plan Actuation	RMA-RE-40A,B	1-148	1R/hr to 10 ⁷ R/hr	Qualified
				RMA-RM-40A,B	1-149		Mild Environment
				RMA-RR-40	1-150		Mild Environment
Secondary Containment Area Radiation High Range	10 ⁻¹ R/hr for Mark I Containments	E-2	Detection of Significant Releases; Release Assessment; Long-Term Surveillance	Fuel Pool Area-		10 ⁻¹ R/hr to 10 ³ R/hr	
				RMA-RE-1	2-114		N/A
				RMA-RM-AU1	2-115		N/A
				RMA-RA-1	2-116		Mild Environment
				HPCI Room-		10 ⁻⁵ R/hr to 10 ⁻¹ R/hr	
				RMA-RE-10	2-117		N/A
				RMA-RA-10	2-188		Mild Environment

ITEM NO.	SEISMIC STATUS ¹	QA STATUS ²	RECORDING CHANNEL ³	POWER SUPPLY	CR DISPLAY	REQUIRED FOR TSC	REQUIRED FOR EDF	INPUT TO PMS	DEVIATIONS AND JUSTIFICATIONS	
2-100	N/A	B	N/A	EE-PNL-CCP(4)	Common Recorder	Yes	Yes	Yes	Implemented as Category 3 for the following reasons: 1) Heat exchanger operation is monitored via qualified instrumentation for cooling water flow to ESP system components (R.G. 1.07 Items 2-105 thru 2-113). 2) Indication of Heat Exchanger outlet temperature on the RAR side is provided by qualified instrumentation (R.G. 1.07 Items 2-08 and 2-09). 3) The river temperature does not significantly change over a short period of time and is indicated by other instrumentation in mild environments.	
2-101	N/A	B	N/A		Computer Pts	Yes	Yes	Yes		
2-102	N/A	B	N/A		Computer Pts	Yes	Yes	Yes		
2-103	N/A	B	N/A		Computer Pts	Yes	Yes	Yes		
2-104	N/A	B	N/A		Computer Pts	Yes	Yes	Yes		
2-105	N/A	A	N/A	EE-PNL-CCP1A(3)		Yes	Yes	Yes	None	
2-106	N/A	B	N/A	EE-PNL-CCP1B(3)						
2-107	N/A	B	N/A							
2-108	N/A	B	N/A							
2-109	N/A	A	N/A	EE-PNL-CCP1A(8)		Yes	Yes	Yes		
2-110	N/A	B	N/A	EE-PNL-CCP1B(17)					None	
2-111	N/A	B	N/A							
2-112	N/A	B	N/A							
2-113	N/A	B	N/A							
2-114	N/A									
3-20	N/A	None	N/A	EE-PNL-MBPP(5) 25-17-(20A-F1)	Radiation C.R. Only	No	No	No	No direct indication in Control Room. Monitored every two hours by Operations Personnel.	
3-21	N/A	None	N/A	EE-PNL-MBPP(5) 25-17-(20A-F1)						
1-140	C	A	Yes ⁶	EE-PNL-CCP1A(19)	Common Recorder	Yes	Yes	Yes		
1-149	C	A		EE-PNL-CCP1B(11)						
1-150	None (See Deviations)	A	No	EE-PNL-CCP1A(19)						
2-114	N/A	B	N/A	EE-PNL-CPP(5), EE-PNL-CPP(5)	Indicator - Single Channel	Yes	Yes	Yes	The recorder is isolated from the readout modules by an optical isolator. Indication is also provided by the 1E readout modules (R.G. 1.07 Item 1-149). MBPP does not intend to qualify this recorder. Not implemented as a Reg. Guide 1.07 parameter. Reference SEE.	
2-115	N/A	B		EE-PNL-CPP(5)						
2-116	N/A	B		EE-PNL-CPP(5)						
2-117	N/A	B	N/A	EE-PNL-CPP(5)	Indicator - Single Channel	Yes	Yes	Yes		
2-118	N/A	B		EE-PNL-CPP(5)						

VARIABLE	RANGE REQUIRED IN A.C. 1.97	TYPE CATEGORY	PURPOSE	COOPER CIC NUMBER	ITEM NO.	INSTALLED RANGE	ED
Area Radiation	10 ⁵ R/hr to 10 ⁶ R/hr	E-3	Detection of Significant Releases; Release Assessment, Long-Term Surveillance	RSE SW QUAD	2-110	10 ⁵ R/hr to 10 ⁶ R/hr	N/A
				RMA-RE-11	2-120		N/A
				RMA-RM-AUT11	2-121		Mild Environment
				RMA-RA-11	2-122	10 ⁵ R/hr to 10 ⁶ R/hr	N/A
				RSE NY QUAD	2-123		N/A
				RMA-RE-12	2-124		Mild Environment
				RMA-RM-AUT12	2-125	10 ⁵ R/hr to 10 ⁶ R/hr	N/A
				RMA-RA-12	2-126		Mild Environment
				RCIC RM	2-127		N/A
				RMA-RE-13	2-128	10 ⁵ R/hr to 10 ⁶ R/hr	N/A
				RMA-RA-13	2-129		Mild Environment
				CS SE RM	2-130		N/A
				RMA-RE-14	2-131	Same List as Above	N/A
				RMA-RM-AUT14	2-132		Mild Environment
				RMA-RA-14	2-133		Same List as Above

Airborne Radioactive Materials
Released from Plant

Noble Gases and Vent Flow Rate Drywell Purge, Standby Gas Treatment System Purge	10 ⁶ uCi/cc to 10 ⁸ uCi/cc 0-1102 Vent Design Flow (DF=6035 cfm)	E-2 C-3	Detection of Significant Releases, Release Assessment	ERP Mi-range Effluent Monitor RMD-RM-3A,B	2-130	5x10 ⁷ uCi/cc to 1x10 ⁸ uCi/cc (Note 4)	Mild Environment
				OS-FIT-4001	2-131		
				RV-FR-4000	2-132		
				RMD-CBX-(3A,B-1)	2-164	0-10,000 cfm	Mild Environment
				RMD-CBX-(3A,B-2)	2-165		
				RMD-RE-5	2-166		
				T-G Mi-range Effluent Monitor RMD-RM-70A,B	2-133	5x10 ⁸ uCi/cc to 1x10 ⁹ uCi/cc (Note 4)	Mild Environment
				RV-FIT-4002A,B,C,D	2-134		
				RV-SST-4002A,B,C,D	2-135		
				RV-SOM-4002	2-136	0-250,000 cfm	Mild Environment
Auxiliary Building	10 ⁶ uCi/cc to 10 ⁸ uCi/cc 0-1102 Vent Design Flow (DF=152,130)	E-2 C-3	Detection of Significant Releases, Release Assessment	RV-FR-4000	2-137		
				RMD-CBX-(20A,B-1)	2-167		
				RMD-CBX-(20A,B-2)	2-168		
				RMD-RE-20	2-169		

ITEM NO.	SEISMIC STATUS	QA STATUS	REDUNDANT CHANNEL	POWER SUPPLY	CR DISPLAY	REQUIRED FOR ISC	REQUIRED FOR EOP	INPUT TO PMS	DEVIATIONS AND JUSTIFICATIONS
2-110 N/A		B	N/A	EE-PNL-CPP(5)	Indicator - Single Channel	Yes	Yes	Yes	See Above
2-120 N/A		B		EE-PNL-CPP(5)					
2-121 N/A		B		EE-PNL-CPP(5)					
2-122 N/A		B	N/A	EE-PNL-CPP(5)	Indicator - Single Channel	Yes	Yes	Yes	See Above
2-123 N/A		B		EE-PNL-CPP(5)					
2-124 N/A		B		EE-PNL-CPP(5)					
2-125 N/A		B	N/A	EE-PNL-CPP(5)	Indicator - Single Channel	Yes	Yes	Yes	See Above
2-126 N/A		B		EE-PNL-CPP(5)					
2-127 N/A		B	N/A	EE-PNL-CPP(5)	Indicator - Single Channel	Yes	Yes	Yes	See Above
2-128 N/A		B		EE-PNL-CPP(5)					
2-129 N/A		B		EE-PNL-CPP(5)					
2-130 N/A		C	N/A	480 VAC from PPG81 120 VAC from LPGB1	Indicator and Recorder - Single Channel	Yes	Yes	Yes	None
2-131 N/A		C		EE-PNL-NSPP(15)					
2-132 N/A		C	N/A	EE-PNL-CCP1B (19)					
2-164 N/A		C		EE-PNL-LPGB1 (12)		No	No	No	None
2-165 N/A		C		EE-PNL-CCP1B (19)					
2-166 N/A		C	N/A	480 VAC from MCC-DG1 120 VAC from CCP2B(7)	Indicator and Recorder - Single Channel	Yes	Yes	Yes	None
2-135 N/A		C		NV-ES-4002A,B					
2-136 N/A		C		NV-ES-4102A,B					
2-137 N/A		C	N/A	EE-PNL-CCP(22)					
2-167 N/A		C		EE-PNL-CCP1B (19)					
2-168 N/A		C		EE-PNL-CCP2B (7)					
2-169 N/A		C		EE-PNL-CCP1B (19)					

Implemented as Category 3 with the range of 10^5 R/hr to 10^7 R/hr for the WPCJ Room, RHR SU DUMD, RHR NU DUMD, RCIC RM and CS SE RM and a range of 10^5 R/hr to 10^7 R/hr for the fuel pool areas. Reference SER.

VARIABLE	RANGE REQUIRED IN P.G. 1.97	TYPE- CATEGORY	PURPOSE	COOPER CIC NUMBER	ITEM NO.	INSTALLED RANGE	EQ STATUS
Auxiliary Building Common Plant Vent	10 ⁶ uCi/cc to 10 ⁷ uCi/cc 0 - 110% Design Flow	E-2 C-3	Detection of Significant Releases, Release Assessment	RU Hi-range Effluent Monitor RMV-RM-30A,B RV-FT-4004 RV-SQRT-4004 RV-FRDP-4003 RMV-CBX-130A,B-1 RMV-CBX-130A,B-2 RMV-RR-30	2-138 2-139 2-140 2-141 2-170 2-171 2-172	5x10 ⁷ uCi/cc to 1x10 ⁸ uCi/cc (Note 4) 0-81,600 cfm	Wild Environment Wild Environment Wild Environment Wild Environment Wild Environment Wild Environment Wild Environment
Common Plant Vent	10 ⁶ uCi/cc to 10 ⁷ uCi/cc 0 - 110% Design Flow (DF=6035)	E-2 C-3	Detection of Significant Releases, Release Assessment	ERP Hi-range Effluent Monitor RMV-RM-3A,B OG-FIT-4001 RV-FR-4000	2-142 2-143 2-144	5x10 ⁷ uCi/cc to 10 ⁸ uCi/cc (Note 4) 0-10,000 cfm	Wild Environment Wild Environment Wild Environment
Particulates and Halogens Common Plant Vent	10 ³ uCi/cc to 10 ⁷ uCi/cc 0 - 110% Design Flow (DF=6035)	E-3	Detection of Significant Releases, Release Assessment; Long-Term Surveillance	ERP Hi-range Effluent Monitor RMV-RM-3A,B OG-FIT-4001 RV-FR-4000	3-22 3-23 3-24	10 ⁸ uCi/cc to 1x10 ⁹ uCi/cc (Note 4) 0-10,000 cfm	N/A N/A N/A
Auxiliary Building Common Plant Vent	10 ³ uCi/cc to 10 ⁷ uCi/cc 0 - 110% Design Flow (DF=152,130)	E-3	Detection of Significant Releases, Release Assessment; Long-Term Surveillance	T-6 Hi-range Effluent Monitor RMV-RM-20A,B RV-FT-4002,A,B,C,D RV-SQRT-4002A,B,C,D RV-SUM-4002 RV-FR-4000	3-25 3-26 3-27 3-28 3-29	10 ⁸ uCi/cc to 10 ⁹ uCi/cc (Note 4) 0-250,000 cfm	N/A N/A N/A N/A N/A
Auxiliary Building Common Plant Vent	10 ³ uCi/cc to 10 ⁷ uCi/cc 0 - 110% Design Flow (DF=56,870)	E-3	Detection of Significant Releases, Release Assessment; Long-Term Surveillance	RU Hi-range Effluent Monitor RMV-RM-30A,B RV-FT-4004 RV-SQRT-4004 RV-FRDP-4003	3-30 3-31 3-32 3-33	10 ⁸ uCi/cc to 10 ⁹ uCi/cc (Note 4) 0-81,600 cfm	N/A N/A N/A N/A
Auxiliary Building Common Plant Vent	10 ³ uCi/cc to 10 ⁷ uCi/cc 0 - 110% Design Flow (DF=15,000 cfm)	E-3	Detection of Significant Releases, Release Assessment; Long-Term Surveillance	MDF Hi-range Effluent Monitor RMV-RM-10 RV-FT-4006 RV-SQRT-4006 RV-FR-4006	3-34 3-35 3-37 3-38	10 ¹⁰ to 10 ¹¹ uCi/cc Particulate Monitor with Onsite Analysis to 10 ⁸ uCi/cc 0-20,000 cfm	N/A N/A N/A N/A
Environ. Radiation and Radioactivity	10 ⁸ uCi/cc to 10 ⁹ uCi/cc	E-3	Release assessment; analysis	RP-1	3-39	10 ⁹ uCi/cc to 10 ¹⁰ uCi/cc	N/A

Environ. Radiation and
Radioactivity

Airborne Radiohalogens and
Particulates (portable
sampling with onsite analysis
capability)

VARIABLE	RANGE REQUIRED IN R.G. 1.97	TYPE- CATEGORY	PURPOSE	COOPER CIC NUMBER	ITEM NO.	INSTALLED RANGE	EQ-STATUS
Plant and Environs Radiation (portable instrumentation)	10^{-3} R/hr to 10^4 R/hr, photons 10^{-3} rads/hr to 10^2 rads/hr, beta radiations and low-energy photons	E-3 E-3	Release assessment; analysis	WP-2 WP-3	3-40	10^{-3} R/hr to 10^3 R/hr Gamma, 10^{-3} rads/hr to 200 rads/hr Beta	N/A
Plant and Environs Radio- activity (portable instrumentation)	(Isotopic Analysis)	E-3	Release assessment; analysis	None	3-42	Iodine Analysis	N/A
Meteorology							
Wind Direction	0 - 360° ($\pm 5^\circ$ accuracy with a deflection of 10"). Starting speed less than 0.4 mps (1.0 mph). Damping ratio greater than or equal to 0.4, delay distance less than or equal to 2 meters.	E-3	Release assessment	M1-T-WD4 M1-T-WD3 M1-T-WD2	3-43	0-540° $\pm 3^\circ$ thresh- hold 0.58 mph damping 0.4 at 1.13 meters	N/A
Wind Speed	0 - 22 mps (50 mph). ± 2 mps (0.5) mph accuracy for speeds less than 2 mps (5 mph), 10% for speeds in excess of 2 mps (5 mph), with a starting thresh- hold of less than 0.4 mps (1.0 mph) and a distance constant not to exceed 2 meters.	E-3	Release assessment	M1-T-WS4 M1-T-WS3 M1-T-WS2	3-44	0-100 mph acc. ± 0.15 mph or 1% threshold 0.6 mph, dist. const. equals 1.5 meters	N/A

ITEM NO.	SEISMIC STATUS ¹	QA STATUS ²	REDUNDANT ³ CHANNEL	POWER SUPPLY	CR DISPLAY	REQUIRED FOR TCC	REQUIRED FOR EOC	INPUT TO PMIS	DEVIATIONS AND JUSTIFICATIONS
3-40	N/A	C	N/A	Portable N/A	No	No	No	No	Reference SEP.
3-42	N/A	C	N/A	N/A	No	No	No	No	Laboratory analysis is used as it is more accurate.
3-43	N/A	C	N/A	Normal-Offsite Emergency-MCC-1	SPDS	Yes	Yes	Yes	None
3-44	N/A	C	N/A	Normal-Offsite Emergency-MCC-1	SPDS	Yes	Yes	Yes	None

VARIABLE	RANGE REQUIRED IN S.G. 1.97	TYPE- CATEGORY	PURPOSE	COOPER CIC NUMBER	ITEM NO.	INSTALLED RANGE	SQ STATUS
Estimation of Atmospheric Stability	Based on vertical temperature difference from primary meteorological system, 5°C to 10°C (-9°F to 18°F) and ±0.15°C accuracy per 50-meter intervals (±0.3°F accuracy per 164-foot intervals) or analogous range for alternative stability estimates.	E-3	Release assessment	Met-005 Met-013 Met-021	3-45	-30 to +50°C ±5% Δ not to exceed 0.15°C	N/A
<u>Accident Sampling Capability</u> (Analysis Capability on Site)							
Primary Coolant and Sump	Grab Sample	E-3	Release assessment; verification; analysis	PASS	3-46		N/A
Gross Activity	1 uCi/ml to 10 Ci/ml					1 uCi/ml to 10 Ci/ml	
Gamma Spectrum	(Isotopic Analysis)					(Isotopic Analysis)	
Boron Content	0 - 1000 ppm					0 to 15 ppm (dilutable)	
Chloride Content	0 to 20 ppm					10 ppb to 10 ppm (dilutable)	
Dissolved Hydrogen or Total Gas	0 to 2000 cc(STP)/kg					Not available-calculated	
Dissolved Oxygen	0 to 20 ppm					10 ppb to 1 ppm (dilutable)	
pH	1 to 13					1 to 14 (online)	
Containment Air	Grab Sample	E-3	Release assessment; verification; analysis	PASS	3-47		N/A
Gamma Spectrum	(Isotopic analysis)					Isotopic Analysis	

ITEM NO.	SEISMIC STATUS ¹	QA STATUS ²	REDUNDANT ³ CHANNEL	POWER SUPPLY	CR DISPLAY	REQUIRED FOR TSC	AIRBORNE FOR EDF	INPUT TO PMIS	EXPLANATIONS AND JUSTIFICATIONS
3-45	N/A	C	N/A	Normal-Offsite Emergency-MCC-1	SPDS	Yes	Yes	Yes	
3-46	N/A	C	N/A	EE-PNL-LPRW2	No	No	No	No	Implement as Category 3 for primary coolant sampling only. Sump sample not implemented. Reference SER.
3-47	N/A	C	N/A	EE-PNL-LPRW2	No	No	No	No	None

Note:

¹Seismic Status

- A - Original Plant Criteria furnished by GE
- B - Original Plant Criteria BOP
- C - Qualified to R.G. 1.100

²QA Status

- A - 10 CFR 50 Appendix B
- B - Original QA Design Criteria
- C - High Quality

³Redundant Channel

- a - All redundant or diverse channels are electrically independent and are physically separated from each other although they do not always meet with the minimum separation distances as specified in Reg. Guide 1.75.
- b - Although supplied by one division, one channel is supplied by a DC source and the other by an AC source.
- c - Diverse circuits supplied by one division
- d - Redundant valve is a check valve without indication.

⁴Airborne radioactive releases will be displayed on two C.R. recorder channels with ranges of 10^{-2} to 10^3 uCi/sec and 10^2 to 10^{12} uCi/sec which are obtained by combining the radioactivity concentration (uCi/cc) and flow rate (cfm). This parameter (uCi/sec) is displayed since it is directly releatable to the off-site release limits.