



PEACH BOTTOM—THE POWER OF EXCELLENCE

PHILADELPHIA ELECTRIC COMPANY

PEACH BOTTOM ATOMIC POWER STATION

R. D. 1, Box 208
Delta, Pennsylvania 17314

(717) 456-7014

April 27, 1990

Docket Nos. 50-277
50-278

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

SUBJECT: Peach Bottom Atomic Power Station, Units 2 and 3
Appendix R Fire Protection Modifications

REFERENCE: Letter from J. W. Gallagher (PECo), to
W. R. Butler (NRC), dated October 5, 1988

In the referenced letter, PECO indicated that Modification (Mod) 2285 "Provide Alternate Power Supply to the Residual Heat Removal (RHR) Minimum Flow Valve," would be implemented on both units as a long-term solution for ensuring minimum flow protection for the RHR pumps in the event of a 10 CFR 50 Appendix R fire. This letter is to inform you that Mod 2285 has been completed on Unit 3, but that Mod 2285 will not be completed on Unit 2 during the 8th refueling outage as previously scheduled. The solution for this 10 CFR 50 Appendix R issue (Mod 2084), as described in the referenced letter, remains in effect on Unit 2. This establishes compliance with the applicable 10 CFR 50 Appendix R requirement.

Should you have any questions or require additional information, please do not hesitate to contact us.

Sincerely,

cc: R. A. Burricelli, Public Service Electric & Gas
T. M. Gerusky, Commonwealth of Pennsylvania
J. J. Lyash, USNRC Senior Resident Inspector
T. E. Magette, State of Maryland
T. T. Martin, Administrator, Region I, USNRC
H. C. Schwemm, Atlantic Electric
J. Urban, Delmarva Power

9005030055 900427
FDR ADOCK 05000277
F PDC

*Adob
1/0*