



Commonwealth Edison  
Byron Nuclear Station  
4450 North German Church Road  
Byron, Illinois 61010

April 10, 1990

LTR: BYRON 90-0366

FILE: 2.12.1718

50-454


Mr. Bert Davis  
Administrator  
Nuclear Regulatory Commission Region III  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Dear Mr. Davis:

Enclosed is Part 3 of the 1989 Byron Station Operating Report, Docket Numbers STN 50-454, and STN 50-455. This report contains the results of the Radiological Environmental and Meteorological Monitoring Programs. Part 1, Facility Operating Experience was submitted under separate cover in February, and Part 2, Radioactive Effluents in February and August.

Two copies of the report are provided for your use. Two copies will be forwarded to the Document Control Desk and one copy to the Resident Inspector.

Sincerely yours,

  
R. Pleniewicz  
Station Manager  
Byron Nuclear Power Station

RP/vb

Enclosure

Behind the file 12/31/89

3003030233 891231  
PUR AD00K 05000454  
R FDC

IP25  
11

BYRON STATION

ANNUAL ENVIRONMENTAL RADIOLOGICAL OPERATING REPORT

1989

MARCH 1990

## TABLE OF CONTENTS

	<u>Page</u>
INTRODUCTION . . . . .	1
SUMMARY . . . . .	2
1.0 EFFLUENTS	
1.1 Gaseous . . . . .	3
1.2 Liquid . . . . .	3
2.0 SOLID RADIOACTIVE WASTE . . . . .	3
3.0 DOSE TO MAN	
3.1 Gaseous Effluent Pathways . . . . .	3
3.2 Liquid Effluent Pathways . . . . .	5
3.3 Direct Radiation . . . . .	5
4.0 SITE METEOROLOGY . . . . .	6
5.0 ENVIRONMENTAL MONITORING . . . . .	6
5.1 Gamma Radiation . . . . .	6
5.2 Airborne I-131 and Particulate Radioactivity . . . . .	6
5.3 Terrestrial Radioactivity . . . . .	7
5.4 Aquatic Radioactivity . . . . .	7
5.5 Milk . . . . .	7
5.6 Sample Collections . . . . .	8
5.7 Program Modifications . . . . .	8
6.0 ANALYTICAL PROCEDURES . . . . .	8
7.0 MILCH ANIMAL CENSUS . . . . .	8
8.0 NEAREST RESIDENCES CENSUS. . . . .	8
9.0 INTERLABORATORY COMPARISON PROGRAM RESULTS . . . . .	8
10.0 ADDENDA . . . . .	8
APPENDIX I - DATA TABLES AND FIGURES . . . . .	9
Station Releases	
Table 1.1-1 Gaseous Effluents . . . . .	10
Table 1.2-1 Liquid Effluents . . . . .	13

## TABLE OF CONTENTS (continued)

	<u>Page</u>
<b>APPENDIX I - DATA TABLES AND FIGURES</b>	
<b>Station Releases (continued)</b>	
Table 2.0-1 Solid Waste Shipments . . . . .	22
Figure 3.1-1 - Figure 3.1-4 Isodose and Concentration Contours . . . . .	34
Table 3.1-1 Maximum Doses Resulting from Airborne Releases . . . . .	38
Table 3.2-1 Maximum Doses Resulting from Liquid Discharges . . . . .	42
<b>Environmental Monitoring</b>	
Figure 5.0-1 - Figure 5.0-4 Locations of Radiological Environmental Stations . . . . .	44
Table 5.0-1 Radiological Environmental Monitoring Sampling Sites . . . . .	48
Table 5.0-2 Radiological Environmental Monitoring Program . . . . .	49
Table 5.0-3 - Table 5.0-6 Environmental Summary Tables . . . . .	55
<b>APPENDIX II - METEOROLOGICAL DATA</b> . . . . .	62
<b>APPENDIX III - INTERLABORATORY COMPARISON PROGRAM RESULTS.</b> . . . . .	91
<b>APPENDIX IV - REVISION TO THE ODCM RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SINCE 1986</b> . . . . .	124
<b>APPENDIX V - ADDENDA</b> . . . . .	128
<b>APPENDIX VI - 1989 REMP SAMPLE RESULTS</b> . . . . .	134

## INTRODUCTION

Byron Station, a two-unit PWR plant, is located about two miles east of the Rock River and approximately three miles southwest of Byron in Ogle County, north central Illinois. Each reactor is designed to have a capacity of 1120 MW net. Unit No. 1 loaded fuel in November 1984 and went on line February 2, 1985. Unit No. 2 went on line January 9, 1987. The plant has been designed to keep releases to the environment at levels below those specified in the regulations.

Liquid effluents from Byron Station are released into the Rock River in controlled batches after radioassay of each batch. Gaseous effluents are released to the atmosphere and are calculated on the basis of analyses of daily grab samples of noble gases and continuously collected composite samples of iodine and particulate matter. The results of effluent analyses are summarized on a monthly basis. Airborne concentrations of noble gases, I-131 and particulate radioactivity in off-site areas are calculated using effluent and meteorological data on isotopic composition of effluents.

Environmental monitoring is conducted by sampling at indicator and reference (background) locations in the vicinity of the Byron Station to measure changes in radiation or radioactivity levels that may be attributable to plant operations. If significant changes attributable to Byron Station are measured, these changes are correlated with effluent releases. External gamma radiation exposure from noble gases and I-131 in milk are the most critical pathways at this site; however, an environmental monitoring program is conducted which includes other pathways of less importance.

## SUMMARY

Gaseous and liquid effluents for the period remained at a fraction of the Technical Specification limits. Calculations of environmental concentrations based on effluent, Rock River flow, and meteorological data for the period indicate that consumption by the public of radionuclides attributable to the plant are well below the regulatory limits. Radiation exposure from radionuclides released to the atmosphere represented the critical pathway for the period with a maximum individual dose estimated to be 6.60E-04 mrem for the year, when a shielding and occupancy factor of 0.7 is assumed. The assessment of radiation doses is performed in accordance with the Offsite Dose Calculation Manual (ODCM). The results of analysis confirm that the station is operating in compliance with 10CFR50 and 40CFR190.

An assessment of radiation doses from liquid and gaseous effluents to members of the public due to their activities inside the site boundary during the reporting period is not included because it is not applicable to Byron Station.

No additional operational controls were implemented in 1989.

No measurements exceeded reporting levels but not result of plant effluents.

The results of the current radiological environmental monitoring program approximate those found during the preoperational studies conducted at Byron Station.

## 1.0 EFFLUENTS

### 1.1 Gaseous Effluents to the Atmosphere

Measured concentrations and isotopic composition of noble gases, radioiodine, and particulate radioactivity released to the atmosphere during the year, are listed in Table 1.1-1. A total of  $8.14E+02$  curies of fission and activation gases was released with a maximum release rate of  $3.74E+03$   $\mu\text{Ci/sec}$ .

A total of  $2.21E-03$  curies of I-131 and I-133 was released during the year.

A total of  $3.40E-05$  curies of beta-gamma emitters and an undetectable amount of alpha emitters were released as airborne particulate matter.

A total of  $1.84E+02$  curies of tritium was released.

### 1.2 Liquids Released to the Rock River

A total of  $3.17E+07$  liters of radioactive liquid waste (prior to dilution) containing 0.65 curies (excluding tritium, gases, and alpha) were discharged after dilution with a total of  $3.58E+10$  liters of water. These wastes were released at a monthly average concentration of  $1.82E-08$   $\mu\text{Ci/ml}$ , discharged on an unidentified nuclide basis. An undetectable amount of alpha radioactivity and  $1.29E+03$  curies of tritium were released. Monthly release estimates and principal radionuclides in liquid effluents are given in Table 1.2-1.

## 2.0 SOLID RADIOACTIVE WASTE

Solid radioactive wastes were shipped to Barnwell Nuclear Center, South Carolina and Richland, Washington. The record of waste shipments is summarized in Table 2.0-1.

## 3.0 DOSE TO MAN

### 3.1 Gaseous Effluent Pathways

#### Gamma Dose Rates

Gamma air and whole body dose rates off-site were calculated based on measured release rates, isotopic composition of the noble gases, and average meteorological data for the period (Table 3.1-1). Isodose contours of whole body dose are shown in Figure 3.1-1 for the year.

Based on measured effluents and meteorological data, the maximum dose to an individual would be 6.60E-04 mrem for the year, with an occupancy or shielding factor of 0.7 included. The maximum gamma air dose was 2.58E-03 mrad.

#### Beta Air and Skin Rates

The range of beta particles in air is relatively small (on the order of a few meters or less); consequently, plumes of gaseous effluents may be considered "infinite" for purpose of calculating the dose from beta radiation incident on the skin. However, the actual dose to sensitive skin tissues is difficult to calculate because this depends on the beta particle energies, thickness of inert skin, and clothing covering sensitive tissues. For purposes of this report the skin is taken to have a thickness of 7 mg/cm<sup>2</sup> and an occupancy factor of 1.0 is used. The skin dose from beta and gamma radiation for the year was 5.34E-03 mrem.

The air concentrations of radioactive noble gases at the off-site receptor locations are given in Figure 3.1-2. The maximum off-site beta air dose for the year was 1.06E-02 mrad.

#### Radioactive Iodine

The human thyroid concentrates ingested or inhaled iodine, and the radioiodine, I-131. Minimal levels released during routine operation of the plant, may be made available to man thus resulting in a dose to the thyroid. The pathway of interest for this radionuclide is ingestion of radioiodine in milk by an infant. Calculations are performed annually but the levels released from the station in previous years indicate that contributions to doses from inhalation of I-131 and I-133, and I-131 in milk, are negligible.

#### Iodine-131 Concentrations in Air

The calculated concentration contours for I-131 in air are shown in Figure 3.1-3. Included in these calculations is an iodine cloud depletion factor which accounts for the phenomenon of elemental iodine deposition on the ground. The maximum off-site concentration is estimated to be 4.30E-04 pCi/m<sup>3</sup> for the year.

#### Dose to Infant's Thyroid

The hypothetical thyroid dose to an infant living near the plant via ingestion of milk was calculated. The radionuclide considered was I-131 and the source of milk was taken to be the nearest dairy farm with the cows pastured from May to October. The maximum infant's thyroid dose was 6.07E-02 mrem during the year (Table 3.1-1).

### Concentrations of Particulates in Air

Concentration contours of radioactive airborne particulates are shown in Figure 3.1-4. The maximum off-site level is estimated to be 4.43E-06 pCi/m<sup>3</sup>.

### Summary of Doses

Table 3.1-1 summarizes the doses resulting from releases of airborne radioactivity via the different exposure pathways.

### 3.2 Liquid Effluent Pathways

The three principal pathways through the aquatic environment for potential doses to man from liquid waste are ingestion of potable water, eating aquatic foods, and exposure while walking on the shoreline. Not all of these pathways are applicable at a given time or station but a reasonable approximation of the dose can be made by adjusting the dose formula for season of the year or type and degree of use of the aquatic environment. NRC\* developed equations were used to calculate the doses to the whole body, lower GI tract, thyroid, bone and skin; specific parameters for use in the equations are given in the Commonwealth Edison Off-site Dose Calculation Manual. The maximum whole body dose for the year was 4.76E-02 mrem and no organ dose exceeded 8.88E-02 mrem.

### 3.3 Direct Radiation

In section 3/4.11 of the Byron Technical Specifications, 40CFR190 calculations of total dose due to the Uranium fuel Cycle are required only when calculated doses from liquid or gaseous releases of radioactivity exceed certain levels. These levels are twice the following limits:

- \* The RETS limits on dose or dose commitment to a Member of the Public due to radioactive materials in liquid effluents from each reactor unit (1.5 mrem to the whole body and 5 mrem to any organ during any calendar quarter; 3.0 mrem to the whole body and 10 mrem to any organ during any calendar year).
- \* The RETS limits on air dose in noble gases released in gaseous effluents to a Member of the Public from each reactor unit (5 mrad for gamma radiation or 10 mrad for beta radiation during any calendar quarter; 10 mrad for gamma radiation or 20 mrad for beta radiation during any calendar year).
- \* The RETS limits on dose to a Member of the Public due to iodine-131, iodine-133, tritium, and radionuclides in particulate form with half-lives greater than 8 days in gaseous effluents released from each reactor unit (7.5 mrem to any organ during any calendar quarter; 15 mrem to any organ during any calendar year).

---

\* Nuclear Regulatory Commission, Regulatory Guide 1.109 (Rev. 1).

During the period January to December, 1989, Byron Stations did not exceed these criteria.

#### 4.0 SITE METEOROLOGY

A summary of the site meteorological measurements taken during each quarter of the year is given in Appendix II. The data are presented as cumulative joint frequency distributions of 250' level wind direction and wind speed class by atmospheric stability class determined from the temperature difference between the 250' and 30' levels. Date recovery for these measurements was about 99.6%.

#### 5.0 ENVIRONMENTAL MONITORING

Tables 5.0-1 and 5.0-2 provide an outline of the radiological environmental monitoring program as required in the Technical Specifications. Sampling locations are shown in Figures 5.0-1 through 5.0-4. Concentrations of radioactivity in various media are summarized in Tables 5.0-3 through 5.0-6. Tables listing all data are presented in Appendix VI.

Specific findings for various environmental media are discussed below.

##### 5.1 Gamma Radiation

External radiation dose from on-site sources and noble gases released to the atmosphere was measured at nine indicator and three reference (background) locations using  $\text{CaSO}_4:\text{Dy}$  thermoluminescent dosimeters (TLD). Additional TLDs, a total of 64, were installed on September 28, 1981, such that each sector was covered at both five miles and the site boundary. Quarterly external radiation dose at twelve air sampling locations averaged  $(14.6 \pm 4.6)$  mR and was similar to that measured in 1985 (14.4 mR), 1986 (14.9 mR), 1987 (15.3 mR), and 1988 (15.2 mR). The differences are not statistically significant.

##### 5.2 Airborne I-131 and Particulate Radioactivity

Airborne I-131 concentration remained below the LLD of 0.07 pCi/m<sup>3</sup> throughout the year in all samples.

Gross beta concentrations ranged from 0.005 to 0.066 pCi/m<sup>3</sup>, and averaged 0.026 pCi/m<sup>3</sup>, similar to the average concentrations in 1985 (0.026 pCi/m<sup>3</sup>), 1986 (0.026 pCi/m<sup>3</sup>), except for the period from May 12 through June 9 when it was influenced by the reactor accident at Chernobyl), 1987 (0.027 pCi/m<sup>3</sup>), and 1988 (0.031 pCi/m<sup>3</sup>).

All gamma-emitting isotopes activities were below their respective LLD levels. No radioactivity attributable to plant operation was detected in any of the samples.

### 5.3 Terrestrial Radioactivity

Vegetables were collected in August and October and analyzed for gamma-emitting isotopes. In addition, green leafy vegetables were analyzed for iodine-131. All isotopes were below the limits of detection indicating that there was no measurable amount of radioactivity attributable to the station releases. Identical results were obtained during the period 1985 through 1988.

Well water was collected quarterly from two off-site wells and analyzed for gross beta, tritium, and gamma-emitting isotopes. Gross beta concentration was below LLD of 2.6 pCi/l in all samples and was similar to that measured in 1988 (2.0 pCi/l) and lower than in 1985 (7.3 pCi/l), 1986 (7.5 pCi/l), and 1987 (7.5 pCi/l). Tritium was detected in one sample (236 pCi/l) and was similar to that in 1985 (232 pCi/l), 1986 (<200 pCi/l), 1987 (<200 pCi/l) and in 1988 (260 pCi/l). All other results were below the lower limits of detection. The results were similar to those obtained in 1988.

### 5.4 Aquatic Radioactivity

Surface water samples were collected weekly from three locations. Weekly samples were composited monthly and analyzed for gamma-emitters. Quarterly composites were analyzed for tritium. Cesium-134 and 137 concentrations were below the LLD level of 10 pCi/l. Tritium concentration was below the LLD of 200 pCi/l in all samples collected from Woodland Creek (BY-09) and Upstream (BY-13). These levels were similar to those obtained in 1985 through 1988.

Downstream from discharge, tritium averaged 847 pCi/l, ranging from 532 to 1470 pCi/l. Cs-134 and Cs-137 levels were below the LLD level of 10 pCi/l. All other gamma-emitters were below their respective LLDs. Elevated levels of tritium at discharge pipe are attributable to the station operation. These levels were similar to those obtained in 1985 through 1988.

Sediment samples were collected two times, from one control and one indicator location, and analyzed for gamma-emitters. All concentrations were below the lower limit of detection.

Levels of gamma radioactivity in fish were measured and found in all cases to be below the lower limits of detection for the program. The results were identical to those obtained in 1985 through 1988.

### 5.5 Milk

Milk samples were collected monthly from November through April and bi-weekly from May through October and analyzed for iodine-131 and gamma-emitting isotopes. Iodine-131 level was below the LLD level of 0.5 pCi/l in all samples.

Cs-134 and Cs-137 were below the LLD level of 5 pCi/l. All other gamma-emitting isotopes, except naturally-occurring K-40, were below their respective LLDs. There was no indication of the effect on the environment due to station operation. The results for I-131, Cs-134 and Cs-137 were identical to those obtained during the period 1985 through 1988, except during several months following accident at Chernobyl, which occurred on April 26, 1986. During those months I-131 ranged from 0.9 to 58.6 pCi/l, Cs-134 ranged from 5.8 to 10.7 pCi/l and Cs-137 ranged from 5.3 to 17.8 pCi/l.

#### 5.6 Sample Collections

All samples were collected as scheduled except those listed in Listing of Missed Samples, Appendix VI.

#### 5.7 Program Modifications

In April of 1988, milk farm at location BY-16, K. Druien, 3.3 mi 134° was changed to BY-25, B. Leupkes, 3.7 mi 190°. In February of 1989, milk farm at location BY-20 was changed from Ed Seabold, 2.5 mi @ 41° to K. Reeverts, 2.1 mi @ 37°. For additional changes in the program see Appendix IV.

### 6.0 ANALYTICAL PROCEDURES

Procedures used during the period covered by this report remained essentially unchanged. A summary of the procedures used for analyzing radioactivity in environmental samples is given in Appendix V of the report for the period January-December 1988.

### 7.0 MILCH ANIMAL CENSUS

A census of milch animals was conducted within five miles of the Station. The survey was conducted by "door-to-door" canvas and by information from Illinois Agricultural Agents. The census was conducted by L. Coleman on August 21, 1989.

### 8.0 NEAREST RESIDENCES CENSUS

The census of nearest residences within a five (5) mile radius, was conducted by L. Coleman on August 21, 1989.

Results of milch animals and nearest residence census are presented in Appendix VI.

### 9.0 INTERLABORATORY COMPARISON PROGRAM RESULTS

Interlaboratory Comparison Program Results are presented in Appendix III.

### 10.0 ADDENDA

Addenda for January - December, 1989, effluent and waste disposal semi-annual reports are presented in Appendix V.

APPENDIX I  
DATA TABLES AND FIGURES

TABLE 1.1-1

BYRON NUCLEAR POWER STATION  
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR January - June, 1989  
GASEOUS EFFLUENTS - SUBTOTAL OF ALL RELEASES

	1 JANUARY	1 FEBRUARY	1 MARCH	1st QUARTER, APRIL	1 MAY	1 JUNE	1 2nd QUARTER
<b>A. Fission and Activation Gas Releases</b>							
1. Total Release Activity	61	5.68E+1	1.07E+1	6.32E0	7.38E+1	4.58E0	6.88E0
2. Maximum Release Rate	sec/sec	5.72E+2	4.27E+2	1.86E+2	5.72E+2	1.31E+2	2.41E+2
3. % of 10CFR20 Limits*							
a. Whole Body (5000 mrem/year)	1	0.00	0.00	0.00	0.00	0.00	0.00
b. Skin (3000 mrem/year)	1	0.00	0.95	0.00	0.00	0.00	0.00
4. % of 10CFR50 Limits							
a. Gamma Quarterly (5 mrem)	1	0.00	0.00	0.00	0.39	0.00	0.00
b. Beta Quarterly (10 mrem)	1	0.00	0.00	0.00	0.00	0.00	0.00
c. Gamma Annual (10 mrem)	1	0.00	0.00	0.00	0.69	0.00	0.00
d. Beta Annual (22 mrem)	1	0.00	0.00	0.00	0.20	0.00	0.00
5. Iodine Releases							
1. Total I-131 and I-133 Activity	61	17.05E-5	1.86E-5	1.36E-5	1.03E-4	1.746E-6	2.10E-4
2. % of 10CFR20/10CFR50 Limits**							

\* % of 10CFR20 limits is based on the maximum release rate for the period considered.

\*\* Iodine, particulate, and tritium limits are expressed as a total limit. See Step E.

TABLE 1.1-1 (continued)

**BYRON NUCLEAR POWER STATION**  
**EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR JULY - DEC. 1989**  
**GASEOUS EFFLUENTS - SUBTOTAL OF ALL RELEASES**

	UNITS	JULY	AUG	SEPT	OCT	NOV	DEC	ANNUAL
<b>A. Fission and Activation Gas Releases</b>								
1. Total Fission Activity	Ci	1.13E+2	1.76E+2	5.23E+1	3.41E+2	5.79E+1	2.27E+2	6.71E+2
2. Maximum Fission Rate	scf/sec	1.10E+3	1.81E+3	1.24E+3	1.61E+3	6.61E+2	3.74E+3	3.74E+3
3. % of 10CFR50 Limits*								
a. Whole Body (500 acres/year)		1	0.01	0.01	0.01	0.00	0.04	0.02
b. Site (3000 acres/year)		1	0.01	0.01	0.01	0.01	0.04	0.04
4. % of 10CFR50 Limits								
a. Gross Quarterly (5 acres)		1	0.00	0.01	0.00	0.01	0.00	0.01
b. Beta Quarterly (10 acres)		1	0.00	0.02	0.01	0.03	0.03	0.05
c. Gamma Annual (10 acres)		1	0.00	0.01	0.00	0.01	0.01	0.01
d. Beta Annual (20 acres)		1	0.00	0.01	0.00	0.01	0.01	0.01
<b>b. Iodine Releases</b>								
1. Total I-131 and I-133 Activity	Ci	12.38E-4	1.61E-4	1.13E-4	5.12E-4	4.43E-4	6.59E-4	1.264E-4
2. % of 10CFR50/I0CFR50 Limits**								1.39E-3

\* % of 10CFR50 limits is based on the maximum release rate for the period considered.  
\*\* Iodine, particulate, and tritium limits are expressed as a total limit. See Step E.

TABLE 1.1-1 (continued)

**BYRON NUCLEAR POWER STATION**  
**EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR January - June, 1989**  
**GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES**

	1. UNITS	1. JANUARY	1. FEBRUARY	1. MARCH	1. 1st QUARTER	1. APRIL	1. MAY	1. JUNE	1. 2nd QUARTER
<b>C. Particulate (&gt; 8 day half-life) Releases</b>									
1. Gross Activity	Cl	<LLD	Cl	<LLD	3.40E-5	3.40E-5	<LLD	<LLD	<LLD
2. Gross Alpha Activity	Cl	<LLD	Cl	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
3. % of 10CFR20/10CFR50 Limits**									
<b>D. Tritium Releases</b>									
1. Total Release Activity	Cl	11.82E+2	11.26E0	11.01E-1	11.83E+2	11.49E-1	8.82E-2	16.99E-2	13.07E-1
2. % of 10CFR20/10CFR50 Limits**									
<b>E. Sum of Iodine, Particulate (&gt; 8 day half-life), and Tritium Releases</b>									
1. Total Activity	Cl	11.82E+2	11.26E0	11.01E-1	11.83E+2	11.49E-1	8.84E-2	16.99E-2	13.07E-1
2. % of 10CFR20 Limit									
a. Any Organ (1500 atoms/year)	Cl	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
3. % of 10CFR50 Limit									
a. Quarterly Avg Organ (17.5 atoms)	Cl	0.77	0.00	0.00	0.77	0.00	0.00	0.00	0.00
b. Annual Avg Organ (15.0 atoms) \	Cl	0.39	0.00	0.00	0.39	0.00	0.00	0.00	0.00

\*\* Iodine, particulate, and tritium limits are expressed as a total limit. See Step E.

TABLE 1.1-1 (continued)

**BYRON NUCLEAR POWER STATION**  
**EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR July-Dec. 1989**  
**GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES**

	JULY	AUG	SEPT	QUARTER	OCT	NOV	DEC	SUM
<b>C. Particulate (&gt; 8 day half-life) Releases</b>								
1. Gross Activity	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
2. Gross Alpha Activity	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
3. % of 10CFR820/10CFR850 Limits**								
<b>D. Tritium Releases</b>								
1. Total Release Activity	6.65E-2	5.76E-2	5.61E-2	1.08E-1	6.17E-2	6.32E-2	4.70E-2	1.72E-1
2. % of 10CFR820/10CFR850 Limits**								
<b>E. Sum of Iodine, Particulate (&gt; 8 day half-life), and Tritium Releases</b>								
1. Total Activity	16.67E-2	15.78E-2	15.66E-2	1.81E-1	6.21E-2	6.39E-2	4.73E-2	1.73E-1
2. % of 10CFR820 Limit								
a. Any Organ (1500 acres/year)	2	0.00	0.00	0.00	0.00	0.00	0.00	1.00
3. % of 10CFR850 Limit								
a. Quarterly Any Organ (17.5 acres)	2	0.00	0.00	0.00	0.02	0.00	0.00	0.02
b. Annual Any Organ (15.0 acres)	2	0.00	0.00	0.00	0.01	0.00	0.00	0.01

\*\* Iodine, particulate, and tritium limits are expressed as a total limit. See Step E.

TABLE 1.1-1 (continued)

**BYRON NUCLEAR POWER STATION**  
**EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR January - June, 1989**  
**GASEOUS EFFLUENTS - VENT STACK RELEASES**

		1 UNITS   JANUARY   FEBRUARY   MARCH		1st QUARTER   APRIL   MAY		1 JUNE   2nd QUARTER	
--	--	--------------------------------------	--	---------------------------	--	----------------------	--

## f. fission and Activation Gas Releases

He-3	C1	2.60E-1	2.36E-1	7.84E-2	15.74E-1	<LLD	5.87E-1
He-33m		4.54E-2	2.30E-2	5.04E-3	7.32E-2	8.33E-3	1.62E-1
He-35m	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	1.05E-1
Ne-133	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
Ne-134	5.54E+1	9.90E0	6.03E0	7.13E+1	4.51E0	6.82E0	3.32E+1
Ne-135	1.80E-1	3.40E-4	2.08E-2	2.01E-1	2.96E-2	2.54E-2	1.48E-1
Ne-135m	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	2.03E-1
Kr-85	9.20E-1	5.30E-1	2.08E-1	1.66E0	<LLD	<LLD	2.98E-3
Kr-87	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	1.88E0
Kr-88	2.20E-1	3.78E-3	<LLD	5.98E-3	<LLD	<LLD	4.21E-3
Ar-41	1.37E-2	1.08E-2	1.29E-2	3.74E-2	2.70E-2	2.01E-2	1.95E-2
Others (Specify)							

## g. Iodine Releases

I-131	C1	5.25E-5	1.86E-5	<LLD	7.11E-5	<LLD	<LLD
I-132	<LLD						
I-133	1.80E-5	<LLD	1.36E-5	2.16E-5	7.46E-6	2.01E-4	8.40E-6
I-134	<LLD						
I-135	<LLD						
Others (Specify)							

TABLE 1.1-1 (continued)

**BYRON NUCLEAR POWER STATION**  
**EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR July-Dec. 1989**  
**GASEOUS EFFLUENTS - VENT STACK RELEASES**

ISOTOPES RELEASED	MONTHS											
	JUN	JUL	AUG	SEPT	OCT	NOV	DEC	JAN	FEB	MAR	APR	
<b>f. Fission and Activation Gas Releases</b>												
$\text{Ne-131m}$	C1 9.00E-1	2.39E+0	4.77E-1	4.41E+0	2.11E-1	7.00E-1	4.94E-1	1.69E+0				
$\text{Ne-133m}$	<LLD	1.69E+0	3.22E-1	2.40E+0	5.08E-1	1.73E+0	1.81E-1	2.02E+0				
$\text{Ne-135m}$	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD				
$\text{Ne-133}$	1.07E+2	1.69E+2	5.06E+1	3.27E+2	5.58E+1	2.20E+2	6.52E+1	3.41E+2				
$\text{Ne-135}$	1.19E+0	3.77E-1	2.06E-1	1.77E+0	6.24E-1	2.95E+0	2.15E-1	3.79E+0				
$\text{Kr-85m}$	7.55E-3	1.40E-2	1.82E-2	3.58E-2	3.54E-2	1.73E-1	<LLD	2.08E-1				
$\text{Kr-85}$	3.52E+0	2.54E+0	7.19E-1	6.78E+0	5.81E-1	1.53E+0	9.80E-1	3.01E+0				
$\text{Kr-87}$	<LLD	<LLD	1.14E-3	1.14E-3	<LLD	<LLD	<LLD	<LLD				
$\text{Kr-88}$	1.89E-1	1.21E-2	1.63E-1	3.56E-1	9.63E-3	4.20E-2	<LLD	5.16E-2				
$\text{Ar-41}$	1.83E-2	2.85E-2	1.53E-2	6.21E-2	3.82E-2	9.72E-2	5.79E-2	1.92E-1				
<b>Others (Specify)</b>												

**6. Iodine Releases**

ISOTOPES RELEASED	MONTHS											
	JUN	JUL	AUG	SEPT	OCT	NOV	DEC	JAN	FEB	MAR	APR	
<b>f. Iodine Releases</b>												
$\text{I-131}$	3.84E-5	<LLD	2.62E-5	6.46E-5	1.29E-4	3.55E-4	1.39E-4	6.23E-4				
$\text{I-132}$	<LLD	<LLD	<LLD	<LLD	1.10E-4	<LLD	<LLD	1.10E-4				
$\text{I-133}$	2.00E-4	1.61E-4	8.71E-5	4.48E-4	3.14E-4	3.04E-4	1.25E-4	7.43E-4				
$\text{I-134}$	<LLD											
$\text{I-135}$	<LLD	<LLD	1.88E-4	1.88E-4	2.48E-4	2.31E-4	1.41E-4	6.20E-4				
<b>Others (Specify)</b>												

TABLE 1.1-1 (continued)

**SYNTHETIC NUCLEAR POWER STATION**  
**EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR January - June, 1989**  
**GASOUS EFFLUENTS - VENT STACK RELEASES**

ISOTOPES RELEASED	JANUARY		FEBRUARY		MARCH		1st QUARTER		APRIL		MAY		JUNE		2nd QUARTER	
	1	2	1	2	1	2	1	2	1	2	1	2	1	2	1	2
H. Particulate (> 8 day half-life) Releases																
Ca-40	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
Mo-94	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
Fe-55	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
Fe-59	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
Co-58	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
Co-60	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
Sr-89	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Sr-90	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Y-88	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
Ba-103	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
Ag-110m	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
Cs-134	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
Cs-136	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
Cs-137	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
Ba/La-140	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
La-144	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
Others (Specify)																

TABLE I.1-1 (continued)

**BYRON NUCLEAR POWER STATION**  
**EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR July-Dec. 1989**  
**GASEOUS EFFLUENTS - VENT STACK RELEASES**

ISOTOPES RELEASED	MATERIAL TESTED												RESULTS
	JULY	AUG	SEPT	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY		
Ar-36	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD
Ca-45	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD
Co-59	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD
Cr-51	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD
Co-60	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD
Sr-89	---	---	---	---	---	---	---	---	---	---	---	---	---
Sr-90	---	---	---	---	---	---	---	---	---	---	---	---	---
Y-88	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD
Se-103	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD
Ag-111	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD
Cs-133	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD
Cs-136	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD
Cs-137	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD
Be/La-140	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD
Co-164	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD	SLD
Others (Specify)													

\* Analysis completed by offsite vendor  
 Results are not available at this time.

TABLE 1.2-1

**SYNCH NUCLEAR POWER STATION**  
**EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR**  
January - June, 1989  
**LIQUID EFFLUENTS - SUMMARY OF ALL RELEASES**

		1 UNITS JANUARY		1 UNITS FEBRUARY		1 UNITS MARCH		1 UNITS APRIL		1 UNITS MAY		1 UNITS JUNE		1 UNITS END OF PERIOD															
<b>I. Fission and Activation Products</b>																													
1. Total Activity Released																													
1.1. Total		6.1	1.73E-1	8.01E-2	1.19E-1	3.72E-1	3.88E-2	1.06E-1	4.18E-2	1.07E-1	4.18E-2	1.06E-1	4.18E-2	1.07E-1	4.18E-2														
1.2. Average Concentration Released		uCi/ml	9.77E-8	5.64E-8	7.53E-9	1.96E-8	2.75E-8	6.06E-8	1.28E-8	3.54E-8	6.06E-8	1.28E-8	6.06E-8	1.28E-8	3.54E-8														
2. Average Concentration Released																													
2.1. % of 10CFR50 1 Units		%	0.87	0.26	1.07	2.20	0.15	0.63	0.10	0.86	0.15	0.63	0.10	0.86	0.10														
2.2. Quarterly Whole Body (1.5 acre)		%	0.56	0.22	0.44	1.22	0.98	1.21	0.14	1.43	0.98	1.21	0.14	1.43	0.14														
2.3. Quarterly Avg Organ (15.0 acre)		%	0.43	0.13	0.54	1.10	0.98	1.32	0.05	0.45	0.98	1.32	0.05	0.45	0.05														
2.4. Annual Whole Body (13.0 acre)		%	0.28	0.11	0.22	0.61	0.04	0.60	0.07	0.71	0.04	0.60	0.07	0.71	0.07														
3. % of Limit																													
J. Tritium																													
1. Total Activity Released		6.1	6.94E+1	5.34E+1	8.90E+1	2.12E+2	8.10E+1	1.17E+2	1.80E+2	3.78E+2	1.80E+2	1.17E+2	1.80E+2	3.78E+2	1.80E+2														
1.1. Total		uCi/ml	4.49E-5	3.76E-5	5.63E-6	1.12E-5	5.75E-5	6.69E-5	8.53E-5	7.17E-5	6.69E-5	8.53E-5	7.17E-5	6.69E-5	7.17E-5														
1.2. Average Concentration Released		uCi/ml	1.50	1.25	0.19	0.37	1.92	2.23	2.84	2.39	1.92	2.23	2.84	2.39	2.39														
K. Dissolved Noble Gasses																													
1. Total Activity Released		6.1	2.78E-1	4.85E-2	4.74E-2	3.74E-1	5.60E-3	7.81E-2	1.53E-1	2.38E-1	7.81E-2	1.53E-1	2.38E-1	7.81E-2	1.53E-1														
1.1. Total		uCi/ml	1.57E-7	3.42E-8	3.00E-10	1.97E-8	3.97E-10	4.46E-8	7.25E-8	4.49E-8	3.97E-10	4.46E-8	7.25E-8	4.49E-8	7.25E-8														
1.2. Average Concentration Released		uCi/ml	0.08	0.02	0.00	0.01	0.00	0.02	0.04	0.02	0.00	0.02	0.04	0.02	0.02														
2. Gross Alpha																													
1. Total Activity Released		6.1	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD														
1.1. Total		uCi/ml	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0														
M. Volume of Liquid Waste to Discharge																													
1.1. Liters		13.08E+6	1.75E+6	2.70E+6	17.52E+6	11.61E+6	2.31E+6	12.49E+6	16.41E+6	16.41E+6	2.31E+6	12.49E+6	16.41E+6	2.31E+6	16.41E+6														
1.2. Liters		11.77E+9	11.42E+9	11.58E+10	11.30E+10	11.41E+9	11.75E+9	12.11E+9	15.21E+9	15.21E+9	12.11E+9	15.21E+9	15.21E+9	12.11E+9	15.21E+9														

TABLE 1.2-1 (continued)

**OROVILLE NUCLEAR POWER STATION**  
**EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR JULY-DEC. 1989**  
**Liquid Effluents - Summary of All Releases**

	units	JULY	AUG	SEPT	OCT	NOV	DEC	GRAND TOTAL	
<b>I. Fission and Activation Products</b>									
<b>1. Total Activity Released</b>									
µCi/yr	Ci	1.40E-2	1.05E-2	1.13E-2	3.58E-2	4.93E-3	3.07E-2	1.72E-2	5.20E-2
<b>2. Average Concentration Released</b>									9.06E-9
µCi/yr	Ci	8.19E-9	4.86E-9	6.11E-9	6.25E-9	2.77E-9	1.39E-9	2.35E-9	
<b>3. Total Release Limits</b>									
a. Quarterly Whole Body (11.5 rem)									0.08
µCi/yr	Ci	0.06	0.02	0.05	0.13	0.04	0.02	0.02	
b. Quarterly Air Dose (5.0 rem)									0.03
µCi/yr	Ci	0.04	0.01	0.02	0.07	0.01	0.01	0.01	
c. Annual Whole Body (3.9 rem)									0.07
µCi/yr	Ci	0.03	0.01	0.03	0.07	0.02	0.01	0.04	
d. Annual Air Dose (1.1 rem)									0.22
<b>J. Tritium</b>									
<b>1. Total Activity Released</b>									
µCi/yr	Ci	1.29E+2	1.14E+2	3.52E+2	1.83E+2	1.15E+2	4.74E+1	3.95E+2	
<b>2. Average Concentration Released</b>									
µCi/yr	Ci	6.08E-5	5.25E-5	7.24E-5	6.18E-5	1.03E-4	5.20E-5	2.52E-5	5.92E-5
<b>3. Total Limit (2E-3 µCi/yr)</b>									1.97
<b>K. Dissolved noble Gases</b>									
<b>1. Total Activity Released</b>									
µCi/yr	Ci	2.16E-1	5.88E-2	2.53E-1	2.77E-1	5.79E-4	8.87E-2	3.94E-1	4.03E-1
<b>2. Average Concentration Released</b>									
µCi/yr	Ci	1.26E-7	2.68E-8	1.39E-6	4.93E-8	3.25E-10	4.01E-8	2.14E-7	6.20E-8
<b>3. Total Limit (2E-4 µCi/yr)</b>									0.04
<b>L. Gross Alpha</b>									
<b>1. Total Activity Released</b>									
µCi/yr	Ci	0.00E+0	0.00E+0	0.00E+0	0.00E+0	0.00E+0	0.00E+0	0.00E+0	0.00E+0
<b>2. Average Concentration Released</b>									
µCi/yr	Ci	0.00E+0	0.00E+0	0.00E+0	0.00E+0	0.00E+0	0.00E+0	0.00E+0	0.00E+0
<b>M. Volume of Liquid Waste in Discharge</b>									
Liters	L	2.61E+6	2.76E+6	2.85E+6	3.05E+6	3.05E+6	3.05E+6	3.05E+6	1.9.50E+6
<b>N. Volume of Dilution Water</b>									
Liters	L	1.71E+9	2.17E+9	1.85E+9	5.73E+9	1.78E+9	2.21E+9	1.09E+9	5.03E+9

TABLE 1.2-1 (continued)

BYRON NUCLEAR POWER STATION  
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR January - June, 1989  
LIQUID EFFLUENTS

ISOTOPES RELEASES	UNITS	JANUARY	FEBRUARY	MARCH	1st QUARTER	APRIL	MAY	JUNE	2nd QUARTER
<b>D. Liquid Effluents</b>									
Sr-89	cI	-	-	-	-	-	-	-	-
Sr-90		-	-	-	-	-	-	-	-
Ca-48		7.16E-2	3.84E-2	4.20E-2	1.52E-1	1.21E-2	3.66E-2	1.28E-2	6.15E-2
Ca-60		3.21E-2	1.33E-2	2.58E-2	7.12E-2	7.26E-3	3.35E-2	1.67E-2	5.75E-2
Cs-134		6.59E-3	1.97E-3	7.20E-3	1.58E-2	9.80E-4	2.97E-3	5.48E-4	4.50E-3
Cs-135		<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
Cs-137		7.06E-3	2.02E-3	1.03E-2	1.94E-2	1.42E-3	4.84E-3	7.73E-4	7.03E-3
I-131		1.99E-4	1.16E-4	<LLD	3.15E-4	<LLD	9.53E-5	<LLD	9.53E-5
I-133		<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
Ba/La-140		5.55E-5	1.60E-5	2.40E-5	9.55E-5	3.24E-6	3.79E-5	1.37E-6	4.25E-5
Xe-133		2.77E-1	4.82E-2	4.74E-2	3.73E-1	1.12E-2	7.78E-2	1.52E-1	2.41E-1
Xe-135		2.30E-4	2.06E-4	4.26E-5	4.79E-4	<LLD	6.84E-5	5.80E-5	1.26E-4
Others (Specify)	Cr-51	1.72E-2	9.30E-3	8.10E-3	3.46E-2	1.05E-2	8.58E-3	2.41E-3	2.15E-2
	Mn-54	4.18E-3	2.50E-3	3.62E-3	1.03E-2	1.26E-3	6.02E-3	2.95E-3	1.02E-2
	Fe-59	1.39E-2	5.44E-3	6.90E-3	1.37E-2	2.40E-3	3.26E-3	1.69E-3	7.35E-3
	Co-57	6.41E-5	9.76E-5	5.00E-5	2.12E-4	9.04E-6	1.72E-4	4.50E-5	2.26E-4
	Nb-95	8.70E-3	3.42E-3	4.84E-3	1.70E-2	1.21E-3	4.28E-3	2.15E-3	7.64E-3
	Zr-95	4.84E-3	1.84E-3	2.72E-3	9.40E-3	6.02E-4	2.45E-3	1.12E-3	4.17E-3
	Sb-122	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD
	Sb-124	3.51E-4	3.26E-5	4.30E-4	3.20E-4	2.30E-5	1.29E-5	<LLD	3.59E-5
	Sb-125	3.93E-3	7.14E-4	4.38E-3	9.02E-3	1.07E-3	1.64E-3	2.04E-4	2.91E-3
	Zn-65	2.78E-4	2.34E-4	1.74E-4	6.86E-4	<LLD	7.18E-4	1.56E-4	8.74E-4
	T-132	6.12E-4	<LLD	1.86E-3	2.47E-3	<LLD	2.39E-4	<LLD	2.39E-4
	Sn-113	9.08E-5	<LLD	1.73E-4	2.64E-4	3.20E-6	5.14E-4	2.08E-4	7.25E-4
	Ag-110m	7.86E-4	8.36E-5	2.12E-4	1.08E-3	<LLD	<LLD	<LLD	<LLD
	Hf-181	1.23E-4	9.92E-5	3.96E-5	2.62E-4	<LLD	<LLD	<LLD	<LLD
	Ru-103	3.93E-5	<LLD	<LLD	3.93E-5	<LLD	<LLD	<LLD	<LLD
	In-113m	4.76E-5	<LLD	<LLD	4.76E-5	<LLD	<LLD	<LLD	<LLD
	Ce-144	4.93E-4	2.04E-4	2.86E-4	9.83E-4	<LLD	3.06E-4	<LLD	3.06E-4
	Xe-133m	2.58E-4	9.78E-5	<LLD	3.56E-4	<LLD	2.49E-4	4.59E-4	7.08E-4
	Mo99/Tc99m	2.92E-5	1.49E-4	<LLD	1.69E-4	<LLD	<LLD	<LLD	<LLD

TABLE 1.2-1 (continued)

BYRON NUCLEAR POWER STATION  
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR July-Dec. 1989  
LIQUID EFFLUENTS

ISOTOPES RELEASES	UNITS	JULY	AUG	SEPT	QUARTER	OCT	NOV	DEC	QUARTER
<b>0. Liquid Effluents</b>									
Sr-89	Ci	---	---	---	<LLD	---	---	---	*
Sr-90		---	---	---	<LLD	---	---	---	*
Ca-50		3.63E-3	2.56E-3	2.49E-3	8.68E-3	6.44E-4	1.35E-2	4.76E-3	1.89E-2
Ca-60		7.30E-3	5.40E-3	6.56E-3	1.93E-2	3.05E-3	9.20E-3	8.95E-3	2.12E-2
Ca-134		3.60E-4	1.67E-4	2.36E-4	7.63E-4	1.26E-4	1.85E-5	8.39E-5	2.28E-4
Ca-136		<LLD							
Ca-137		4.81E-4	4.77E-4	4.73E-4	1.63E-3	2.65E-4	6.95E-5	1.46E-4	4.81E-4
I-131		2.68E-5	6.46E-5	5.24E-5	1.24E-4	1.50E-4	8.90E-4	1.01E-3	2.05E-3
I-133		<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	5.03E-5	5.03E-5
Ba/La-140		<LLD	3.87E-5	3.83E-6	4.25E-5	3.03E-6	9.79E-4	8.31E-5	1.07E-3
Xe-133		2.14E-1	5.79E-2	2.57E-3	2.74E-1	5.79E-4	8.74E-2	3.87E-1	4.75E-1
Xe-135		2.05E-5	<LLD	<LLD	3.05E-5	<LLD	2.65E-5	6.21E-5	8.86E-5
Others (Specify)	Cr-51	1.16E-4	2.30E-4	<LLD	3.46E-4	<LLD	1.21E-3	2.25E-4	1.44E-3
	Mn-54	1.05E-3	9.09E-4	1.00E-3	2.96E-3	3.82E-4	1.32E-3	9.35E-4	2.64E-3
	Fe-59	1.59E-4	8.13E-5	<LLD	2.40E-4	<LLD	2.67E-3	1.02E-4	2.77E-3
	Nb-95	5.60E-4	4.48E-4	2.72E-4	1.28E-3	4.11E-5	6.61E-4	3.36E-4	1.04E-3
	Zr-95	2.23E-4	1.57E-4	1.20E-4	5.00E-4	1.79E-5	1.70E-4	2.29E-4	9.16E-4
	Xe-131m	1.33E-3	2.79E-4	<LLD	1.61E-3	<LLD	7.53E-4	3.82E-3	4.58E-3
	Xe-133m	6.57E-4	5.61E-5	<LLD	7.13E-4	<LLD	5.12E-4	2.97E-3	3.08E-3
	Mo-99	7.08E-5	<LLD	<LLD	7.08E-5	<LLD	1.00E-5	<LLD	1.00E-5
	Zn-65	<LLD	1.70E-5	<LLD	1.70E-5	<LLD	3.03E-5	<LLD	3.03E-5
	Sr-113	<LLD	1.16E-5	1.51E-5	2.67E-5	<LLD	<LLD	5.05E-5	5.05E-5
	Co-57	<LLD	<LLD	1.68E-5	1.68E-5	<LLD	1.11E-5	1.17E-5	2.20E-5
	Sb-125	<LLD	<LLD	3.23E-5	3.23E-5	2.44E-4	<LLD	6.56E-5	3.10E-4
	Br-82	<LLD	<LLD	<LLD	<LLD	5.73E-6	<LLD	1.55E-4	1.61E-4
	Ar-41	<LLD	<LLD	<LLD	<LLD	<LLD	2.26E-5	3.46E-6	2.61E-5
	Ba-133	<LLD	<LLD	<LLD	<LLD	<LLD	<LLD	4.01E-5	4.01E-5
	Fe-55	---	---	---	<LLD	---	---	---	*

\* Analysis completed by offsite vendor. Results are not available at this time.

TABLE 2.0-1

**BYRON NUCLEAR POWER STATION**  
**EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT**  
**SOLID RADIOACTIVE WASTE**  
MONTH JAN. YEAR 1989

DATE	Disposition of Material			Mode of Transport	Destination	Volume Per Shipment (cu ft) <sup>3</sup>	Curies Per Shipment
	Description, Class	Type	Solidifying Agent				
1-3	Dewatered Resin, Class A, LSA, Liner in Cask, none			Exclusive Use	Barnwell, SC	177.3	1.46
1-9	Dewatered Resin, Class C, LSA, HIC in Cask, none			Exclusive Use	Barnwell, SC	135.8	330
1-11	Dewatered Resin, Class C, LSA, HIC in Cask, none			Exclusive Use	Barnwell, SC	135.8	53.7
1-20	Dewatered Resin, Class A, LSA, HIC in Cask, none			Exclusive Use	Barnwell, SC	178.9	9.69
1-26	DAW, Class A, LSA, drums, none			Exclusive Use	Vendor for Compaction	300.6 (final burial volume)	0.39
1-30	Dewatered Resin, Class A, LSA, HIC in Cask, none			Exclusive Use	Barnwell, SC	178.9	24.1
MONTHLY TOTALS:				6	1110	419	

TABLE 2.0-1 (continued)

BYRON NUCLEAR POWER STATION  
 EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT  
 SOLID RADIOACTIVE WASTE  
 MONTH FEB. YEAR 1989

DATE	Disposition of Material			Mode of Transport	Destination	Volume Per Shipment (cu ft) <sup>3</sup>	Curies Per Shipment
	Description	Class	Type				
2-1	Dewatered Resin, Class A, LSA, Liner in Cask, none			Exclusive Use	Barnwell, SC	177.3	0.17
2-10	Dewatered Resin, Class A, LSA, Liner in Cask, none			Exclusive Use	Barnwell, SC	177.3	2.33
2-15	Dewatered Resin, Class A, LSA, Liner in Cask, none			Exclusive Use	Barnwell, SC	177.3	4.86
2-24	DAW, Class A, LSA, drums, none			Exclusive Use	To Vendor for Compaction	307.1 (final burial volume)	0.21
MONTHLY TOTALS:				4	839	7.57	

TABLE 2.0-1 (continued)  
 BYRON NUCLEAR POWER STATION  
 EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT  
 SOLID RADIOACTIVE WASTE  
 MONTH MARCH YEAR 1989

DATE	Disposition of Material			Mode of Transport	Destination	Volume Per Shipment (cu ft) <sup>3</sup>	Cycles Per Shipment	
	Description	Class	Type					
3-8	Dewatered Resin	Class A	LSA	Liner in cask, none	Exclusive Use	Barnwell, SC	177.3	1.07
3-13	Dewatered Resin	Class A	LSA	Liner in cask, none	Exclusive Use	Barnwell, SC	177.3	0.96
3-17	Dewatered Resin	Class A	LSA	Liner in cask, none	Exclusive Use	Barnwell, SC	177.3	1.87
3-22	Dewatered Resin	Class A	LSA	Liner in cask, none	Exclusive Use	Barnwell, SC	177.3	0.76
3-29	Dewatered Resin	Class A	LSA	Liner in cask, none	Exclusive Use	Barnwell, SC	177.3	0.78
MONTHLY TOTALS:								
					5	887	5.44	

TABLE 2.0-1 (continued)

**BYRON NUCLEAR POWER STATION**  
**EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT**  
**SOLID RADIOACTIVE WASTE**  
**MONTH APRIL YEAR 1989**

<u>DATE</u>	<u>Disposition of Material</u>			<u>Volume Per Shipment (cu ft)</u>	<u>Curies Per Shipment</u>
	<u>Description, Class</u>	<u>Type</u>	<u>Solidifying Agent</u>		
4-10	DAW, Class A, LSA, Seavan, none			1280	0.11
4-17	DAW, Class A, LSA, Seavan, none			1280	0.17
4-19	Dewatered Resin, Class A, LSA, Liner in cask, none			177.3	2.20
<b>MONTHLY TOTALS:</b>					
				3	2740
					2.48

\*Volume sent to vendor. This is not final burial volume.

TABLE 2.0-1 (continued)

**BYRON NUCLEAR POWER STATION**  
**EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT**  
**SOLID RADIOACTIVE WASTE**

DATE	Disposition of Material			Mode of Transport	Destination	Volume Per Shipment (cu ft)	Curta Per Shipment
	Description	Class	Type				
5-5	Dewatered Resin, Class A, LSA, Liner in Cask, none			Exclusive Use	Barnwell, SC	177.3	1.65
5-11	Spent Filters, Class A, HIC in cask, none			Exclusive Use	Barnwell, SC	73.4	3.92
5-16	Dewatered Resin, Class A, LSA, Liner in cask, none			Exclusive Use	Barnwell, SC	177.3	0.68
5-26	Dewatered Resin, Class C, LSA, HIC in cask, none			Exclusive Use	Barnwell, SC	73.4	269

TABLE 2.0-1 (continued)

**SYNTH NUCLEAR POWER STATION**  
**EFFLUENT AND WASTE DISPOSAL SCHEDULE REPORT**  
**SOLID HAZARDOUS WASTE**  
MONTH JUNE YEAR 1989

DATE	Description, Class, Type, Solidifying Agent	Mode of Transport	Destination	Volume Per Shipment, ft <sup>3</sup>	Curton Per Shipment
6-1	Dewatered Resin, Class C, LSA, HIC in cask, none	Exclusive Use	Barnwell, SC	135.8	175
6-21	Dewatered Resin, Class B, LSA, HIC in cask, none	Exclusive Use	Barnwell, SC	135.8	9.92
<b>MONTLY TOTALS:</b>					<b>272</b>
					<b>185</b>

TABLE 2.0-1 (continued)

BYRON NUCLEAR POWER STATION  
 EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT  
 SOLID RADIOACTIVE WASTE  
 MONTH July YEAR 1989

DATE	Disposition of Material			Mode of Transport	Destination	Volume Per Shipment (ft. <sup>3</sup> )	Curies Per Shipment
	Description	Class	Type				
7-5	Dewatered Resin, Class A, LSA, HIC in Cask, None			Exclusive Use	Barnwell	177.3	14.6
7-7	Dewatered Resin, Class A, LSA, Liner in Cask, None			Exclusive Use	Barnwell	177.3	4.72
7-13	DAW, Class A, LSA, Seavan, None			Exclusive Use	Vendor for Compaction	297.0 (Final Burial Volume)	0.29
7-19	Dewatered Resin, Class A, LSA, Liner in Cask, None			Exclusive Use	Barnwell	177.3	2.16
MONTHLY TOTALS:						829	21.8

TABLE 2.0-1 (continued)

BYRON NUCLEAR POWER STATION  
 EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT  
 SOLID RADIOACTIVE WASTE  
 MONTH August YEAR 1989

DATE	Disposition of Material (Description, Class)	Type	Solidifying Agent	Mode of Transport	Destination	Volume Per Shipment, cu. <sup>3</sup>	Curves Per Shipment
8-11	Dewatered Resin, Class A, LSA, Liner in Cask, None			Exclusive Use	Barnwell	177.3	5.26
8-24	DAW, Class A, LSA, Drums, None			Exclusive Use	Vendor for Compaction	330.3 (Final Burial Volume)	9.9522
MONTHLY TOTALS:							5088 6.21

TABLE 2.0-1 (continued)

**BYRON NUCLEAR POWER STATION**  
**EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT**  
**SOLID RADIOACTIVE WASTE**  
MONTH September YEAR 1989

<u>DATE</u>	<u>Disposition of Material</u>			<u>Mode of Transport</u>	<u>Destination</u>	<u>Volume Per Shipment (ft<sup>3</sup>)</u>	<u>Curies Per Shipment</u>
	<u>Description, Class</u>	<u>Type</u>	<u>Solidifying Agent</u>				
9-15	Dewatered Resin, Class A, LSA, Liner in Cask, None			Exclusive Use	Barnwell, SC	177.3	4.41
9-22	Dewatered Resin, Class A, LSA, Liner in Cask, None			Exclusive Use	Barnwell, SC	177.3	1.06
<u>MONTHLY TOTALS:</u>				2*		355	5.47

TABLE 2.0-1 (continued)

**BYRON NUCLEAR POWER STATION**  
**ESFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT**  
**SOLID RADIOACTIVE WASTE**  
**MONTH October YEAR 1989**

DATE	Disposition of Material			Mode of Transport	Destination	Volume Per Shipment (cu ft) <sup>3</sup>	Curies Per Shipment
	Description	Class	Type				
10-6	Dewatered Resin, Class A, LSA, Liner in Cask, None			Exclusive Use	Barnwell, SC	177.3	0.205
10-16	Dewatered Resin, Class A, LSA, Liner in Cask, None			Exclusive Use	Barnwell, SC	177.3	1.36
10-16	Dewatered Resin, Class A, LSA, Liner in Cask, None			Exclusive Use	Barnwell, SC	139.1	1.14
10-30	DAW, Class A, LSA, Drums, None			Exclusive Use	Vendor for Compaction	314.7 (Final Burial Volume)	0.91
<b>MONTHLY TOTALS:</b>				4		808	3.62

TABLE 2.0-1 (continued)

**BYRON NUCLEAR POWER STATION**  
**EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT**  
**SOLID RADIOACTIVE WASTE**  
MONTH November YEAR 1989

DATE	Disposition of Material			Mode of Transport	Destination	Volume Per Shipment (ft <sup>3</sup> )	Curies Per Shipment
	Description	Class	Type				
NOVEMBER	11-1	Dewatered Resin, Class A, LSA, Liner in Cask, None		Exclusive Use	Barnwell, SC	177.3	0.094
	11-2	DAW (Fuel Racks), Class A, LSA, Steel Box, None		Exclusive Use	Richland, W	78.0	5.53E-5
	11-2	DAW (Fuel Racks), Class A, LSA, Steel Box, None		Exclusive Use	Richland, W	190.0	7.94E-5
	11-6	Dewatered Resin, Class C, LSA, HIC in Cask, None		Exclusive Use	Barnwell, SC	73.4	271
	11-20	Dewatered Resin, Class B, LSA, HIC in Cask, None		Exclusive Use	Barnwell, SC	135.8	75.4
	11-20	VAN, Class A, LSA, Drums, None		Exclusive Use	Richland, W	630	0.86
	11-27	Dewatered Resin, Class A, LSA, Liner in Cask, None		Exclusive Use	Barnwell, SC	135.8	9.01
MONTHLY TOTALS:				7-	1420		356

TABLE 2.0-1 (continued)  
 BYRON NUCLEAR POWER STATION  
 EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT  
 SOLID RADIOACTIVE WASTE  
 MONTH December YEAR 1989

DATE	Disposition of Material			Mode of Transport	Destination	Volume Per Shipment (ft <sup>3</sup> )	Curies Per Shipment
	Description	Class	Type				
12-4	DAW, Class A, LSA, Drums, None			Exclusive Use	Vendor for Compaction	320.2	8.28
12-5	DAW (Fuel Racks), Class A, LSA, Steel Box, None			Exclusive Use	Richland, W	197	5.38E-6
12-5	Dewatered Resin, Class A, LSA, HIC in Cask, None			Exclusive Use	Barnwell, SC	178.9	3.7
12-12	DAW (Fuel Racks), Class A, LSA, Steel Box, None			Exclusive Use	Richland, W	17.5	2.76E-6
CQ	Dewatered Resin, Class A, LSA, Liner in Cask, None			Exclusive Use	Barnwell, SC	177.3	0.962
	DAW, Class A, LSA, Drums, None			Exclusive Use	Richland, W	630	8E-4
	DAW, Class A, LSA, Seavan, None			Exclusive Use	Vendor for Compaction	*928	0.08
	Dewatered Resin, Class A, LSA, HIC in Cask, None			Exclusive Use	Barnwell, SC	177.3	1.11
	Dewatered Resin, Class A, LSA, HIC in Cask, None			Exclusive Use	Barnwell, SC	177.3	0.703
MONTHLY TOTALS:						9*	2800
							14.8

\* Volume sent to vendor. This is not final burial volume.

FIGURE 3.1-1

Estimated Cumulative Gamma Dose (in mrem)  
from the Byron Station for the period  
January-December 1989

Isopleth Labels

Small figure - multiply by  $10^{-5}$   
Large figure - multiply by  $10^{-5}$




FIGURE 3.1-2

Estimated Total Concentrations (in pCi/m<sup>3</sup>)  
of Noble Gases from the Byron Station for  
the period January-December 1989

Isopleth Labels

Small figure - multiply by 10<sup>-1</sup>  
Large figure - multiply by 10<sup>-1</sup>




FIGURE 3.1-3

Estimated Total Concentrations (in pCi/m<sup>3</sup>)  
of Iodine from the Byron Station for the  
period January-December 1989

Isopleth Labels

Small figure - multiply by 10<sup>-6</sup>  
Large figure - multiply by 10<sup>-6</sup>





FIGURE 3.1-4

Estimated Total Concentrations (in pCi/m<sup>3</sup>)  
of Particulate Matter from the Byron Station  
for the period January-December 1989

Isopleth Labels

Small figure - multiply by 10<sup>-8</sup>  
Large figure - multiply by 10<sup>-8</sup>





TABLE 3.1-1

## BYRON UNIT ONE

1989 ANNUAL REPORT  
 MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES  
 PERIOD OF RELEASE - 01/01/89 TO 12/31/89 CALCULATED 01/16/90  
 INFANT RECEPTOR

TYPE	1ST	2ND	3RD	4TH	ANNUAL
	QUARTER JAN-MAR	QUARTER APR-JUN	QUARTER JUL-SEP	QUARTER OCT-DEC	
GAMMA AIR (MRAD)	5.27E-05 (SE )	9.37E-05 (SE )	5.87E-04 (SE )	3.27E-04 (SE )	1.06E-03 (SE )
BETA AIR (MRAD)	2.31E-04 (SE )	3.97E-04 (SE )	2.43E-03 (SE )	1.33E-03 (SE )	4.38E-03 (SE )
TOT. BODY (MRER)	1.34E-05 (SE )	2.38E-05 (SE )	1.50E-04 (SE )	8.39E-05 (SE )	2.71E-04 (SE )
SKIN (MRER)	1.18E-04 (SE )	2.01E-04 (SE )	1.22E-03 (SE )	6.75E-04 (SE )	2.21E-03 (SE )
ORGAN (MRER)	2.93E-02 (NE )	5.07E-05 (NE )	6.32E-04 (NE )	1.20E-03 (NE )	3.11E-02 (NE )
	THYROID	THYROID	THYROID	THYROID	THYROID

THIS IS A REPORT FOR THE CALENDAR YEAR 1989

COMPLIANCE STATUS - 10 CFR 50 APP. I  
 INFANT RECEPTOR

QTRLY OBJ	% OF APP I.					YRLY OBJ	% OF APP.I
	1ST QTR JAN-MAR	2ND QTR APR-JUN	3RD QTR JUL-SEP	4TH QTR OCT-NOV			
GAMMA AIR (MRAD)	5.0	0.00	0.00	0.01	0.01	10.0	0.01
BETA AIR (MRAD)	10.0	0.00	0.00	0.02	0.01	20.0	0.02
TOT. BODY (MRER)	2.5	0.00	0.00	0.01	0.00	5.0	0.01
SKIN (MRER)	7.5	0.00	0.00	0.02	0.01	15.0	0.01
ORGAN (MRER)	7.5	0.39	0.00	0.01	0.02	15.0	0.21
	THYROID	THYROID	THYROID	THYROID	THYROID		

RESULTS BASED UPON  
 ODCM REVISION 11  
 UPDATE CS204  
 FEBRUARY 1986

TABLE 3.1-1 (continued)

## BYRON UNIT ONE

1989 ANNUAL REPORT  
 MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES  
 PERIOD OF RELEASE - 01/01/89 TO 12/31/89 CALCULATED 01/16/90  
 ADULT RECEPTOR

TYPE	1ST QUARTER JAN-MAR	2ND QUARTER APR-JUN	3RD QUARTER JUL-SEP	4TH QUARTER OCT-DEC	ANNUAL
GAMMA AIR (MRAD)	5.27E-05 (SE )	9.37E-05 (SE )	5.87E-04 (SE )	3.27E-04 (SE )	1.06E-03 (SE )
BETA AIR (MRAD)	2.31E-04 (SE )	3.97E-04 (SE )	2.43E-03 (SE )	1.33E-03 (SE )	4.38E-03 (SE )
TOT. BODY (MRER)	1.34E-05 (SE )	2.38E-05 (SE )	1.50E-04 (SE )	8.39E-05 (SE )	2.71E-04 (SE )
SKIN (MRER)	1.18E-04 (SE )	2.01E-04 (SE )	1.22E-03 (SE )	6.75E-04 (SE )	2.21E-03 (SE )
ORGAN (MRER)	1.98E-02 (ME )	7.58E-05 (ESE )	3.75E-04 (ESE )	6.16E-04 (ESE )	2.07E-02 (ME )
	THYROID	THYROID	THYROID	THYROID	THYROID

THIS IS A REPORT FOR THE CALENDAR YEAR 1989

COMPLIANCE STATUS - 10 CFR 50 APP. I  
 ADULT RECEPTOR

QTRLY OBJ	% OF APP I.				YRLY OBJ	% OF APP.I
	1ST QTR JAN-MAR	2ND QTR APR-JUN	3RD QTR JUL-SEP	4TH QTR OCT-NOV		
GAMMA AIR (MRAD)	5.0	0.00	0.00	0.01	0.01	10.0 0.01
BETA AIR (MRAD)	10.0	0.00	0.00	0.02	0.01	20.0 0.02
TOT. BODY (MRER)	2.5	0.00	0.00	0.01	0.00	5.0 0.01
SKIN (MRER)	7.5	0.00	0.00	0.02	0.01	15.0 0.01
ORGAN (MRER)	7.5	0.26	0.00	0.01	0.01	15.0 0.14
	THYROID	THYROID	THYROID	THYROID	THYROID	

RESULTS BASED UPON  
 ODCM REVISION 11  
 UPDATE CS204  
 FEBRUARY 1986

TABLE 3.1-1 (continued)

BYRON UNIT TWO

1989 ANNUAL REPORT  
 MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES  
 PERIOD OF RELEASE - 01/01/89 TO 12/31/89 CALCULATED 01/16/90  
 INFANT RECEPTOR

TYPE	1ST	2ND	3RD	4TH	ANNUAL
	QUARTER JAN-MAR	QUARTER APR-JUN	QUARTER JUL-SEP	QUARTER OCT-DEC	
GAMMA AIR (MRAD)	1.73E-04 (SE )	5.25E-05 (SE )	4.84E-04 (SE )	8.09E-04 (SE )	1.52E-03 (SE )
BETA AIR (MRAD)	7.24E-04 (SE )	2.30E-04 (SE )	2.00E-03 (SE )	3.23E-03 (SE )	6.19E-03 (SE )
TOT. BODY (MREM)	4.28E-05 (SE )	1.36E-05 (SE )	1.25E-04 (SE )	2.08E-04 (SE )	3.89E-04 (SE )
SKIN (MREM)	3.57E-04 (SE )	1.19E-04 (SE )	1.01E-03 (SE )	1.64E-03 (SE )	3.13E-03 (SE )
ORGAN (MREM)	2.93E-02 (NE )	5.07E-05 (NE )	2.11E-04 (NE )	4.75E-05 (NE )	2.96E-02 (NE )
	THYROID	THYROID	THYROID	THYROID	THYROID

THIS IS A REPORT FOR THE CALENDAR YEAR 1989

COMPLIANCE STATUS - 10 CFR 50 APP. I  
 INFANT RECEPTOR

QTRLY OBJ	% OF APP. I.					YRLY OBJ	% OF APP. I.
	1ST QTR JAN-MAR	2ND QTR APR-JUN	3RD QTR JUL-SEP	4TH QTR OCT-NOV			
GAMMA AIR (MRAD)	5.0	0.00	0.00	0.01	0.02	10.0	0.02
BETA AIR (MRAD)	10.0	0.01	0.00	0.02	0.03	20.0	0.03
TOT. BODY (MREM)	2.5	0.00	0.00	0.00	0.01	5.0	0.01
SKIN (MREM)	7.5	0.00	0.00	0.01	0.02	15.0	0.02
ORGAN (MREM)	7.5	0.39	0.00	0.00	0.00	15.0	0.20
	THYROID	THYROID	THYROID	THYROID	THYROID		

RESULTS BASED UPON  
 ODCP REVISION 11  
 UPDATE CS204  
 FEBRUARY 1986

TABLE 3.1-1 (continued)

## BYRON UNIT TWO

1989 ANNUAL REPORT  
 MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES  
 PERIOD OF RELEASE - 01/01/89 TO 12/31/89 CALCULATED 01/16/90  
 ADULT RECEPTOR

TYPE	1ST	2ND	3RD	4TH	ANNUAL
	QUARTER JAN-MAR	QUARTER APR-JUN	QUARTER JUL-SEP	QUARTER OCT-DEC	
GAMMA AIR (MRAD)	1.73E-04 (SE )	5.25E-05 (SE )	4.84E-04 (SE )	8.09E-04 (SE )	1.52E-03 (SE )
BETA AIR (MRAD)	7.24E-04 (SE )	2.30E-06 (SE )	2.00E-03 (SE )	3.23E-03 (SE )	6.19E-03 (SE )
TOT. BODY (MRREN)	4.28E-05 (SE )	1.36E-05 (SE )	1.25E-04 (SE )	2.08E-04 (SE )	3.89E-04 (SE )
SKIN (MRREN)	3.57E-04 (SE )	1.19E-04 (SE )	1.01E-03 (SE )	1.64E-03 (SE )	3.13E-03 (SE )
ORGAN (MRREN)	1.98E-02 (NE )	7.58E-05 (ESE )	1.77E-04 (ESE )	5.49E-05 (SE )	2.01E-02 (NE )
	THYROID	THYROID	THYROID	THYROID	THYROID

THIS IS A REPORT FOR THE CALENDAR YEAR 1989

COMPLIANCE STATUS - 10 CFR 50 APP. I  
 ADULT RECEPTOR

QTRLY OBJ	% OF APP I.				YRLY OBJ	% OF APP.I
	1ST QTR JAN-MAR	2ND QTR APR-JUN	3RD QTR JUL-SEP	4TH QTR OCT-NOV		
GAMMA AIR (MRAD)	5.0	0.00	0.00	0.01	0.02	10.0 0.02
BETA AIR (MRAD)	10.0	0.01	0.00	0.02	0.03	20.0 0.03
TOT. BODY (MRREN)	2.5	0.00	0.00	0.00	0.01	5.0 0.01
SKIN (MRREN)	7.5	0.00	0.00	0.01	0.02	15.0 0.02
ORGAN (MRREN)	7.5	0.26	0.00	0.00	0.00	15.0 0.13
	THYROID	THYROID	THYROID	THYROID	THYROID	

RESULTS BASED UPON  
 ODCM REVISION 11  
 UPDATE CS204  
 FEBRUARY 1986

TABLE 3.2-1

BYRON UNIT ONE  
ADULT RECEPTOR

1989 ANNUAL REPORT  
MAXIMUM DOSES (MRM) RESULTING FROM LIQUID EFFLUENTS  
PERIOD OF RELEASE - 01/01/89 TO 12/31/89 CALCULATED 01/16/90

DOSE TYPE	1ST QUARTER JAN-MAR	2ND QUARTER APR-JUN	3RD QUARTER JUL-SEP	4TH QUARTER OCT-DEC	ANNUAL
TOTAL BODY	1.65E-02	5.49E-03	1.20E-03	5.49E-04	2.38E-02
INTERNAL ORGAN	2.74E-02	1.27E-02	2.35E-03	2.01E-03	4.44E-02
	GI-LLI	GI-LLI	GI-LLI	GI-LLI	GI-LLI

THIS IS A REPORT FOR THE CALENDAR YEAR 1989

COMPLIANCE STATUS - 10 CFR 50 APP. I

QTRLY OBJ	% OF APP I.				YRLY OBJ	% OF APP.I
	1ST QTR JAN-MAR	2ND QTR APR-JUN	3RD QTR JUL-SEP	4TH QTR OCT-NOV		
TOTAL BODY (MRM)	1.5	1.10	0.37	0.08	0.04	3.0 0.79
CRIT. ORGAN(MRM)	5.0	0.55	0.25	0.05	0.04	10.0 0.44
	GI-LLI	GI-LLI	GI-LLI	GI-LLI	GI-LLI	

RESULTS BASED UPON  
ODCM REVISION 11  
UPDATE CS204  
FEBRUARY 1986

TABLE 3.2-1 (continued)

BYRON UNIT TWO  
ADULT RECEPTOR

1989 ANNUAL REPORT  
MAXIMUM DOSES (MRREN) RESULTING FROM LIQUID EFFLUENTS  
PERIOD OF RELEASE - 01/01/89 TO 12/31/89 CALCULATED 01/16/90

DOSE TYPE	1ST QUARTER JAN-MAR	2ND QUARTER APR-JUN	3RD QUARTER JUL-SEP	4TH QUARTER OCT-DEC	ANNUAL
TOTAL BODY	1.65E-02	5.49E-03	1.20E-03	5.49E-04	2.38E-02
INTERNAL ORGAN	2.74E-02	1.27E-02	2.35E-03	2.01E-03	4.44E-02
	GI-LLI	GI-LLI	GI-LLI	GI-LLI	GI-LLI

THIS IS A REPORT FOR THE CALENDAR YEAR 1989

COMPLIANCE STATUS - 10 CFR 50 APP. I

QTRLY OBJ	% OF APP. I.				YRLY OBJ	% OF APP. I
	1ST QTR JAN-MAR	2ND QTR APR-JUN	3RD QTR JUL-SEP	4TH QTR OCT-NOV		
TOTAL BODY (MRREN)	1.5	1.10	0.37	0.08	0.04	3.0 0.79
CRIT. ORGAN(MRREN)	5.0	0.55	0.25	0.05	0.04	10.0 0.44
	GI-LLI	GI-LLI	GI-LLI	GI-LLI	GI-LLI	

RESULTS BASED UPON  
ODCR REVISION 11  
UPDATE CS204  
FEBRUARY 1986

FIGURE 1




FIGURE 5.0-2






FIGURE 5.0-3



BY-09 Woodland Creek  
BY-12 Oregon Pool of Rock River  
BY-13 Rock River, Upstream  
BY-14 Offsite Well Water  
BY-15 W. Danakas  
BY-17 Whitten Holstein Dairy  
BY-18 McCoy Farmstand  
BY-19-1 Oregon Farmstand  
BY-19-2 Oregon Farmstand  
BY-20 K. Reeverts  
BY-25 8111 Leupke Farm

**BYRON STATION**  
INGESTION AND WATERBORNE EXPOSURE  
PATHWAY SAMPLE LOCATIONS

FIGURE 5.0-4



● Location of TLD

BYRON STATION

INNER RING AND OUTER RING TLD LOCATIONS

TABLE 5.0-1

**Byron Station  
Radiological Environmental Monitoring  
Locations**

	Air Sampling	TLD	Cooling Water	Fish	Lake Water	Milk	Public Water	Rabbits	Sediments	Surface Water	Vegetables	Ground/Well Water
BY-01 Byron	OO											
BY-02 Suliman Valley	OOOO											
BY-03 Nearsite-East	OOO											
BY-04 Paynes Point	OO											
BY-05 Nearsite-South	OO											
BY-06 Oregon	OO											
BY-07 Mt. Morris	OO											
BY-08 Leaf River	OO											
BY-09 Woodland Creek	.											
BY-12 Oregon Pool of Rock River	.				OO		OO					
BY-13 Rock River, Upstream	.									OO		
BY-14 Offsite Well Water	.									OO		
BY-15 J. A. Reeverts Pine Hill Dairy	.					OO						O
BY-17 Whitten Holstein Dairy	.					OO						
BY-18 McCoy Farmstand Well	.					OO						O
BY-19-1 966 E Weld Bark Rd	.											
BY-19-2 6993 N River Rd	.							OO				
BY-20 Kenneth Reeverts Farm	.							OO				
BY-21 Near Site N		OO										
BY-22 Near Site ESE		OOO										
BY-23 Near Site S		OOO										
BY-24 Near Site SW		OOO										
BY-25 Bill Leupkes Farm		OOO										
						O						

**CENSUS**

Dairy  
Residence

TABLE 5.0-2  
BYRON STATION  
ENVIRONMENTAL RADIOLOGIAL MONITORING PROGRAM, SAMPLING LOCATIONS

1. AIR SAMPLERS

<u>Site Code<sup>a</sup></u>	<u>Location</u>	<u>Distance</u> <u>(miles)</u>	<u>Direction</u> <u>(°)</u>
BY-01	Byron	3.5	25
BY-02 (C)	Stillman Valley	6.2	56
BY-03	Nearsite - East	3.8	85
BY-04	Paynes Point	4.5	140
BY-05	Nearsite - South	3.6	180
BY-06	Oregon	4.6	213
BY-07 (C)	Mt. Morris	7.8	240
BY-08 (C)	Leaf River	7.0	315
BY-21	Nearsite North	0.3	9
BY-22	Nearsite East-Southeast	0.3	101
BY-23	Nearsite South	0.6	182
BY-24	Nearsite Southwest	0.6	229

2. TLDs

a. Same as No. 1

b. Special TLD Samplers

<u>Site Code</u>	<u>Distance</u> <u>(miles)</u>	<u>Direction</u> <u>(°)</u>
<u>Inner Ring</u>		
BY-101-1,2	1.2	13
BY-102-1,2	1.0	25
BY-103-1,2	1.7	51
BY-104-1,2	1.4	64
BY-105-1,2	1.3	84
BY-106-1,2	1.4	108
BY-107-1,2	1.4	141
BY-108-1,2	0.6	158
BY-109-1,2	0.6	183
BY-110-1,2	0.6	201
BY-111-1,2	0.9	235
BY-112-1,2	0.8	247

<sup>a</sup> Control (reference) locations are denoted by a "C" after site code. All other locations are indicators.

TABLE 5.0-2 (continued)

BYRON STATION

ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM, SAMPLING LOCATIONS

**2. TLDs**

**b. Special TLD Samplers (continued)**

<u>Site Code</u>	<u>Distance (miles)</u>	<u>Direction (°)</u>
BY-113-1,2	0.7	270
BY-114-1,2	0.8	298
BY-115-1,2	1.0	314
BY-116-1,2	1.4	329
<b>Outer Ring</b>		
BY-201-1,2	4.8	360
BY-202-1,2	4.5	13
BY-203-1,2	5.1	42
BY-204-1,2	4.2	66
BY-205-1,2	3.9	89
BY-206-1,2	4.2	112
BY-207-1,2	4.2	140
BY-208-1,2	4.1	159
BY-209-1,2	3.8	189
BY-210-1,2	3.6	218
BY-211-1,2	5.2	238
BY-212-1,2	4.9	257
BY-213-1,2	5.0	280
BY-214-1,2	4.8	298
BY-215-1,2	5.2	322
BY-216-1,2	4.8	337

**3. MILK**

<u>Site Code<sup>a</sup></u>	<u>Location</u>	<u>Distance (miles)</u>	<u>Direction (°)</u>
BY-15	Warren Danakas Dairy	3.3	110
BY-17 (C)	Whitten Holstein Dairy	9.0	270
BY-20	Kenneth Reeverts Farm	2.1	37
BY-25	Bill Leupkes Farm	3.7	190

<sup>a</sup> Control (reference) locations are denoted by a "C" after site code. All other locations are indicators.

TABLE 5.0-2 (continued)

## BYRON STATION

## ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM, SAMPLING LOCATIONS

4. VEGETABLES

<u>Site Code</u>	<u>Location</u>	<u>Distance (miles)</u>	<u>Direction (°)</u>
BY-19-1	966 East Weld Park Road	5.1	200
BY-19-2	6993 North River Road	5.1	200

5. GROUND/WELL WATER

<u>Site Code</u>	<u>Location</u>	<u>Distance (miles)</u>	<u>Direction (°)</u>
BY-14	CECo Off-site Well	0.3	101
BY-18	McCoy Farmstead (CECo-owned well)	1.0	235

6. SURFACE WATER

<u>Site Code</u>	<u>Location</u>	<u>Distance (miles)</u>	<u>Direction (°)</u>
BY-09	Woodland Creek	2.1	320
BY-12	Oregon Pool of Rock River	4.5	213
BY-13	Rock River Upstream	2.6	302

7. FISH

<u>Site Code</u>	<u>Location</u>	<u>Distance (miles)</u>	<u>Direction (°)</u>
BY-12	Oregon Pool of Rock River	4.5	213
BY-13	Rock River Upstream	2.6	302

8. SHORELINE SEDIMENTS

<u>Site Code</u>	<u>Location</u>	<u>Distance (miles)</u>	<u>Direction (°)</u>
BY-12	Oregon Pool of Rock River	4.5	213
BY-13	Rock River Upstream	2.6	302

Table 5.0-2 (continued)

**BYRON STATION**  
**ENVIRONMENTAL RADILOGICAL MONITORING PROGRAM, SAMPLE COLLECTION AND ANALYSES**

Sample Media	Code*	Location Site	Collection Frequency	Type of Analysis	Frequency of Analysis	Remarks
1. Airborne Particulates	BY-1 BY-2 (C) BY-3 BY-4 BY-5 BY-6 BY-7 (C) BY-8 (C) BY-21 BY-22 BY-23 BY-24	Byron Stillman Valley NearSite East Paynes Point NearSite South Oregon Mt. Morris Leaf River Near Site North Near Site East-Southeast Near Site South Near Site Southwest	Continuous operation for a week	Gross beta Gamma Isot Gamma Isot	Weekly Quarterly Weekly	On all samples. On quarterly composites from each location. If gross beta activity in air particulate samples >10 times the yearly mean of control samples.
				Filter Exchange	Weekly	
2. Airborne Iodine	Same as 1.		Continuous operation for a week	I-131	Weekly	On all samples.
3. Air Sampling Train	Same as 1.		--	Test and Maintenance	Weekly	On all samples.
4. TLD	Same as 1.  BY-101-1,2 102-1,2 103-1,2 104-1,2 105-1,2 106-1,2 107-1,2 108-1,2 109-1,2 110-1,2 111-1,2 112-1,2 113-1,2 114-1,2 115-1,2 116-1,2	Inner Ring	Quarterly	Gamma	Quarterly	Two sets at all AP locations. One set read quarterly. Second set read if required by Commonwealth Edison. At other locations, all sets read quarterly.  Minimum of two TLDs per set.

\* Control (reference) locations are denoted by a "C" in this column. All other locations are indicators.

TABLE 5.0-2 (continued)  
BYRON STATION  
ENVIRONMENTAL RADILOGICAL MONITORING PROGRAM, SAMPLE COLLECTION AND ANALYSES

Sample Media	Code <sup>a</sup>	Location	Site	Collection Frequency	Type of Analysis	Frequency of Analysis	Remarks
4. TLD's (continued)	BY-201-1,2	Outer Ring					
	202-1,2						
	203-1,2						
	204-1,2						
	205-1,2						
	206-1,2						
	207-1,2						
	208-1,2						
	209-1,2						
	210-1,2						
	211-1,2						
	212-1,2						
	213-1,2						
	214-1,2						
	215-1,2						
	216-1,2						
5. Milk	BY-15	W. Danakas		Semimonthly	I-131	Semimonthly	On all samples.
	BY-17 (C)	Whitten Holstein Dairy		May-October	Gamma Isot.	May-October	
	BY-20	K. Reeverts		Monthly		Monthly	
				November-April		November-April	
	BY-25	Bill Leupkes Farm		Monthly			
6. Vegetables	BY-19-1			Annually at harvest	Gamma Isot	Annually	Four varieties from each location as available at harvest. (Gamma isotopic on edible portion only.)
	BY-19-2						
7. Ground/Well Water	BY-14	CECo Off-site Well Office		Semimonthly	Gross beta Gamma Isot	Monthly	On monthly composite for each location.
	BY-18	McCoy Farmstead			Tritium I-131	Monthly Quarterly Semimonthly	On monthly composite for each location. On quarterly composite for each location. On semimonthly composite when dose calculated for water consumption is greater than one mrem per year.
8. Surface Water	BY-09	Woodland Creek		Weekly	Tritium	Quarterly	On quarterly composite from each location.
	BY-12	Oregon Pool of Rock River			Gamma Isot	Monthly	On monthly composite from each location.
	BY-13 (C)	Rock River, upstream					

<sup>a</sup> Control (references) locations are denoted by a "C" in this column. All other locations are indicators.

TABLE 5.0-2 (continued)  
BYRON STATION  
ENVIRONMENTAL RADILOGICAL MONITORING PROGRAM, SAMPLE COLLECTION AND ANALYSES

Sample Media	Location	Collection Frequency	Type of Analysis	Frequency of Analysis	Remarks
	Code <sup>a</sup>	Site			
9. Fish	BY-12	Oregon Pool of Rock River	Three times a year.	Gamma Isot	Three times a year. Spring, Summer, and Fall
	BY-13	Rock River, upstream			From Oregon pool of Rock River, on edible portions only. At least two species.
10. Shoreline Sediments	BY-12	Oregon Pool of Rock River	Semifannual	Gamma Isot	Semifannual
	BY-13	Upstream of Oregon Dam			On all samples
11. Dairy Census	a. Site boundary to 2 miles	--	a. Enumeration by a door-to-door or equivalent counting technique.	Annually	During grazing season.
	b. 2 miles to 5 miles	--	b. Enumeration by using referenced information from county agricultural agents or other reliable sources.	Annually	During grazing season.
	c. At dairies listed in Item 5.	--	c. Inquire as to feeding practices:	Annually	During grazing season.
			1. Pasture only.		
			2. Feed and chop only.		
			3. Pasture and feed; if both, ask farmer to estimate fraction of food from pasture: <25%, 25-50%, 50-75%, or >75%.		
12. Nearest Residence Census	In all 16 sectors up to 5 miles			Annually	During growing season.

<sup>a</sup> Control (reference) locations are denoted by a "C" in this column. All other locations are indicators.

TABLE 5.0-3

## ENVIRONMENTAL RADIOLICAL MONITORING PROGRAM QUARTERLY SUMMARY

Name of Facility	Byron Nuclear Power Station		Docket No.	50-454, 50-455	
Location of Facility	Ogle, Illinois (County, State)		Reporting Period	1st Quarter 1989	

Sample Type (Units)	Type and Number of Analyses	LLD	Indicator Locations Mean <sup>a</sup> Range	Location with Highest Quarterly Mean		Control Locations Mean <sup>a</sup> Range	Number of Non-routine Results
				Location	Mean Range		
Air Particulates (pCi/m <sup>3</sup> )	Gross Beta	156	0.01	0.032 (117/117) (0.012-0.066)	By-24, Near-site S.W. 0.65 mi 229°	0.035 (13/13) (0.023-0.066)	0.031 (38/39) (0.015-0.056)
	Gamma Spec.	12	0.01	<LLD	-	-	<LLD
Airborne Iodine (pCi/m <sup>3</sup> )	I-131	156	0.07	<LLD	-	-	<LLD
Gamma Background (TLDs) (mR/Qtr.)	Gamma Dose	12	3.0	12.8 (9/9) (9.6-15.3)	By-22, Onsite 0.3 mi 101°	15.3 (1/1) -	11.5 (3/3) (10.9-12.0)
Milk (pCi/l)	I-131	11	0.5	<LLD	-	-	<LLD
	Gamma Spec.	11	5.0	<LLD	-	-	<LLD
	Cs-134		5.0	<LLD	-	-	<LLD
	Cs-137		5.0	<LLD	-	-	<LLD
	Other Gammas		10.0	<LLD	-	-	<LLD
Surface Water (pCi/l)	Gamma Spec.	6		<LLD	-	-	<LLD
	Cs-134		10	<LLD	-	-	<LLD
	Cs-137		10	<LLD	-	-	<LLD
	Other Gammas		15	<LLD	-	-	<LLD
	Tritium	3	200	596 (1/2)	By-12, Downstream of Intake 4.5 mi 213°	596 (1/2)	<LLD
Well Water (pCi/l)	Gross Beta	5	1.8	<LLD	-	-	None
	Gamma Spec.	5		<LLD	-	-	None
	Cs-134		10	<LLD	-	-	None
	Cs-137		10	<LLD	-	-	None
	Other Gammas		15	<LLD	-	-	None
	Tritium	2	200	<LLD	-	-	None

<sup>a</sup> Mean and range based on detectable measurements only. Fraction indicated in parenthesis.

TABLE 5.0-4

## ENVIRONMENTAL RADILOGICAL MONITORING PROGRAM QUARTERLY SUMMARY

Name of Facility Byron Nuclear Power Station  
 Location of Facility Ogle, Illinois  
(County, State)

Docket No. 50-454, 50-455  
 Reporting Period 2nd Quarter 1989

Sample Type (Units)	Type and Number of Analyses	LLD	Indicator Locations Mean <sup>a</sup> Range	Location with Highest Quarterly Mean		Control Locations Mean <sup>a</sup> Range	Number of Non-routine Results
				Location	Mean Range		
Air Particulates (pCi/m <sup>3</sup> )	Gross Beta 156	0.01	0.021 (116/117) (0.005-0.042)	By-06, Oregon 4.6 mi @ 213°	0.024 (13/13) (0.015-0.042)	0.020 (39/39) (0.010-0.035)	0
	Gamma Spec. 12	0.01	<LLD	-	-	<LLD	0
Airborne Iodine (pCi/m <sup>3</sup> )	I-131 156	0.07	<LLD	-	-	<LLD	0
Gamma Background (TLDs) (mR/0tr.)	Gamma Dose 12	3.0	16.0 (9/9) (11.0-19.0)	By-05, Near site South 3.6 mi @ 180°	19.0 (1/1) -	14.6 (3/3) (13.3-15.8)	0
Milk (pCi/l)	I-131 20	0.5 <sup>b</sup>	<LLD	-	-	<LLD	0
	Gamma Spec. 20	5.0	<LLD	-	-	<LLD	0
	Cs-134 5.0	<LLD	-	-	-	<LLD	0
	Cs-137 10.0	<LLD	-	-	-	<LLD	0
Surface Water (pCi/l)	Other Gammas						
	Gamma Spec. 9	10	<LLD	-	-	<LLD	0
	Cs-134 10	<LLD	-	-	-	<LLD	0
	Cs-137 10	<LLD	-	-	-	<LLD	0
	Other Gammas 15	<LLD	-	-	-	<LLD	0
Well Water (pCi/l)	Tritium 3	200	790 (1/2)	By-12, Downstream of Intake 4.5 mi @ 213°	790 (1/2)	<LLD	0
	Gross Beta 6	2.4	<LLD	-	-	None	0
	Gamma Spec. 6	10	<LLD	-	-	None	0
	Cs-134 10	<LLD	-	-	-	None	0
	Cs-137 10	<LLD	-	-	-	None	0
	Other Gammas 15	<LLD	-	-	-	None	0
	Tritium 2	200	<LLD	-	-	None	0

TABLE 5.0-4 (continued)

## ENVIRONMENTAL RADILOGICAL MONITORING PROGRAM QUARTERLY SUMMARY

Name of Facility Byron Nuclear Power Station Docket No. 50-454, 50-455  
 Location of Facility Ogle, Illinois Reporting Period 2nd Quarter 1989  
 (County, State)

Sample Type (Units)	Type and Number of Analyses	LLD	Indicator Locations Mean <sup>a</sup> Range	Location with Highest Quarterly Mean		Control locations Mean <sup>a</sup> Range	Number of Non-routine Results
				Location	Mean Range		
Fish (pCi/g wet)	Gamma Spec. 4 Cs-134 Cs-137 Other Gammas	0.1 0.1 0.13	<LLD <LLD <LLD	- - -	- - -	<LLD <LLD <LLD	0 0 0
Bottom Sediments (pCi/g dry)	Gamma Spec. 2 Cs-134 Cs-137 Other Gammas	0.1 0.1 0.2	<LLD <LLD <LLD	- - -	- - -	<LLD <LLD <LLD	0 0 0

<sup>a</sup> Mean and range based on detectable measurements only. Fractions indicated in parentheses.

TABLE 5.0-5

## ENVIRONMENTAL RADILOGICAL MONITORING PROGRAM QUARTERLY SUMMARY

Name of Facility	Byron Nuclear Power Station		Docket No.	50-454, 50-455	
Location of Facility	Ogle, Illinois (County, State)		Reporting Period	3rd Quarter 1989	

Sample Type (Units)	Type and Number of Analyses	LLD	Indicator Locations Mean <sup>a</sup> Range	Location with Highest Quarterly Mean		Control Locations Mean <sup>a</sup> Range	Number of Non-routine Results
				Location	Mean Range		
Air Particulates (pCi/m <sup>3</sup> )	Gross Beta 156	0.01	0.022 (117/117) (0.006-0.041)	By-21, Nearsite North 0.7 mi 9°	0.025 (13/13) (0.018-0.038)	0.021 (39/39) (0.007-0.034)	0
	Gamma Spec. 12	0.01	<LLD	-	-	<LLD	0
Airborne Iodine (pCi/m <sup>3</sup> )	I-131 156	0.07 <sup>c</sup>	<LLD	-	-	<LLD	0
Gamma Background (TLDs) (mR/0tr.)	Gamma Dose 12	3.0	15.1 (9/9) (11.4-18.0)	By-22, Onsite ESE 0.3 mi 101°	18.0 (1/1) -	14.0 (3/3) (13.3-14.4)	0
Milk (pCi/l)	I-131 24	0.5	* <LLD	-	-	<LLD	0
	Gamma Spec. 24	5.0	<LLD	-	-	<LLD	0
	Cs-134 5.0	5.0	<LLD	-	-	<LLD	0
	Cs-137 10.0	10.0	<LLD	-	-	<LLD	0
Surface Water (pCi/l)	Gamma Spec. 9	10	<LLD	-	-	<LLD	0
	Cs-134 10	10	<LLD	-	-	<LLD	0
	Cs-137 15	15	<LLD	-	-	<LLD	0
	Tritium 3 200	532 (1/2)	By-12, Downstream of Oregon Dam, 4.6 mi 213°	532 (1/1)	-	<LLD	0

<sup>a</sup> Mean and range based on detectable measurements only. Fractions indicated in parentheses.

TABLE 5.0-5 (continued)

## ENVIRONMENTAL RADIOTOLOGICAL MONITORING PROGRAM QUARTERLY SUMMARY

Name of Facility	Byron Nuclear Power Station		Docket No.	50-454, 50-455
Location of Facility	Ogle, Illinois (County, State)		Reporting Period	3rd Quarter 1989

Sample Type (Units)	Type and Number of Analyses	LLD	Indicator Locations Mean <sup>a</sup> Range	Location with Highest Quarterly Mean		Control Locations Mean <sup>a</sup> Range	Number of Non-routine Results
				Location	Mean Range		
Well Water (pCi/l)	Gross Beta	6	2.6	<LLD	-	-	None 0
	Gamma Spec.	6		<LLD	-	-	None 0
	Cs-134	10		<LLD	-	-	None 0
	Cs-137	10		<LLD	-	-	None 0
	Other Gammas	15		<LLD	-	-	None 0
Fish (pCi/g wet)	Tritium	2	200	236 (1/2)	BY-14, Offsite Well 0.3 mi E 101*	236 (1/1)	None 0
	Gamma Spec.	4		<LLD	-	-	<LLD 0
	Cs-134	0.10		<LLD	-	-	<LLD 0
	Cs-137	0.10		<LLD	-	-	<LLD 0
Vegetables (pCi/g wet)	Other Gammas	0.13		<LLD	-	-	<LLD 0
	Gamma Spec.	7		<LLD	-	-	None 0
	Cs-134	0.1		<LLD	-	-	None 0
	Cs-137	0.1		<LLD	-	-	None 0
	Other Gammas	0.2		<LLD	-	-	None 0
I-131	I-131	0.06		<LLD	-	-	0

<sup>a</sup> Mean and range based on detectable measurements only. Fractions indicated in parentheses.

TABLE 5.0-6

## ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM QUARTERLY SUMMARY

Name of Facility	Byron Nuclear Power Station		Docket No.	50-454, 50-455	
Location of Facility	Ogle, Illinois (County, State)		Reporting Period	4th Quarter 1989	

Sample Type (Units)	Type and Number of Analyses	LLD	Indicator Locations Mean <sup>a</sup> Range	Location with Highest Quarterly Mean		Control Locations Mean <sup>a</sup> Range	Number of Non-routine Results
Air Particulates (pCi/m <sup>3</sup> )	Gross Beta 156	0.01	0.029 (116/117) (0.007-0.051)	BY-24, Nearsite South-west 0.65 mi @ 229°	0.032 (13/13) (0.020-0.051)	0.029 (39/39) (0.014-0.045)	0
	Gamma Spec. 12	0.01	<LLD	-	-	<LLD	0
Airborne Iodine (pCi/m <sup>3</sup> )	I-131 156	0.07	<LLD	-	-	<LLD	0
Gamma Background (TLDs) (mR/Qtr.)	Gamma Dose 12	3.0	15.5 (9/9) (11.5-18.5)	By-22, Onsite, 0.3 mi @ 101°	18.5 (1/1) -	14.6 (3/3) (14.0-15.6)	0
Milk (pCi/l)	I-131 16	0.5	<LLD	-	-	<LLD	0
	Gamma Spec. 16	5.0	<LLD	-	-	<LLD	0
	Cs-134	5.0	<LLD	-	-	<LLD	0
	Cs-137	5.0	<LLD	-	-	<LLD	0
	Other Gammas 10.0	<LLD	-	-	-	<LLD	0
Surface Water (pCi/l)	Gamma Spec. 9						
	Cs-134 10	<LLD	-	-	-	<LLD	0
	Cs-137 10	<LLD	-	-	-	<LLD	0
	Other Gammas 15	<LLD	-	-	-	<LLD	0
	Tritium 3	200	1470 (1/2) *	BY-12, Downstream of Oregon Dam 4.6 mi @ 213°	1470 (1/1)	<LLD	0

TABLE 5.0-6 (continued)

## ENVIRONMENTAL RADILOGICAL MONITORING PROGRAM QUARTERLY SUMMARY

Name of Facility	Byron Nuclear Power Station		Docket No.	50-454, 50-455	
Location of Facility	Ogle, Illinois (County, State)		Reporting Period	4th Quarter 1989	

Sample Type (Units)	Type and Number of Analyses	LLD	Indicator Locations Mean <sup>a</sup> Range	Location with Highest Quarterly Mean		Control Locations Mean <sup>a</sup> Range	Number of Non-routine Results
				Location	Mean Range		
Well Water (pCi/l)	Gross Beta	2	2.6	<LLD	-	-	None 0
	Gamma Spec.	2		<LLD	-	-	None 0
	Cs-134	10		<LLD	-	-	None 0
	Cs-137	10		<LLD	-	-	None 0
	Other Gammas	15		<LLD	-	-	None 0
	Tritium	2	200	<LLD	-	-	None 0
Fish (pCi/g wet)	Gamma Spec.	4		<LLD	-	-	<LLD 0
	Cs-134	0.10		<LLD	-	-	<LLD 0
	Cs-137	0.10		<LLD	-	-	<LLD 0
	Other Gammas	0.13		<LLD	-	-	<LLD 0
Bottom Sediments (pCi/g dry)	Gamma Spec.	2		<LLD	-	-	<LLD 0
	Cs-134	0.1		<LLD	-	-	<LLD 0
	Cs-137	0.1		<LLD	-	-	<LLD 0
	Other Gammas	0.2		<LLD	-	-	<LLD 0
Vegetables	I-131	2	0.06	<LLD	-	-	None 0

<sup>a</sup> Mean and range based on detectable measurements only. Fractions indicated in parentheses.

APPENDIX II

METEOROLOGICAL DATA

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - JANUARY-MARCH 1989  
 STABILITY CLASS - EXTREMELY UNSTABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
VARIABLE	0	0	0	0	0	0	0
TOTAL	0	0	0	0	0	0	0

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 77

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - JANUARY-MARCH 1989  
 STABILITY CLASS - MODERATELY UNSTABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	1	0	1
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
VARIABLE	0	0	0	0	0	0	0
TOTAL	0	0	0	0	1	0	1

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 77

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - JANUARY-MARCH 1989  
 STABILITY CLASS - SLIGHTLY UNSTABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	1	0	1
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	1	1	2
WNW	0	0	1	0	0	0	1
NW	0	0	3	0	0	0	3
NNW	0	0	0	0	0	0	0
VARIABLE	0	0	0	0	0	0	0
TOTAL	0	0	4	0	2	1	7

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 77

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - JANUARY-MARCH 1989  
 STABILITY CLASS - NEUTRAL (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	4	27	42	20	8	101
NNE	0	2	21	22	17	7	69
NE	0	9	20	16	25	11	81
ENE	1	3	9	32	16	0	61
E	0	1	15	29	5	2	52
ESE	0	1	0	7	1	0	9
SE	0	2	6	13	9	8	38
SSE	1	5	24	32	14	3	79
S	2	5	20	31	29	9	96
SSW	0	5	7	10	28	15	65
SW	1	4	14	18	17	3	57
WSW	0	4	18	42	21	3	88
W	2	6	13	44	17	19	101
WNW	2	6	17	29	19	10	83
NW	1	3	19	28	13	8	72
NNW	3	6	22	50	14	1	96
VARIABLE	0	0	0	0	0	0	0
TOTAL	13	66	252	445	265	107	1148

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 77

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - JANUARY-MARCH 1989  
 STABILITY CLASS - SLIGHTLY STABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
-----	-----	-----	-----	-----	-----	-----	-----
N	1	1	8	14	5	2	31
NNE	1	4	2	10	12	0	29
NE	1	3	5	5	1	1	16
ENE	3	4	3	4	3	0	17
E	0	4	7	16	15	2	44
ESE	0	0	5	8	4	3	20
SE	1	3	5	9	5	0	23
SSE	1	2	7	20	21	3	54
S	0	2	7	27	27	17	80
SSW	0	5	10	22	43	26	106
SW	0	4	9	12	13	12	50
WSW	1	3	6	25	19	0	54
W	1	4	10	32	18	11	76
WNW	0	4	8	32	24	5	73
NW	1	7	11	41	12	1	73
NNW	0	4	12	21	3	3	43
VARIABLE	0	0	0	0	0	0	0
TOTAL	11	54	115	298	225	86	789

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 77

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - JANUARY-MARCH 1989  
 STABILITY CLASS - MODERATELY STABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	0	0	2	5	0	7
NNE	0	0	0	0	0	0	0
NE	0	1	0	2	0	0	3
ENE	0	3	5	0	0	0	8
E	0	0	1	0	0	0	1
ESE	0	0	3	1	2	0	6
SE	0	0	1	4	4	4	13
SSE	0	1	0	6	7	3	17
S	0	2	1	3	5	2	13
SSW	0	0	2	3	3	0	8
SW	0	0	6	1	0	0	7
WSW	0	0	2	4	0	0	6
W	0	0	0	2	0	0	2
WNW	0	0	1	5	0	0	6
NW	0	0	0	10	0	0	10
NNW	0	0	1	3	3	0	7
VARIABLE	0	0	0	0	0	0	0
TOTAL	0	7	23	46	29	9	114

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 77

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - JANUARY-MARCH 1989  
 STABILITY CLASS - EXTREMELY STABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	3	0	0	0	3
ENE	0	2	2	0	0	0	4
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	1	0	0	0	1
SSE	0	0	0	1	0	0	1
S	0	0	0	3	2	0	5
SSW	0	0	2	3	1	0	6
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	1	0	1	0	0	2
NW	0	0	1	1	0	0	2
NNW	0	0	0	0	0	0	0
VARIABLE	0	0	0	0	0	0	0
TOTAL	0	3	9	9	3	0	24

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 77

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - APRIL-JUNE 1989  
 STABILITY CLASS - EXTREMELY UNSTABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4-7	8-12	13-18	19-24	GT 24	
N	0	0	0	2	0	0	2
NNE	0	0	0	0	2	0	2
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	1	0	0	1
SSE	0	0	0	0	0	1	1
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
VARIABLE	0	0	0	0	0	0	0
TOTAL	0	0	0	3	2	1	6

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 11

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - APRIL-JUNE 1989  
 STABILITY CLASS - MODERATELY UNSTABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	0	1	3	0	0	4
NNE	0	0	0	4	7	0	11
NE	0	0	0	0	0	0	0
ENE	0	0	0	1	0	0	1
E	0	0	0	0	0	0	0
ESE	0	0	0	0	1	4	5
SE	0	0	0	0	0	0	0
SSE	0	0	0	3	0	1	4
S	0	0	0	0	2	0	2
SSW	0	0	0	0	0	0	0
SW	0	0	0	1	0	0	1
WSW	0	0	1	0	0	0	1
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	1	0	0	1
NNW	0	0	0	1	0	0	1
VARIABLE	0	0	0	0	0	0	0
TOTAL	0	0	2	14	10	5	31

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 11

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - APRIL-JUNE 1989  
 STABILITY CLASS - SLIGHTLY UNSTABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	1	0	3	0	0	4
NNE	0	1	1	1	4	0	7
NE	0	1	0	2	0	0	3
ENE	0	0	1	4	1	0	5
E	0	0	2	0	1	0	3
ESE	0	0	1	1	2	1	5
SE	0	0	0	0	1	0	1
SSE	0	0	0	1	0	0	1
S	0	0	0	0	1	0	1
SSW	0	0	1	0	0	1	2
SW	0	0	0	0	0	0	0
WSW	0	0	0	2	0	0	2
W	0	2	1	0	0	0	3
WNW	0	0	3	2	0	0	5
NW	0	0	5	6	0	0	11
NNW	0	1	2	2	0	0	5
VARIABLE	0	0	0	0	0	0	0
TOTAL	0	6	17	24	10	2	59

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 11

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - APRIL-JUNE 1989  
 STABILITY CLASS - NEUTRAL (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	2	14	23	29	7	0	75
NNE	1	12	19	4	7	1	44
NE	1	8	6	8	2	2	27
ENE	0	4	11	18	10	0	43
E	0	7	14	26	10	0	57
ESE	0	2	20	11	9	1	43
SE	2	5	11	17	11	4	50
SSE	1	11	20	19	19	6	76
S	1	7	22	20	18	10	78
SSW	3	7	17	12	13	7	59
SW	1	1	14	31	15	1	63
WSW	0	13	22	24	4	4	67
W	3	13	26	14	12	14	82
WNW	1	17	22	41	22	12	115
NW	1	15	45	47	13	9	130
NNW	2	17	30	19	4	0	72
VARIABLE	0	0	0	0	0	0	0
TOTAL	19	153	322	340	176	71	108:

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 11

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - APRIL-JUNE 1989  
 STABILITY CLASS - SLIGHTLY STABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	3	5	7	2	0	17
NNE	1	2	3	12	7	1	26
NE	1	5	2	13	5	0	26
ENE	0	3	3	11	15	1	33
E	1	2	4	16	20	2	45
ESE	1	1	1	11	16	1	31
SE	0	3	2	23	8	9	45
SSE	1	1	11	6	13	6	38
S	0	3	7	17	24	6	57
SSW	0	2	22	18	16	2	60
SW	0	5	14	16	9	0	44
WSW	0	4	14	14	2	0	34
W	0	5	15	13	0	0	33
WNW	0	9	20	19	3	0	51
NW	1	7	16	25	0	0	49
NNW	3	6	12	13	0	0	34
VARIABLE	0	0	0	0	0	0	0
TOTAL	9	61	151	234	140	28	623

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 1

Hours of missing stability measurements in all stability classes: 11

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - APRIL-JUNE 1989  
 STABILITY CLASS - MODERATELY STABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	4	3	4	0	0	11
NNE	0	0	4	7	2	0	13
NE	1	1	3	1	0	0	6
ENE	0	2	0	0	0	0	2
E	0	0	2	7	10	2	21
ESE	2	1	2	4	12	1	22
SE	0	1	2	5	9	0	17
SSE	0	3	1	6	11	2	23
S	0	4	4	11	12	0	31
SSW	0	2	7	28	5	0	42
SW	0	1	6	15	1	0	23
WSW	3	0	7	6	0	0	16
W	0	2	6	9	0	0	17
WNW	0	1	9	6	0	0	16
NW	0	2	8	13	0	0	23
NNW	0	3	7	2	0	0	12
VARIABLE	0	0	0	0	0	0	0
TOTAL	6	27	71	124	62	5	295

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 11

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - APRIL-JUNE 1989  
 STABILITY CLASS - EXTREMELY STABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
-----	-----	-----	-----	-----	-----	-----	-----
N	0	0	6	4	0	0	10
NNE	0	0	1	2	0	0	3
NE	0	0	1	0	0	0	1
ENE	0	2	0	0	0	0	2
E	0	0	0	0	1	0	1
ESE	0	0	0	0	0	0	0
SE	1	0	1	3	8	0	13
SSE	0	0	0	1	0	0	1
S	0	1	1	0	1	0	3
SSW	0	0	2	4	2	0	8
SW	0	0	1	6	0	0	7
WSW	0	0	2	3	0	0	5
W	0	0	2	0	0	0	2
WNW	0	2	5	2	0	0	9
NW	0	0	3	0	0	0	3
NNW	0	1	7	1	0	0	9
VARIABLE	0	0	0	0	0	0	0
TOTAL	1	6	32	26	12	0	77

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 11

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - JULY-SEPTEMBER 1989  
 STABILITY CLASS - EXTREMELY UNSTABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	3	0	0	3
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	2	0	0	0	2
ESE	0	0	0	0	0	0	0
SE	0	0	1	0	0	0	1
SSE	0	0	5	0	0	0	3
S	0	0	4	4	0	0	8
SSW	0	0	2	0	0	0	2
SW	0	0	0	3	0	0	3
WSW	0	0	0	5	0	0	5
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	1	0	4	1	0	6
VARIABLE	0	0	0	0	0	0	0
TOTAL	0	1	12	19	1	0	33

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 9

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - JULY-SEPTEMBER 1989  
 STABILITY CLASS - MODERATELY UNSTABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	1	5	1	0	0	7
NNE	0	1	0	4	0	0	5
NE	0	0	0	1	1	0	2
ENE	0	0	1	0	0	0	1
E	0	0	2	0	0	0	2
ESE	0	0	0	0	0	0	0
SE	0	0	2	0	0	0	2
SSE	0	0	0	0	0	0	0
S	0	0	5	0	0	0	5
SSW	0	0	4	1	0	0	5
SW	0	0	0	2	0	0	2
WSW	0	0	0	4	0	0	4
W	0	0	0	1	0	0	1
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	1	1	0	0	2
VARIABLE	0	0	0	0	0	0	0
TOTAL	0	2	20	15	1	0	38

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 9

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - JULY-SEPTEMBER 1989  
 STABILITY CLASS - SLIGHTLY UNSTABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	0	0	1	0	0	1
NNE	0	0	7	1	0	0	8
NE	0	0	0	2	0	0	2
ENE	0	0	0	1	0	0	1
E	0	3	5	1	0	0	9
ESE	0	0	1	2	0	0	3
SE	0	0	2	0	0	0	2
SSE	0	0	2	2	0	0	4
S	0	0	2	2	0	0	4
SSW	0	2	3	0	0	0	5
SW	0	3	0	0	1	0	4
WSW	0	0	0	4	0	0	4
W	0	1	0	2	0	0	3
WNW	0	1	0	0	0	0	1
NW	0	2	0	0	0	0	2
NNW	0	1	0	0	0	0	1
VARIABLE	0	0	0	0	0	0	0
TOTAL	0	13	22	18	1	0	54

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 9

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - JULY-SEPTEMBER 1989  
 STABILITY CLASS - NEUTRAL (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
-----	-----	-----	-----	-----	-----	-----	-----
N	1	12	19	30	0	1	63
NNE	1	8	25	16	10	2	62
NE	0	13	20	17	2	0	52
ENE	0	10	17	9	1	0	37
E	0	11	17	6	2	0	36
ESE	2	11	8	8	0	0	29
SE	1	11	10	6	0	0	28
SSE	2	14	20	25	3	0	64
S	2	13	25	21	2	0	63
SSW	1	18	22	14	5	1	61
SW	0	17	22	22	1	0	62
WSW	4	13	14	10	5	0	46
W	2	21	20	16	3	0	62
WNW	0	7	7	5	0	0	19
NW	0	8	16	5	0	0	29
NNW	2	16	13	11	2	0	44
VARIABLE	0	0	0	0	0	0	0
TOTAL	18	203	275	221	36	4	757

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 9

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - JULY-SEPTEMBER 1989  
 STABILITY CLASS - SLIGHTLY STABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
-----	-----	-----	-----	-----	-----	-----	-----
N	1	5	10	14	7	3	40
NNE	0	5	11	24	18	2	60
NE	0	9	11	22	4	0	46
ENE	0	8	11	13	8	0	40
E	0	6	14	13	9	0	42
ESE	1	5	9	8	4	0	27
SE	0	5	8	15	7	0	35
SSE	2	10	11	24	7	0	54
S	1	4	16	22	10	1	54
SSW	0	8	17	24	6	1	56
SW	2	6	16	13	9	0	46
WSW	1	5	19	20	2	0	47
W	1	9	9	2	0	1	22
WNW	1	2	3	5	0	0	11
NW	3	4	5	7	2	1	22
NNW	1	3	15	13	7	2	41
VARIABLE	0	0	0	0	0	0	0
TOTAL	14	94	185	239	100	11	643

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 9

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - JULY-SEPTEMBER 1989  
 STABILITY CLASS - MODERATELY STABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
-----	-----	-----	-----	-----	-----	-----	-----
N	0	2	2	8	2	0	14
NNE	2	5	3	5	0	0	15
NE	0	3	6	5	0	0	14
ENE	0	1	1	2	1	0	5
E	0	1	7	11	7	0	26
ESE	0	2	3	15	7	0	27
SE	1	2	18	24	9	0	54
SSE	0	2	18	20	10	1	51
S	0	5	10	10	16	0	41
SSW	1	0	8	23	9	0	41
SW	1	4	15	14	2	0	36
WSW	1	2	14	4	0	0	21
W	0	1	5	4	0	0	10
WNW	2	1	4	4	1	0	12
NW	0	4	7	16	1	0	28
NNW	1	4	3	11	0	0	19
VARIABLE	0	0	0	0	0	0	0
TOTAL	9	39	124	176	65	1	414

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 9

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - JULY-SEPTEMBER 1989  
 STABILITY CLASS - EXTREMELY STABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	2	0	4	0	1	0	7
NNE	1	2	3	3	1	0	10
NE	0	4	5	1	0	0	10
ENE	3	2	4	0	0	0	9
E	0	3	3	8	3	0	17
ESE	0	2	2	9	3	0	16
SE	2	2	10	14	2	0	30
SSE	0	4	6	17	16	1	44
S	1	1	11	17	18	1	49
SSW	1	2	5	12	1	0	21
SW	3	1	5	8	0	0	17
WSW	1	2	4	2	0	0	9
W	2	2	2	1	0	0	7
WNW	0	1	3	5	0	0	9
NW	0	0	0	1	0	0	1
NNW	1	0	0	3	0	0	4
VARIABLE	0	0	0	0	0	0	0
TOTAL	17	28	67	101	45	2	260

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 9

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - OCTOBER-DECEMBER 1989  
 STABILITY CLASS - EXTREMELY UNSTABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	1	0	0	1
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	1	0	0	1
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	1	0	1
W	0	0	0	0	0	0	0
WNW	0	0	1	2	0	0	3
NW	0	0	1	0	0	0	1
NNW	0	0	2	0	0	0	2
VARIABLE	0	0	0	0	0	0	0
TOTAL	0	0	4	4	1	0	9

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 1

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - OCTOBER-DECEMBER 1989  
 STABILITY CLASS - MODERATELY UNSTABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	0	3	0	0	0	3
NNE	0	0	0	0	1	2	3
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	2	0	0	2
ESE	0	0	0	1	0	0	1
SE	0	0	0	0	0	0	0
SSE	0	0	2	1	0	0	3
S	0	0	0	0	0	0	0
SSW	0	0	0	1	0	0	1
SW	0	0	0	0	0	0	0
WSW	0	0	0	4	0	0	4
W	0	0	1	1	1	0	3
WNW	0	0	0	3	1	0	4
NW	0	0	1	3	1	0	5
NNW	0	0	0	0	0	0	0
VARIABLE	0	0	0	0	0	0	0
TOTAL	0	0	7	16	4	2	29

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 1

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - OCTOBER-DECEMBER 1989  
 STABILITY CLASS - SLIGHTLY UNSTABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	0	2	0	0	0	2
NNE	0	0	0	0	1	0	1
NE	0	0	0	0	0	0	0
ENE	0	0	1	0	0	0	1
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	1	7	1	0	9
S	0	0	2	2	0	1	5
SSW	0	1	0	2	3	1	7
SW	0	0	2	1	3	0	6
WSW	0	0	2	5	0	0	7
W	0	3	1	2	0	0	6
WNW	0	1	2	2	1	0	6
NW	0	0	5	3	3	0	11
NNW	0	1	4	1	1	0	7
VARIABLE	0	0	0	0	0	0	0
TOTAL	0	6	22	25	13	2	68

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 1

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - OCTOBER-DECEMBER 1989  
 STABILITY CLASS - NEUTRAL (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
-----	-----	-----	-----	-----	-----	-----	-----
N	0	11	12	38	37	8	106
NNE	1	8	17	6	27	5	64
NE	0	2	8	5	0	2	17
ENE	0	8	10	24	0	0	42
E	0	5	4	0	0	0	9
ESE	0	2	1	0	2	0	5
SE	1	0	8	11	0	1	21
SSE	0	4	9	16	9	5	43
S	1	7	24	38	24	12	106
SSW	0	13	29	32	35	5	114
SW	2	6	32	35	7	4	86
WSW	1	8	16	33	7	0	65
V	4	9	19	30	21	2	85
WNW	0	13	32	50	19	14	128
NW	0	7	32	49	47	16	151
NNW	0	8	9	26	42	3	88
VARIABLE	0	0	0	0	0	0	0
TOTAL	10	111	262	393	277	77	1130

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 1

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - OCTOBER-DECEMBER 1989  
 STABILITY CLASS - SLIGHTLY STABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	2	3	15	5	0	25
NNE	0	3	6	5	1	0	15
NE	0	0	6	2	1	0	9
ENE	0	0	0	3	0	0	3
E	1	3	1	0	1	0	6
ESE	0	0	2	0	3	6	11
SE	0	3	3	3	2	2	13
SSE	1	0	6	11	13	5	36
S	0	0	14	23	31	20	88
SSW	0	1	5	14	16	18	54
SW	1	2	8	12	14	6	43
WSW	0	4	7	20	7	0	38
W	0	2	14	48	16	0	80
WNW	0	3	22	46	6	0	77
NW	0	8	22	68	11	0	109
NNW	0	2	9	36	12	1	60
VARIABLE	0	0	0	0	0	0	0
TOTAL	3	33	128	306	139	58	667

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 1

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - OCTOBER-DECEMBER 1989  
 STABILITY CLASS - MODERATELY STABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	2	3	2	0	0	7
NNE	0	1	0	0	0	0	1
NE	1	0	0	0	0	0	1
ENE	0	1	0	0	0	0	1
E	2	1	1	0	0	0	4
ESE	0	1	0	1	1	1	4
SE	0	0	1	2	5	1	9
SSE	0	0	3	3	9	0	15
S	0	0	4	11	64	7	86
SSW	0	2	4	8	8	0	22
SW	0	0	4	2	1	0	7
WSW	0	2	6	3	1	0	12
W	0	0	1	6	1	0	8
WNW	0	2	2	8	0	0	12
NW	1	1	2	9	0	0	13
NNW	0	0	3	11	0	0	14
VARIABLE	0	0	0	0	0	0	0
TOTAL	4	13	34	66	90	9	216

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 1

BYRON NUCLEAR POWER STATION  
 PERIOD OF RECORD - OCTOBER-DECEMBER 1989  
 STABILITY CLASS - EXTREMELY STABLE (DIFF TEMP 250-30 FT)  
 WINDS MEASURED AT 250 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.8-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	1	1	0	0	0	2
NNE	0	1	0	0	0	0	1
NE	0	0	0	0	0	0	0
ENE	0	1	0	0	0	0	1
E	0	0	0	0	0	0	0
ESE	0	0	0	1	0	0	1
SE	0	1	0	0	1	0	2
SSE	0	0	0	1	5	3	9
S	1	1	3	5	19	1	30
SSW	0	1	2	9	5	0	17
SW	0	0	2	5	2	0	9
WSW	0	0	2	0	0	0	2
W	0	0	0	0	0	0	0
WNW	0	0	1	0	0	0	1
NW	0	1	1	5	0	0	7
NNW	0	0	1	5	0	0	6
VARIABLE	0	0	0	0	0	0	0
TOTAL	1	7	13	31	32	4	88

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 1

APPENDIX III  
INTERLABORATORY COMPARISON PROGRAM RESULTS

### Interlaboratory Comparison Program Results

Teledyne Isotopes Midwest Laboratory (formerly Hazleton Environmental Sciences) has participated in interlaboratory comparison (crosscheck) programs since the formulation of its quality control program in December 1971. These programs are operated by agencies which supply environmental-type samples (e.g., milk or water) containing concentrations of radionuclides known to the issuing agency but not to participant laboratories. The purpose of such a program is to provide an independent check on the laboratory's analytical procedures and to alert it to any possible problems.

Participant laboratories measure the concentrations of specified radionuclides and report them to the issuing agency. Several months later, the agency reports the known values to the participant laboratories and specifies control limits. Results consistently higher or lower than the known values or outside the control limits indicate a need to check the instruments or procedures used.

The results in Table A-1 were obtained through participation in the environmental sample crosscheck program for milk, water, air filters, and food samples during the period January 1986 through November, 1989. This program has been conducted by the U.S. Environmental Protection Agency Intercomparison and Calibration Section, Quality Assurance Branch, Environmental Monitoring and Support Laboratory, Las Vegas, Nevada.

The results in Table A-2 were obtained for thermoluminescent dosimeters (TLD's) during the period 1976, 1977, 1979, 1980, 1984, and 1985-1986 through participation in the Second, Third, Fourth, Fifth, Seventh, and Eighth International Intercomparison of Environmental Dosimeters under the sponsorships listed in Table A-2. Also Teledyne testing results are listed.

Table A-3 lists results of the analyses on in-house spiked samples.

Table A-4 lists results of the analyses on in-house "blank" samples.

Attachment B lists acceptance criteria for "spiked" samples.

Addendum to Appendix A provides explanation for out of limit results.

Table A-1. U.S. Environmental Protection Agency's crosscheck program, comparison of EPA and Teledyne Isotopes Midwest Laboratory results for milk, water, air filters, and food samples, 1986 through 1989.<sup>a</sup>

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l <sup>b</sup>		
				$\pm 2\sigma^c$	1s, N=1	EPA Result <sup>d</sup> Control Limits
STF-447	Food	Jan 1986	Sr-89	24.3 $\pm$ 2.5	25.0 $\pm$ 5.0	16.3-33.7
			Sr-90	17.3 $\pm$ 0.6	10.0 $\pm$ 1.5	7.4-12.6
			I-131	22.7 $\pm$ 2.3	20.0 $\pm$ 0.6	9.6-30.4
			Cs-137	16.3 $\pm$ 0.6	15.0 $\pm$ 5.0	6.3-23.7
			K	927 $\pm$ 46	950 $\pm$ 144	701-1199
STW-448	Water	Feb 1986	Cr-51	45.0 $\pm$ 3.6	38.0 $\pm$ 5.0	29.3-46.7
			Co-60	19.7 $\pm$ 1.5	18.0 $\pm$ 5.0	9.3-26.7
			Zn-65	44.0 $\pm$ 3.5	40.0 $\pm$ 5.0	31.3-48.7
			Ru-106	<9.0	0.0 $\pm$ 5.0	0.0-8.7
			Cs-134	28.3 $\pm$ 2.3	30.0 $\pm$ 5.0	21.3-38.7
			Cs-137	23.7 $\pm$ 0.6	22.0 $\pm$ 5.0	13.3-30.7
STW-449	Water	Feb 1986	H-3	5176 $\pm$ 48	5227 $\pm$ 525	4317<6137
STW-450	Water	Feb 1986	U total	8.0 $\pm$ 0.0	9.0 $\pm$ 6.0	0.0-19.4
STM-451	Milk	Feb 1986	I-131	7.0 $\pm$ 0.0	9.0 $\pm$ 6.0	0.0-19.4
STW-452	Water	Mar 1986	Ra-226	3.8 $\pm$ 0.1	4.1 $\pm$ 0.6	3.0-5.2
			Ra-228	11.0 $\pm$ 0.5	12.4 $\pm$ 1.8	9.2-15.5
STW-453	Water	Mar 1986	Gr. alpha	6.7 $\pm$ 0.6	15.0 $\pm$ 5.0	6.3-23.7
			Gr. beta	7.3 $\pm$ 0.6	8.0 $\pm$ 5.0	0.0-16.7
STW-454	Water	Apr 1986	I-131	7.0 $\pm$ 0.0	9.0 $\pm$ 6.0	0.0-19.4
STW-455 456	Water (Blind)	Apr 1986	Sample A	Gr. alpha	15.0 $\pm$ 1.0	17.0 $\pm$ 5.0
				Ra-226	3.1 $\pm$ 0.1	2.9 $\pm$ 0.4
				Ra-228	1.5 $\pm$ 0.2	2.0 $\pm$ 0.3
				Uranium	4.7 $\pm$ 0.6	5.0 $\pm$ 6.0
			Sample B	Gr. beta	28.7 $\pm$ 1.2	35.0 $\pm$ 5.0
				Sr-89	5.7 $\pm$ 0.6	7.0 $\pm$ 5.0
				Sr-90	7.0 $\pm$ 0.0	7.0 $\pm$ 1.5
				Co-60	10.7 $\pm$ 1.5	10.0 $\pm$ 5.0
				Cs-134	4.0 $\pm$ 1.7	5.0 $\pm$ 5.0
				Cs-137	5.3 $\pm$ 0.6	5.0 $\pm$ 5.0

Table A-1. (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/lb		
				TIML Result $\pm 2\sigma^c$	EPA Result <sup>d</sup> 1s, N=1	Control Limits
STAF-457	Air Filter	April 1986	Gr. alpha	13.7 $\pm$ 0.6	15.0 $\pm$ 5.0	6.3-23.7
			Gr. beta	46.3 $\pm$ 0.6	47.0 $\pm$ 5.0	38.3-55.7
			Sr-90	14.7 $\pm$ 0.6	18.0 $\pm$ 1.5	15.4-20.6
			Cs-137	10.7 $\pm$ 0.6	10.0 $\pm$ 5.0	1.3-18.7
STU-458	Urine	April 1986	Tritium	4313 $\pm$ 70	4423 $\pm$ 189	4096-4750
STW-459	Water	May 1986	Sr-89	4.3 $\pm$ 0.6	5.0 $\pm$ 5.0	0.0-13.7
			Sr-90	5.0 $\pm$ 0.0	5.0 $\pm$ 1.5	2.4-7.6
STW-460	Water	May 1986	Gr. alpha	5.3 $\pm$ 0.6	8.0 $\pm$ 5.0	0.0-16.7
			Gr. beta	11.3 $\pm$ 1.2	15.0 $\pm$ 5.0	6.3-23.7
STW-461	Water	June 1986	Cr-51	<9.0	0.0 $\pm$ 5.0	0.0-8.7
			Co-60	66.0 $\pm$ 1.0	66.0 $\pm$ 5.0	57.3-74.7
			Zn-65	87.3 $\pm$ 1.5	86.0 $\pm$ 5.0	77.3-94.7
			Ru-106	39.7 $\pm$ 2.5	50.0 $\pm$ 5.0	41.3-58.7
			Cs-134	49.3 $\pm$ 2.5	49.0 $\pm$ 5.0	40.3-57.7
			Cs-137	10.3 $\pm$ 1.5	10.0 $\pm$ 5.0	1.3-18.7
STW-462	Water	June 1986	Tritium	3427 $\pm$ 25	3125 $\pm$ 361	2499-3751
STM-464	Milk	June 1986	Sr-89	<1.0	0.0 $\pm$ 5.0	0.0-8.7
			Sr-90	15.3 $\pm$ 0.6	16.0 $\pm$ 1.5	13.4-18.6
			I-131	48.3 $\pm$ 2.3	41.0 $\pm$ 6.0	30.6-51.4
			Cs-137	43.7 $\pm$ 1.5	31.0 $\pm$ 5.0	22.3-39.7
			K	1567 $\pm$ 114	1600 $\pm$ 80	1461-1739
STW-465	Water	July 1986	Gr. alpha	4.7 $\pm$ 0.6	6.0 $\pm$ 5.0	0.0-14.7
			Gr. beta	18.7 $\pm$ 1.2	18.0 $\pm$ 5.0	9.3-26.7
STW-467	Water	August 1986	I-131	30.3 $\pm$ 0.6	45.0 $\pm$ 6.0	34.4-55.4
STW-468	Water	August 1986	Pu-239	11.3 $\pm$ 0.6	10.1 $\pm$ 1.0	8.3-11.9
STW-469	Water	August 1986	Uranium	4.0 $\pm$ 0.0	4.0 $\pm$ 6.0	0.0-14.4
STAF-470	Air Filter	Sept 1986	Gr. alpha	19.3 $\pm$ 1.5	22.0 $\pm$ 5.0	13.3-30.7
			Gr. beta	64.0 $\pm$ 2.6	66.0 $\pm$ 5.0	57.3-74.7
			Sr-90	22.0 $\pm$ 1.0	22.0 $\pm$ 5.0	19.4-24.6
			Cs-137	25.7 $\pm$ 1.5	22.0 $\pm$ 5.0	13.3-30.7
STW-473	Water	Sep. 1986	Ra-226	6.0 $\pm$ 0.1	6.1 $\pm$ 0.9	4.5-7.7
			Ra-228	8.7 $\pm$ 1.1	9.1 $\pm$ 1.4	6.7-11.5

Table A-1. (continued).

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/lb		
				TIML Result $\pm 2\sigma^c$	1s, N=1	EPA Result <sup>d</sup> Control Limits
STW-474	Water	Sept 1986	Gr. alpha	16.3 $\pm$ 3.2	15.0 $\pm$ 5.0	6.3-23.7
			Gr. beta	9.0 $\pm$ 1.0	8.0 $\pm$ 5.0	0.0-16.7
STW-475	Water	Oct 1986	Cr-51	63.3 $\pm$ 5.5	59.0 $\pm$ 5.0	50.3-67.7
			Co-60	31.0 $\pm$ 2.0	31.0 $\pm$ 5.0	22.3-39.7
			Zn-65	87.3 $\pm$ 5.9	85.0 $\pm$ 5.0	76.3-93.7
			Ru-106	74.7 $\pm$ 7.4	74.0 $\pm$ 5.0	65.3-82.7
			Cs-134	25.7 $\pm$ 0.6	28.0 $\pm$ 5.0	19.3-36.7
			Cs-137	46.3 $\pm$ 1.5	44.0 $\pm$ 5.0	35.3-52.7
STW-476	Water	Oct 1986	H-3	5918 $\pm$ 60	5973 $\pm$ 597	4938-7008
SPW-477	Water	Oct 1986				
478	(Blind)					
	Sample A		Gr. alpha	34.0 $\pm$ 6.0	40.0 $\pm$ 5.0	31.3-48.7
			Ra-226	5.8 $\pm$ 0.2	6.0 $\pm$ 0.9	4.4-7.6
			Ra-228	2.7 $\pm$ 1.0	5.0 $\pm$ 0.8	3.7-6.3
			Uranium	11.0 $\pm$ 0.0	10.0 $\pm$ 6.0	0.0-20.4
	Sample B		Gr. beta	38.7 $\pm$ 1.2	51.0 $\pm$ 5.0	42.3-59.7
			Sr-89	5.0 $\pm$ 0.0	10.0 $\pm$ 5.0	1.3-18.7
			Sr-90	3.0 $\pm$ 0.0	4.0 $\pm$ 1.5	1.4-6.6
			Co-60	24.7 $\pm$ 1.2	24.0 $\pm$ 5.0	15.3-32.7
			Cs-134	11.0 $\pm$ 2.0	12.0 $\pm$ 5.0	3.3-20.7
			Cs-137	9.3 $\pm$ 1.2	8.0 $\pm$ 5.0	0.0-16.7
STM-479	Milk	Nov 1986	Sr-89	7.7 $\pm$ 1.2	9.0 $\pm$ 5.0	0.3-17.7
			Sr-90	1.0 $\pm$ 0.0	0.0 $\pm$ 1.5	0.0-2.6
			I-131	52.3 $\pm$ 3.1	49.0 $\pm$ 6.0	38.6-59.4
			Cs-137	45.7 $\pm$ 3.1	39.0 $\pm$ 5.0	30.3-47.7
			K	1489 $\pm$ 104	1565 $\pm$ 78	1430-1700
STU-480	Urine	Nov 1986	H-3	5540 $\pm$ 26	5257 $\pm$ 912	4345-6169
STW-481	Water	Nov 1986	Gr. alpha	12.0 $\pm$ 4.0	20.0 $\pm$ 5.0	11.3-28.7
			Gr. beta	20.0 $\pm$ 3.5	20.0 $\pm$ 5.0	11.3-28.7
STW-482	Water	Dec 1986	Ra-226	6.7 $\pm$ 0.2	6.8 $\pm$ 1.0	5.0-8.6
			Ra-228	5.2 $\pm$ 0.2	11.1 $\pm$ 1.7	8.2-14.0
STW-483	Water	Jan 1987	Sr-89	19.7 $\pm$ 5.0	25.0 $\pm$ 5.0	16.3-33.7
			Sr-90	21.0 $\pm$ 2.0	25.0 $\pm$ 1.5	22.4-27.6

Table A-1. (continued).

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/lb			
				TIML Result $\pm 2\sigma^c$	1s, N=1	EPA Result <sup>d</sup> Control Limits	
STW-484	Water	Jan 1987	Pu-239	17.0 $\pm$ 2.3	16.7 $\pm$ 1.7	13.8-19.6	
STF-486	Food	Jan 1987	Sr-90 I-131 Cs-137 K	36.0 $\pm$ 4.0 78.0 $\pm$ 3.4 89.7 $\pm$ 3.0 942 $\pm$ 56	49.0 $\pm$ 10.0 78.0 $\pm$ 8.0 84.0 $\pm$ 5.0 980 $\pm$ 49	31.7-66.3 64.1-91.9 75.3-92.7 895-1065	
STF-487	Food (Blank)	Jan 1987	SR-90 I-131 Cs-137 K	2.0 $\pm$ 0.0 <3 <2 993 $\pm$ 102	---	---	
STW-488	Water	Feb 1987	Co-60 Zn-65 Ru-106 Cs-134 Cs-137	49.0 $\pm$ 0.0 96.0 $\pm$ 7.2 92.0 $\pm$ 20.2 53.0 $\pm$ 3.4 89.3 $\pm$ 4.6	50.0 $\pm$ 5.0 91.0 $\pm$ 5.0 100.0 $\pm$ 5.0 59.0 $\pm$ 5.0 87.0 $\pm$ 5.0	41.3-58.7 82.3-99.7 91.3-108.7 50.3-67.7 78.3-95.7	
STW-489	Water	Feb 1987	H-3	4130 $\pm$ 140	4209 $\pm$ 420	3479-4939	
STW-490	Water	Feb 1987	Uranium	8.3 $\pm$ 1.2	8.0 $\pm$ 6.0	0.0-18.4	
STM-491	Milk	Feb 1987	I-131	10.0 $\pm$ 0.0	9.0 $\pm$ 0.9	7.4-10.6	
STW-492	Water	Mar 1987	Gr. alpha Gr. beta	3.7 $\pm$ 1.2 11.3 $\pm$ 1.2	3.0 $\pm$ 5.0 13.0 $\pm$ 5.0	0.0-11.7 4.3-21.7	
STW-493	Water	Mar 1987	Ra-226 Ra-228	7.0 $\pm$ 0.1 7.1 $\pm$ 2.3	7.3 $\pm$ 1.1 7.5 $\pm$ 1.1	5.4-9.2 5.5-9.5	
STW-494	Water	Apr 1987	I-131	8.0 $\pm$ 0.0	7.0 $\pm$ 0.7	5.8-8.2	
STAF-495	Air Filter	Apr 1987	Gr. alpha Gr. beta Sr-90 Cs-137	15.0 $\pm$ 0.0 41.0 $\pm$ 2.0 16.3 $\pm$ 1.2 7.0 $\pm$ 0.0	14.0 $\pm$ 5.0 43.0 $\pm$ 5.0 17.0 $\pm$ 1.5 8.0 $\pm$ 5.0	5.3-22.7 34.3-51.7 14.4-19.6 0.0-16.7	
STW-496 497	Water (Blind)	Apr 1987	Sample A	Gr. alpha Ra-226 Ra-228 Uranium	30.7 $\pm$ 1.2 3.9 $\pm$ 0.2 4.9 $\pm$ 0.9 5.0 $\pm$ 0.0	30.0 $\pm$ 8.0 3.9 $\pm$ 0.6 4.0 $\pm$ 0.6 5.0 $\pm$ 6.0	16.1-43.9 2.9-4.9 3.0-5.0 0.0-15.4

Table A-1. (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l <sup>b</sup>			
				TIML Result $\pm 2\sigma^c$	1s, N=1	EPA Result <sup>d</sup> Control Limits	
STW-496 497	Water (Blind)	Apr 1987	Sample B	Gr. Beta Sr-89 Sr-90 Co-60 Cs-134 Cs-137	69.3 $\pm$ 9.4 16.3 $\pm$ 3.0 10.0 $\pm$ 0.0 8.3 $\pm$ 3.0 19.0 $\pm$ 2.0 14.7 $\pm$ 1.2	66.0 $\pm$ 5.0 19.0 $\pm$ 5.0 10.0 $\pm$ 1.5 8.0 $\pm$ 5.0 20.0 $\pm$ 5.0 15.0 $\pm$ 5.0	57.3-74.7 10.3-27.7 7.4-12.6 0.0-16.7 11.3-28.7 6.3-23.7
STU-498	Urine	Apr 1987	H-3		6017 $\pm$ 494	5620 $\pm$ 795	4647-6593.
STW-499	Water	May 1987	Sr-89 Sr-90		38.0 $\pm$ 6.0 21.0 $\pm$ 2.0	41.0 $\pm$ 5.0 20.0 $\pm$ 1.5	32.3-49.7 17.4-22.6
STW-500	Water	May 1987	Gr. alpha Gr. beta		9.0 $\pm$ 3.4 10.3 $\pm$ 1.2	11.0 $\pm$ 5.0 7.0 $\pm$ 5.0	2.3-19.7 0.0-15.7
STW-501	Water	June 1987	Cr-51 Co-60 Zn-65 Ru-106 Cs-134 Cs-137		40.0 $\pm$ 8.0 60.3 $\pm$ 3.0 11.3 $\pm$ 5.0 78.3 $\pm$ 6.4 36.7 $\pm$ 3.0 80.3 $\pm$ 4.2	41.0 $\pm$ 5.0 64.0 $\pm$ 5.0 10.0 $\pm$ 5.0 75.0 $\pm$ 5.0 40.0 $\pm$ 5.0 80.0 $\pm$ 5.0	32.3-49.7 55.3-72.7 1.3-18.7 66.3-83.7 31.3-48.7 71.3-88.7
STW-502	Water	June 1987	H-3		2906 $\pm$ 86	2895 $\pm$ 357	2277-3513
STW-503	Water	June 1987	Ra-226 Ra-228		6.9 $\pm$ 0.1 13.3 $\pm$ 1.0	7.3 $\pm$ 1.1 15.2 $\pm$ 2.3	5.4-9.2 11.2-19.2
STM-504	Milk	June 1987	Sr-89 Sr-90 I-131 Cs-137 K		57.0 $\pm$ 4.3 32.0 $\pm$ 1.0 64.0 $\pm$ 2.0 77.7 $\pm$ 0.6 1383 $\pm$ 17	69.0 $\pm$ 5.0 35.0 $\pm$ 1.5 59.0 $\pm$ 6.0 74.0 $\pm$ 5.0 1525 $\pm$ 76	60.3-77.7 32.4-37.6 48.6-69.4 65.3-82.7 1393-1657
STW-505	Water	July 1987	Gr. alpha Gr. beta		2.3 $\pm$ 0.7 4.0 $\pm$ 1.0	5.0 $\pm$ 5.0 5.0 $\pm$ 5.0	0.0-13.7 0.0-13.7
STF-506	Food	July 1987	I-131 Cs-137 K		82.7 $\pm$ 4.6 53.7 $\pm$ 3.0 1548 $\pm$ 57	80.0 $\pm$ 8.0 50.0 $\pm$ 5.0 1680 $\pm$ 84	66.1-93.9 41.3-58.7 1534-1826
STW-507	Water	Aug 1987	I-131		45.7 $\pm$ 4.2	48.0 $\pm$ 6.0	37.6-58.4
STW-508	Water	Aug 1987	Pu-239		5.8 $\pm$ 0.2	5.3 $\pm$ 0.5	4.4-6.2

Table A-1. (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/lb		
				TIML Result $\pm 2\sigma^c$	1s, N=1	EPA Result <sup>d</sup> Control Limits
STW-509	Water	Aug 1987	Uranium	13.3 $\pm$ 0.3	13.0 $\pm$ 6.0	2.6-23.4
STAF-510	Air Filter	Aug 1987	Gr. alpha	9.7 $\pm$ 0.4	10.0 $\pm$ 5.0	1.3-18.7
			Gr. beta	28.3 $\pm$ 0.6	30.0 $\pm$ 5.0	21.3-38.7
			Sr-90	10.0 $\pm$ 0.9	10.0 $\pm$ 1.5	7.4-12.6
			Cs-137	10.0 $\pm$ 1.0	10.0 $\pm$ 5.0	1.3-18.7
STW-511	Water	Sept 1987	Ra-226	9.9 $\pm$ 0.1	9.7 $\pm$ 1.5	7.2-12.2
			Ra-228	8.1 $\pm$ 1.4	6.3 $\pm$ 1.0	4.6-8.0
STW-512	Water	Sept 1987	Gr. alpha	2.0 $\pm$ 0.6	4.0 $\pm$ 5.0	0.0-12.7
			Gr. beta	11.3 $\pm$ 1.3	12.0 $\pm$ 5.0	3.3-20.7
STW-513	Water	Oct 1987	H-3	4473 $\pm$ 100	4492 $\pm$ 449	3714-5270
STW-514	Water (Blind)		Sample A	Gr. alpha	29.3 $\pm$ 2.6	28.0 $\pm$ 7.0
				Ra-226	4.9 $\pm$ 0.1	4.8 $\pm$ 0.7
				Ra-228	4.2 $\pm$ 1.0	3.6 $\pm$ 0.5
				Uranium	3.0 $\pm$ 0.1	3.0 $\pm$ 6.0
			Sample B	Sr-89	14.3 $\pm$ 1.3	16.0 $\pm$ 0
				Sr-90	9.7 $\pm$ 0.4	10.0 $\pm$ 1.5
STW-516	Water	Oct 1987	Co-60	16.7 $\pm$ 3.0	16.0 $\pm$ 5.0	7.3-24.7
			Cs-134	16.7 $\pm$ 2.3	16.0 $\pm$ 5.0	7.3-24.7
			Cs-137	24.3 $\pm$ 3.3	24.0 $\pm$ 5.0	15.3-32.7
			Cr-51	80.3 $\pm$ 17.5	70.0 $\pm$ 5.0	61.3-78.7
			Zn-65	16.0 $\pm$ 2.3	15.0 $\pm$ 5.0	6.3-23.7
			Ru-106	46.3 $\pm$ 6	46.0 $\pm$ 5.0	37.3-54.7
			Cs-134	23.7 $\pm$ 2.5	25.0 $\pm$ 5.0	16.3-33.7
STU-517	Urine	Nov 1987	Cs-137	51.7 $\pm$ 3.2	51.0 $\pm$ 5.0	42.3-59.7
			H-3	7267 $\pm$ 100	7432 $\pm$ 743	6145-8719
STW-518	Water	Nov 1987	Gr. alpha	3.0 $\pm$ 0	7.0 $\pm$ 5.0	0.0-15.7
			Gr. beta	15.7 $\pm$ 2.3	19.0 $\pm$ 5.0	10.3-27.7
STW-519	Water	Dec 1987	I-131	26.0 $\pm$ 3.0	26.0 $\pm$ 6.0	15.6-36.4

Table A-1. (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/lb		
				TIML Result $\pm 2\sigma^c$	EPA Resultd 1s, N=1	Control Limits
STW-520	Water	Dec 1987	Ra-226 Ra-228	5.1 $\pm$ 0.8 3.4 $\pm$ 0.1	4.8 $\pm$ 0.7 5.3 $\pm$ 0.8	3.6-6.0 3.9-6.7
STW-521	Water	Jan 1988	Sr-89 Sr-90	27.3 $\pm$ 5.0 15.3 $\pm$ 1.2	30.0 $\pm$ 5.0 15.0 $\pm$ 1.5	21.3-38.7 12.4-17.6
STW-523	Water	Jan 1988	Gr. alpha Gr. beta	2.3 $\pm$ 1.2 7.7 $\pm$ 1.2	4.0 $\pm$ 5.0 8.0 $\pm$ 5.0	0.0-12.7 0.0-16.7
STF-524	Feed	Jan 1988	Sr-89 Sr-90 I-131 Cs-137 K	44.0 $\pm$ 4.0 53.0 $\pm$ 2.0 102.3 $\pm$ 4.2 95.7 $\pm$ 6.4 1011 $\pm$ 158	46.0 $\pm$ 5.0 55.0 $\pm$ 2.8 102.0 $\pm$ 10.2 91.0 $\pm$ 5.0 1230 $\pm$ 62	37.3-54.7 50.2-59.8 84.3-119.7 82.3-99.7 1124-1336
STW-525	Water	Feb 1988	Co-60 Zn-65 Ru-106 Cs-134 Cs-137	69.3 $\pm$ 2.3 99.0 $\pm$ 3.4 92.7 $\pm$ 14.4 61.7 $\pm$ 8.0 99.7 $\pm$ 3.0	69.0 $\pm$ 5.0 94.0 $\pm$ 9.4 105.0 $\pm$ 10.5 64.0 $\pm$ 5.0 94.0 $\pm$ 5.0	60.3-77.7 77.7-110.3 86.8-123.2 55.3-72.7 85.3-102.7
STW-526	Water	Feb 1988	H-3	3453 $\pm$ 103	3327 $\pm$ 362	2700-3954
STW-527	Water	Feb 1988	Uranium	3.0 $\pm$ 0.0	3.0 $\pm$ 5.0	0.0-13.4
STM-528	Milk	Feb 1988	I-131	4.7 $\pm$ 1.2	4.0 $\pm$ 0.4	3.3-4.7
STW-529	Water	Mar 1988	Ra-226 Ra-228	7.1 $\pm$ 0.6 NA <sup>e</sup>	7.6 $\pm$ 1.1 7.7 $\pm$ 1.2	5.6-9.6 5.7-9.7
STW-530	Water	Mar 1988	Gr. alpha Gr. beta	4.3 $\pm$ 1.2 13.3 $\pm$ 1.3	6.0 $\pm$ 5.0 13.0 $\pm$ 5.0	0.0-14.7 4.3-21.7
STAF-531	Air Filter	Mar 1988	Gr. alpha Gr. beta Sr-90 Cs-137	21.0 $\pm$ 2.0 48.0 $\pm$ 0.0 16.7 $\pm$ 1.2 18.7 $\pm$ 1.3	20.0 $\pm$ 5.0 50.0 $\pm$ 5.0 17.0 $\pm$ 1.5 16.0 $\pm$ 5.0	11.3-28.7 41.3-58.7 14.4-19.6 7.3-24.7
STW-532	Water	Apr 1988	I-131	9.0 $\pm$ 2.0	7.5 $\pm$ 0.8	6.2-8.8

Table A-1. (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/lb		
				$\pm 2\sigma$	Is, N=1	EPA Result Control Limits
STW-533 534	Water (Blind)	Apr 1988				
	Sample A		Gr. alpha	ND	46.0 $\pm$ 11.0	27.0-65.0
			Ra-226	ND	6.4 $\pm$ 1.0	4.7-8.1
			Ra-228	ND	5.6 $\pm$ 0.8	4.2-7.0
			Uranium	6.1 $\pm$ 0.0	6.0 $\pm$ 6.0	0.0-16.4
	Sample B		Gr. beta	ND	57.0 $\pm$ 5.0	48.3-65.7
			Sr-89	3.3 $\pm$ 1.2	5.0 $\pm$ 5.0	0.0-13.7
			Sr-90	5.3 $\pm$ 1.2	5.0 $\pm$ 1.5	2.4-7.6
			Co-60	63.3 $\pm$ 1.3	50.0 $\pm$ 5.0	41.3-58.7
			Cs-134	7.7 $\pm$ 1.2	7.0 $\pm$ 5.0	0.0-15.7
			Cs-137	8.3 $\pm$ 1.2	7.0 $\pm$ 5.0	0.0-15.7
STU-535	Urine	Apr 1988	H-3	6483 $\pm$ 155	6202 $\pm$ 620	5128-7276
STW-536	Water	Apr 1988	Sr-89	14.7 $\pm$ 1.3	20.0 $\pm$ 5.0	11.3-28.7
			Sr-90	20.0 $\pm$ 2.0	20.0 $\pm$ 1.5	17.4-22.6
STW-538	Water	June 1988	Cr-51	331.7 $\pm$ 13.0	302.0 $\pm$ 30.0	250.0-354.0
			Co-60	16.0 $\pm$ 2.0	15.0 $\pm$ 5.0	6.3-23.7
			Zn-65	107.7 $\pm$ 11.4	101.0 $\pm$ 10.0	83.7-118.3
			Ru-106	191.3 $\pm$ 11.0	195.0 $\pm$ 20.0	160.4-229.6
			Cs-134	18.3 $\pm$ 4.6	20.0 $\pm$ 5.0	11.3-28.7
			Cs-137	26.3 $\pm$ 1.2	25.0 $\pm$ 5.0	16.3-33.7
STW-539	Water	June 1988	H-3	5586 $\pm$ 92	5565 $\pm$ 557	4600-6530
STM-541	Milk	June 1988	Sr-89	33.7 $\pm$ 11.4	40.0 $\pm$ 5.0	31.3-48.7
			Sr-90	55.3 $\pm$ 5.8	60.0 $\pm$ 3.0	54.8-65.2
			I-131	103.7 $\pm$ 3.1	94.0 $\pm$ 9.0	78.4-109.6
			Cs-137	52.7 $\pm$ 3.1	51.0 $\pm$ 5.0	42.3-59.7
			K	1587 $\pm$ 23	1600 $\pm$ 80	1461-1739
STW-542	Water	July 1988	Gr. alpha	8.7 $\pm$ 4.2	15.0 $\pm$ 5.0	6.3-23.7
			Gr. beta	5.3 $\pm$ 1.2	4.0 $\pm$ 5.0	0.0-12.7
STF-543	Food	July 1988	Sr-89	ND	33.0 $\pm$ 5.0	24.3-41.7
			Sr-90	ND	34.0 $\pm$ 2.0	30.5-37.5
			I-131	115.0 $\pm$ 5.3	107.0 $\pm$ 11.0	88.0-126.0
			Cs-137	52.7 $\pm$ 6.4	49.0 $\pm$ 5.0	40.3-57.7
			K	1190 $\pm$ 66	1240 $\pm$ 62	1133-1347

Table A-1. (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/lb				
				TIML Result $\pm 2\sigma^c$	Is, N=1	EPA Result <sup>d</sup> Control Limits		
STW-544	Water	Aug 1988	I-131	80.0 $\pm$ 0.0	76.0 $\pm$ 8.0	62.1-89.9		
STW-545	Water	Aug 1988	Pu-239	11.0 $\pm$ 0.2	10.2 $\pm$ 1.0	8.5-11.9		
STW-546	Water	Aug 1988	Uranium	6.0 $\pm$ 0.0	6.0 $\pm$ 6.0	0.0-16.4		
STAF-547	Air Filter	Aug 1988	Gr. alpha	8.0 $\pm$ 0.0	8.0 $\pm$ 5.0	0.0-16.7		
			Gr. beta	26.3 $\pm$ 1.2	29.0 $\pm$ 5.0	20.3-37.7		
			Sr-90	8.0 $\pm$ 2.0	8.0 $\pm$ 1.5	5.4-10.6		
			Cs-137	13.0 $\pm$ 2.0	12.0 $\pm$ 5.0	3.3-20.7		
STW-548	Water	Sep 1988	Ra-226	9.3 $\pm$ 0.5	8.4 $\pm$ 2.6	6.2-10.6		
			Ra-228	5.8 $\pm$ 0.4	5.4 $\pm$ 1.6	4.0-6.8		
STW-549	Water	Sep 1988	Gr. alpha	7.0 $\pm$ 2.0	8.0 $\pm$ 5.0	0.0-16.7		
			Gr. beta	11.3 $\pm$ 1.2	10.0 $\pm$ 5.0	1.3-18.7		
STW-550	Water	Oct 1988	Cr-51	252.0 $\pm$ 14.0	251.0 $\pm$ 25.0	207.7-294.3		
			Co-60	26.0 $\pm$ 2.0	25.0 $\pm$ 5.0	16.3-33.7		
			Zn-65	158.3 $\pm$ 10.2	151.0 $\pm$ 15.0	125.0-177.0		
			Ru-106	153.0 $\pm$ 9.2	152.0 $\pm$ 15.0	126.0-178.0		
			Cs-134	28.7 $\pm$ 5.0	25.0 $\pm$ 5.0	16.3-33.7		
			Cs-137	16.3 $\pm$ 1.2	15.0 $\pm$ 5.0	6.3-23.7		
STW-551	Water	Oct 1988	H-3	2333 $\pm$ 127	2316 $\pm$ 350	1710-2927		
STW-552 553	Water (Blind)	Oct 1988	Sample A	Gr. alpha Ra-226 Ra-228 Uranium	41.0 $\pm$ 10.0 5.0 $\pm$ 0.8 5.2 $\pm$ 0.8 5.0 $\pm$ 6.0	23.7-58.3 3.6-6.4 3.6-6.4 0.0-15.4		
STW-552 553			Sample B	Gr. beta Sr-89 Sr-90 Cs-134 Cs-137	54.0 $\pm$ 5.0 11.0 $\pm$ 5.0 10.0 $\pm$ 1.5 15.0 $\pm$ 5.0 15.0 $\pm$ 5.0	45.3-62.7 2.3-19.7 7.4-12.6 6.3-23.7 6.3-23.7		

Table A-1. (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l <sup>b</sup>		
				TIML Result $\pm 2\sigma^c$	Is, N=1	EPA Result <sup>d</sup> Control Limits
STM-554	Milk	Oct 1988	Sr-89	40.3 $\pm$ 7.0	40.0 $\pm$ 5.0	31.3-48.7
			Sr-90	51.0 $\pm$ 2.0	60.0 $\pm$ 3.0	54.8-65.2
			I-131	94.0 $\pm$ 3.4	91.0 $\pm$ 9.0	75.4-106.6
			Cs-137	45.0 $\pm$ 4.0	50.0 $\pm$ 5.0	41.3-58.7
			K	1500 $\pm$ 45	1600 $\pm$ 80	1461-1739
STU-555	Urine	Nov 1988	H-3	3030 $\pm$ 209	3025 $\pm$ 359	2403-3647
STW-556	Water	Nov 1988	Gr. alpha	9.0 $\pm$ 3.5	9.0 $\pm$ 5.0	0.3-17.7
			Gr. beta	9.7 $\pm$ 1.2	9.0 $\pm$ 5.0	0.3-17.7
STW-557	Water	Dec 1988	I-131	108.7 $\pm$ 3.0	115.0 $\pm$ 12.0	94.2-135.8
STW-559	Water	Jan 1989	Sr-89	40.0 $\pm$ 8.7	40.0 $\pm$ 5.0	31.3-48.7
			Sr-90	24.3 $\pm$ 3.1	25.0 $\pm$ 1.5	22.4-27.6
STW-560	Water	Jan 1989	Pu-239	5.8 $\pm$ 1.1	4.2 $\pm$ 0.4	3.5-4.9
STW-561	Water	Jan 1989	Gr. alpha	7.3 $\pm$ 1.2	8.0 $\pm$ 5.0	0.0-16.7
			Gr. beta	5.3 $\pm$ 1.2	4.0 $\pm$ 5.0	0.0-12.7
STW-562	Water	Feb 1989	Cr-51	245 $\pm$ 46	235 $\pm$ 24	193.4-276.6
			Co-60	10.0 $\pm$ 2.0	10.0 $\pm$ 5.0	1.3-18.7
			Zn-65	170 $\pm$ 10	159 $\pm$ 16	139.2-186.7
			Ru-106	181 $\pm$ 7.6	178 $\pm$ 18	146.8-209.2
			Cs-134	9.7 $\pm$ 3.0	10.0 $\pm$ 5.0	1.3-18.7
			Cs-137	11.7 $\pm$ 1.2	10.0 $\pm$ 5.0	1.3-18.7

Table A-1. (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l <sup>b</sup>		
				TIML Result $\pm 2\sigma^c$	ls, N=1	EPA Result <sup>d</sup> Control Limits
STW-563	Water	Feb 1989	I-131	109.0 $\pm$ 4.0	106.0 $\pm$ 11.0	86.9-125.1
STW-564	Water	Feb 1989	H-3	2820 $\pm$ 20	2754 $\pm$ 356	2137-3371
STW-565	Water	Mar 1989	Ra-226	4.2 $\pm$ 0.3	4.9 $\pm$ 0.7	3.7-6.1
			Ra-228	1.9 $\pm$ 1.0	1.7 $\pm$ 0.3	1.2-2.2
STW-566	Water	Mar 1989	U	5.0 $\pm$ 0.0	5.0 $\pm$ 6.0	0.0-15.4
STW-567	AirFilter	Mar 1989	Gr. alpha	21.7 $\pm$ 1.2	21.0 $\pm$ 5.0	12.3-29.7
			Gr. beta	68.3 $\pm$ 4.2	62.0 $\pm$ 5.0	53.3-70.7
			Sr-90	20.0 $\pm$ 2.0	20.0 $\pm$ 1.5	17.4-22.6
			Cs-137	21.3 $\pm$ 1.2	20.0 $\pm$ 5.0	11.3-28.7
STW-568	Water	Apr 1989				
569	(Blind)		Sample A			
			Gr. alpha	22.7 $\pm$ 2.3	29.0 $\pm$ 7.0	16.9-41.2
			Ra-226	3.6 $\pm$ 0.6	3.5 $\pm$ 0.5	2.6-4.4
			Ra-228	2.6 $\pm$ 1.0	3.6 $\pm$ 0.5	2.7-4.5
			U	3.0 $\pm$ 0.0	3.0 $\pm$ 6.0	0.0-13.4
		Sample B	Gr. beta	52.3 $\pm$ 6.1	57.0 $\pm$ 5.0	43.3-65.7
			Sr-89	5.0 $\pm$ 5.4	8.0 $\pm$ 5.0	0.0-16.7
			Sr-90	7.0 $\pm$ 0.0	8.0 $\pm$ 1.5	5.4-10.6
			Cs-134	21.0 $\pm$ 5.2	20.0 $\pm$ 5.0	11.3-28.7
			Cs-137	23.0 $\pm$ 2.0	20.0 $\pm$ 5.0	11.3-28.7
STM-570	Milk	Apr 1989	Sr-89	26.0 $\pm$ 10.0	39.0 $\pm$ 5.0	30.3-47.7
			Sr-90	45.7 $\pm$ 4.2	55.0 $\pm$ 3.0	49.8-60.2
			Cs-137	54.0 $\pm$ 6.9	50.0 $\pm$ 5.0	41.3-58.7
			K-40	1521 $\pm$ 208	1600 $\pm$ 80	1461-1739

Table A-1. (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l <sup>b</sup>		
				TIML Result $\pm 2\sigma^c$	1s, N=1	EPA Result <sup>d</sup> Control Limits
STW-571 <sup>g</sup>	Water	May 1989	Sr-89	4.0.7	6.0±5.0	0.0-14.7
			Sr-90	5.0±1.0	6.0±1.5	3.4-8.6
STW-572	Water	May 1989	Gr. alpha	24.0±2.0	30.0±8.0	16.1-43.9
			Gr. beta	49.3±15.6	50.0±5.0	41.3-58.7
STW-573	Water	Jun 1989	Ba-133	50.7±1.2	49.0±5.0	40.3-57.7
			Co-60	31.3±2.3	31.0±5.0	22.3-39.7
			Zn-65	167±10	165±17	135.6-194.4
			Ru-106	123±9.2	128±13	105.5-150.5
			Cs-134	40.3±1.2	39±5	30.3-47.7
			Cs-137	22.3±1.2	20±5	11.3-28.7
STW-574	Water	Jun 1989	H-3	4513±136	4503±450	3724-5282
STW-575	Water	Jul 1989	Ra-226	16.8±3.1	17.7±2.7	13.0-22.4
			Ra-228	13.8±3.7	18.3±2.7	13.0-22.4
STW-576	Water	Jul 1989	J	40.3±1.2	41.0±6.0	30-40
STW-577	Water	Aug 1989	I-131	84.7±5.8	83.0±8.0	69.1-91.3
STW-579	Air Filter	Aug 1989	Gr. alpha	6.0±0.0	6.0±5.0	0.0-14.7
			Cs-137	10.3±2.3	10.0±5.0	1.3-18.7
STW-580	Water	Sep 1989	Sr-89	14.7±1.2	14.0±5.0	5.3-22.7
			Sr-90	9.7±1.2	10.0±1.5	7.4-12.6
STW-581	Water	Sep 1989	Gr. alpha	5.0±0.0	4.0±5.0	0.0-12.7
			Gr. Beta	8.7±2.3	6.0±5.0	0.0-14.7

Table A-1. (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l <sup>b</sup>		
				$\pm 2\sigma^c$	EPA Result <sup>d</sup> 1s, N=1	Control Limits
STW-583	Water	Oct 1989	Ba-133	60.3 $\pm$ 10.0	59.0 $\pm$ 6.0	48.6-69.4
			Co-60	29.0 $\pm$ 4.0	30.0 $\pm$ 5.0	21.3-38.7
			Zn-65	132.3 $\pm$ 6.0	129.0 $\pm$ 13.0	106.5-151.5
			Ru-106	155.3 $\pm$ 6.1	161.0 $\pm$ 16.0	133.3-188.7
			Cs-134	30.7 $\pm$ 6.1	29.0 $\pm$ 5.0	20.3-37.7
			Cs-137	66.3 $\pm$ 4.6	59.0 $\pm$ 5.0	50.3-67.7
STW-584	Water	Oct 1989	H-3	3407 $\pm$ 150	3496 $\pm$ 364	2866-4126
STW-585 586	Water (Blind)	Oct 1989				
	Sample A		Gr. Alpha	41.7 $\pm$ 9.4	49.0 $\pm$ 12.0	28.2-69.8
			Ra-226	7.9 $\pm$ 0.4	8.4 $\pm$ 1.3	6.2-10.6
			Ra-228	4.4 $\pm$ 0.8	4.1 $\pm$ 0.6	3.1-5.1
			U	12.0 $\pm$ 0.0	12.0 $\pm$ 6.0	1.6-22.4
	Sample B		Gr. Beta	31.7 $\pm$ 2.3	32.0 $\pm$ 5.0	23.3-40.7
			Sr-89	13.3 $\pm$ 4.2	15.0 $\pm$ 5.0	6.3-23.7
			Sr-90	7.0 $\pm$ 2.0	7.0 $\pm$ 3.0	4.4-9.6
			Cs-134	5.0 $\pm$ 0.0	5.0 $\pm$ 5.0	0.0-13.7
			Cs-137	7.0 $\pm$ 0.0	5.0 $\pm$ 5.0	0.0-13.7
STW-587	Water	Nov 1989	Ra-226	7.9 $\pm$ 0.4	8.7 $\pm$ 1.3	6.4-11.0
			Ra-228	8.9 $\pm$ 1.2	9.3 $\pm$ 1.2	6.9-11.7
STW-588	Water	Nov 1989	U	15.0 $\pm$ 0.09	15.0 $\pm$ 6.0	4.6-25.4

a Results obtained by Teledyne Isotopes Midwest Laboratory as a participant in the environmental sample crosscheck program operated by the Intercomparison and Calibration Section, Quality Assurance Branch, Environmental Monitoring and Support Laboratory, U.S. Environmental Protection Agency (EPA), Las Vegas, Nevada.

b All results are in the pCi/l, except for elemental potassium (K) data in milk, which are in mg/l; air filter samples, which are in pCi/filter; and food, which is in mg/kg.

c Unless otherwise indicated, the TIML results are given as the mean  $\pm$  2 standard deviations for three determinations.

d USEPA results are presented as the known values and expected laboratory precision (1s, 1 determination) and control limits as defined by EPA.

e NA = Not analyzed.

f ND = No data. Not analyzed due to relocation of the lab.

g Sample was analyzed but the results not submitted to EPA because deadline was missed.

Table A-2. Crosscheck program results, thermoluminescent dosimeters (TLDs).

Lab Code	TLD Type	Measurement	Teledyne Result $\pm 2\sigma^a$	mR Known Value <sup>c</sup>	Average $\pm 2 \sigma^d$ (all participants)
<b>2nd International Intercomparison<sup>b</sup></b>					
115-2	CaF <sub>2</sub> :Mn Bulb	Field	17.0 $\pm$ 1.9	17.1	16.4 $\pm$ 7.7
		Lab	20.8 $\pm$ 4.1	21.3	18.8 $\pm$ 7.6
<b>3rd International Intercomparison<sup>e</sup></b>					
115-3	CaF <sub>2</sub> :Mn Bulb	Field	30.7 $\pm$ 3.2	34.9 $\pm$ 4.8	31.5 $\pm$ 3.0
		Lab	89.6 $\pm$ 6.4	91.7 $\pm$ 14.6	86.2 $\pm$ 24.0
<b>4th International Intercomparison<sup>f</sup></b>					
115-4	CaF <sub>2</sub> :Mn Bulb	Field	14.1 $\pm$ 1.1	14.1 $\pm$ 1.4	16.0 $\pm$ 9.0
		Lab (Low)	9.3 $\pm$ 1.3	12.2 $\pm$ 2.4	12.0 $\pm$ 7.6
		Lab (High)	40.4 $\pm$ 1.4	45.8 $\pm$ 9.2	43.9 $\pm$ 13.2
<b>5th International Intercomparison<sup>g</sup></b>					
115-5A	CaF <sub>2</sub> :Mn Bulb	Field	31.4 $\pm$ 1.8	30.0 $\pm$ 6.0	30.2 $\pm$ 14.6
		Lab at beginning	77.4 $\pm$ 5.8	75.2 $\pm$ 7.6	75.8 $\pm$ 40.4
		Lab at end	96.6 $\pm$ 5.8	88.4 $\pm$ 8.8	90.7 $\pm$ 31.2

Table A-2. (Continued)

Lab Code	TLD Type	Measurement	Teledyne Result $\pm 2\sigma^a$	Known Value <sup>c</sup>	mR	Average $\pm 2\sigma^d$ (all participants)
115-5B	LiF-100 Chips	Field	30.3 $\pm$ 4.8	30.0 $\pm$ 6.0	30.2 $\pm$ 14.6	
		Lab at beginning	81.1 $\pm$ 7.4	75.2 $\pm$ 7.6	75.8 $\pm$ 40.4	
		Lab at the end	85.4 $\pm$ 11.7	88.4 $\pm$ 8.8	90.7 $\pm$ 31.2	
<u>7th International Intercomparison<sup>h</sup></u>						
115-7A	LiF-100 Chips	Field	75.4 $\pm$ 2.6	75.8 $\pm$ 6.0	75.1 $\pm$ 29.8	
		Lab (Co-60)	80.0 $\pm$ 3.5	79.9 $\pm$ 4.0	77.9 $\pm$ 27.6	
		Lab (Cs-137)	66.6 $\pm$ 2.5	75.0 $\pm$ 3.8	73.0 $\pm$ 22.2	
115-7B	CaF <sub>2</sub> :Mn Bulbs	Field	71.5 $\pm$ 2.6	75.8 $\pm$ 6.0	75.1 $\pm$ 29.8	
		Lab (Co-60)	84.8 $\pm$ 6.4	79.9 $\pm$ 4.0	77.9 $\pm$ 27.6	
		Lab (Cs-137)	78.8 $\pm$ 1.6	75.0 $\pm$ 3.8	73.0 $\pm$ 22.2	
115-7C	CaSO <sub>4</sub> :By Cards	Field	76.8 $\pm$ 2.7	75.8 $\pm$ 6.0	75.1 $\pm$ 29.8	
		Lab (Co-60)	82.5 $\pm$ 3.7	79.9 $\pm$ 4.0	77.9 $\pm$ 27.6	
		Lab (Cs-137)	79.0 $\pm$ 3.2	75.0 $\pm$ 3.8	73.0 $\pm$ 22.2	

Table A-2. (Continued)

Lab Code	TLD Type	Measurement	Teledyne	Known Value <sup>C</sup>	Average $\pm 2\sigma$ <sup>d</sup> (all participants)
			Result $\pm 2\sigma^a$		mR
<b>8th International Intercomparison<sup>i</sup></b>					
115-8A	LiF-100 Chips	Field Site 1	29.5 $\pm$ 1.4	29.7 $\pm$ 1.5	28.9 $\pm$ 12.4
		Field Site 2	11.3 $\pm$ 0.8	10.4 $\pm$ 0.5	10.1 $\pm$ 9.06
		Lab (Cs-137)	13.7 $\pm$ 0.9	17.2 $\pm$ 0.9	16.2 $\pm$ 6.8
115-8B	CaF <sub>2</sub> :Mn Bulbs	Field Site 1	32.3 $\pm$ 1.2	29.7 $\pm$ 1.5	28.9 $\pm$ 12.4
		Field Site 2	9.0 $\pm$ 1.0	10.4 $\pm$ 0.5	10.1 $\pm$ 9.0
		Lab (Cs-137)	15.8 $\pm$ 0.9	17.2 $\pm$ 0.9	16.2 $\pm$ 6.8
115-8C	CaSO <sub>4</sub> :Dy Cards	Field Site 1	32.3 $\pm$ 0.7	29.7 $\pm$ 1.5	28.9 $\pm$ 12.4
		Field Site 2	10.6 $\pm$ 0.6	10.4 $\pm$ 0.5	10.1 $\pm$ 9.0
		Lab (Cs-137)	18.1 $\pm$ 0.8	17.2 $\pm$ 0.9	16.2 $\pm$ 6.8
<b>Teledyne Testing<sup>j</sup></b>					
89-1	LiF-100 Chips	Lab	21.0 $\pm$ 0.4	22.4	-
89-2	Teledyne CaSO <sub>4</sub> :Dy Cards	Lab	20.9 $\pm$ 1.0	20.3	-

<sup>a</sup> Lab result given is the mean  $\pm 2$  standard deviations of three determinations.

<sup>b</sup> Second International Intercomparison of Environmental Dosimeters conducted in April of 1976 by the Health and Safety Laboratory (GASL), New York, New York, and the School of Public Health of the University of Texas, Houston, Texas.

<sup>c</sup> Value determined by sponsor of the intercomparison using continuously operated pressurized ion chamber.

<sup>d</sup> Mean  $\pm 2$  standard deviations of results obtained by all laboratories participating in the program.

Table A-2. (continued)

Lab Code	TLD Type	Measurement	mR		
			Teledyne Result $\pm 2\sigma^a$	Known Value <sup>c</sup>	Average $\pm 2\sigma^d$ (all participants)

Footnotes continued

- e Third International Intercomparison of Environmental Dosimeters conducted in summer of 1977 by Oak Ridge National Laboratory and the School of Public Health of the University of Texas, Houston, Texas.
- f Fourth International Intercomparison of Environmental Dosimeters conducted in summer of 1979 by the School of Public Health of the University of Texas, Houston, Texas.
- g Fifth International Intercomparison of Environmental Dosimeter conducted in fall of 1980 at Idaho Falls, Idaho and sponsored by the School of Public Health of the University of Texas, Houston, Texas and Environmental Measurements Laboratory, New York, New York, U.S. Department of Energy.
- h Seventh International Intercomparison of Environmental Dosimeters conducted in the spring and summer of 1984 at Las Vegas, Nevada, and sponsored by the U.S. Department of Energy, the U.S. Nuclear Regulatory Commission, and the U.S. Environmental Protection Agency.
- i Eighth International Intercomparison of Environmental Dosimeters conducted in the fall and winter of 1985-1986 at New York, New York, and sponsored by the U.S. Department of Energy.
- j Chips were submitted in September, 1989 and cards were submitted in November, 1989 to Teledyne Isotopes, Inc., Westwood, NJ for irradiation.

Table A-3. In-house spiked samples.

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l		
				TIML Result n=3	Known Activity	Expected ls, n=3 <sup>a</sup>
QC-MI-6	Milk	Feb. 1986	Sr-89	6.0±1.9	6.4±3.0	8.7
			Sr-90	14.2±1.7	12.9±2.0	5.2
			I-131	34.2±3.8	35.2±3.5	10.4
			Cs-134	32.0±1.8	27.3±5.0	8.7
			Cs-137	35.8±2.1	35.0±5.0	8.7
QC-W-14	Water	Mar. 1986	Sr-89	1.6±0.4	1.6±1.0	7.1
			Sr-90	2.4±0.2	2.4±2.0	4.2
QC-W-15	Water	Apr. 1986	I-131	44.9±2.4	41.5±7.0	10.6
			Co-60	10.6±1.7	12.1±5.0	7.1 <sup>b</sup>
			Cs-134	30.2±2.4	25.8±8.0	7.1 <sup>b</sup>
			Cs-137	21.9±1.9	19.9±5.0	7.1 <sup>b</sup>
QC-MI-7	Milk	Apr. 1986	I-131	39.7±3.3	41.5±7.0	10.4
			Cs-134	28.7±2.8	25.8±8.0	8.7
			Cs-137	21.2±2.8	19.9±5.0	8.7
SPW-1	Water	May 1986	Gross alpha	15.8±1.8	18.0±5.0	5 <sup>c</sup>
QC-W-16	Water	June 1986	Gross alpha	16.2±0.7	16.9±2.5	8.7
			Gross beta	38.4±3.5	30.2±5.0	8.7
QC-MI-9	Milk	June 1986	Sr-89	<1.0	0.0	7.1 <sup>b</sup>
			Sr-90	12.6±1.8	13.3±3.0	4.2 <sup>b</sup>
			I-131	38.9±7.0	34.8±7.0	10.4
			Cs-134	33.0±3.4	36.1±5.0	8.7
			Cs-137	38.5±2.8	39.0±5.0	8.7
SPW-2	Water	June 1986	Gross alpha	16.8±1.8	18.0±5.0	5 <sup>c</sup>
SPW-3	Water	June 1986	Gross alpha	17.7±0.8	18.0±5.0	5 <sup>c</sup>
QC-W-18	Water	Sep. 1986	Cs-134	34.7±5.6	31.3±5.0	8.7
			Cs-137	51.1±7.0	43.3±8.0	8.7
QC-W-19	Water	Sep. 1986	Sr-89	13.6±4.1	15.6±3.5	7.1 <sup>b</sup>
			Sr-90	6.4±1.6	6.2±2.0	4.2 <sup>b</sup>

Table A-3. In-house spiked samples (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l		
				TIML Result n=3	Known Activity	Expected Precision 1s, n=3 <sup>a</sup>
QC-W-21	Water	Oct. 1986	C -60	19.2±2.2	18.5±3.0	8.7
			Cs-134	31.7±5.2	25.6±8.0	8.7
			Cs-137	23.8±1.0	21.6±5.0	8.7
QC-MI-11	Milk	Oct 1986	Sr-89	12.3±1.8	14.3±3.0	8.7
QC-W-20	Water	Nov. 1986	H-3	3855±180	3960±350	520 <sup>b</sup>
QC-W-22	Water	Dec. 1986	Gross alpha	9.8±1.4	11.2±4.0	8.7
			Gross beta	21.7±2.0	23.8±5.0	8.7
QC-W-23	Water	Jan. 1987	I-131	29.8±2.5	27.9±3.0	10.4
QC-MI-12	Milk	Jan. 1987	I-131	36.5±1.3	32.6±5.0	10.4
			Cs-137	32.6±4.2	27.4±8.0	8.7
QC-MI-13	Milk	Jan 1987	Sr-89	10.4±2.1	12.2±4.0	8.7
			Sr-90	14.6±1.6	12.6±3.0	5.2
			I-131	49.5±1.2	54.9±8.0	10.4
			Cs-134	41.6	0.0	8.7
			Cs-137	33.3±0.6	27.4±8.0	8.7
QC-W-24	Water	Mar 1987	Sr-89	24.7±3.6	25.9±5.0	8.7
			Sr-90	23.9±3.8	22.8±8.0	5.2
QC-W-25	Water	Apr 1987	I-131	28.0±1.9	29.3±5.0	10.6
QC-MI-14	Milk	Apr 1987	I-131	25.0±2.2	23.9±5.0	10.4
			Cs-134	42.1	0.0	8.7
			Cs-137	34.2±2.0	27.2±7.0	8.7
QC-W-26	Water	Jun 1987	H-3	3422±100	3362±300	520
			Co-60	24.8±1.4	26.5±7.0	8.7
			Cs-134	42.0	0.0	8.7
			Cs-137	21.2±0.5	21.6±7.0	8.7
QC-W-27	Water	Jun 1987	Gr. alpha	8.5±1.9	10.1±4.0	8.7
			Gr. beta	22.6±1.9	21.2±5.0	8.7
QC-W-28	Water	Jun 1987	Gr. alpha	8.7±1.3	10.1±4.0	8.7
			Gr. beta	12.2±5.2	9.4±3.0	8.7

Table A-3. In-house spiked samples (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l		
				TIML Result n=3	Known Activity	Expected Precision ls, n=3 <sup>a</sup>
QC-W-29	Water	Jun 1987	Gr. alpha Gr. beta	16.4±1.3 15.9±4.0	18.9±5.0 11.8±4.0	8.7 8.7
QC-MI-15	Milk	Jul 1987	Sr-90 I-131 Cs-134 Cs-137	19.4±1.6 43.5±0.7 17.9±2.2 25.4±1.8	18.8±3.5 45.3±7.0 16.0±5.3 22.7±5.0	5.2 10.4 8.7 8.7
QC-W-30	Water	Sep 1987	Sr-89 Sr-90	17.5±3.0 18.4±2.2	14.3±5.0 17.5±2.2	8.7 5.2
QC-W-31	Water	Oct 1987	H-3	2053±939	2059±306	520
QC-W-32	Water	Dec 1987	Gr. alpha Gr. beta	8.6±1.0 15.2±0.1	10.1±5.0 13.1±3.0	8.7 8.7
QC-W-33	Water	Dec 1987	Gr. alpha Gr. beta	7.7±1.4 10.9±1.0	10.1±5.0 7.9±3.0	8.7 8.7
QC-W-34	Water	Dec 1987	Gr. alpha Gr. beta	4.0±0.9 9.4±0.9	5.1±3.0 7.9±3.0	8.7 8.7
QC-MI-16	Milk	Feb 1988	Sr-89 Sr-90 I-131 Cs-134 Cs-137	31.8±4.7 25.5±2.7 26.4±0.5 23.8±2.3 26.5±0.8	31.7±6.0 27.8±3.5 23.2±5.0 24.2±6.0 25.1±6.0	8.7 5.2 10.4 8.7 8.7
QC-MI-17	Milk	Feb 1988	I-131	10.6±1.2	14.3±1.6	10.4
QC-W-35	Water	Feb 1988	I-131	9.7±1.1	11.6±1.1	10.4
QC-W-36	Water	Feb 1988	I-131	10.5±1.3	11.6±1.0	10.4
QC-W-37	Water	Mar 1988	Sr-89 Sr-90	17.1±2.0 18.7±0.9	19.8±8.0 17.3±5.0	8.7 5.2
QC-MI-18	Milk	Mar 1988	I-131 Cs-134 Cs-137	33.2±2.3 31.3±2.1 29.9±1.4	26.7±5.0 30.2±5.0 26.2±5.0	10.4 8.7 8.7

Table A-3. In-house spiked samples (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l		
				TIML Result n=3	Known Activity	Expected Precision ls, n=3 <sup>a</sup>
QC-W-38	Water	Apr 1988	I-131	17.1±1.1	14.2±5.0	10.4
QC-W-39	Water	Apr 1988	H-3	4439±31	4176±500	724
QC-W-40	Water	Apr 1988	Co-60 Cs-134 Cs-137	23.7±0.5 25.4±2.6 26.6±2.3	26.1±4.0 29.2±4.5 26.2±4.0	8.7 8.7 8.7
QC-W-41	Water	Jun 1988	Gr. alpha Gr. beta	12.3±0.4 22.6±1.0	13.1±5.0 20.1±5.0	8.7 8.7
QC-MI-19	Milk	Jul 1988	Sr-89 Sr-90 I-131 Cs-137	15.1±1.6 18.0±0.6 88.4±4.9 22.7±0.8	16.4±5.0 18.3±5.0 86.6±8.0 20.8±6.0	8.7 5.2 10.4 8.7
QC-W-42	Water	Sep 1988	Sr-89 Sr-90	48.5±3.3 10.9±1.0	50.8±8.0 11.4±3.5	8.7 5.2
QC-W-43	Water	Oct 1988	Co-60 Cs-134 Cs-137	20.9±3.2 38.7±1.6 19.0±2.4	21.4±3.5 38.0±6.0 21.0±3.5	8.7 8.7 8.7
QC-W-44	Water	Oct 1988	I-131	22.2±0.6	23.3±3.5	10.4
QC-W-45	Water	Oct 1988	H-3	4109±43	4153±500	724
QC-MI-20	Milk	Oct 1988	I-131 Cs-134 Cs-137	59.8±0.9 49.6±1.8 25.8±4.6	60.6±9.0 48.6±7.5 24.7±4.0	10.4 8.7 8.7
QC-W-46	Water	Dec 1988	Gr. alpha Gr. beta	11.5±2.3 26.5±2.0	15.2±5.0 25.7±5.0	8.7 8.7
QC-MI-21	Milk	Jan 1989	Sr-89 Sr-90 I-131 Cs-134 Cs-137	25.5±10.3 28.3±3.2 540±13 24.5±2.6 24.0±0.6	34.0±10.0 27.1±3.0 550±20 22.6±5.5 20.5±5.0	8.7 5.2 10.4 8.7 8.7

Table A-3. In-house spiked samples (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l		
				TIML Result n=3	Known Activity	Expected Precision ls, n=3 <sup>a</sup>
QC-W-47	Water	Mar 1989	Sr-89	15.2±3.8	16.1±5.0	8.7
			Sr-90	16.4±1.7	16.9±3.0	5.2
QC-MI-22	Milk	Apr 1989	I-131	36.3±1.1	37.2±5.0	10.4
			Cs-134	20.8±2.8	20.7±8.0	8.7
			Cs-137	22.2±2.4	20.4±8.0	8.7
QC-W-48	Water	Apr 1989	Co-60	23.5±2.0	25.1±8.0	8.7
			Cs-134	24.2±1.1	25.9±8.0	8.7
			Cs-137	23.6±1.2	23.0±8.0	8.7
QC-W-49	Water	Apr 1989	I-131	37.2±3.7	37.2±5.0	10.4
QC-W-50	Water	Apr 1989	H-3	3011±59	3089±500	724
QC-W-51	Water	Jun 1989	Gr. alpha	13.0±1.8	15.0±5.0	8.7
			Gr. beta	26.0±1.2	25.5±8.0	8.7
QC-MI-23	Milk	Jul 1989	Sr-89	19.4±6.5	22.0±10.0	8.7
			Sr-90	27.6±3.5	28.6±3.0	5.2
			I-131	46.8±3.2	43.4±5.0	10.4
			Cs-134	27.4±1.8	28.3±6.0	8.7
			Cs-137	24.1±1.8	20.8±6.0	8.7
QC-MI-24	Milk	Aug 1989	Sr-89	25.4±2.7	27.2±10.0	8.7
			Sr-90	46.0±1.1	47.8±9.6	8.3
QC-W-52	Water	Sep 1989	I-131	9.6±0.3	9.7±1.9	10.4
QC-W-53	Water	Sep 1989	I-131	19.0±0.2	20.9±4.2	10.4
QC-W-54	Water	Sep 1989	Sr-89	25.8±4.6	24.7±4.0	8.7
			Sr-90	26.5±5.3	29.7±5.0	5.2

<sup>a</sup> n=3 unless noted otherwise.<sup>b</sup> n=2.<sup>c</sup> n=1.

Table A-3. In-house spiked samples (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l		
				TIML Result n=3	Known Activity	Expected Precision ls, n=3 <sup>a</sup>
QC-MI-25	Milk	Oct 1989	I-131	70.0±3.3	73.5±20.0	10.4
			Cs-134	22.1±2.6	22.6±8.0	8.7
			Cs-137	29.4±1.5	27.5±8.0	8.7
QC-W-55	Water	Oct 1989	I-131	33.3±1.3	35.3±10.0	10.4
QC-W-56	Water	Oct 1989	Co-60	15.2±0.9	17.4±5.0	8.7
			Cs-134	22.1±4.4	18.9±8.0	8.7
			Cs-137	27.2±1.2	22.9±8.0	8.7
QC-W-57	Water	Oct 1989	H-3	3334±22	3379±500	724
QC-W-58	Water	Nov 1989	Sr-89	10.9±1.4 <sup>d</sup>	11.1±1.0 <sup>d</sup>	8.7
			Sr-90	10.4±1.0 <sup>d</sup>	10.3±1.0 <sup>d</sup>	5.2
QC-W-59	Water	Nov 1989	Sr-89	101.0±6.0 <sup>d</sup>	104.1±10.5 <sup>d</sup>	17.5
			Sr-90	98.0±3.0 <sup>d</sup>	95.0±10.0 <sup>d</sup>	17.0
QC-W-60	Water	Dec 1989	Gr. alpha	10.8±1.1	10.6±4.0	8.7
			Gr. beta	11.6±0.5	11.4±4.0	8.7

<sup>a</sup> n=3 unless noted otherwise.<sup>b</sup> n=2.<sup>c</sup> n=1.<sup>d</sup> Concentration in pCi/ml

Table A-4. In-house "blank" samples.

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l	
				Results ( $4.66\sigma$ )	Acceptance Criteria ( $^A.66\sigma$ )
BL-1	D.I. Water	Nov. 1985	Gross alpha Gross beta	<0.1 <0.4	<1 <4
BL-2	D.I. Water	Nov. 1985	Cs-137 (gamma)	<1.9	<10
BL-3	D.I. Water	Nov. 1985	Sr-89 Sr-90	<0.5 <0.6	<5 <1
BL-5	D.I. Water	Nov. 1985	Ra-226 Ra-228	<0.4 <0.4	<1 <1
SPW-2265	D.I. Water	Apr. 1985	Gross alpha Gross beta Sr-89 Sr-90 I-131 Cs-137 (gamma)	<0.6 <2.2 <0.2 <0.4 <0.2 <7.4	<1 <4 <5 <1 <1 <10
BL-6	D.I. Water	Apr. 1986	Gross alpha	<0.4	<1
BL-7	D.I. Water	Apr. 1986	Gross alpha	<0.4	<1
BL-8	D.I. Water	June 1986	Gross alpha	<0.4	<1
BL-9	D.I. Water	June 1986	Gross alpha	<0.3	<1
SPW-3185	D.I. Water	Jan 1987	Ra-226 Ra-228	<0.1 <0.9	<1 <1
SPS-3292	Milk	Jan 1987	I-131 Cs-134 Cs-137	<0.1 <6.2 <6.4	<1 <10 <10
SPW-3554	D.I. Water	Feb 1987	H-3 Gross beta	<180 <2.6	<300 <4
SPS-3555	Milk	Feb 1987	Sr-89 Sr-90	<0.6 $1.9 \pm 0.4^a$	<5 <1
SPS-3731	Milk	Mar 1987	Cs-134 Cs-137	<2.2 <2.5	<10 <10

<sup>a</sup> Low level (1 - 5 pCi/l) of Sr-90 concentration in milk is not unusual.

Table A-4. In-house "blank" samples (continued).

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l	
				Results (4.66 $\sigma$ )	Acceptance Criteria (4.66 $\sigma$ )
SPS-3732	D.I. Water	Mar 1987	Sr-89 Sr-90 I-131 Co-60 Cs-134 Cs-137 Ra-226 Ra-228 Np-237 Th-230 Th-232 U-234 U-235 U-238	<0.9 <0.8 <0.3 <2.3 <2.2 <2.4 <0.1 <1.0 <0.04 <0.05 <0.02 <0.05 <0.03 <0.03	<5 <1 <1 <10 <10 <10 <1 <1 <1 <0.1 <0.1 <0.1 <0.1 <0.1 <0.1
SPS-4023	Milk	May 1987	I-131	<0.1	<1
SPS-4203	D.I. Water	May 1987	Gross alpha Gross beta	<0.7 <1.7	<1 <4
SPS-4204	Milk	May 1987	Sr-89 Sr-90	<0.5 $2.4 \pm 0.6^a$	<5 <1
SPS-4390	Milk	Jun 1987	Cs-134 Cs-137	<4.7 <5.2	<10 <10
SPS-4391	D.I. Water	Jun 1987	Sr-89 Sr-90 I-121 Co-60 Cs-137 Ra-226 Ra-228	<0.4 <0.4 <0.1 <3.8 <5.7 <0.1 <0.9	<5 <1 <1 <10 <10 <1 <1
SPW-4627	D.I. Water	Aug 1987	Gross alpha Gross beta Tritium	<0.6 <1.4 <150	<1 <4
SPS-4628	Milk	Aug 1987	Sr-89 Sr-90	<0.6 $2.4 \pm 0.6^a$	<5 <1
SPS-4847	Milk	Sep 1987	Cs-134 Cs-137	<4.4 <5.3	<10 <10

<sup>a</sup> Low level (1 - 5 pCi/l) of Sr-90 concentration in milk is not unusual.

Table A-4. In-house "blank" samples (continued).

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l	
				Results (4.66 $\sigma$ )	Acceptance Criteria (4.66 $\sigma$ )
SPS-4848	D.I. Water	Sep 1987	I-131	<0.2	<1
SPW-4849	D.I. Water	Sep 1987	Co-60	<4.1	<10
			Cs-134	<4.8	<10
			Cs-137	<4.0	<10
			Sr-89	<0.7	<5
			Sr-90	<0.7	<1
SPW-4850	D.I. Water	Sep 1987	Th-228	<0.04	<1
			Th-232	<0.8	<1
			U-234	<0.03	<1
			U-235	<0.03	<1
			U-238	<0.02	<1
			Am-241	<0.06	<1
			Cm-242	<0.04	<1
			Ra-226	<0.1	<1
			Ra-228	<1.0	<2
SPW-4859	D.I. Water	Oct 1987	Fe-55	<0.5	<1
SPS-5348	Milk	Dec 1987	Cs-134	<2.3	<10
			Cs-137	<2.5	<10
SPW-5384	D.I. Water	Dec 1987	Co-60	<2.8	<10
			Cs-134	<2.6	<10
			Cs-137	<2.8	<10
			I-131	<0.2	<1
			Ra-226	<0.1	<1
			Ra-228	<1.2	<2
			Sr-89	<0.5	<1
			Sr-90	<0.4	<1
SPW-5385	D.I. Water	Nov 1987	Gr. alpha	<0.4	<1
			Gr. beta	<2.2	<4
			Fe-55	<0.3	<1
SPS-5386	Milk	Jan 1988	I-131	<0.1	<1
SPW-5448	"Dead" Water	Jan 1988	H-3	<177	<300

Table A-4. In-house "blank" samples (continued).

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l	
				Results (4.66 $\sigma$ )	Acceptance Criteria (4.66 $\sigma$ )
SPS-5615	Milk	Mar 1988	Cs-134 Cs-137 I-131 Sr-89 Sr-90	<2.4 <2.5 <0.3 <0.4 $2.4 \pm 0.5^a$	<10 <10 <1 <5 <1
SPS-5650	D.I. Water	Mar 1988	Th-228 Th-230 Th-232 U-234 U-235 U-238 Am-241 Cm-242 Pu-238 Pu-240	<0.3 <0.04 <0.05 <0.03 <0.03 <0.03 <0.05 <0.01 <0.08 <0.02	<1 <1 <1 <1 <1 <1 <1 <1 <1
SPS-6090	Milk	Jul 1988	Sr-89 Sr-90 I-131 Cs-137	<0.5 $1.8 \pm 0.5^a$ <0.4 <0.4	<1 <1 <1 <10
SPW-6209	Water	Jul 1988	Fe-55	<0.8	<1
SPW-6292	Water	Sep 1988	Sr-89 Sr-90	<0.7 <0.7	<1 <1
SPS-6477	Milk	Oct 1988	I-131 Cs-134 Cs-137	<0.2 <6.1 <5.9	<1 <10 <10
SPW-6478	Water	Oct 1988	I-131	<0.2	<1
SPW-6479	Water	Oct 1988	Co-60 Cs-134 Cs-137	<5.7 <3.7 <4.3	<10 <10 <10
SPW-6480	Water	Oct 1988	H-3	<170	<300
SPW-6625	Water	Dec 1988	Gr. alpha Gr. beta	<0.7 <1.9	<1 <4

<sup>a</sup> Low level (1 - 5 pCi/l) of Sr-90 concentration in milk is not unusual.

Table A-4. In-house "blank" samples (continued).

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l	
				Results (4.66 $\sigma$ )	Acceptance Criteria (4.66 $\sigma$ )
SPS-6723	Milk	Jan 1989	Sr-89	<0.6	<5
			Sr-90	1.9±0.5a	<1
			I-131	<0.2	<1
			Cs-134	<4.3	<10
			Cs-137	<4.4	<10
SPW-6877	Water	Mar 1989	Sr-89	<0.4	<5
			Sr-90	<0.6	<1
SPS-6963	Milk	Apr 1989	I-131	<0.3	<1
			Cs-134	<5.9	<10
			Cs-137	<6.2	<10
SPW-7561	Water	Apr 1989	H-3	<150	<300
SPW-7207	Water	Jun 1989	Ra-226	<0.2	<1
			Ra-228	<0.6	<1
SPS-7208	Milk	Jun 1989	Sr-89	<0.6	<5
			Sr-90	2.1±0.5a	<1
			I-131	<0.3	<1
			Cs-134	<6.4	<10
			Cs-137	<7.2	<10
SPW-7558	Water	Jun 1989	Gr. alpha	<0.2	<1
			Gr. beta	<1.0	<4
SPS-7322	Milk	Aug 1989	Sr-89	<1.4	<5
			Sr-90	4.8±1.0a	<1
			I-131	<0.2	<1
			Cs-134	<6.9	<10
			Cs-137	<8.2	<10
SPW-7559	Water	Sep 1989	Sr-89	<2.0	<5
			Sr-90	<0.7	<1
SPW-7560	Water	Oct 1989	I-131	<0.1	<1.0
SPW-7562	Water	Oct 1989	H-3	<140	<300
SPS-7605	Milk	Nov 1989	I-131	<0.2	<1
			Cs-134	<8.6	<10
			Cs-137	<10	<10
SPW-7971	Water	Dec 1989	Gr. alpha	<0.4	<1
			Gr. beta	<0.8	<4

a Low level (1-5 pCi/l) of Sr-90 concentration in milk is not unusual.

ATTACHMENT B

## ACCEPTANCE CRITERIA FOR "SPIKED" SAMPLES

LABORATORY PRECISION: ONE STANDARD DEVIATION VALUES FOR VARIOUS ANALYSES<sup>a</sup>

Analysis	Level	One Standard Deviation for Single Determination
Gamma Emitters	5 to 100 pCi/liter or kg >100 pCi/liter or kg	5 pCi/liter 5% of known value
Strontium-89 <sup>b</sup>	5 to 50 pCi/liter or kg >50 pCi/liter or kg	5 pCi/liter 10% of known value
Strontium-90 <sup>b</sup>	2 to 30 pCi/liter or kg >30 pCi/liter or kg	3.0 pCi/liter 10% of known value
Potassium	>0.1 g/liter or kg	5% of known value
Gross Alpha	<20 pCi/liter >20 pCi/liter	5 pCi/liter 25% of known value
Gross Beta	<100 pCi/liter >100 pCi/liter	5 pCi/liter 5% of known value
Tritium	<4,000 pCi/liter >4,000 pCi/liter	1s = ( $\mu$ Ci/liter) = 169.85 x (known).0933 10% of known value
Radium-226, Radium-228	<0.1 pCi/liter	15% of known value
Plutonium	0.1 pCi/liter, gram, or sample	10% of known value
Iodine-131, Iodine-129 <sup>b</sup>	<55 pCi/liter >55 pCi/liter	6 pCi/liter 10% of known value
Uranium-238, Nickel-63 <sup>b</sup> , Technetium-99 <sup>b</sup>	<35 pCi/liter >35 pCi/liter	6 pCi/liter 15% of known value
Iron-55 <sup>b</sup>	50 to 100 pCi/liter	10 pCi/liter 10% of known value

<sup>a</sup> From EPA publication, "Environmental Radioactivity Laboratory Intercomparison Studies Program, Fiscal Year 1981-1982, EPA-600/4-81-004.

<sup>b</sup> TML limit.

ADDENDUM TO APPENDIX A

The following is an explanation of the reasons why certain samples were outside the control limit specified by the Environmental Protection Agency for the Interlaboratory Comparison Program starting January 1987.

Lab Code	Analysis	TIML Result	EPA Control Limit	Explanation
STM-504	Sr-89	57.0±4.3	60.3-77.7	Milk had high fat content which made analyses difficult. Addition of errors to TIML result would put values within EPA control limits. EPA also had the same problem in analyzing its own sample.
	Sr-90	32.0±1.0	32.4-37.6	
STW-511	Ra-228	8.1±1.4	4.6-8.0	TIML results are usually within EPA control limits. Analysis of the next sample was within EPA control limits. No further action is planned.
STW-516	Cr-51	80.3±17.5	61.3-78.7	Results in the past have been within EPA control limits and TIML will monitor the situation in the future.
STF-524	K	1010.7±158.5	1123.5-1336.5	Error in transference of data. Correct data was 1105±33. Results in the past have been within the limits and TIML will monitor the situation in the future.
STW-532	I-131	9.0±2.0	6.2-8.8	Sample recounted after 12 days. The average result was 8.8±1.7 (within EPA control limits). The sample was recounted in order to check the decay. Results in the past have been within the limits and TIML will continue to monitor the situation in the future.
STW-534	Co-60	63.3±1.3	41.3-58.7	High level of Co-60 was due to contamination of beaker. Beaker was discarded upon discovery of contamination and sample was recounted. Recount results were 53.2±3.6 and 50.9±2.4.

ADDENDUM TO APPENDIX A (continued)

Lab Code	Analysis	TIML Result	EPA Control Limit	Explanation
STM-554	Sr-90	51.0±2.0	54.8-65.2	The cause of low result is not known and is under investigation. It should be noted that 63% of all participants failed this test. Also, the average for all participants was 54.0 pCi/l before the Grubb and 55.8 pCi/l after the Grubb.
STW-560	Pu-239	5.8±1.1	3.5-4.9	The cause of high results is not known (suspected contaminated standard) and is under investigation. New Pu-236 standard was obtained and will be used for the next test.
STW-568	Ra-228	2.6±1.0	2.7-4.5	The cause of low results is under investigation. New dilution was prepared and sample is being reanalyzed. Sample was used up during testing. Next EPA crosschecks with the control limits.
STM-570	Sr-89 Sr-90	26.0±10.0 45.7±4.2	39.0±5.0 55.0±3.0	The cause of low results is under investigation. New "spike" milk sample was prepared and being analyzed. Results of analysis: See Table A-3, sample QC-Mi-24.

Table A-1. (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/lb		
				TIML Result ± 2°C	Is, N=1	EPA Resulted Control Limits
STM-554	Milk	Oct 1988	Sr-89	40.3±7.0	40.0±5.0	31.3-48.7
			Sr-90	51.0±2.0	60.0±3.0	54.8-65.2
			I-131	94.0±3.4	91.0±9.0	75.4-106.6
			Cs-137	45.0±4.0	50.0±5.0	41.3-58.7
			K	1500±45	1600±80	1461-1739
STU-555	Urine	Nov 1988	H-3	3030±209	3025±359	2403-3647
STW-556	Water	Nov 1988	Gr. alpha	9.0±3.5	9.0±5.0	0.3-17.7
			Gr. beta	9.7±1.2	9.0±5.0	0.3-17.7
STW-557	Water	Dec 1988	I-131	108.7±3.0	115.0±12.0	94.2-135.8
STW-559	Water	Jan 1989	Sr-89	40.0±8.7	40.0±5.0	31.3-48.7
			Sr-90	24.3±3.1	25.0±1.5	22.4-27.6
STW-560	Water	Jan 1989	Pu-239	5.8±1.1	4.2±0.4	3.5-4.9
STW-561	Water	Jan 1989	Gr. alpha	7.3±1.2	8.0±5.0	0.0-16.7
			Gr. beta	5.3±1.2	4.0±5.0	0.0-12.7
STW-562	Water	Feb 1989	Cr-51	245±46	235±24	193.4-276.6
			Co-60	10.0±2.0	10.0±5.0	1.3-18.7
			Zn-65	170±10	159±16	139.2-186.7
			Ru-106	181±7.6	178±18	146.8-209.2
			Cs-134	9.7±3.0	10.0±5.0	1.3-18.7
			Cs-137	11.7±1.2	10.0±5.0	1.3-18.7

Table A-1. (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/lb			
				TIML Result $\pm 2\sigma^c$	EPA Result <sup>d</sup> 1s, N=1	Control Limits	
STW-563	Water	Feb 1989	I-131	109.0 $\pm$ 4.0	106.0 $\pm$ 11.0	86.9-125.1	
STW-564	Water	Feb 1989	H-3	2820 $\pm$ 20	2754 $\pm$ 356	2137-3371	
STW-565	Water	Mar 1989	Ra-226 Ra-228	4.2 $\pm$ 0.3 1.9 $\pm$ 1.0	4.9 $\pm$ 0.7 1.7 $\pm$ 0.3	3.7-6.1 1.2-2.2	
STW-566	Water	Mar 1989	U	5.0 $\pm$ 0.0	5.0 $\pm$ 6.0	0.0-15.4	
STW-567	Air Filter	Mar 1989	Gr. alpha Gr. beta Sr-90 Cs-137	21.7 $\pm$ 1.2 68.3 $\pm$ 4.2 20.0 $\pm$ 2.0 21.3 $\pm$ 1.2	21.0 $\pm$ 5.0 62.0 $\pm$ 5.0 20.0 $\pm$ 1.5 20.0 $\pm$ 5.0	12.3-29.7 53.3-70.7 17.4-22.6 11.3-28.7	
STW-568 569	Water (Blind)	Apr 1989	Sample A	Gr. alpha Ra-226 Ra-228 U	22.7 $\pm$ 2.3 3.6 $\pm$ 0.6 2.6 $\pm$ 1.0 3.0 $\pm$ 0.0	29.0 $\pm$ 7.0 3.5 $\pm$ 0.5 3.6 $\pm$ 0.5 3.0 $\pm$ 6.0	16.9-41.2 2.6-4.4 2.7-4.5 0.0-13.4
			Sample B	Gr. beta Sr-89 Sr-90 Cs-134 Cs-137	52.3 $\pm$ 6.1 9.3 $\pm$ 5.4 7.0 $\pm$ 0.0 21.0 $\pm$ 5.2 23.0 $\pm$ 2.0	57.0 $\pm$ 5.0 8.0 $\pm$ 5.0 8.0 $\pm$ 1.5 20.0 $\pm$ 5.0 20.0 $\pm$ 5.0	43.3-65.7 0.0-16.7 5.4-10.6 11.3-28.7 11.3-28.7
STM-570	Milk	Apr 1989	Sr-89 Sr-90 Cs-137 K-40	26.0 $\pm$ 10.0 45.7 $\pm$ 4.2 54.0 $\pm$ 6.9 1521 $\pm$ 208	39.0 $\pm$ 5.0 55.0 $\pm$ 3.0 50.0 $\pm$ 5.0 1600 $\pm$ 80	30.3-47.7 49.8-60.2 41.3-58.7 1461-1739	

Table A-1. (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l <sup>b</sup>		
				TIML Result $\pm 2\sigma^c$	1s, N=1	EPA Result <sup>d</sup> Control Limits
STW-571 <sup>g</sup>	Water	May 1989	Sr-89	40.7	6.0±5.0	0.0-14.7
			Sr-90	5.0±1.0	6.0±1.5	3.4-8.6
STW-572	Water	May 1989	Gr. alpha	24.0±2.0	30.0±8.0	16.1-43.9
			Gr. beta	49.3±15.6	50.0±5.0	41.3-58.7
STW-573	Water	Jun 1989	Ba-133	50.7±1.2	49.0±5.0	40.3-57.7
			Co-60	31.3±2.3	31.0±5.0	22.3-39.7
			Zn-65	167±10	165±17	135.6-194.4
			Ru-106	123±9.2	128±13	105.5-150.5
			Cs-134	40.3±1.2	39±5	30.3-47.7
			Cs-137	22.3±1.2	20±5	11.3-28.7
STW-574	Water	Jun 1989	H-3	4513±136	4503±450	3724-5282
STW-575	Water	Jul 1989	Ra-226	16.8±3.1	17.7±2.7	13.0-22.4
			Ra-228	13.8±3.7	18.3±2.7	13.6-23.0
STW-576	Water	Jul 1989	U	40.3±1.2	41.0±6.0	30.6-51.4
STW-577	Water	Aug 1989	I-131	84.7±5.8	83.0±8.0	69.1-96.9
STW-579	Air Filter	Aug 1989	Gr. alpha	6.0±0.0	6.0±5.0	0.0-14.7
			Cs-137	10.3±2.3	10.0±5.0	1.3-18.7
STW-580	Water	Sep 1989	Sr-89	14.7±1.2	14.0±5.0	5.3-22.7
			Sr-90	9.7±1.2	10.0±1.5	7.4-12.6
STW-581	Water	Sep 1989	Gr. alpha	5.0±0.0	4.0±5.0	0.0-12.7
			Gr. Beta	8.7±2.3	6.0±5.0	0.0-14.7

Table A-1. (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l <sup>b</sup>		
				TIML Result $\pm 2\sigma^c$	1s, N=1	EPA Result <sup>d</sup> Control Limits
STW-583	Water	Oct 1989	Ba-133 Co-60 Zn-65 Ru-106 Cs-134 Cs-137	60.3 $\pm$ 10.0 29.0 $\pm$ 4.0 132.3 $\pm$ 6.0 155.3 $\pm$ 6.1 30.7 $\pm$ 6.1 66.3 $\pm$ 4.6	59.0 $\pm$ 6.0 30.0 $\pm$ 5.0 129.0 $\pm$ 13.0 161.0 $\pm$ 16.0 29.0 $\pm$ 5.0 59.0 $\pm$ 5.0	48.6-69.4 21.3-38.7 106.5-151.5 133.3-188.7 20.3-37.7 50.3-67.7
STW-584	Water	Oct 1989	H-3	3407 $\pm$ 150	3496 $\pm$ 364	2866-4126
STW-585 586	Water (Blind)	Oct 1989				
	Sample A		Gr. Alpha Ra-226 Ra-228 U	41.7 $\pm$ 9.4 7.9 $\pm$ 0.4 4.4 $\pm$ 0.8 12.0 $\pm$ 0.0	49.0 $\pm$ 12.0 8.4 $\pm$ 1.3 4.1 $\pm$ 0.6 12.0 $\pm$ 6.0	28.2-69.8 6.2-10.6 3.1-5.1 1.6-22.4
	Sample B		Gr. Beta Sr-89 Sr-90 Cs-134 Cs-137	31.7 $\pm$ 2.3 13.3 $\pm$ 4.2 7.0 $\pm$ 2.0 5.0 $\pm$ 0.0 7.0 $\pm$ 0.0	32.0 $\pm$ 5.0 15.0 $\pm$ 5.0 7.0 $\pm$ 3.0 5.0 $\pm$ 5.0 5.0 $\pm$ 5.0	23.3-40.7 6.3-23.7 4.4-9.6 0.0-13.7 0.0-13.7
STW-587	Water	Nov 1989	Ra-226 Ra-228	7.9 $\pm$ 0.4 8.9 $\pm$ 1.2	8.7 $\pm$ 1.3 9.3 $\pm$ 1.2	6.4-11.0 6.9-11.7
STW-588	Water	Nov 1989	U	15.0 $\pm$ 0.09	15.0 $\pm$ 6.0	4.6-25.4

a Results obtained by Teledyne Isotopes Midwest Laboratory as a participant in the environmental sample crosscheck program operated by the Intercomparison and Calibration Section, Quality Assurance Branch, Environmental Monitoring and Support Laboratory, U.S. Environmental Protection Agency (EPA), Las Vegas, Nevada.

b All results are in the pCi/l, except for elemental potassium (K) data in milk, which are in mg/l; air filter samples, which are in pCi/filter; and food, which is in mg/kg.

c Unless otherwise indicated, the TIML results are given as the mean  $\pm$  2 standard deviations for three determinations.

d USEPA results are presented as the known values and expected laboratory precision (1s, 1 determination) and control limits as defined by EPA.

e NA = Not analyzed.

f ND = No data. Not analyzed due to relocation of the lab.

g Sample was analyzed but the results not submitted to EPA because deadline was missed.

Table A-2. Crosscheck program results, thermoluminescent dosimeters (TLDs).

Lab Code	TLD Type	Measurement	Teledyne Result $\pm 2\sigma^a$	mR Known Value <sup>c</sup>	Average $\pm 2 \sigma^d$ (all participants)
<b>2nd International Intercomparison<sup>b</sup></b>					
115-2	CaF <sub>2</sub> :Mn Bulb	Field	17.0 $\pm$ 1.9	17.1	16.4 $\pm$ 7.7
		Lab	20.8 $\pm$ 4.1	21.3	18.8 $\pm$ 7.6
<b>3rd International Intercomparison<sup>e</sup></b>					
115-3	CaF <sub>2</sub> :Mn Bulb	Field	30.7 $\pm$ 3.2	34.9 $\pm$ 4.8	31.5 $\pm$ 3.0
		Lab	89.6 $\pm$ 6.4	91.7 $\pm$ 14.6	86.2 $\pm$ 24.0
<b>4th International Intercomparison<sup>f</sup></b>					
115-4	CaF <sub>2</sub> :Mn Bulb	Field	14.1 $\pm$ 1.1	14.1 $\pm$ 1.4	16.0 $\pm$ 9.0
		Lab (Low)	9.3 $\pm$ 1.3	12.2 $\pm$ 2.4	12.0 $\pm$ 7.6
		Lab (High)	40.4 $\pm$ 1.4	45.8 $\pm$ 9.2	43.9 $\pm$ 13.2
<b>5th International Intercomparison<sup>g</sup></b>					
115-5A	CaF <sub>2</sub> :Mn Bulb	Field	31.4 $\pm$ 1.8	30.0 $\pm$ 6.0	30.2 $\pm$ 14.6
		Lab at beginning	77.4 $\pm$ 5.8	75.2 $\pm$ 7.6	75.8 $\pm$ 40.4
		Lab at end	96.6 $\pm$ 5.8	88.4 $\pm$ 8.8	90.7 $\pm$ 31.2

Table A-2. (Continued)

Lab Code	TLD Type	Measurement	mR		
			Teledyne Result $\pm 2\sigma^a$	Known Value <sup>c</sup>	Average $\pm 2\sigma^d$ (all participants)
115-58	LiF-100 Chips	Field	30.3 $\pm$ 4.8	30.0 $\pm$ 6.0	30.2 $\pm$ 14.6
		Lab at beginning	81.1 $\pm$ 7.4	75.2 $\pm$ 7.6	75.8 $\pm$ 40.4
		Lab at the end	85.4 $\pm$ 11.7	88.4 $\pm$ 8.8	90.7 $\pm$ 31.2
<b>7th International Intercomparison<sup>h</sup></b>					
115-7A	LiF-100 Chips	Field	75.4 $\pm$ 2.6	75.8 $\pm$ 6.0	75.1 $\pm$ 29.8
		Lab (Co-60)	80.0 $\pm$ 3.5	79.9 $\pm$ 4.0	77.9 $\pm$ 27.6
		Lab (Cs-137)	66.6 $\pm$ 2.5	75.0 $\pm$ 3.8	73.0 $\pm$ 22.2
115-7B	CaF <sub>2</sub> :Mn Bulbs	Field	71.5 $\pm$ 2.6	75.8 $\pm$ 6.0	75.1 $\pm$ 29.8
		Lab (Co-60)	84.8 $\pm$ 6.4	79.9 $\pm$ 4.0	77.9 $\pm$ 27.6
		Lab (Cs-137)	78.8 $\pm$ 1.6	75.0 $\pm$ 3.8	73.0 $\pm$ 22.2
115-7C	CaSO <sub>4</sub> :Dy Cards	Field	76.8 $\pm$ 2.7	75.8 $\pm$ 6.0	75.1 $\pm$ 29.8
		Lab (Co-60)	82.5 $\pm$ 3.7	79.9 $\pm$ 4.0	77.9 $\pm$ 27.6
		Lab (Cs-137)	79.0 $\pm$ 3.2	75.0 $\pm$ 3.8	73.0 $\pm$ 22.2

Table A-2. (Continued)

Lab Code	TLD Type	Measurement	Teledyne Result $\pm 2\sigma^a$	Known Value <sup>c</sup>	mR	Average $\pm 2\sigma^d$ (all participants)
<b>8th International Intercomparison<sup>b</sup></b>						
115-8A	LiF-100 Chips	Field Site 1	29.5 $\pm$ 1.4	29.7 $\pm$ 1.5	28.9 $\pm$ 12.4	
		Field Site 2	11.0 $\pm$ 0.8	10.4 $\pm$ 0.5	10.1 $\pm$ 9.06	
		Lab (Cs-137)	13.7 $\pm$ 0.9	17.2 $\pm$ 0.9	16.2 $\pm$ 6.8	
115-8B	CaF <sub>2</sub> :Mn Bulbs	Field Site 1	32.3 $\pm$ 1.2	29.7 $\pm$ 1.5	28.9 $\pm$ 12.4	
		Field Site 2	9.0 $\pm$ 1.0	10.4 $\pm$ 0.5	10.1 $\pm$ 9.0	
		Lab (Cs-137)	15.8 $\pm$ 0.9	17.2 $\pm$ 0.9	16.2 $\pm$ 6.8	
115-8C	CaSO <sub>4</sub> :Dy Cards	Field Site 1	32.3 $\pm$ 0.7	29.7 $\pm$ 1.5	28.9 $\pm$ 12.4	
		Field Site 2	10.6 $\pm$ 0.6	10.4 $\pm$ 0.5	10.1 $\pm$ 9.0	
		Lab (Cs-137)	18.1 $\pm$ 0.8	17.2 $\pm$ 0.9	16.2 $\pm$ 6.8	
<b>Teledyne Testing<sup>j</sup></b>						
89-1	LiF-100 Chips	Lab	21.0 $\pm$ 0.4	22.4	-	
89-2	Teledyne CaSO <sub>4</sub> :Dy Cards	Lab	20.9 $\pm$ 1.0	20.3	-	

<sup>a</sup> Lab result given is the mean  $\pm 2$  standard deviations of three determinations.

<sup>b</sup> Second International Intercomparison of Environmental Dosimeters conducted in April of 1976 by the Health and Safety Laboratory (GASL), New York, New York, and the School of Public Health of the University of Texas, Houston, Texas.

<sup>c</sup> Value determined by sponsor of the intercomparison using continuously operated pressurized ion chamber.

<sup>d</sup> Mean  $\pm 2$  standard deviations of results obtained by all laboratories participating in the program.

Table A-2. (continued)

Lab Code	TLD Type	Measurement	Teledyne Result $\pm 2\sigma^a$	mR Known Value <sup>c</sup>	Average $\pm 2\sigma^d$ (all participants)
-------------	-------------	-------------	---------------------------------------	-----------------------------------	--

Footnotes continued

- e Third International Intercomparison of Environmental Dosimeters conducted in summer of 1977 by Oak Ridge National Laboratory and the School of Public Health of the University of Texas, Houston, Texas.
- f Fourth International Intercomparison of Environmental Dosimeters conducted in summer of 1979 by the School of Public Health of the University of Texas, Houston, Texas.
- g Fifth International Intercomparison of Environmental Dosimeter conducted in fall of 1980 at Idaho Falls, Idaho and sponsored by the School of Public Health of the University of Texas, Houston, Texas and Environmental Measurements Laboratory, New York, New York, U.S. Department of Energy.
- h Seventh International Intercomparison of Environmental Dosimeters conducted in the spring and summer of 1984 at Las Vegas, Nevada, and sponsored by the U.S. Department of Energy, the U.S. Nuclear Regulatory Commission, and the U.S. Environmental Protection Agency.
- i Eighth International Intercomparison of Environmental Dosimeters conducted in the fall and winter of 1985-1986 at New York, New York, and sponsored by the U.S. Department of Energy.
- j Chips were submitted in September, 1989 and cards were submitted in November, 1989 to Teledyne Isotopes, Inc., Westwood, NJ for irradiation.

Table A-3. In-house spiked samples.

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l		
				TIML Result n=3	Known Activity	Expected Precision ls, n=3 <sup>a</sup>
QC-MI-6	Milk	Feb. 1986	Sr-89	6.0±1.9	6.4±3.0	8.7
			Sr-90	14.2±1.7	12.9±2.0	5.2
			I-131	34.2±3.8	35.2±3.5	10.4
			Cs-134	32.0±1.8	27.3±5.0	8.7
			Cs-137	35.8±2.1	35.0±5.0	8.7
QC-W-14	Water	Mar. 1986	Sr-89	1.6±0.4	1.6±1.0	7.1
			Sr-90	2.4±0.2	2.4±2.0	4.2
QC-W-15	Water	Apr. 1986	I-131	44.9±2.4	41.5±7.0	10.6
			Co-60	10.6±1.7	12.1±5.0	7.1 <sup>b</sup>
			Cs-134	30.2±2.4	25.8±8.0	7.1 <sup>b</sup>
			Cs-137	21.9±1.9	19.9±5.0	7.1 <sup>b</sup>
QC-MI-7	Milk	Apr. 1986	I-131	39.7±3.3	41.5±7.0	10.4
			Cs-134	28.7±2.8	25.8±8.0	8.7
			Cs-137	21.2±2.8	19.9±5.0	8.7
SPW-1	Water	May 1986	Gross alpha	15.8±1.8	18.0±5.0	5 <sup>c</sup>
QC-W-16	Water	June 1986	Gross alpha	16.2±0.7	16.9±2.5	8.7
			Gross beta	38.4±3.5	30.2±5.0	8.7
QC-MI-9	Milk	June 1986	Sr-89	<1.0	0.0	7.1 <sup>b</sup>
			Sr-90	12.6±1.8	13.3±3.0	4.2 <sup>b</sup>
			I-131	38.9±7.0	34.8±7.0	10.4
			Cs-134	33.0±3.4	36.1±5.0	8.7
			Cs-137	38.5±2.8	39.0±5.0	8.7
SPW-2	Water	June 1986	Gross alpha	16.8±1.8	18.0±5.0	5 <sup>c</sup>
SPW-3	Water	June 1986	Gross alpha	17.7±0.8	18.0±5.0	5 <sup>c</sup>
QC-W-18	Water	Sep. 1986	Cs-134	34.7±5.6	31.3±5.0	8.7
			Cs-137	51.1±7.0	43.3±8.0	8.7
QC-W-19	Water	Sep. 1986	Sr-89	13.6±4.1	15.6±3.5	7.1 <sup>b</sup>
			Sr-90	6.4±1.6	6.2±2.0	4.2 <sup>b</sup>

Table A-3. In-house spiked samples (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l		
				TIML Result n=3	Known Activity	Expected Precision 1s, n=3a
QC-W-21	Water	Oct. 1986	C -60 Cs-134 Cs-137	19.2±2.2 31.7±5.2 23.8±1.0	18.5±3.0 25.6±8.0 21.6±5.0	8.7 8.7 8.7
QC-MI-11	Milk	Oct 1986	Sr-89	12.3±1.8	14.3±3.0	8.7
QC-W-20	Water	Nov. 1986	H-3	3855±180	3960±350	520 <sup>b</sup>
QC-W-22	Water	Dec. 1986	Gross alpha Gross beta	9.8±1.4 21.7±2.0	11.2±4.0 23.8±5.0	8.7 8.7
QC-W-23	Water	Jan. 1987	I-131	29.8±2.5	27.9±3.0	10.4
QC-MI-12	Milk	Jan. 1987	I-131 Cs-137	36.5±1.3 32.6±4.2	32.6±5.0 27.4±8.0	10.4 8.7
QC-MI-13	Milk	Jan 1987	Sr-89 Sr-90 I-131 Cs-134 Cs-137	10.4±2.1 14.6±1.6 49.5±1.2 41.6 33.3±0.6	12.2±4.0 12.6±3.0 54.9±8.0 0.0 27.4±8.0	8.7 5.2 10.4 8.7 8.7
QC-W-24	Water	Mar 1987	Sr-89 Sr-90	24.7±3.6 23.9±3.8	25.9±5.0 22.8±8.0	8.7 5.2
QC-W-25	Water	Apr 1987	I-131	28.0±1.9	29.3±5.0	10.6
QC-MI-14	Milk	Apr 1987	I-131 Cs-134 Cs-137	25.0±2.2 42.1 34.2±2.0	23.9±5.0 0.0 27.2±7.0	10.4 8.7 8.7
QC-W-26	Water	Jun 1987	H-3 Co-60 Cs-134 Cs-137	3422±100 24.8±1.4 42.0 21.2±0.5	3362±300 26.5±7.0 0.0 21.6±7.0	520 8.7 8.7 8.7
QC-W-27	Water	Jun 1987	Gr. alpha Gr. beta	8.5±1.9 22.6±1.9	10.1±4.0 21.2±5.0	8.7 8.7
QC-W-28	Water	Jun 1987	Gr. alpha Gr. beta	8.7±1.3 12.2±5.2	10.1±4.0 9.4±3.0	8.7 8.7

Table A-3. In-house spiked samples (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l		
				TIML Result n=3	Known Activity	Expected Precision ls, n=3 <sup>a</sup>
QC-W-29	Water	Jun 1987	Gr. alpha Gr. beta	16.4±1.3 15.9±4.0	18.9±5.0 11.8±4.0	8.7 8.7
QC-MI-15	Milk	Jul 1987	Sr-90 I-131 Cs-134 Cs-137	19.4±1.6 43.5±0.7 17.9±2.2 25.4±1.8	18.8±3.5 45.3±7.0 16.0±5.3 22.7±5.0	5.2 10.4 8.7 8.7
QC-W-30	Water	Sep 1987	Sr-89 Sr-90	17.5±3.0 18.4±2.2	14.3±5.0 17.5±2.2	8.7 5.2
QC-W-31	Water	Oct 1987	H-3	2053±939	2059±306	520
QC-W-32	Water	Dec 1987	Gr. alpha Gr. beta	8.6±1.0 15.2±0.1	10.1±5.0 13.1±3.0	8.7 8.7
QC-W-33	Water	Dec 1987	Gr. alpha Gr. beta	7.7±1.4 10.9±1.0	10.1±5.0 7.9±3.0	8.7 8.7
QC-W-34	Water	Dec 1987	Gr. alpha Gr. beta	4.0±0.9 9.4±0.9	5.1±3.0 7.9±3.0	8.7 8.7
QC-MI-16	Milk	Feb 1988	Sr-89 Sr-90 I-131 Cs-134 Cs-137	31.8±4.7 25.5±2.7 26.4±0.5 23.8±2.3 26.5±0.8	31.7±6.0 27.8±3.5 23.2±5.0 24.2±6.0 25.1±6.0	8.7 5.2 10.4 8.7 8.7
QC-MI-17	Milk	Feb 1988	I-131	10.6±1.2	14.3±1.6	10.4
QC-W-35	Water	Feb 1988	I-131	9.7±1.1	11.6±1.1	10.4
QC-W-36	Water	Feb 1988	I-131	10.5±1.3	11.6±1.0	10.4
QC-W-37	Water	Mar 1988	Sr-89 Sr-90	17.1±2.0 18.7±0.9	19.8±8.0 17.3±5.0	8.7 5.2
QC-MI-18	Milk	Mar 1988	I-131 Cs-134 Cs-137	33.2±2.3 31.3±2.1 29.9±1.4	26.7±5.0 30.2±5.0 26.2±5.0	10.4 8.7 8.7

Table A-3. In-house spiked samples (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l		
				TIML Result n=3	Known Activity	Expected ls, n=3 <sup>a</sup>
QC-W-38	Water	Apr 1988	I-131	17.1±1.1	14.2±5.0	10.4
QC-W-39	Water	Apr 1988	H-3	4439±31	4176±500	724
QC-W-40	Water	Apr 1988	Co-60	23.7±0.5	26.1±4.0	8.7
			Cs-134	25.4±2.6	29.2±4.5	8.7
			Cs-137	26.6±2.3	26.2±4.0	8.7
QC-W-41	Water	Jun 1988	Gr. alpha	12.3±0.4	13.1±5.0	8.7
			Gr. beta	22.6±1.0	20.1±5.0	8.7
QC-MI-19	Milk	Jul 1988	Sr-89	15.1±1.6	16.4±5.0	8.7
			Sr-90	18.0±0.6	18.3±5.0	5.2
			I-131	88.4±4.9	86.6±8.0	10.4
			Cs-137	22.7±0.8	20.8±6.0	8.7
QC-W-42	Water	Sep 1988	Sr-89	48.5±3.3	50.8±8.0	8.7
			Sr-90	10.9±1.0	11.4±3.5	5.2
QC-W-43	Water	Oct 1988	Co-60	20.9±3.2	21.4±3.5	8.7
			Cs-134	38.7±1.6	38.0±6.0	8.7
			Cs-137	19.0±2.4	21.0±3.5	8.7
QC-W-44	Water	Oct 1988	I-131	22.2±0.6	23.3±3.5	10.4
QC-W-45	Water	Oct 1988	H-3	4109±43	4153±500	724
QC-MI-20	Milk	Oct 1988	I-131	59.8±0.9	60.6±9.0	10.4
			Cs-134	49.6±1.8	48.6±7.5	8.7
			Cs-137	25.8±4.6	24.7±4.0	8.7
QC-W-46	Water	Dec 1988	Gr. alpha	11.5±2.3	15.2±5.0	8.7
			Gr. beta	26.5±2.0	25.7±5.0	8.7
QC-MI-21	Milk	Jan 1989	Sr-89	25.5±10.3	34.0±10.0	8.7
			Sr-90	28.3±3.2	27.1±3.0	5.2
			I-131	540±13	550±20	10.4
			Cs-134	24.5±2.6	22.6±5.5	8.7
			Cs-137	24.0±0.6	20.5±5.0	8.7

Table A-3. In-house spiked samples (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l		
				TIML Result n=3	Known Activity	Expected Precision 1s, n=3 <sup>a</sup>
QC-W-47	Water	Mar 1989	Sr-89	15.2±3.8	16.1±5.0	8.7
			Sr-90	16.4±1.7	16.9±3.0	5.2
QC-MI-22	Milk	Apr 1989	I-131	36.3±1.1	37.2±5.0	10.4
			Cs-134	20.8±2.8	20.7±8.0	8.7
			Cs-137	22.2±2.4	20.4±8.0	8.7
QC-W-48	Water	Apr 1989	Co-60	23.5±2.0	25.1±8.0	8.7
			Cs-134	24.2±1.1	25.9±8.0	8.7
			Cs-137	23.6±1.2	23.0±8.0	8.7
QC-W-49	Water	Apr 1989	I-131	37.2±3.7	37.2±5.0	10.4
QC-W-50	Water	Apr 1989	H-3	3011±59	3089±500	724
QC-W-51	Water	Jun 1989	Gr. alpha	13.0±1.8	15.0±5.0	8.7
			Gr. beta	26.0±1.2	25.5±8.0	8.7
QC-MI-23	Milk	Jul 1989	Sr-89	19.4±6.5	22.0±10.0	8.7
			Sr-90	27.6±3.	28.6±3.0	5.2
			I-131	46.8±3.2	43.4±5.0	10.4
			Cs-134	27.4±1.8	28.3±6.0	8.7
			Cs-137	24.1±1.8	20.8±6.0	8.7
QC-MI-24	Milk	Aug 1989	Sr-89	25.4±2.7	27.2±10.0	8.7
			Sr-90	46.0±1.1	47.8±9.6	8.3
QC-W-52	Water	Sep 1989	I-131	9.6±0.3	9.7±1.9	10.4
QC-W-53	Water	Sep 1989	I-131	19.0±0.2	20.9±4.2	10.4
QC-W-54	Water	Sep 1989	Sr-89	25.8±4.6	24.7±4.0	8.7
			Sr-90	26.5±5.3	29.7±5.0	5.2

<sup>a</sup> n=3 unless noted otherwise.<sup>b</sup> n=2.<sup>c</sup> n=1.

Table A-3. In-house spiked samples (continued)

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l		
				TIML Result n=3	Known Activity	Expected ls, n=3 <sup>a</sup>
QC-MI-25	Milk	Oct 1989	I-131	70.0±3.3	73.5±20.0	10.4
			Cs-134	22.1±2.6	22.6±8.0	8.7
			Cs-137	29.4±1.5	27.5±8.0	8.7
QC-W-55	Water	Oct 1989	I-131	33.3±1.3	35.3±10.0	10.4
QC-W-56	Water	Oct 1989	Co-60	15.2±0.9	17.4±5.0	8.7
			Cs-134	22.1±4.4	18.9±8.0	8.7
			Cs-137	27.2±1.2	22.9±8.0	8.7
QC-W-57	Water	Oct 1989	H-3	3334±22	3379±500	724
QC-W-58	Water	Nov 1989	Sr-89	10.9±1.4 <sup>d</sup>	11.1±1.0 <sup>d</sup>	8.7
			Sr-90	10.4±1.0 <sup>d</sup>	10.3±1.0 <sup>d</sup>	5.2
QC-W-59	Water	Nov 1989	Sr-89	101.0±5.0 <sup>d</sup>	104.1±10.5 <sup>d</sup>	17.5
			Sr-90	98.0±3.0 <sup>d</sup>	95.0±10.0 <sup>d</sup>	17.0
QC-W-60	Water	Dec 1989	Gr. alpha	10.8±1.1	10.6±4.0	8.7
			Gr. beta	11.6±0.5	11.4±4.0	8.7

<sup>a</sup> n=3 unless noted otherwise.<sup>b</sup> n=2.<sup>c</sup> n=1.<sup>d</sup> Concentration in pCi/ml

Table A-4. In-house "blank" samples.

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l	
				Results (4.66 $\sigma$ )	Acceptance Criteria (4.66 $\sigma$ )
BL-1	D.I. Water	Nov. 1985	Gross alpha Gross beta	<0.1 <0.4	<1 <4
BL-2	D.I. Water	Nov. 1985	Cs-137 (gamma)	<1.9	<10
BL-3	D.I. Water	Nov. 1985	Sr-89 Sr-90	<0.5 <0.6	<5 <1
BL-5	D.I. Water	Nov. 1985	Ra-226 Ra-228	<0.4 <0.4	<1 <1
SPW-2265	D.I. Water	Apr. 1985	Gross alpha Gross beta Sr-89 Sr-90 I-131 Cs-137 (gamma)	<0.6 <2.2 <0.2 <0.4 <0.2 <7.4	<1 <4 <5 <1 <1 <10
BL-6	D.I. Water	Apr. 1986	Gross alpha	<0.4	<1
BL-7	D.I. Water	Apr. 1986	Gross alpha	<0.4	<1
BL-8	D.I. Water	June 1986	Gross alpha	<0.4	<1
BL-9	D.I. Water	June 1986	Gross alpha	<0.3	<1
SPW-3185	D.I. Water	Jan 1987	Ra-226 Ra-228	<0.1 <0.9	<1 <1
SPS-3292	Milk	Jan 1987	I-131 Cs-134 Cs-137	<0.1 <6.2 <6.4	<1 <10 <10
SPW-3554	D.I. Water	Feb 1987	H-3 Gross beta	<180 <2.6	<300 <4
SPS-3555	Milk	Feb 1987	Sr-89 Sr-90	<0.6 $1.9 \pm 0.4$ a	<5 <1
SPS-3731	Milk	Mar 1987	Cs-134 Cs-137	<2.2 <2.5	<10 <10

a Low level (1 - 5 pCi/l) of Sr-90 concentration in milk is not unusual.

Table A-4. In-house "blank" samples (continued).

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l	
				Results (4.66 <sup>c</sup> )	Acceptance Criteria (4.66 <sup>c</sup> )
SPS-3732	D.I. Water	Mar 1987	Sr-89 Sr-90 I-131 Co-60 Cs-134 Cs-137 Ra-226 Ra-228 Np-237 Th-230 Th-232 U-234 U-235 U-238	<0.9 <0.8 <0.3 <2.3 <2.2 <2.4 <0.1 <1.0 <0.04 <0.05 <0.02 <0.05 <0.03 <0.03	<5 <1 <1 <10 <10 <10 <1 <1 <1 <0.1 <0.1 <0.1 <0.1 <0.1
SPS-4023	Milk	May 1987	I-131	<0.1	<1
SPS-4203	D.I. Water	May 1987	Gross alpha Gross beta	<0.7 <1.7	<1 <4
SPS-4204	Milk	May 1987	Sr-89 Sr-90	<0.5 $2.4 \pm 0.6^a$	<5 <1
SPS-4390	Milk	Jun 1987	Cs-134 Cs-137	<4.7 <5.2	<10 <10
SPS-4391	D.I. Water	Jun 1987	Sr-89 Sr-90 I-121 Co-60 Cs-137 Ra-226 Ra-228	<0.4 <0.4 <0.1 <3.8 <5.7 <0.1 <0.9	<5 <1 <1 <10 <10 <1 <1
SPW-4627	D.I. Water	Aug 1987	Gross alpha Gross beta Tritium	<0.6 <1.4 <150	<1 <4
SPS-4528	Milk	Aug 1987	Sr-89 Sr-90	<0.6 $2.4 \pm 0.6^a$	<5 <1
SPS-4847	Milk	Sep 1987	Cs-134 Cs-137	<4.4 <5.3	<10 <10

<sup>a</sup> Low level (1 - 5 pCi/l) of Sr-90 concentration in milk is not unusual.

Table A-4. In-house "blank" samples (continued).

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l	
				Results (4.66 <sup>-1</sup> )	Acceptance Criteria (4.66 <sup>-1</sup> )
SPS-4848	D.I. Water	Sep 1987	I-131	<0.2	<1
SPW-4849	D.I. Water	Sep 1987	Co-60	<4.1	<10
			Cs-134	<4.8	<10
			Cs-137	<4.0	<10
			Sr-89	<0.7	<5
			Sr-90	<0.7	<1
SPW-4850	D.I. Water	Sep 1987	Th-228	<0.04	<1
			Th-232	<0.8	<1
			U-234	<0.03	<1
			U-235	<0.03	<1
			U-238	<0.02	<1
			Am-241	<0.06	<1
			Cm-242	<0.04	<1
			Ra-226	<0.1	<1
			Ra-228	<1.0	<2
SPW-4859	D.I. Water	Oct 1987	Fe-55	<0.5	<1
SPS-5348	Milk	Dec 1987	Cs-134	<2.3	<10
			Cs-137	<2.5	<10
SPW-5384	D.I. Water	Dec 1987	Co-60	<2.8	<10
			Cs-134	<2.6	<10
			Cs-137	<2.8	<10
			I-131	<0.2	<1
			Ra-226	<0.1	<1
			Ra-228	<1.2	<2
			Sr-89	<0.5	<1
			Sr-90	<0.4	<1
SPW-5385	D.I. Water	Nov 1987	Gr. alpha	<0.4	<1
			Gr. beta	<2.2	<4
			Fe-55	<0.3	<1
SPS-5386	Milk	Jan 1988	I-131	<0.1	<1
SPW-5448	"Dead" Water	Jan 1988	H-3	<177	<300

Table A-4. In-house "blank" samples (continued).

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l	
				Results (4.66 <sup>c</sup> )	Acceptance Criteria (4.66 <sup>c</sup> )
SPS-5615	Milk	Mar 1988	Cs-134	<2.4	<10
			Cs-137	<2.5	<10
			I-131	<0.3	<1
			Sr-89	<0.4	<5
			Sr-90	2.4±0.5 <sup>a</sup>	<1
SPS-5650	D.I. Water	Mar 1988	Th-228	<0.3	<1
			Th-230	<0.04	<1
			Th-232	<0.05	<1
			U-234	<0.03	<1
			U-235	<0.03	<1
			U-238	<0.03	<1
			Am-241	<0.06	<1
			Cm-242	<0.01	<1
			Pu-238	<0.08	<1
			Pu-240	<0.02	<1
SPS-6090	Milk	Jul 1988	Sr-89	<0.5	<1
			Sr-90	1.8±0.5 <sup>a</sup>	<1
			I-131	<0.4	<1
			Cs-137	<0.4	<10
SPW-6209	Water	Jul 1988	Fe-55	<0.8	<1
SPW-6292	Water	Sep 1988	Sr-89	<0.7	<1
			Sr-90	<0.7	<1
SPS-6477	Milk	Oct 1988	I-131	<0.2	<1
			Cs-134	<6.1	<10
			Cs-137	<5.9	<10
SPW-6478	Water	Oct 1988	I-131	<0.2	<1
SPW-6479	Water	Oct 1988	Co-60	<5.7	<10
			Cs-134	<3.7	<10
			Cs-137	<4.3	<10
SPW-6480	Water	Oct 1988	H-3	<170	<300
SPW-6625	Water	Dec 1988	Gr. alpha	<0.7	<1
			Gr. beta	<1.9	<4

<sup>a</sup> Low level (1 - 5 pCi/l) of Sr-90 concentration in milk is not unusual.

Table A-4. In-house "blank" samples (continued).

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/l	
				Results (4.66 <sup>c</sup> )	Acceptance Criteria (4.66 <sup>c</sup> )
SPS-6723	Milk	Jan 1989	Sr-89	<0.6	<5
			Sr-90	1.9±0.5 <sup>a</sup>	<1
			I-131	<0.2	<1
			Cs-134	<4.3	<10
			Cs-137	<4.4	<10
SPW-6877	Water	Mar 1989	Sr-89	<0.4	<5
			Sr-90	<0.6	<1
SPS-6963	Milk	Apr 1989	I-131	<0.3	<1
			Cs-134	<5.9	<10
			Cs-137	<6.2	<10
SPW-7561	Water	Apr 1989	H-3	<150	<300
SPW-7207	Water	Jun 1989	Ra-226	<0.2	<1
			Ra-228	<0.6	<1
SPS-7208	Milk	Jun 1989	Sr-89	<0.6	<5
			Sr-90	2.1±0.5 <sup>a</sup>	<1
			I-131	<0.3	<1
			Cs-134	<6.4	<10
			Cs-137	<7.2	<10
SPW-7558	Water	Jun 1989	Gr. alpha	<0.2	<1
			Gr. beta	<1.0	<4
SPS-7322	Milk	Aug 1989	Sr-89	<1.4	<5
			Sr-90	4.8±1.0 <sup>a</sup>	<1
			I-131	<0.2	<1
			Cs-134	<6.9	<10
			Cs-137	<8.2	<10
SPW-7559	Water	Sep 1989	Sr-89	<2.0	<5
			Sr-90	<0.7	<1
SPW-7560	Water	Oct 1989	I-131	<0.1	<1.0
SPW-7562	Water	Oct 1989	H-3	<140	<300
SPS-7605	Milk	Nov 1989	I-131	<0.2	<1
			Cs-134	<8.6	<10
			Cs-137	<10	<10
SPW-7971	Water	Dec 1989	Gr. alpha	<0.4	<1
			Gr. beta	<0.8	<4

<sup>a</sup> Low level (1-5 pCi/l) of Sr-90 concentration in milk is not unusual.

ATTACHMENT B

## ACCEPTANCE CRITERIA FOR "SPIKED" SAMPLES

LABORATORY PRECISION: ONE STANDARD DEVIATION VALUES FOR VARIOUS ANALYSES<sup>a</sup>

Analysis	Level	One Standard Deviation for Single Determination
Gamma Emitters	5 to 100 pCi/liter or kg >100 pCi/liter or kg	5 pCi/liter 5% of known value
Strontium-89 <sup>b</sup>	5 to 50 pCi/liter or kg >50 pCi/liter or kg	5 pCi/liter 10% of known value
Strontium-90 <sup>b</sup>	2 to 30 pCi/liter or kg >30 pCi/liter or kg	3.0 pCi/liter 10% of known value
Potassium	>0.1 g/liter or kg	5% of known value
Gross Alpha	<20 pCi/liter >20 pCi/liter	5 pCi/liter 25% of known value
Gross Beta	<100 pCi/liter >100 pCi/liter	5 pCi/liter 5% of known value
Tritium	<4,000 pCi/liter >4,000 pCi/liter	1s = (pCi/liter) = 169.85 x (known).0933 10% of known value
Radium-226, Radium-228	<0.1 pCi/liter	15% of known value
Plutonium	0.1 pCi/liter, gram, or sample	10% of known value
Iodine-131, Iodine-129 <sup>b</sup>	<55 pCi/liter >55 pCi/liter	6 pCi/liter 10% of known value
Uranium-238, Nickel-63 <sup>b</sup> , Technetium-99 <sup>b</sup>	<35 pCi/liter >35 pCi/liter	6 pCi/liter 15% of known value
Iron-55 <sup>b</sup>	50 to 100 pCi/liter	10 pCi/liter 10% of known value

<sup>a</sup> From EPA publication, "Environmental Radioactivity Laboratory Intercomparison Studies Program, Fiscal Year 1981-1982, EPA-600/4-81-004.

<sup>b</sup> TML limit.

ADDENDUM TO APPENDIX A

The following is an explanation of the reasons why certain samples were outside the control limit specified by the Environmental Protection Agency for the Interlaboratory Comparison Program starting January 1987.

Lab Code	Analysis	TIML Result	EPA Control Limit	Explanation
STM-504	Sr-89	57.0±4.3	60.3-77.7	Milk had high fat content which made analyses difficult. Addition of errors to TIML result would put values within EPA control limits. EPA also had the same problem in analyzing its own sample.
	Sr-90	32.0±1.0	32.4-37.6	
STW-511	Ra-228	8.1±1.4	4.6-8.0	TIML results are usually within EPA control limits. Analysis of the next sample was within EPA control limits. No further action is planned.
STW-516	Cr-51	80.3±17.5	61.3-78.7	Results in the past have been within EPA control limits and TIML will monitor the situation in the future.
STF-524	K	1010.7±158.5	1123.5-1336.5	Error in transference of data. Correct data was 1105±33. Results in the past have been within the limits and TIML will monitor the situation in the future.
STW-532	I-131	9.0±2.0	6.2-8.8	Sample recounted after 12 days. The average result was 8.8±1.7 (within EPA control limits). The sample was recounted in order to check the decay. Results in the past have been within the limits and TIML will continue to monitor the situation in the future.
STW-534	Co-60	63.3±1.3	41.3-58.7	High level of Co-60 was due to contamination of beaker. Beaker was discarded upon discovery of contamination and sample was recounted. Recount results were 53.2±3.6 and 50.9±2.4.

ADDENDUM TO APPENDIX A (continued)

Lab Code	Analysis	TIML Result	EPA Control Limit	Explanation
STM-554	Sr-90	51.0±2.0	54.8-65.2	The cause of low result is not known and is under investigation. It should be noted that 63% of all participants failed this test. Also, the average for all participants was 54.0 pCi/l before the Grubb and 55.8 pCi/l after the Grubb.
STW-560	Pu-239	5.8±1.1	3.5-4.9	The cause of high results is not known (suspected contaminated standard) and is under investigation. New Pu-236 standard was obtained and will be used for the next test.
STW-568	Ra-228	2.6±1.0	2.7-4.5	The cause of low results is under investigation. New dilution was prepared and sample is being reanalyzed. Sample was used up during testing. Next EPA crosschecks with the control limits.
STM-570	Sr-89 Sr-90	26.0±10.0 45.7±4.2	39.0±5.0 55.0±3.0	The cause of low results is under investigation. New "spike" milk sample was prepared and being analyzed. Results of analysis: See Table A-3, sample QC-MI-24.

APPENDIX IV

REVISIONS TO THE ODCM RADIOLOGICAL ENVIRONMENTAL  
MONITORING PROGRAM SINCE 1986

REVISIONS TO THE RADIOPHYSICAL ENVIRONMENTAL MONITORING PROGRAM  
BYRON STATION

DATE (ODCM Revision)	SAMPLE TYPE	MONITORING LOCATION		COMMENTS
'86 (11A)	Airborne	All	Revision	Established monitoring locations identification numbers.
		All	Addition	Sr-89 and 90 analysis on a quarterly composite.
		BY-22	Revision	CECo Real Estate was retitled to CECO Property.
		All	Addition	Gross beta, Sr-89, and 90 analyses, quarterly.
		BY-14	Revision	CECo Real Estate was retitled to CECO Property.
		BY-18	Revision	Station's Onsite Well was changed to the McCoy Farmstead Well, 1.25 mi SW.
	Surface Water	All	Addition	Gross beta analysis weekly and Sr-89, 90 analyses on a quarterly composite.
		BY-13	Revision	Oregon Pool of Rock River, Upstream of Intake, 4.3 mi, SSW was changed to Rock River, Upstream of Intake, 2.6 mi, WNW.
	Cooling Water	All	Addition	Gross beta analysis weekly. Gamma isotopic, tritium, Sr-89 and 90 analyses on a composite, monthly.
		BY-10	Revision	Byron Intake Pipe/River, at the station. Initially, this monitoring location was considered surface water exposure pathway.
		BY-11	Revision	Byron Discharge Pipe/River, at the station. Initially, this monitoring location was considered surface water exposure pathway.
	Sediments	All	Addition	Gross beta analysis three times a year, not semiannually.
		BY-13	Revision	Oregon Pool of Rock River, Upstream of Intake, 4.3 mi, SSW was changed to Rock River, Upstream of Intake, 2.6 mi, WNW.
	Precipitation	All	Addition	Gross beta analysis monthly. Gamma isotopic, tritium, Sr-89 and 90 analyses on a quarterly composite at all the milk monitoring locations.

REVISIONS TO THE RADIOPHYSICAL ENVIRONMENTAL MONITORING PROGRAM  
BYRON STATION Cont'd

DATE (ODCM Revision)	SAMPLE TYPE	MONITORING LOCATION	COMMENTS
'86 (IIA) Cont'd	Aquatic Plants	All	Addition
		BY-12	Addition
	Fish/Invertebrates	BY-13	Addition
		All	/Addition
	Milk	BY-13	Revision
		All	Addition
	Cattle Feed/Grass	BY-15	Revision
		BY-16	Revision
		BY-20	Revision
	Vegetables	All	Addition
		BY-19-1,2	Deletion
			Gamma isotopic and gross beta analyses, three times a year. Oregon Pool of Rock River, Downstream of Discharge, 4.5 mi SSW.
			Rock River, Upstream of Intake, 2.6 mi WNW.
			Gross beta, Sr-89 and Sr-90 analysis three times a year. Oregon Pool of Rock River, Upstream of Intake, 4.3 mi, SSW was changed to Rock River, Upstream of Intake, 2.6 mi, WNW.
			Sr-89, 90 analysis biweekly when milch animals are on pasture, monthly at other times.
			Groenhagen/Oltmann Farm, 2.0 mi S was changed to J.A. Reevorts Pine Hill Dairy, 3.2 mi ESE.
			Ashelford Farm, 2.7 mi W was changed to Kenneth Durien Farm, 3.3 mi SE.
			Meyers Farm, 5.0 mi SE was changed to Ed Seabold Farm, 2.5 mi NE.
			Gamma isotopic, gross beta, Sr-89 and 90 analyses quarterly at all the milk monitoring locations.
			Collection frequency is annually and the following ODCM statement is deleted: "If harvest occurs more than once a year, sampling shall be performed during each discrete harvest. If harvest occurs continuously, sampling shall be monthly. Attention shall be paid to including samples of tuberous and root food products."
			Gamma isotopic, gross beta, Sr-89 and 90 analyses annually. I-131 analysis on leafy vegetables annually. Both locations are Oregon Vegetable Stands, 5.1 mi SSW.

REVISIONS TO THE RADIOPHYSICAL ENVIRONMENTAL MONITORING PROGRAM  
BYRON STATION Cont'd

DATE (ODCM Revision)	SAMPLE TYPE	MONITORING LOCATION	COMMENTS
'87 (11B)	A11	A11	Addition Listed distances from the center of the station in kilometers and listed sectors.
	Airborne	A11	Deletion Sr-89 and 90 analysis
		BY-21	Revision Onsite, W, was retitled to BY Nearsite, N.
		BY-22	Revision CECo Property, W, was retitled to BY Nearsite, ESE.
		BY-23	Revision Onsite, S, was retitled to BY Nearsite, S.
		BY-24	Revision The Meteorological Tower was retitled to BY Nearsite, SW.
	Direct Radiation	All	Addition The station code, BY, proceeds the identification number.
	Ground/Well Water	All	Deletion Sr-89 and 90 analysis
		All	Revision Collection to occur biweekly, not quarterly.
		All	Addition Analysis frequency is clarified the following ODCM statement: "I-131 analysis to occur biweekly when dose rate calculations from water consumption exceeds >1 mrem/yr."
		BY-14	Revision CECo Property was retitled Offsite Well.
		BY-18	Addition McGoy Farm Well is identified as CECO owned.
	Surface Water	All	Deletion Gross beta, Sr-89 and 90 analyses
	Cooling Water	All	Deletion
	Sediments	All	Deletion Gross beta analysis.
		All	Revision Collection frequency was changed to semiannually, not three times a year.
	Precipitation	All	Deletion
	Aquatic Plants	All	Deletion
	Milk	All	Deletion Sr-89 and 90 analysis
	Cattlefeed and Grass	All	Deletion
	Vegetables	All	Deletion
	Food Products		Addition Gross beta, I-131, Sr-89 and 90 analyses annually. Analysis frequency is clarified with the following ODCM statement: "Gamma isotopic and I-131 analyses shall occur at two different offsite monitoring locations and a location that is 15-30 km from the station having the highest predicted annual average ground level D/Q if milk sampling is not performed."

APPENDIX V

ADDENDA

BYRON NUCLEAR POWER STATION  
EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT  
JANUARY TO JUNE 1989

ADDENDUM

A. The following is the breakdown for the continuous releases for gaseous effluents:

1st quarter:      Xe-133  19.8 Curies  
                      Xe-135  0.077 Curies  
  
                      TOTAL = 19.88 Curies

2nd quarter:      No continuous releases

B. The following data is the estimated composition of Byron's solid waste streams:

1. Dry Active Waste (DAW)	2. Primary Resin	3. Radwaste Resin
C-14      7.7%	Mn-54      1.54%	Mn-54      2.7%
Mn-54      4.0%	Co-58      60.9%	Co-58      30.6%
Fe-55      46.6%	Co-60      4.3%	Co-60      6.8%
Co-58      12.2%	Cs-134      8.7%	Cs-134      17.8%
Co-60      12.0%	Cs-137      7.5%	Cs-137      24.3%
Cs-134      3.3%	H-3      0.6%	H-3      9.0%
Cs-137      5.8%	C-14      1.2%	C-14      0.45%
Ni-63      8.4%	Fe-55      14.3%	Fe-55      6.8%
	Ni-63      0.9%	Tc-99      0.05%
	Sr-90      0.02%	I-129      0.1%
	Tc-99      0.03%	Pu-239      0.01%
	I-129      0.001%	Pu-238      0.01%
	Pu-239      0.001%	Am-241      0.04%
	Pu-238      0.001%	Cm-244      0.04%
	Am-241      0.001%	Ni-63      1.3%
	Cm-244      0.001%	
	Pu-241      0.005%	

C. Per Technical Specifications 3.3.3.9 and 3.3.3.10, the following is a summary of effluent monitoring instrumentation inoperable for a period of time greater than specified in the Technical Specification:

1. Unit 1 Reactor Containment Fan Cooler Essential Service Water Outlet Monitor was inoperable for greater than 30 days. The extended period of inoperability was due to a faulty sample pump.

D. During this period, there were no major changes to the liquid, gaseous, or solid radwaste treatment systems. There were no major changes to the Process Control Program (PCP). Byron Station continues to utilize the services of Westinghouse-Hittman for dewatering and solidification services.

E. Error Analysis

The following is an estimate of the errors associated with effluent monitoring and analysis. The estimate is calculated using the square root of the sum of the squares methodology.

1. Gaseous Effluents

Sampling error = 1 to 3.5%	
Calibration error = 10%	
Counting Statistics error = 5%	
Vent Stack flowrates error = 1.5%	
<hr/>	
Total error = 11 - 12%	

2. Liquid Effluents

Sampling error = 1%	
Calibration error = 10%	
Sample volume error = 1%	
Discharged volume error = 2%	
<hr/>	
Total error = 10%	

F. Meteorological and environmental impact information is reported in the Station Annual Radiological Environmental Operating Report as required by Technical Specification 6.9.1.6.

BYRON NUCLEAR POWER STATION  
EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT  
JULY TO DECEMBER 1989

ADDENDUM

- A. The following is the breakdown for the continuous releases for gaseous effluents:

3rd quarter: No continuous releases.

4th quarter: Xe-133 36.1 Curies

- B. The following data is the estimated composition of Byron's solid waste streams:

1. Dry Active Waste (DAW)		2. Primary Resin		3. Radwaste Resin	
C-14	4.3%	Mn-54	20.79%	Mn-54	7.1%
Mn-54	1.5%	Co-58	11.14%	Co-58	51.95%
Fe-55	60.6%	Co-60	9.28%	Co-60	9.97%
Co-58	13.3%	Cs-134	7.05%	Cs-134	9.90%
Co-60	15.5%	Cs-137	15.22%	Cs-137	9.01%
Cs-134	1.3%	H-3	1.15%	H-3	0.022%
Cs-137	1.4%	C-14	2.49%	C-14	0.419%
Ni-63	2.06%	Fe-55	30.80%	Fe-55	9.69%
Sr-90	0.038%	Ni-63	1.97%	Tc-99	1.89%
Tc-99	0.005%	Sr-90	0.048%	I-129	0.004%
I-129	0.0001%	Tc-99	0.052%	Pu-239	0.004%
		I-129	0.001%	Pu-238	0.002%
		Pu-239	0.0004%	Am-241	0.005%
		Pu-238	0.0003%	Cm-244	0.014%
		Am-241	0.0002%	Ni-63	0.016%
		Cm-244	0.0002%		
		Pu-241	0.012%		

- C. Per Technical Specifications 3.3.3.9 and 3.3.3.10, there were no effluent monitoring instrumentation inoperable for a period of time greater than specified in the Technical Specification.

- D. During this period, there were three changes to the liquid, gaseous, or solid radwaste treatment systems. There were no major changes to the Process Control Program (PCP). Byron Station continues to utilize the services of Westinghouse-Hittman for dewatering and solidification services. The three radwaste treatment systems changes are as follows:

Radwaste Changes For 89

- 1) MOD 0-87-116: Installed bypass line around the Spent Resin Storage Tank to allow transferring a low activity bed for disposal and holding a high activity bed in the SRST.

- 2) MOD 0-88-012: Installed separate control switches for the WX monitor inlet valves. This allows both valves to be open at the same time and reduces radwaste processing time by half.
- 3) MOD 0-89-034: Converted from dry cleaners to wet wash. This prevents the production of a mixed hazardous waste (Freon).

#### E. Error Analysis

The following is an estimate of the errors associated with effluent monitoring and analysis. The estimate is calculated using the square root of the sum of the squares methodology.

##### 1. Gaseous Effluents

Sampling error	=	1 to 3.5%
Calibration error	=	10%
Counting Statistics error	=	5%
<u>Vent Stack flowrates error</u>	=	<u>1.5%</u>
Total error	=	11 - 12%

##### 2. Liquid Effluents

Sampling error	=	1%
Calibration error	=	10%
Sample volume error	=	1%
<u>Discharged volume error</u>	=	<u>2%</u>
Total error	=	10%

##### 3. Waste Resin

Sampling error	=	5%
Counting Statistics error	=	7%
Weight error	=	1%
<u>Volume error</u>	=	<u>5%</u>
Total error	=	10%

##### 4. DAW

Counting Statistics error	=	7%
Calibration error	=	10%
<u>Weight error</u>	=	<u>2%</u>
Total error	=	12.4%

F. Meteorological and environmental impact information is reported in the Station Annual Radiological Environmental Operating Report as required by Technical Specification 6.9.1.6.

G. No limits were exceeded in liquid hold up tanks as stated in Technical Specifications 3.11.1.4 or in waste gas decay tanks as stated in Technical Specifications 3.11.2.6.

H. There were no irradiated fuel shipments during this period.

I. Lower Limits of Detection are defined in Technical Specifications Table 4.11-1 for liquid and Table 4.11-2 for gaseous waste. The Lower Limits of Detection are as follows:

1. Liquid Waste

- a. Principal Gamma Emitters  $5 \times 10^{-7}$   $\mu\text{Ci}/\text{ml}$
- b. I-131  $1 \times 10^{-5}$   $\mu\text{Ci}/\text{ml}$
- c. Dissolved and Entrained Gases (Gamma Emitters)  $1 \times 10^{-5}$   $\mu\text{Ci}/\text{ml}$
- d. H<sub>3</sub>  $1 \times 10^{-5}$   $\mu\text{Ci}/\text{ml}$
- e. Gross Alpha  $1 \Delta 10^{-7}$   $\mu\text{Ci}/\text{ml}$
- f. Sr 89-90  $5 \times 10^{-8}$   $\mu\text{Ci}/\text{ml}$
- g. Fe 55  $1 \times 10^{-6}$   $\mu\text{Ci}/\text{ml}$

2. Gaseous Waste

a. Waste Gas Decay Tanks and Containment Purge

- 1. Principal Gamma Emitters  $1 \times 10^{-4}$   $\mu\text{Ci}/\text{ml}$
- 2. H<sub>3</sub>  $1 \times 10^{-4}$   $\mu\text{Ci}/\text{ml}$

b. Auxiliary Building Vent Stack Grab

- 1. Principal Gamma  $1 \times 10^{-4}$   $\mu\text{Ci}/\text{ml}$
- 2. H<sub>3</sub>  $1 \times 10^{-7}$   $\mu\text{Ci}/\text{ml}$

c. Auxiliary Building Vent Stack Continuous

- 1. I-131  $1 \times 10^{-12}$   $\mu\text{Ci}/\text{ml}$
- 2. I-133  $1 \times 10^{-10}$   $\mu\text{Ci}/\text{ml}$
- 3. Principal Gamma Emitter  $1 \times 10^{-11}$   $\mu\text{Ci}/\text{ml}$
- 4. Sr 89-90  $1 \times 10^{-11}$   $\mu\text{Ci}/\text{ml}$
- 5. Noble Gas Gross Beta or Gamma  $1 \times 10^{-6}$   $\mu\text{Ci}/\text{ml}$

APPENDIX VI

1989 REMP SAMPLE RESULTS



MIDWEST LABORATORY  
700 LANDWEHR ROAD  
NORTHBROOK, ILLINOIS 60062-2310  
(708) 564-0700 FAX (708) 564-4617

FINAL PROGRESS REPORT  
TO  
COMMONWEALTH EDISON COMPANY

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM (REMP)  
FOR  
BYRON NUCLEAR POWER STATION  
BYRON, ILLINOIS

PREPARED AND SUBMITTED  
BY  
TELEDYNE ISOTOPES MIDWEST LABORATORY

Reporting Period: January - December, 1989

Reviewed and  
Approved by:

A handwritten signature in black ink, appearing to read "L.G. Huebner".

Date 3-19-80

L. G. Huebner  
General Manager

BYRON

TABLE OF CONTENTS

<u>Section</u>		<u>Page</u>
	List of Tables . . . . .	iii
1.0	INTRODUCTION . . . . .	1
2.0	LISTING OF MISSED SAMPLES . . . . .	2

BYRON

LIST OF TABLES

No.	Title	Page
1	Airborne Particulates and Iodine-131, Locations By-01, 02, 03, 04 . . . . .	4
2	Airborne Particulates and Iodine-131, Locations By-05, 06, 07, 08 . . . . .	6
3	Airborne Particulates and Iodine-131, Locations By-21, 22, 23, 24 . . . . .	8
4	Airborne Particulates, Quarterly Composites of Weekly Collections . . . . .	10
5	Gamma Radiation, as Measured by TLDs . . . . .	12
6	Milk . . . . .	15
7	Fish, Edible Portions . . . . .	17
8	Vegetables . . . . .	18
9	Surface Water . . . . .	19
10	Well Water . . . . .	21
11	Bottom Sediments . . . . .	23
	Milch Animal and Nearest Residence Census . . . . .	24

BYRON

1.0 INTRODUCTION

The following constitutes the final Progress Report for the Environmental Radiological Monitoring Program conducted at the Byron Nuclear Power Station, Byron, Illinois. Results of completed analyses are presented in the attached tables. Missing entries indicate analyses that are not completed and the results will appear in subsequent reports.

Data obtained in the program are well within the ranges previously encountered in the program and to be expected in the environmental media sampled.

For all gamma isotopic analyses, spectrum is computer scanned from 80 to 2048 KeV. Specifically included are Mn-54, Co-58, Fe-59, Co-60, Zn-65, Zr-95, Nb-95, Ru-103, Ru-106, I-131, Ba-La-140, Cs-134, Cs-137, Ce-141, and Ce-144. Naturally occurring gamma-emitters, such as K-40 and Ra daughters, are frequently detected but not listed here. Data listed as "<" are at the 4.66 sigma level, others are 2 sigma. Cs-134 and Cs-137 are listed separately. All other gamma emitters are listed under "Other Gammas". Unless noted otherwise, the less than value ("<") reported under "Other Gammas" is for Co-60 and may be higher or lower for other radionuclides.

All concentrations, except gross beta, are decay corrected to the time of collection.

Deviations from Scheduled Sampling and Corrective Actions Taken

All samples were collected within the scheduled period unless noted otherwise in the Listing of Missed Samples.

## BYRON

LISTING OF MISSED SAMPLES

Sample Type	Location	Expected Collection Date	Reason
Well Water	BY-14	01-23-89	No power to pump.
	BY-14	01-30-89	No power to pump.
Milk	BY-20	01-02-89	No sample available.
Surface Water	BY-09	01-02-89	River frozen.
	BY-09	01-09-89	River frozen.
	BY-09	01-16-89	River frozen.
	BY-09	01-23-89	River frozen.
	BY-12	01-02-89	River frozen.
	BY-12	01-09-89	River frozen.
	BY-12	01-16-89	River frozen.
	BY-12	01-23-89	River frozen.
	BY-13	01-02-89	River frozen.
	BY-13	01-09-89	River frozen.
Surface Water	BY-09	02-06-89	River frozen.
	BY-09	02-13-89	River frozen.
	BY-09	02-20-89	River frozen.
	BY-09	02-27-89	River frozen.
	BY-09	03-06-89	River frozen.
Surface Water	BY-12	02-06-89	River frozen.
	BY-12	02-13-89	River frozen.
	BY-12	02-20-89	River frozen.
	BY-12	02-27-89	River frozen.
	BY-12	03-06-89	River frozen.
Surface Water	BY-13	02-06-89	River frozen.
	BY-13	02-13-89	River frozen.
	BY-13	02-20-89	River frozen.
	BY-13	02-27-89	River frozen.
	BY-13	03-06-89	River frozen.
	BY-09	12-26-89	River frozen.
	BY-13	12-26-89	River frozen.

NOTE: Page 3 is intentionally left out.

## BYRON

Table 1. Airborne Particulates and Iodine-131<sup>a</sup>  
 Collection: Weekly  
 Units:  $10^{-2}$  pCi/m<sup>3</sup>

Week Ending	Byron BY-01		Stillman Valley BY-02 (C)		Near Site E BY-03		Paynes Point BY-04	
	Volume (m <sup>3</sup> )	Gross Beta	Volume (m <sup>3</sup> )	Gross Beta	Volume (m <sup>3</sup> )	Gross Beta	Volume (m <sup>3</sup> )	Gross Beta
01-09-89	284	5.3±0.5	274	5.6±0.5	282	4.7±0.5	282	4.6±0.5
01-16-89	286	2.9±0.4	286	<0.4 <sup>b</sup>	286	3.1±0.4	285	2.8±0.4
01-23-89	286	2.0±0.4	285	2.3±0.4	285	2.0±0.4	285	2.1±0.4
01-30-89	285	3.6±0.4	285	3.5±0.4	285	4.0±0.4	285	3.3±0.4
02-06-89	286	5.0±0.5	296	4.3±0.5	289	4.5±0.5	288	4.3±0.5
02-13-89	284	2.5±0.4	275	2.9±0.4	282	3.0±0.4	283	2.6±0.4
02-20-89	286	2.1±0.4	286	2.1±0.4	286	2.4±0.4	286	1.6±0.4
02-27-89	285	3.5±0.4	285	3.6±0.4	284	3.5±0.4	284	3.4±0.4
03-06-89	284	2.5±0.4	291	3.2±0.4	286	2.6±0.4	286	2.9±0.4
03-13-89	285	3.4±0.4	278	3.3±0.4	285	2.7±0.4	285	3.0±0.4
03-20-89	283	3.0±0.3	283	3.0±0.3	284	2.9±0.3	283	2.7±0.3
03-27-89	285	2.7±0.4	285	2.8±0.4	286	3.0±0.4	286	3.1±0.4
04-03-89	286	2.5±0.4	296	2.2±0.4	289	2.0±0.4	288	1.9±0.4
1st Qtr mean±s.d.	3.2±1.0		3.2±1.0		3.1±0.9		2.9±0.9	
04-10-89	284	1.8±0.4	274	1.7±0.4	283	1.5±0.4	283	1.6±0.4
04-17-89	285	3.4±0.4	285	3.5±0.5	283	3.5±0.5	283	3.3±0.4
04-24-89	285	2.2±0.4	285	1.8±0.4	285	2.0±0.4	285	2.2±0.4
05-01-89	288	1.8±0.4	294	2.0±0.4	288	2.4±0.4	288	1.8±0.4
05-08-89	285	1.1±0.4	278	1.5±0.4	285	1.4±0.4	285	1.4±0.4
05-15-89	284	1.2±0.3	284	1.6±0.3	284	1.6±0.3	284	1.0±0.3
05-22-89	285	2.8±0.3	278	3.1±0.3	284	2.9±0.3	284	2.3±0.3
05-29-89	289	1.6±0.3	286	2.3±0.3	290	2.1±0.3	288	1.6±0.3
06-05-89	280	2.0±0.2	281	2.4±0.2	274	2.0±0.2	280	1.8±0.2
06-12-89	283	1.4±0.3	286	2.1±0.4	290	1.6±0.3	283	1.4±0.3
06-19-89	289	2.3±0.4	295	1.8±0.4	290	1.7±0.4	290	1.7±0.4
06-26-89	288	2.6±0.4	287	2.3±0.4	287	2.0±0.3	287	2.4±0.4
07-03-89	288	2.0±0.3	290	2.1±0.3	290	1.9±0.3	289	1.9±0.3
2nd Qtr mean±s.d.	2.0±0.6		2.2±0.6		2.0±0.6		1.9±0.6	

<sup>a</sup> Iodine-131 concentrations are <0.07 pCi/m<sup>3</sup> unless noted otherwise.

<sup>b</sup> Filter paper very light.

## BYRON

Table 1. Airborne Particulates and Iodine-131<sup>a</sup> (continued)

Week Ending	Byron BY-01		Stillman Valley BY-02 (C)		Near Site E BY-03		Paynes Point BY-04	
	Volume (m <sup>3</sup> )	Gross Beta	Volume (m <sup>3</sup> )	Gross Beta	Volume (m <sup>3</sup> )	Gross Beta	Volume (m <sup>3</sup> )	Gross Beta
07-10-89	284	3.1±0.3	272	2.9±0.3	281	1.4±0.2	272	2.8±0.3
07-17-89	285	2.0±0.2	292	1.8±0.2	284	2.1±0.2	285	2.0±0.2
07-24-89	284	1.9±0.2	278	1.9±0.2	284	2.0±0.2	284	1.9±0.2
07-31-89	286	1.4±0.3	286	1.6±0.3	286	1.3±0.3	286	1.4±0.3
08-07-89	288	2.0±0.3	298	1.8±0.3	290	1.9±0.3	290	1.8±0.3
08-14-89	281	2.2±0.3	272	3.0±0.4	279	2.6±0.4	279	2.4±0.3
08-21-89	286	2.2±0.3	292	2.5±0.3	286	2.4±0.3	286	2.2±0.3
08-28-89	293	1.7±0.3	288	1.8±0.3	294	2.4±0.4	294	1.6±0.3
09-04-89	279	1.3±0.3	286	1.8±0.3	280	1.2±0.3	280	1.5±0.3
09-11-89	285	1.6±0.3	277	1.8±0.4	284	1.2±0.3	284	1.4±0.3
09-18-89	285	1.5±0.3	285	1.8±0.3	285	2.1±0.3	285	1.6±0.3
09-25-89	286	2.3±0.3	277	2.9±0.4	284	2.9±0.4	283	2.4±0.3
10-02-89	288	2.9±0.4	297	3.0±0.4	290	3.4±0.4	290	3.0±0.4
3rd Qtr mean±s.d.	2.0±0.5			2.2±0.6		2.1±0.7		2.0±0.5
10-09-89	285	1.9±0.3	274	1.9±0.3	283	2.5±0.3	283	1.7±0.3
10-16-89	282	2.9±0.4	290	3.9±0.4	281	3.5±0.4	281	3.5±0.4
10-23-89	286	2.0±0.3	281	2.4±0.3	286	2.0±0.3	286	1.8±0.3
10-30-89	288	3.8±0.4	287	4.0±0.4	288	1.8±0.3	288	4.2±0.4
11-06-89	287	2.0±0.3	294	2.3±0.3	287	1.1±0.3	287	2.4±0.3
11-13-89	284	1.5±0.3	277	1.5±0.3	283	0.8±0.3	283	1.6±0.3
11-20-89	287	2.7±0.4	286	3.0±0.4	286	1.6±0.3	288	3.0±0.4
11-27-89	285	3.4±0.4	285	2.9±0.4	284	2.1±0.3	284	3.0±0.4
12-04-89	285	2.8±0.4	291	2.8±0.4	286	3.0±0.4	286	3.2±0.4
12-11-89	288	2.7±0.4	280	2.8±0.4	287	3.0±0.4	287	3.0±0.4
12-18-89	282	4.3±0.4	283	4.4±0.4	283	4.8±0.4	283	4.2±0.4
12-26-89	329	3.6±0.4	329	3.4±0.4	329	3.8±0.4	329	3.6±0.4
01-02-90	285	1.9±0.3	296	2.4±0.3	288	2.0±0.3	288	2.4±0.3
4th Qtr mean±s.d.	2.7±0.8			2.9±0.8		2.5±1.1		2.9±0.9

<sup>a</sup> Iodine-131 concentrations are <0.07 pCi/m<sup>3</sup> unless noted otherwise.

## BYRON

Table 2. Airborne Particulates and Iodine-131<sup>a</sup>  
 Collection: Weekly  
 Units: 10<sup>-2</sup> pCi/m<sup>3</sup>

Week Ending	Near Site S BY-05		Oregon BY-06		Mt. Morris BY-07 (C)		Leaf River BY-08 (C)	
	Volume (m <sup>3</sup> )	Gross Beta						
01-09-89	282	5.5±0.5	284	5.6±0.5	284	5.3±0.5	284	5.3±0.5
01-16-89	286	3.3±0.4	286	3.1±0.4	286	3.1±0.4	286	3.0±0.4
01-23-89	285	2.2±0.4	285	2.4±0.4	285	2.2±0.4	285	2.4±0.4
01-30-89	285	3.5±0.4	285	3.7±0.4	285	3.0±0.4	285	3.4±0.4
02-06-89	287	4.6±0.5	286	4.4±0.5	286	4.2±0.5	286	4.7±0.5
02-13-89	284	3.6±0.5	285	3.0±0.4	285	2.4±0.4	285	2.7±0.4
02-20-89	286	2.3±0.4	286	2.4±0.4	286	2.8±0.4	286	1.5±0.4
02-27-89	284	3.8±0.5	285	3.0±0.4	285	3.4±0.4	285	3.2±0.4
03-06-89	286	3.0±0.4	286	3.6±0.4	286	3.0±0.4	284	3.5±0.4
03-13-89	285	3.8±0.5	285	3.1±0.4	285	3.5±0.4	285	2.8±0.4
03-20-89	283	2.9±0.3	283	2.9±0.3	285	2.3±0.3	284	2.5±0.3
03-27-89	285	2.9±0.4	285	2.4±0.4	286	2.7±0.4	286	2.4±0.4
04-03-89	288	1.9±0.4	285	2.4±0.4	285	1.9±0.4	285	2.2±0.4
1st Qtr mean±s.d.	3.3±1.0			3.2±0.9		3.1±0.9		3.0±1.0
04-10-89	282	1.4±0.4	284	2.1±0.4	284	1.4±0.4	284	1.8±0.4
04-17-89	285	3.4±0.4	285	4.2±0.5	285	3.2±0.4	285	3.1±0.4
04-24-89	285	2.5±0.4	285	2.8±0.4	285	1.6±0.4	285	2.1±0.4
05-01-89	288	2.5±0.4	287	2.3±0.4	286	1.9±0.4	286	1.9±0.4
05-08-89	284	1.4±0.4	285	1.5±0.4	286	1.0±0.4	286	1.2±0.4
05-15-89	285	1.8±0.3	284	2.0±0.4	283	1.7±0.3	283	1.5±0.3
05-22-89	284	2.6±0.3	284	3.2±0.3	286	2.6±0.3	286	2.7±0.3
05-29-89	287	1.9±0.3	286	2.0±0.3	288	1.7±0.3	288	2.0±0.3
06-05-89	280	2.1±0.2	281	2.4±0.2	282	2.2±0.2	282	2.2±0.2
06-12-89	283	1.7±0.3	283	1.7±0.3	283	1.8±0.3	283	1.6±0.3
06-19-89	290	1.5±0.4	289	1.8±0.4	289	1.6±0.4	289	1.6±0.4
06-26-89	287	2.4±0.4	287	2.6±0.4	288	2.2±0.4	288	2.2±0.4
07-03-89	289	1.9±0.3	288	2.1±0.3	286	1.6±0.3	286	1.8±0.3
2nd Qtr mean±s.d.	2.1±0.6			2.4±0.7		1.9±0.6		2.0±0.5

<sup>a</sup> Iodine-131 concentrations are <0.07 pCi/m<sup>3</sup> unless noted otherwise.

## BYRON

Table 2. Airborne Particulates and Iodine-131<sup>a</sup> (continued)

Week Ending	Near Site S BY-05		Oregon BY-06		Mt. Morris BY-07 (C)		Leaf River BY-08 (C)	
	Volume (m <sup>3</sup> )	Gross Beta						
07-10-89	282	2.7±0.3	272	3.0±0.3	284	2.6±0.3	284	2.6±0.3
07-17-89	285	1.9±0.2	284	2.2±0.2	285	1.9±0.2	285	1.9±0.2
07-24-89	284	2.2±0.2	285	2.2±0.2	285	1.8±0.2	285	1.6±0.2
07-31-89	286	1.6±0.3	286	1.4±0.3	286	1.5±0.3	286	1.1±0.3
08-07-89	290	2.3±0.4	286	1.6±0.3	280	1.8±0.3	288	1.6±0.3
08-14-89	281	2.6±0.4	283	2.7±0.4	283	2.7±0.4	283	2.7±0.4
08-21-89	286	2.7±0.3	286	2.2±0.3	286	2.2±0.3	286	1.9±0.3
08-28-89	294	2.2±0.3	294	2.0±0.3	294 <sup>b</sup>	1.7±0.3	293	1.7±0.3
09-04-89	279	1.8±0.3	279	1.8±0.3	279	0.7±0.3	279	1.6±0.3
09-11-89	284	2.6±0.4	286	1.8±0.3	286	1.6±0.3	285	1.7±0.3
09-18-89	285	2.3±0.3	284	2.4±0.3	285	2.4±0.3	285	2.3±0.3
09-25-89	283	2.5±0.3	286	3.1±0.4	286	2.6±0.3	285	3.0±0.4
10-02-89	290	2.8±0.4	286	3.0±0.4	294	2.7±0.4	293	3.4±0.4
3rd Qtr mean±s.d.	2.3±0.4		2.3±0.6		2.1±0.6		2.1±0.7	
10-09-89	283	1.7±0.3	286	1.8±0.3	286	1.7±0.3	285	2.2±0.3
10-16-89	282	3.7±0.4	283	3.9±0.4	283	2.9±0.4	284	3.6±0.4
10-23-89	286	0.7±0.2	286	2.3±0.3	286	1.9±0.3	286	2.3±0.3
10-30-89	288	4.7±0.4	289	4.3±0.4	287	4.0±0.4	287	3.9±0.4
11-06-89	287	2.4±0.3	285	1.9±0.3	287	1.6±0.3	286	2.5±0.4
11-13-89	283	1.9±0.3	285	1.4±0.3	285	1.4±0.3	285	1.7±0.3
11-20-89	287	3.3±0.4	287	3.2±0.4	286	2.6±0.4	286	3.0±0.4
11-27-89	285	3.3±0.4	285	3.2±0.4	285	2.8±0.4	285	3.5±0.4
12-04-89	285	3.6±0.4	284	3.3±0.4	284	3.1±0.4	284	2.7±0.4
12-11-89	287	2.4±0.4	288	3.1±0.4	288	3.1±0.4	288	2.6±0.4
12-18-89	283	4.5±0.4	283	4.7±0.4	283	4.1±0.4	283	4.2±0.4
12-26-89	329	3.4±0.4	329	4.4±0.4	329	4.0±0.4	329	4.5±0.4
01-02-90	296	2.5±0.3	284	2.3±0.3	284	2.1±0.3	284	2.4±0.3
4th Qtr mean±s.d.	2.9±1.1		3.1±1.1		2.7±0.9		3.0±0.9	

<sup>a</sup> Iodine-131 concentrations are <0.07 pCi/m<sup>3</sup> unless noted otherwise.<sup>b</sup> Timer out of order, volume is assumed.

## BYRON

Table 3. Airborne Particulates and Iodine-131<sup>a</sup>  
 Collection: Weekly  
 Units:  $10^{-2}$  pCi/m<sup>3</sup>

Week Ending	BY-21		BY-22		BY-23		BY-24	
	Volume (m <sup>3</sup> )	Gross Beta						
01-09-89	284	5.7±0.5	284	4.3±0.5	284	1.2±0.3	284	6.6±0.5
01-16-89	286	3.5±0.4	286	3.4±0.4	286	3.6±0.4	286	3.2±0.4
01-23-89	285	2.9±0.4	285	2.4±0.4	286	3.1±0.4	286	2.7±0.4
01-30-89	285	3.6±0.4	285	4.0±0.4	285	4.2±0.4	285	4.0±0.4
02-06-89	287	4.9±0.5	287	5.5±0.5	287	5.4±0.5	287	5.0±0.5
02-13-89	284	2.6±0.4	284	2.8±0.4	284	4.2±0.5	284	3.2±0.4
02-20-89	286	2.2±0.4	286	2.0±0.4	286	2.7±0.4	286	2.3±0.4
02-27-89	285	3.2±0.4	285	3.7±0.5	285	3.6±0.4	284	3.5±0.4
03-06-89	287	3.5±0.4	286	3.1±0.4	286	3.3±0.4	286	3.1±0.4
03-13-89	285	4.0±0.5	285	3.2±0.4	285	3.0±0.4	285	3.5±0.4
03-20-89	285	3.1±0.3	283	3.0±0.3	283	3.0±0.3	283	3.0±0.3
03-27-89	286	2.7±0.4	286	3.4±0.4	286	3.0±0.4	285	3.3±0.4
04-03-89	287	2.2±0.4	286	2.1±0.4	287	2.4±0.4	287	2.5±0.4
1st Qtr mean±s.d.	3.4±1.0		3.3±1.0		3.3±1.0		3.5±1.1	
04-10-89	284	1.3±0.3	284	1.4±0.4	283	1.5±0.4	283	1.7±0.4
04-17-89	285	4.1±0.5	285	3.4±0.4	285	4.1±0.5	285	3.4±0.4
04-24-89	285	2.1±0.4	285	2.6±0.4	285	2.4±0.4	285	2.5±0.4
05-01-89	288	2.4±0.4	288	2.1±0.4	288	2.4±0.4	288	2.2±0.4
05-08-89	285	0.8±0.4	285	0.6±0.4	285	0.5±0.4	285	<0.6
05-15-89	283	1.6±0.3	283	1.5±0.3	284	1.6±0.3	284	1.5±0.3
05-22-89	285	2.7±0.3	285	2.7±0.3	285	2.4±0.3	285	2.7±0.3
05-29-89	288	2.0±0.3	286	2.0±0.3	287	2.3±0.3	272	2.4±0.4
06-05-89	282	2.4±0.2	187	3.5±0.4	282	2.3±0.2	280	2.6±0.3
06-12-89	283	1.9±0.3	283	2.1±0.4	283	1.7±0.3	283	2.0±0.3
06-19-89	289	1.8±0.4	289	1.7±0.4	289	1.9±0.4	290	1.9±0.4
06-26-89	287	2.4±0.4	288	2.2±0.4	287	2.5±0.4	287	2.8±0.4
07-03-89	288	1.1±0.3	288	1.8±0.3	288	2.2±0.3	288	2.3±0.3
2nd Qtr mean±s.d.	2.0±0.8		2.1±0.8		2.1±0.8		2.3±0.5	

<sup>a</sup> Iodine-131 concentrations are <0.07 pCi/m<sup>3</sup> unless noted otherwise.

## BYRON

Table 3. Airborne Particulates and Iodine-131<sup>a</sup> (continued)

Week Ending	BY-21		BY-22		BY-23		BY-24	
	Volume (m <sup>3</sup> )	Gross Beta						
07-10-89	283	3.8±0.3	283	3.0±0.3	283	2.8±0.3	283	2.7±0.3
07-17-89	285	2.0±0.2	285	2.1±0.2	285	2.0±0.2	285	1.9±0.2
07-24-89	284	2.1±0.2	284	2.0±0.2	284	2.1±0.2	284	2.1±0.2
07-31-89	286	1.8±0.4	286	1.8±0.4	286	1.6±0.3	286	1.9±0.4
08-07-89	272	2.0±0.4	272	2.1±0.4	289	1.9±0.3	284	1.7±0.3
08-14-89	281	3.5±0.4	281	3.1±0.4	280	3.1±0.4	280	3.1±0.4
08-21-89	286	3.2±0.3	286	2.6±0.3	286	2.4±0.3	287	2.7±0.3
08-28-89	294	2.4±0.4	294	1.7±0.3	294	1.9±0.3	294	1.9±0.3
09-04-89	278	1.9±0.3	279	1.8±0.3	279	1.8±0.3	279	2.0±0.3
09-11-89	285	2.0±0.4	285	2.0±0.4	285	1.8±0.3	285	2.1±0.4
09-18-89	284	2.0±0.3	285	1.8±0.3	285	1.9±0.3	285	2.6±0.4
09-25-89	284	3.0±0.4	283	2.9±0.4	283	2.6±0.3	283	2.6±0.3
10-02-89	284	2.4±0.4	293	0.6±0.3	285	2.7±0.4	285	4.1±0.5
3rd Qtr mean±s.d.	2.5±0.7			2.1±0.7		2.2±0.5		2.4±0.7
10-09-89	284	2.1±0.3	284	2.5±0.3	284	1.6±0.3	284	2.0±0.3
10-16-89	281	3.9±0.4	282	4.0±0.4	282	3.8±0.4	282	3.6±0.4
10-23-89	286	2.3±0.3	286	2.2±0.3	286	2.2±0.3	286	2.2±0.3
10-30-89	288	4.4±0.4	288	4.2±0.4	288	4.4±0.4	288	4.8±0.4
11-06-89	287	2.6±0.4	287	2.3±0.3	287	2.4±0.3	287	3.1±0.4
11-13-89	283	1.9±0.3	283	2.0±0.3	283	2.0±0.3	283	2.1±0.4
11-20-89	287	3.2±0.4	287	3.7±0.4	287	2.9±0.4	287	3.5±0.4
11-27-89	282	1.2±0.3	284	3.0±0.4	284 <sup>b</sup>	<0.04	285	3.1±0.4
12-04-89	285	3.3±0.4	285	3.3±0.4	285	3.1±0.4	285	3.0±0.4
12-11-89	288	3.3±0.4	287	3.2±0.4	287	2.3±0.4	287	3.5±0.4
12-18-89	282	4.7±0.4	282	3.6±0.4	283	4.7±0.4	283	5.1±0.4
12-26-89	328	4.1±0.4	328	4.5±0.4	328	4.2±0.4	329	4.0±0.4
01-02-90	285	2.7±0.4	286	2.4±0.3	286	2.7±0.4	286	2.3±0.3
4th Qtr mean±s.d.	3.1±1.0			3.1±0.8		3.0±1.0		3.2±1.0

<sup>a</sup> Iodine-131 concentrations are <0.07 pCi/m<sup>3</sup> unless noted otherwise.<sup>b</sup> filter paper very light, probably due to improper seating of filter in housing.

## BYRON

Table 4. Airborne Particulates  
 Collection: Quarterly composites of weekly collections  
 Units: pCi/m<sup>3</sup>

Location	Lab Code	Volume (m <sup>3</sup> )	Cs-134	Cs-137	Other Gammas <sup>a</sup>
<u>1st Quarter 1989</u>					
BY-01	BYAP-1459	3705	<0.01	<0.01	<0.01
BY-02	1460	3705	<0.01	<0.01	<0.01
BY-03	1461	3709	<0.01	<0.01	<0.01
BY-04	1462	3706	<0.01	<0.01	<0.01
BY-05	1463	3706	<0.01	<0.01	<0.01
BY-06	1464	3706	<0.01	<0.01	<0.01
BY-07	1465	3709	<0.01	<0.01	<0.01
BY-08	1466	3706	<0.01	<0.01	<0.01
BY-21	1467	3712	<0.01	<0.01	<0.01
BY-22	1468	3708	<0.01	<0.01	<0.01
BY-23	1469	3710	<0.01	<0.01	<0.01
BY-24	1470	3708	<0.01	<0.01	<0.01
<u>2nd Quarter 1989</u>					
BY-01	BYAP-1568	3713	<0.01	<0.01	<0.01
BY-02	1569	3703	<0.01	<0.01	<0.01
BY-03	1570	3713	<0.01	<0.01	<0.01
BY-04	1571	3709	<0.01	<0.01	<0.01
BY-05	1572	3709	<0.01	<0.01	<0.01
BY-06	1573	3708	<0.01	<0.01	<0.01
BY-07	1574	3711	<0.01	<0.01	<0.01
BY-08	1575	3711	<0.01	<0.01	<0.01
BY-21	1576	3712	<0.01	<0.01	<0.01
BY-22	1577	3616	<0.01	<0.01	<0.01
BY-23	1578	3711	<0.01	<0.01	<0.01
BY-24	1579	3695	<0.01	<0.01	<0.01

<sup>a</sup> See Introduction.

## BYRON

Table 4. Airborne Particulates

Collection: Quarterly composites of weekly collections  
 Units: pCi/m<sup>3</sup>

Location	Lab Code	Volume (m <sup>3</sup> )	Cs-134	Cs-137	Other Gammas <sup>a</sup>
<u>3rd Quarter 1988</u>					
BY-01	BYAP-1672	3710	NA	<0.01	<0.01
BY-02	1673	3700	<0.01	<0.01	<0.01
BY-03	1674	3707	<0.01	<0.01	<0.01
BY-04	1675	3698	<0.01	<0.01	<0.01
BY-05	1676	3709	<0.01	<0.01	<0.01
BY-06	1677	3697	<0.01	<0.01	<0.01
BY-07	1678	3713	<0.01	<0.01	<0.01
BY-08	1679	3717	<0.01	<0.01	<0.01
BY-21	1680	3686	<0.01	<0.01	<0.01
BY-22	1681	3696	<0.01	<0.01	<0.01
BY-23	1682	3704	<0.01	<0.01	<0.01
BY-24	1683	3700	<0.01	<0.01	<0.01
<u>4th Quarter 1988</u>					
BY-01	BYAP-1779	3753	<0.01	<0.01	<0.01
BY-02	1780	3753	<0.01	<0.01	<0.01
BY-03	1781	3751	<0.01	<0.01	<0.01
BY-04	1782	3753	<0.01	<0.01	<0.01
BY-05	1783	3761	<0.01	<0.01	<0.01
BY-06	1784	3754	<0.01	<0.01	<0.01
BY-07	1785	3753	<0.01	<0.01	<0.01
BY-08	1786	3752	<0.01	<0.01	<0.01
BY-21	1787	3746	<0.01	<0.01	<0.01
BY-22	1788	3749	<0.01	<0.01	<0.01
BY-23	1789	3750	<0.01	<0.01	<0.01
BY-24	1790	3752	<0.01	<0.01	<0.01

<sup>a</sup> See Introduction.

## BYRON

Table 5. Gamma Radiation, as Measured by Thermoluminescent Dosimeters (TLDs)

## STANDARD RADIOLOGICAL MONITORING PROGRAM

	<u>1st Quarter</u>	<u>2nd Quarter</u>	<u>3rd Quarter</u>	<u>4th Quarter</u>
Date Placed:	01-02-89	04-03-89	07-03-89	10-02-89
Date Removed:	04-03-89	07-03-89	10-02-89	01-02-90
Days in the Field:	91	91	91	91
<u>Location</u>		<u>Average mR/Qtr.</u>		
<u>Offsite Indicator Locations</u>				
BY-01 - Byron	13.5±0.9	12.6±0.9	12.6±1.3	13.0±0.8
BY-03 - Nearsite East	12.3±0.9	16.6±1.2	16.0±0.9	15.9±0.9
BY-04 - Paynes Point	11.9±0.9	16.8±1.3	14.8±0.9	16.2±0.8
BY-05 - Nearsite South	13.9±0.8	19.0±1.3	17.0±0.9	17.6±1.3
BY-06 - Oregon	<u>12.1±1.0</u>	<u>14.8±1.5</u>	<u>13.9±1.0</u>	<u>13.6±0.8</u>
Mean ± s.d.	12.7±0.9	16.0±2.4	14.9±1.7	15.3±1.9
<u>Onsite Indicator Locations</u>				
BY-21 - Onsite North	9.6±1.0	11.0±0.8	11.4±0.9	11.5±0.7
BY-22 - Onsite ESE	15.3±1.2	18.8±0.8	18.0±1.1	18.5±1.1
BY-23 - Onsite South	14.0±1.3	17.5±0.8	16.7±1.4	16.9±0.9
BY-24 - Met. Tower	<u>12.3±1.2</u>	<u>16.8±1.0</u>	<u>15.8±1.4</u>	<u>16.7±0.9</u>
Mean ± s.d.	12.8±2.5	16.0±3.4	15.5±2.9	15.9±3.0
<u>Background Locations</u>				
BY-02 - Stillman Valley	10.9±0.9	13.3±0.8	13.3±1.0	14.0±0.8
BY-07 - Mt. Morris	11.6±0.8	15.8±1.0	14.4±1.1	15.6±0.8
BY-08 - Leaf River	<u>12.0±0.9</u>	<u>14.6±1.1</u>	<u>14.4±1.3</u>	<u>14.1±0.7</u>
Mean ± s.d.	11.5±0.6	14.6±1.2	14.0±0.6	14.6±0.9

## BYRON

Table 5. Gamma Radiation, as Measured by TLDs (continued)

	<u>SPECIAL PROGRAM</u>			
	<u>Inner Ring, Near Site Boundary, Indicator Locations</u>			
	<u>1st Quarter</u>	<u>2nd Quarter</u>	<u>3rd Quarter</u>	<u>4th Quarter</u>
Date Placed:	01-02-89	04-03-89	07-03-89	10-02-89
Date Removed:	04-03-89	07-03-89	10-02-89	01-02-90
Days in the Field:	91	91	91	91
Location	<u>Average mR/Qtr.</u>			
BY-101-1	13.2±1.3	17.9±0.8	17.2±1.6	17.4±0.7
BY-101-2	15.9±0.9	18.6±0.8	16.8±0.8	18.0±0.7
BY-102-1	13.9±1.0	19.1±0.8	17.1±1.1	19.4±1.3
BY-102-2	15.8±1.0	18.2±1.0	17.5±1.0	17.8±0.8
BY-103-1	12.6±0.9	17.1±0.8	15.6±1.2	16.5±0.9
BY-103-2	14.1±0.9	17.4±0.8	15.3±0.8	16.4±0.6
BY-104-1	13.4±0.9	18.2±0.8	16.3±0.8	18.3±1.2
BY-104-2	15.0±1.0	17.6±0.8	16.5±1.1	17.6±0.7
BY-105-1	14.4±0.9	18.7±0.9	17.3±0.8	18.3±0.7
BY-105-2	15.3±0.9	17.9±0.8	16.5±1.0	17.8±0.9
BY-106-1	13.3±0.9	18.2±0.8	16.9±0.9	17.6±0.7
BY-106-2	14.1±1.1	16.8±1.0	15.0±0.9	16.3±0.8
BY-107-1	14.4±1.2	21.1±1.1	17.4±1.0	19.8±0.9
BY-107-2	16.4±0.9	18.6±1.1	17.6±0.9	18.0±0.9
BY-108-1	14.9±0.9	19.4±0.8	18.0±1.0	18.5±0.7
BY-108-2	13.0±0.9	14.4±0.9	14.3±0.9	14.9±0.8
BY-109-1	12.8±0.8	17.4±1.0	15.9±0.9	17.2±0.7
BY-109-2	14.6±1.1	14.7±1.0	16.1±1.0	16.8±1.0
BY-110-1	15.0±0.8	16.9±0.9	14.8±1.0	16.3±0.7
BY-110-2	14.4±1.2	15.4±1.1	16.1±1.0	15.4±0.9
BY-111-1	16.0±1.1	18.3±0.8	16.0±0.7	17.6±0.7
BY-111-2	15.7±1.1	16.3±0.9	17.0±0.9	16.1±0.8
BY-112-1	14.6±1.0	17.5±0.9	15.8±1.0	16.8±0.6
BY-112-2	14.2±0.9	15.5±1.0	16.0±0.8	15.3±0.8
BY-113-1	13.9±0.9	16.8±1.1	15.1±0.9	16.4±0.7
BY-113-2	12.8±0.9	13.6±0.9	13.9±0.8	14.5±1.0
BY-114-1	11.6±0.8	13.8±1.1	12.7±0.8	14.0±1.0
BY-114-2	14.1±0.9	16.3±0.9	15.7±0.9	15.9±0.7
BY-115-1	14.3±1.0	16.3±1.2	15.3±1.0	16.2±1.0
BY-115-2	13.8±1.0	15.6±1.2	14.0±1.0	15.4±0.8
BY-116-1	12.3±0.9	14.0±0.9	15.3±1.2	14.1±0.7
BY-116-2	14.9±1.1	15.8±1.1	15.4±1.0	15.6±1.3
Mean ± s.d.	14.2±1.1	17.0±1.8	16.0±1.2	16.8±1.4

## BYRON

Table 5. Gamma Radiation, as Measured by TLDs (continued)

<u>SPECIAL PROGRAM</u>				
<u>Outer Ring, Near 5 Mile Radius, Indicator Locations</u>				
	<u>1st Quarter</u>	<u>2nd Quarter</u>	<u>3rd Quarter</u>	<u>4th Quarter</u>
Date Placed:	01-02-89	04-03-89	07-03-89	10-02-89
Date Removed:	04-03-89	07-03-89	10-02-89	01-02-90
Days in the Field:	91	91	91	91
Location			Average mR/Qtr.	
BY-201-1	13.1±1.1	16.6±1.1	14.0±1.4	16.5±0.8
BY-201-2	16.2±1.0	18.4±0.9	17.8±1.0	17.9±0.7
BY-202-1	13.4±0.9	15.6±0.9	14.0±0.8	15.3±0.8
BY-202-2	15.1±0.8	16.8±1.3	16.7±1.2	17.5±0.8
BY-203-1	10.8±0.9	11.7±1.0	11.6±0.7	12.5±0.9
BY-203-2	14.7±1.5	16.1±1.0	15.7±1.3	16.2±0.9
BY-204-1	11.2±0.8	13.0±0.9	12.6±0.8	13.5±0.7
BY-204-2	15.4±0.9	18.4±0.8	17.0±0.8	17.5±0.8
BY-205-1	15.6±0.9	18.2±1.6	17.2±1.1	17.3±0.9
BY-205-2	14.6±1.0	16.8±0.9	15.6±0.9	16.5±1.0
BY-206-1	16.6±1.2	18.5±1.0	17.6±1.0	17.9±0.8
BY-206-2	15.8±0.9	17.5±0.9	17.1±0.8	16.9±0.8
BY-207-1	15.7±0.9	19.0±0.9	17.8±1.1	18.7±0.9
BY-207-2	15.1±0.8	17.4±1.0	16.2±0.8	16.4±1.0
BY-208-1	17.4±0.9	20.5±0.9	19.9±0.8	19.4±0.9
BY-208-2	15.8±1.0	17.5±0.9	16.8±0.8	17.2±0.8
BY-209-1	17.5±1.5	19.5±1.9	19.0±1.2	18.7±1.4
BY-209-2	13.0±1.0	15.1±0.9	14.6±0.9	14.7±0.8
BY-210-1	15.1±0.8	19.2±0.8	17.5±1.0	18.2±1.0
BY-210-2	15.2±1.1	16.8±1.1	17.0±0.8	17.1±1.0
BY-211-1	15.3±0.8	16.4±0.9	16.6±1.1	17.1±1.1
BY-211-2	15.6±1.7	19.0±1.1	17.8±1.3	18.6±0.9
BY-212-1	15.6±0.8	18.3±0.8	17.5±0.9	18.2±1.5
BY-212-2	14.7±0.9	20.4±1.0	17.7±0.9	19.5±1.0
BY-213-1	15.6±0.8	16.7±1.1	17.4±0.9	16.5±0.9
BY-213-2	15.2±1.0	19.7±1.1	18.1±0.9	19.0±0.7
BY-214-1	14.5±1.0	16.0±1.0	16.2±1.0	16.1±0.9
BY-214-2	15.0±1.4	17.8±0.8	16.9±0.8	17.8±0.8
BY-215-1	15.8±1.0	17.6±0.8	17.1±0.9	17.7±0.8
BY-215-2	14.1±0.9	18.7±1.1	16.9±0.9	18.1±0.7
BY-216-1	17.1±1.0	17.8±1.0	18.3±1.6	17.4±1.0
BY-216-2	16.5±1.1	19.6±0.9	18.1±1.2	18.5±0.8
Mean ± s.d.	15.1±1.5	17.5±1.9	16.7±1.7	17.2±1.6

BYRON

Table 5. Gamma Radiation, as Measured by TLDs (continued)

RESTRICTED AREA MONITORING PROGRAM		
	<u>3rd Quarter</u>	<u>4th Quarter</u>
Date Placed:	07-03-89	10-02-89
Date Removed:	10-02-89	01-02-90
Days in the Field:	91	91
Location	Average mR/Qtr.	
B-1 Security Gatehouse (Parking Lot)	14.5±0.8	16.8±1.4

## BYRON

Table 6. Milk

Collection: Monthly; semimonthly during grazing season (May-October)  
 Units: pCi/l

Collection Date	Lab Code	I-131	Cs-134	Cs-137	Other Gammas <sup>a</sup>
<u>Warren Danakas Farm BY-15</u>					
01-02-89	BYMI-2968	<0.5	<5	<5	<10
02-06-89	3072	<0.5	<5	<5	<10
03-06-89	3139,40	<0.5	<5	<5	<10
04-03-89	3214	<0.5	<5	<5	<10
05-01-89	3288	<0.5	<5	<5	<10
05-15-89	3365	<0.5	<5	<5	<10
06-05-89	3465	<0.5	<5	<5	<10
06-19-89	3544	<0.5	<5	<5	<10
07-03-89	3609	<0.5	<5	<5	<10
07-17-89	3676	<0.5	<5	<5	<10
08-07-89	3792	<0.5	<5	<5	<10
08-21-89	3870	<0.5	<5	<5	<10
09-04-89	3933	<0.5	<5	<5	<10
09-18-89	4017	<0.5	<5	<5	<10
10-02-89	4083	<0.5	<5	<5	<10
10-16-89	4146,7	<0.5	<5	<5	<10
11-06-89	4233	<0.5	<5	<5	<10
12-04-89	4298	<0.5	<5	<5	<10
<u>Bill Leupkes Farm BY-25</u>					
01-02-89	BYMI-2970	<0.5	<5	<5	<10
02-06-89	3074	<0.5	<5	<5	<10
03-06-89	3143	<0.5	<5	<5	<10
04-03-89	3217	<0.5	<5	<5	<10
05-01-89	3292	<0.5	<5	<5	<10
05-15-89	3368	<0.5	<5	<5	<10
06-05-89	3468	<0.5	<5	<5	<10
06-19-89	3547	<0.5	<5	<5	<10
07-03-89	3611	<0.5	<5	<5	<10
07-17-89	3679	<0.5	<5	<5	<10
08-07-89	3796	<0.5	<5	<5	<10
08-21-89	3873	<0.5	<5	<5	<10
09-04-89	3937	<0.5	<5	<5	<10
09-18-89	4020	<0.5	<5	<5	<10
10-02-89	4086,7	<0.5	<5	<5	<10
10-16-89	4150	<0.5	<5	<5	<10
11-06-89	4236,7	<0.5	<5	<5	<10
12-04-89	4301	<0.5	<5	<5	<10

<sup>a</sup> See Introduction.

## BYRON

Table 6. Milk (continued)

Collection Date	Lab Code	I-131	Cs-134	Cs-137	Other Gammas <sup>a</sup>
Whitten Holsteins BY-17					
01-02-89	BYMI-2969	<0.5	<5	<5	<10
02-06-89	3073	<0.5	<5	<5	<10
03-06-89	3141	<0.5	<5	<5	<10
04-03-89	3215	<0.5	<5	<5	<10
05-01-89	3289	<0.5	<5	<5	<10
05-15-89	3366	<0.5	<5	<5	<10
06-05-89	3466	<0.5	<5	<5	<10
06-19-89	3545	<0.5	<5	<5	<10
07-10-89	3639	<0.5	<5	<5	<10
07-17-89	3677	<0.5	<5	<5	<10
08-07-89	3793	<0.5	<5	<5	<10
08-21-89	3871	<0.5	<5	<5	<10
09-04-89	3934,5	<0.5	<5	<5	<10
09-18-89	4018	<0.5	<5	<5	<10
10-02-89	4084	<0.5	<5	<5	<10
10-16-89	4148	<0.5	<5	<5	<10
11-06-89	4234	<0.5	<5	<5	<10
12-04-89	4299	<0.5	<5	<5	<10
Kenneth Reevorts Farm BY-20 <sup>b</sup>					
01-02-89	BYMI-NS <sup>c</sup>	--	--	--	--
02-13-89	3100	<0.5	<5	<5	<10
03-06-89	3142	<0.5	<5	<5	<10
04-03-89	3216	<0.5	<5	<5	<10
05-01-89	3290,1	<0.5	<5	<5	<10
05-15-89	3367	<0.5	<5	<5	<10
06-05-89	3467	<0.5	<5	<5	<10
06-19-89	3546	<0.5	<5	<5	<10
07-03-89	3610	<0.5	<5	<5	<10
07-17-89	3678	<0.5	<5	<5	<10
08-07-89	3794,5	<0.5	<5	<5	<10
08-21-89	3872	<0.5	<5	<5	<10
09-04-89	3936	<0.5	<5	<5	<10
09-18-89	4019	<0.5	<5	<5	<10
10-02-89	4085	<0.5	<5	<5	<10
10-16-89	4149	<0.5	<5	<5	<10
11-06-89	4235	<0.5	<5	<5	<10
12-04-89	4300	<0.5	<5	<5	<10

<sup>a</sup> See Introduction.<sup>b</sup> On February 13, 1989, Ed Seabold Farm was replaced by K. Reevorts Farm, 5674 German Church Road, Byron, IL.<sup>c</sup> NS = No sample available.

## BYRON

Table 7. Fish, Edible Portions.  
 Collection: 3 times per year  
 Unit: pCi/g wet weight

Collection Date	Lab Code	Type	Cs-134	Cs-137	Other Gammas <sup>a</sup>
<u>Oregon Pool of Rock River BY-12</u>					
05-08-89	BYF-659	Perch	<0.10	<0.10	<0.13
05-15-89	676	Bass	<0.10	<0.10	<0.13
07-24-89	770	Catfish	<0.10	<0.10	<0.13
07-31-89	777	Carp	<0.10	<0.10	<0.13
10-16-89	863	Catfish	<0.10	<0.10	<0.13
10-16-89	864	Walleye	<0.10	<0.10	<0.13
<u>Upstream BY-13</u>					
05-15-89	BYF-677	Carp	<0.10	<0.10	<0.13
05-15-89	678	Catfish	<0.10	<0.10	<0.13
07-17-89	753	Carp	<0.10	<0.10	<0.13
07-24-89	771	Catfish	<0.10	<0.10	<0.13
10-30-89	902	Carp	<0.10	<0.10	<0.13
11-06-89	907	Catfish	<0.10	<0.10	<0.13

<sup>a</sup> See introduction.

## BYRON

Table 8. Vegetables  
 Collection: Annually  
 Units: pCi/g wet weight

Collection Date	Lab Code	Type	I-131 <sup>a</sup>	Cs-134	Cs-137	Gammas <sup>b</sup>	Other
<u>BY-19-1 966 East Weld Park Road</u>							
08-07-89	BYVe-689,90	Cucumber	----	<0.1	<0.1	<0.2	
08-07-89	692	Brussel Sprouts	----	<0.1	<0.1	<0.2	
08-07-89	693	Zucchini	----	<0.1	<0.1	<0.2	
10-09-89	816	Broccolli Leaves	0.02	<0.1	<0.1	<0.2	
<u>BY-19-2 6993 North River Road</u>							
08-07-89	BYVe-695	Cucumber	----	<0.1	<0.1	<0.2	
08-07-89	696	Carrots	----	<0.1	<0.1	<0.2	
08-07-89	697	Corn	----	<0.1	<0.1	<0.2	
08-07-89	698	Beets	----	<0.1	<0.1	<0.2	
10-09-89	817	Cabbage	0.03	<0.1	<0.1	<0.2	

<sup>a</sup> Analysis for I-131 required for green leafy vegetation only.

<sup>b</sup> See Introduction.

## BYRON

Table 9. Surface Water  
Units: pCi/l

MONTHLY COMPOSITES OF WEEKLY COLLECTIONS					
Composite Period	Lab Code	Cs-134	Cs-137	Other Gammas <sup>a</sup>	
<u>Woodland Creek BY-09</u>					
January, 89	BYSW-319 <sup>b</sup>	<10	<10	<15	
February, 89	NSC	--	--	--	
March, 89	1282	<10	<10	<15	
April, 89	1660	<10	<10	<15	
May, 89	1862	<10	<10	<15	
June, 89	2552	<10	<10	<15	
July, 89	2884,5	<10	<10	<15	
August, 89	3132	<10	<10	<15	
September, 89	3677	<10	<10	<15	
October, 89	4098	<10	<10	<15	
November, 89	4290	<10	<10	<15	
December, 89	NS <sup>b</sup>	--	--	--	
<u>Downstream BY-12</u>					
January, 89	BYSW-617 <sup>b</sup>	<10	<10	<15	
February, 89	NSC	--	--	--	
March, 89	1283	<10	<10	<15	
April, 89	1661	<10	<10	<15	
May, 89	1863	<10	<10	<15	
June, 89	2553	<10	<10	<15	
July, 89	2886	<10	<10	<15	
August, 89	3133,4	<10	<10	<15	
September, 89	3678	<10	<10	<15	
October, 89	4099,100	<10	<10	<15	
November, 89	4291,2	<10	<10	<15	
December, 89	4729	<10	<10	<15	
<u>Upstream BY-13</u>					
January, 89	BYSW-321 <sup>b</sup>	<10	<10	<15	
February, 89	NSC	--	--	--	
March, 89	1284	<10	<10	<15	
April, 89	1662	<10	<10	<15	
May, 89	1868	<10	<10	<15	
June, 89	2554	<10	<10	<15	
July, 89	2887	<10	<10	<15	
August, 89	3135	<10	<10	<15	
September, 89	3679,80	<10	<10	<15	
October, 89	4101	<10	<10	<15	
November, 89	4293	<10	<10	<15	
December, 89	NS <sup>b</sup>	--	--	--	

<sup>a</sup> See Introduction.

<sup>b</sup> Grab sample, collected 01-30-89.

c NS = No sample available. River frozen.

## BYRON

Table 9. Surface Water (continued)

<u>QUARTERLY COMPOSITES OF WEEKLY COLLECTIONS</u>		
<u>Composite Period</u>	<u>Lab Code</u>	<u>Concentration (pCi/l)</u>
		Tritium
<u>Woodland Creek BY-09</u>		
1st Quarter, 1989	BYSW-1086	<200
2nd Quarter, 1989	2491	<200
3rd Quarter, 1989	3614	<200
4th Quarter, 1989	4724	<200
<u>Downstream BY-12</u>		
1st Quarter, 1989	BYSW-1087	596±105
2nd Quarter, 1989	2492	790±100
3rd Quarter, 1989	3615	532±113
4th Quarter, 1989	4725	1470±136
<u>Upstream BY-13(C)</u>		
1st Quarter, 1989	BYSW-1088	<200
2nd Quarter, 1989	2493	<200
3rd Quarter, 1989	3616	<200
4th Quarter, 1989	4726	<200

## BYRON

Table 10. Well Water

Units: pCi/l

Collection: Composite of semimonthly collections.

Collection Date	Lab Code	MONTHLY COMPOSITE OF SEMIMONTHLY COLLECTIONS					Lab Code	BY-18				
		Gross Beta	BY-14		Other Gammas			Gross Beta	BY-18		Other Gammas	
			Cs-134	Cs-137				Cs-134	Cs-137			
January, 89	ND <sup>b</sup>	--	--	--	--		BYWW-572,3	1.3±0.6	<10	<10	<10	<15
February, 89	BYWW-748	<1.7	<10	<10	<15		749	<1.8	<10	<10	<10	<15
March, 89	1285	<1.5	<10	<10	<15		1286	<1.6	<10	<10	<10	<15
April, 89	1663	2.2±1.3	<10	<10	<15		1664,5	1.8±1.3	<10	<10	<10	<15
May, 89	1869	<2.4	<10	<10	<15		1870	<2.3	<10	<10	<10	<15
June, 89	2555,6	<1.6	<10	<10	<15		2557	<1.7	<10	<10	<10	<15
July, 89	2888	<2.6	<10	<10	<15		2889	<2.3	<10	<10	<10	<15
August, 89	3136	<2.2	<10	<10	<15		3137	<2.3	<10	<10	<10	<15
September, 89	3681	<1.8	<10	<10	<15		3682	<1.6	<10	<10	<10	<15
October, 89	3757 <sup>c</sup>	<2.5	<10	<10	<15		4102	<2.5	<10	<10	<10	<15
November, 89	4294	<1.8	<10	<10	<15		4295	<1.6	<10	<10	<10	<15
December, 89	4730	<1.6	<10	<10	<15		4731	2.2±1.1	<10	<10	<10	<15

<sup>a</sup> See Introduction.<sup>b</sup> ND = No data. Sample not collected, pump out of order.<sup>c</sup> Grab sample only; pump out of order first part of October.<sup>d</sup> In monthly reports "other gammas" were reported as <20. The change to <15 was made to comply with Technical Specifications. Actual LLD's obtained for all samples were much lower than reported.

## BYRON

Table 10. Well Water  
Units: pCi/l

QUARTERLY GRAB SAMPLES		
Collection Date	Lab Code	Tritium
<u>Off-Site Well BY-14</u>		
1st Quarter, 89	BYWW-1089	<200
2nd Quarter, 89	2494	<200
3rd Quarter, 89	3617	236±103
4th Quarter, 89	4727	<200
<u>McCoy Farmstead Well BY-18</u>		
1st Quarter, 89	BYWW-1090	<200
2nd Quarter, 89	2495,6	<200
3rd Quarter, 89	3618	<200
4th Quarter, 89	4728	<200

<sup>a</sup> See Introduction.

## BYRON

Table 11. Bottom Sediments  
 Collection: Semiannually  
 Units: pCi/g dry weight.

Date Collected	Lab Code	Cs-134	Cs-137	Other Gammas <sup>a</sup>
<u>Oregon Pool of Rock River BY-12</u>				
05-01-89	BYBS-510,1	<0.1	<0.1	<0.2
10-09-89	BYBS-623	<0.1	<0.1	<0.2
<u>Upstream BY-13</u>				
05-01-89	BYBS-640	<0.1	<0.1	<0.2
10-09-89	BYBS-624	<0.1	<0.1	<0.2

<sup>a</sup> See Introduction.

BYRON

MILCH ANIMALS AND NEAREST RESIDENCES CENSUS

BYRON

BYRON DAIRY CENSUS 1989

A. Site Boundary to 2 mi.

None

B. 2 mi. to 5 mi.

1. Reeverts Dairy Farm (BY-20)  
5674 N. German Church Road  
Route 1  
Byron, Illinois

2.1 miles @ 037'

Milks 40 cows

2. Whitten Dairy Farm (BY-17)  
Didtown Road  
Route 1  
Byron, Illinois

8.5 miles @ 250'

Milks 40 cows

3. Warren Danakas (BY-15)  
5845 East Holcomb Road  
Route 1  
Oregon, Illinois

3.3 miles @ 110'

Milks 14 cows

4. Oltmann Dairy Farm; Richard Oltmann, owner  
1858 N. German Church Road  
Route 1  
Oregon, Illinois

2.2 miles @ 180'

Milks 15 cows

BYRON DAIRY CENSUS 1989 (continued)

5. Bill Luepkes (BY-25)  
2887 Brick Road  
Route 1  
Oregon, Illinois

3.7 miles @ 190'

Milks 56 cows

6. Ashelford Dairy Farm  
4210 IL Route 2  
Route 3  
Oregon, Illinois

2.6 miles @ 275'

Milks 12 cows

7. CAM-DEE Farms, Gerald DeVries, owner  
5213 N. Town Hall Road  
Route 3  
Oregon, Illinois

3.3 miles @ 290'

Milks 35 cows

8. Duane Camling  
50 East Camling Road  
Route 3  
Oregon, Illinois

3.2 miles @ 305'

Milks 26 cows

C. Sampling Locations

BY-15      Warren Danakas  
Milks 14 cows  
Diet:

May - October:      Pasture 5 acres. Pasture, hay, corn,

oats, protein/mineral supplement.

November - April:      Feedlot 1 acre. Hay, corn, oats and  
protein/supplement.

BYRON DAIRY CENSUS 1989 (continued)

BY-25 Bill Luepkes

Milks 56 cows

Diet:

May - October: Pasture feedlot 2 acres. Haylage, corn, hay, and protein/mineral supplement.

November - April: Feedlot less than 2 acres. Haylage, hay, corn, silage, oats, and protein/mineral supplement.

BY-17 Whitten Farm

Milks 40 cows

Diet:

May - October: Pasture feedlot 5 acres. Green chop, hay, haylage, mineral supplement.

November - April: Feedlot 0.5 acres. Silage, haylage, corn, hay, mineral supplement.

BY-20 Koeverts Dairy

Milks 40 cows

Diet:

May - October: Pasture 7 acres. Pasture, Haylage, hay, corn, protein/mineral supplement.

November - April: Feedlot less than 2 acres. Hay, silage, corn, protein/mineral supplement.

---

Census conducted by L. Coleman on August 21, 1989.

BYRON

NEAREST RESIDENCE CENSUS, 1989

Nearest residences of the Byron Station within a five (5) mile radius.

N	1.9 miles
NNE	1.5 miles
NE	0.9 miles
ENE	1.3 miles
E	1.2 miles
ESE	1.6 miles
SE	1.1 miles
SSE	1.2 miles
S	0.7 miles
SSW	0.6 miles
SW	0.9 miles
WSW	1.7 miles
W	2.0 miles
WNW	0.8 miles
NW	1.2 miles
NNW	1.3 miles

---

Census conducted by L. Coleman on August 21, 1989.