



CHARLES CENTER • P. O. BOX 1475 • BALTIMORE, MARYLAND 21203

GEORGE C. CREEL
VICE PRESIDENT
NUCLEAR ENERGY
(301) 260-4455

May 10, 1990

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
Second Ten-Year Inservice Inspection Program Plan for Calvert Cliffs
Units 1 and 2

REFERENCE: (a) Letter to Mr. G. C. Creel (BG&E) from Mr. Robert A. Capra (NRC),
dated January 11, 1990, Approval of Second Ten-Year Inservice
Inspection Program Plan for Calvert Cliffs Units 1 and 2

Gentlemen:

Reference (a) reported approval of our second ten-year Inservice Inspection (ISI) Program Plan. However, the Safety Evaluation enclosed in Reference (a) discussed the NRC staff determination that our plan must be revised to include volumetric and surface examinations of a representative sampling of Class 2 piping welds in the Containment Spray and Shutdown Cooling systems.

That revision to our ISI Program Plan (Change 3) has been completed. Change 3 affected pages 2, 22, 27, and 31 of the ISI Program Plan. Those pages, plus the Effectivity and Approval sheet (page i) for the change, are attached.

Changes 1 (3 pages) and 2 (2 pages) to our ISI Program Plan are attached for your information. Page 18 of the Plan is also attached, where a minor typographical error (reference to part 2.5 vice 2.4) has been corrected.

Should you have any further questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

GCC/DLS/db

Enclosures

9005140169 900510
PDR ADDCK 05000317
Q PDC

Cont'd
P395887A96
AOA7
11

Document Control Desk

May 10, 1990

Page 2

cc: D. A. Brune, Esquire
J. E. Silberg, Esquire
R. A. Capra, NRC
D. G. McDonald, Jr., NRC
T. T. Martin, NRC
L. E. Nicholson, NRC
R. McLean, DNR