

May 10, 1990

Docket Nos. 50-325
and 50-324

Mr. Lynn W. Eury
Executive Vice President
Power Supply
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602

Dear Mr. Eury:

SUBJECT: EVALUATION OF BASES SECTION OF TECHNICAL SPECIFICATION
3/4.8 ON EMERGENCY DIESEL GENERATOR SURVEILLANCE -
BRUNSWICK STEAM ELECTRIC PLANT, UNITS 1 AND 2
(TAC NOS. 76089 AND 76090)

By letter dated February 23, 1990, you requested a change to the Bases section of Technical Specification (TS) 3/4.8, "Electrical Power System," to clarify Surveillance Requirement 4.8.1.1.2.d at Brunswick Steam Electric Plant, (BSEP), Units 1 and 2. The proposed change is to clarify that the 18 month surveillance of emergency diesel generators (EDG) 1 and 2 will be performed when BSEP, Unit 1, is shutdown and of EDG 3 and 4 will be performed when BSEP, Unit 2, is shutdown. The staff has reviewed the proposed TS change request and finds the proposed change to be acceptable. The related staff Safety Evaluation and the revised Bases pages for both Units are enclosed.

Sincerely,

Original Signed By:

Ngoc B. Le, Project Manager
Project Directorate II-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Projects - I/II

Enclosures:
As stated

cc w/enclosures:
See next page

DISTRIBUTION
See attached page

9005210013 900510
PDR ADDOCK 05000324
P FDC

OFC	:LA:PDII-1	:PM:PDII-1	:D:PDII-1	:	:	:
NAME	:PAnderson	:NLe:sw	:EAdensam	:	:	:
DATE	:5/9/90	:5/10/90	:5/10/90	:	:	:

OFFICIAL RECORD COPY
Document Name: LTR EURY 76089/90

DF01
111

Mr. L. W. Eury
Carolina Power & Light Company

Brunswick Steam Electric Plant
Units 1 and 2

cc:

Mr. Russell B. Starkey, Jr.
Vice President
Brunswick Nuclear Project
P. O. Box 10429
Southport, North Carolina 28461

Mr. H. A. Cole
Special Deputy Attorney General
State of North Carolina
P. O. Box 629
Raleigh, North Carolina 27602

Mr. R. E. Jones, General Counsel
Carolina Power & Light Company
P. O. Box 1551
Raleigh, North Carolina 27602

Mr. Robert P. Gruber
Executive Director
Public Staff - NCUC
P. O. Box 29520
Raleigh, North Carolina 27626-0520

Ms. Frankie Rabon
Board of Commissioners
P. O. Box 249
Bolivia, North Carolina 28422

Resident Inspector
U. S. Nuclear Regulatory Commission
Star Route 1
P. O. Box 208
Southport, North Carolina 28461

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 2900
Atlanta, Georgia 30323

Mr. Dayne H. Brown, Director
Division of Radiation Protection
N. C. Department of Environmental,
Commerce and Natural Resources
P. O. Box 27687
Raleigh, North Carolina 27611-7687

Mr. J. L. Harness
Plant General Manager
Brunswick Steam Electric Plant
P. O. Box 10429
Southport, North Carolina 28461