

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION

UNIT 1 CYCLE 3

CORE OPERATING LIMITS REPORT

REVISION 0

MAY 1, 1990

SOUTH TEXAS UNIT 1 CYCLE 3

1.0 Core Operating Limits

This Core Operating Limits Report for STPEGS Unit 1 Cycle 3 has been prepared in accordance with the requirements of Technical Specification 6.9.1.6. The core operating limits have been developed using the NRC-approved methodologies specified in Reference 1 and 2.

The following cycle-specific core operating limits required by Technical Specifications are included in this report:

- 1) Control Rod Insertion Limits (Figure 1) as required by Technical Specification 3.1.3.6. Fully withdrawn for all control and shutdown banks shall be 259 steps.
- 2) AFD Limits as required by Technical Specification 3.2.1 are determined by CAOC Operations with a Delta-I allowable operating band throughout Cycle 3 life of +3, -12%.
- 3) Radial Peaking Factor Limits as required by Technical Specification 4.2.2.2 are provided for Cycle 3 operation in Figure 2.

SOUTH TEXAS UNIT 1 CYCLE 3

2.0 References


1. "Westinghouse Reload Safety Evaluation Methodology",
WCAP-9272-P-A, July 1985.
2. "Power Distribution and Load Following Procedures",
WCAP-8385, September, 1974.
3. NUREG-1346, Technical Specifications, South Texas Project,
Unit Nos. 1 and 2.

SOUTH TEXAS UNIT 1 CYCLE 3

ATTACHMENT 1
ST-HL-AE-3481
PAGE 4 OF 5

FIGURE 1

CONTROL ROD INSERTION LIMITS VERSUS POWER LEVEL



SOUTH TEXAS UNIT 1 CYCLE 3

FIGURE 2
RADIAL PEAKING FACTOR LIMITS

The F_{xy} limits for RATED THERMAL POWER within specific core planes shall be:

1. F_{xy}^{RTP} less than or equal to 1.94 for all core planes containing bank "D" control rods, and
2. F_{xy}^{RTP} less than or equal to 1.64 for all unrodded core planes.

These $F_{xy}(z)$ limits were used to confirm that the heat flux hot channel factor $F_Q(z)$ will be limited to the Technical Specification values of:

$$F_Q(z) \leq [2.50/P] [K(z)] \quad \text{for } P > 0.5 \text{ and,}$$

$$F_Q(z) \leq [5.00] [K(z)] \quad \text{for } P \leq 0.5$$

assuming the most limiting axial power distributions expected to result from the insertion and removal of control banks C and D during operation, including the accompanying variations in the axial xenon and power distributions, as described in Reference 2. Therefore, these F_{xy} limits provide assurance that the initial conditions assumed in the LOCA analysis are met, along with the ECCS acceptance criteria of 10CFR50.46.

The function $K(z)$ is given in Figure 3.2-2 of the Technical Specifications.