

Duquesne Light Company

Beaver Valley Power Station
PO Box 4
Shippingport, PA 15077-0004

June 11, 1990

JOHN D. SIEBER
Vice President - Nuclear Group

(412) 393-6255

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 2
Docket No. 50-412, License No. NPF-73
Proposed Operating License Change Request No. 41
(TAC No. 76893)

Gentlemen:


Enclosed are:

1. Application for Amendment to the above operating license to delete surveillance requirement 4.4.9.3.1.d. This surveillance requires the Power Operated Relief Valves, associated with the Cold Overpressure Protection System, to be stroke tested every time the plant enters Mode 5 if not tested within the proceeding three months.

This change has been reviewed by the OSC and ORC and was determined to be safe and does not involve an unreviewed safety question.

2. Documents designated Attachments A, B, and C which set forth the change in Technical Specifications, the safety analysis and no significant hazard evaluation.

Very truly yours,


J. D. Sieber
Vice President
Nuclear Group

cc: Mr. J. Beall, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. A. DeAgazio, Project Manager
Mr. R. Janati, BRP/DER
Mr. R. Saunders (VEPCO)

9006210146 900611
PDR ADOCK 05000412
P PDC

Adol
11