

Attachment 1

EOL shall complete the following requirements on the schedule noted below:

Emergency Response Facilities (Generic Letter 82-33, NUREG-0737
Supplement 1, SSER #5)

EOL shall implement the specific items below, in the manner described in MP&L letter (AECM-83/0232) dated April 15, 1983, as modified in MP&L letter (AECM-83/0486) dated August 22, 1983, no later than the following specified dates:

- (a) Safety Parameter Display System (SPDS)
- (1) Submit a safety analysis and implementation plan to the NRC July 1985
 - (2) SPDS fully operational and operator trained Prior to startup following first refueling outage.
- (b) Detailed Control Room Design Review (DCRDR)
- (1) Submit a program plan to the NRC December 1984
 - (2) Submit a summary report to the NRC including a proposed schedule for implementation July 1986
- (c) Regulatory Guide 1.97 - Application to Emergency Response Facilities
- (1) Submit a report to the NRC describing how the requirements of Supplement 1 to NUREG-0737 have been or will be met. February 1985
 - (2) Implement (installation or upgrade) requirements of R.G. 1.97 with exception of flux monitoring and coolant level monitoring. Prior to startup following first refueling outage.
 - (3) Implement (installation or upgrade) requirements of R.G. 1.97 for coolant level monitoring. Prior to startup following second refueling outage.
 - (4) Implement (installation or upgrade) requirements of R.G. 1.97 for flux monitoring. Prior to startup following ~~fourth~~ ^{fifth} refueling outage.
- (d) Upgrade Emergency Operating Procedures (EOP's)
- (1) Submit a Procedures Generation Package to the NRC. April 1985