



General Electric Company  
175 Curtiss Avenue, San Jose, CA 95125

March 8, 1993

Docket No. STN 52-001

Chet Poslusny, Senior Project Manager  
Standardization Project Directorate  
Associate Directorate for Advanced Reactors  
and License Renewal  
Office of the Nuclear Reactor Regulation

Subject: **Submittal Supporting Accelerated ABWR Review Schedule - ECCS  
Suction from Suppression Pool**

Dear Chet:

Enclosed is a memo from Jack Duncan to Glenn Kelly responding to NRC question regarding ECCS pumps taking suction from the suppression pool, which during Class II sequences could exceed the pump design basis temperature.

Sincerely,

Jack Fox  
Advanced Reactor Programs

cc: Jack Duncan (GE)  
Norman Fletcher (DOE)  
Jason Post (GE)  
Bill Taft (GE)  
Cal Tang (GE)

JF93-55

9303220039 930308  
PDR ADOCK 05200001  
A PDR