

CATAWBA NUCLEAR STATION
MONTHLY OPERATING STATUS REPORT
January 1993

1. Personnel Exposure -

Duke Power Company has changed the monthly monitoring exposure report to quarterly. First quarter TLD results will be available for inclusion in the April 1993 report.

2. The total station liquid release for January has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for January has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this list.

DOCKET: 50-414

UNIT: Catawba 2

Date: 03/15/93

NARRATIVE SUMMARY

MONTH: February 1993

Catawba Unit 2 began the month of February in end-of-cycle 5 refueling outage. The unit was in the outage for the entire month.