



Pyrotronics

8 Ridgedale Avenue, Cedar Knolls, New Jersey 07927
(201) 267-1300

Cable Address: Baker Pyro

RECEIVED

2305

1979 AUG 10 PM 2 59

U.S. DEPARTMENT OF ENERGY
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20545

August 7, 1979

U. S. Nuclear Regulatory Commission
Division of Fuel Cycle and Material Safety
Washington, D. C. 20555

Attention: James A. Jones

Reference: Control No. 97991

Dear Jim:

I have enclosed the report by Western Radiation Consultants
on the Model DI-4A I.C.S.D.

If you have any questions or require further data, please
contact me.

Sincerely,

Robert E. Butchko

Robert E. Butchko
Chief Radiation Protection Officer

REB:lg

Enclosure

COPIES SENT TO OFF. OF
INSPECTION AND ENFORCEMENT

9305140285 921109
PDR FOIA
MIS92-414 PDR

9305140285 A/96

Industries, Inc.

A Division of Baker Protective Services, Inc.

The attached data are submitted in support of an application for amendment to Pyrotronics NRC Distribution and Manufacturing Licenses for Ionization Chamber Smoke Detectors containing ^{241}Am .

The new Pyrotronics model, DI-4A, contains two sources with nominal activities of $0.4\mu\text{Ci}$ each. Model DI-4A is an industrial type smoke detector.

The sources are identical to sources used in previously licensed Pyrotronics models.

External radiation exposure levels were measured for model DI-4A.

The unit was dropped 100 times from a height of 8 ft onto a concrete surface.



WESTERN RADIATION CONSULTANTS, INC. Industrial, Medical, Environment

1306 Winfield Drive
Fort Collins, Colorado 80526
303-482-3029

EXTERNAL RADIATION EXPOSURE RATES

The external radiation exposure rates at the surface and 5 cm and 25 cm from the surface of Pyrotronics Model DI-4A ionization chamber smoke detector were measured using a Ge(Li) detector with a multi-channel analyzer system. A 0.0111 μCi ^{241}Am standard was counted using the same system. A conversion factor, the ratio of calculated exposure rate to count rate summed over eleven channels, was determined.

Exposure rate at 5 cm from standard source:

Source activity 0.0111 μCi

36% of ^{241}Am disintegrations produce a 60 keV gamma photon

Exposure rate = $\phi(\text{energy fluence}) \times \mu/\rho$ (mass absorption coefficient)

$$= \frac{0.0111 \mu\text{Ci} \times 2.2 \times 10^6 \text{ d/m-}\mu\text{Ci} \times 0.36 \times 60 \text{ keV}/\gamma \times 60 \text{ m/h}}{4 \pi (5\text{cm})^2 \times 6.24 \times 10^8 \text{ keV/erg} \times 86.9 \text{ erg/g-R}}$$

$$= 1.88 \times 10^{-6} \text{ R-g/h-cm}^2 \text{ at 5 cm}$$

$\mu/\rho = 0.0292 \text{ cm}^2/\text{g}$ (1970 edition of the Radiological Health Handbook)

$$\text{Exposure rate (R/h)} = 1.88 \times 10^{-6} \text{ R-g/h-cm}^2 \times 0.0292 \text{ cm}^2/\text{g}$$

$$= 5.48 \times 10^{-8} \text{ R/h} = 5.48 \times 10^{-2} \mu\text{R/h}$$

Net count rate summed over eleven channels - 78.5

Standard deviation = 5%

$$\text{Conversion factor} = 5.48 \times 10^{-2} \mu\text{R/h}/78.5 \text{ c/m}$$

$$= 6.98 \times 10^{-4} \mu\text{R/h/c/m}$$

The exposure rates from the units are directional. The source is centrally located in the unit, however the exposure rates vary somewhat due to differences in shielding by components of the detector.

Table 1
Measured Exposure Rates
Model DI-4A
(See Figures 1 and 2)

<u>Detector Position</u>	<u>Exposure Rate (μR/h)</u>		
	<u>surface</u>	<u>5cm</u>	<u>25cm</u>
front	4.20	0.92	0.077
back	7.86	1.21	0.064
side 1	0.98	0.11	0.02
side 2	1.21	0.20	0.02
side 3	1.06	0.27	0.03
side 4	0.77	0.29	0.03
side 5	0.53	0.12	0.02
side 6	0.94	0.17	0.02
<u>Packaged Detector</u>			
side a	2.12	0.86	0.063
side b	4.37	0.64	0.056
side c	0.41	0.04	<0.01
side d	0.22	0.08	0.03
side e	0.58	0.10	0.02
side f	0.64	0.07	0.01

Figure 1
External Radiation Levels ($\mu\text{R/h}$)





Figure 2

External Radiation Levels ($\mu\text{R/h}$)

25cm - 0.077
5cm - 0.92
surface - 4.20



surface - 7.86
5cm - 1.21
25cm - 0.064

ESTIMATED ANNUAL RADIATION EXPOSURES

2306

All exposure calculations are based on the maximum measured exposure rates.

1. Individual in protected building

a. Whole body exposure in normal use.

Maximum measured exposure rate at 25cm = 0.077 μ R/h

Estimated annual exposure (assuming 8 hour per day)

$$0.077 \mu\text{R/h} \times 8 \text{ h/d} \times 365 \text{ d/y} = 0.2 \text{ mR/y}$$

25 cm was used as the distance as it is the greatest distance for which the exposure rate was measured. A more reasonable distance would be 1 m. The annual exposure rate at 1 m is approximately:

$$0.2 \text{ mR/y} \times \left(\frac{25 + 2 \text{ cm}}{100 + 2 \text{ cm}} \right)^2 = 0.02 \text{ mR/y}$$

In the extreme case of the units being situated at 1 meter directly above a bed occupied 24 hours per day, 365 days per year the total annual exposure would not exceed 0.05 mR/y.

b. Individual installing units

1) Whole body exposure

Assume an individual spends 200 hours per year installing these units and whole body distance, 25 cm. Maximum measured exposure rate at 25 cm from smoke detector - 0.077 μ R/h

$$0.077 \mu\text{R/h} \times 200 \text{ h/y} = 0.02 \text{ mR/y}$$

2) Exposure to hands

Maximum measured exposure rate at surface of the unit -

$$7.86 \mu\text{R/h}$$

$$7.86 \mu\text{R/h} \times 200 \text{ h/y} = 2 \text{ mR/y}$$

Prototype Test

The unit was dropped from a height of 8 ft onto a concrete floor 100 times. The outside of the unit was wiped prior to the drop test. Both sources were wiped after the unit had been dropped 100 times.

After 5 drops the reference chamber cover came off exposing the reference source. After 20 drops the screen over the sensing chamber broke off exposing the sensing source. There was no apparent damage to either the sources or the source mounts. The sources remained firmly attached to the mount; the source mount was securely attached to the base of the unit after 100 drops.

It is improbable that accidental abuse of the detector would result in loss of a source or impairment of source integrity.

The wipes were counted in a low background gas flow counter. The wipe of the outside of the unit prior to the drop test showed no significant contamination (< 1 pCi). A wipe of the sensing source showed 2 pCi removable alpha contamination. The reference source wipe indicated 10 pCi removable alpha contamination.