



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

May 17, 1993

*Docket  
File*

Docket No. 50-213

Mr. John F. Opeka  
Executive Vice President, Nuclear  
Connecticut Yankee Atomic Power Company  
Northeast Nuclear Energy Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. M86065)

The Commission has issued the enclosed Amendment No. 157 to Facility Operating License No. DPR-61 for the Haddam Neck Plant, in response to your application dated March 22, 1993.

The amendment will change the following:

The footnote to Technical Specification 3.8.3.2.b is being revised to identify the available options for providing power to the 480 volt buses during plant shutdown (mode 5 or mode 6). This change adds the bus tie breakers 6T11 and 11T6 to the list of available tie breakers.

The change to Special Test Exception Technical Specifications 3.10.3 and Bases Section 3/4.10.3, Position Indication System-Shutdown, addresses exceptions for operability of the individual rod position indication (IRPI) system during shutdown modes.

A change to Bases Section 3/4.4.4., Relief Valves, clarifies why it is acceptable to place the power-operated relief valve (PORV) auto-trip signal in the bypass position if a pressurizer pressure channel fails.

A change to Bases Section 3/4.7.3, Service Water System, clarifies the definition of the service water header and describes the Adams filter bypass line and valves that were recently added to the service water system.

190044

9305200289 930517  
PDR ADDCK 05000213  
P PDR

*2501  
11*  
NRC FILE CENTER COPY

Mr. John F. Opeka

-2-

May 17, 1993

A copy of the related Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by

Alan B. Wang, Project Manager  
Project Directorate I-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. to DPR-61
2. Safety Evaluation

cc w/enclosures:  
See next page

Distribution:

Docket File  
NRC & Local PDRs  
PD I-4 Plant  
SVarga  
JCalvo  
SNorris  
AWang  
OGC  
DHagan  
GHill (2)  
Wanda Jones  
CGrimes  
RJones  
ACRS (10)  
OPA  
OC/LFDCB  
LTDoerflein, RI

*provided that the amendment  
not be issued prior to 5/15/93*

OFFICE	LA:PDI-4	PM:PDI-4	BC:SRXB	D:PDI-4	OGC <i>TH</i>
NAME	SNorris	AWang:cn	RJones	JStolz	JHill
DATE	4/20/93	4/20/93	4/21/93	5/17/93	5/15/93

OFFICIAL RECORD COPY

Document Name: G:\WANG\BREAKTSA

Mr. John F. Opeka

-2-

A copy of the related Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

*Alan Wang*

Alan B. Wang, Project Manager  
Project Directorate I-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 157 to DPR-61
2. Safety Evaluation

cc w/enclosures:  
See next page

Mr. John F. Opeka  
Connecticut Yankee Atomic Power Company

Haddam Neck Plant

cc:

Gerald Garfield, Esquire  
Day, Berry and Howard  
Counselors at Law  
City Place  
Hartford, Connecticut 06103-3499

R. M. Kacich, Director  
Nuclear Licensing  
Northeast Utilities Service Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

W. D. Romberg, Vice President  
Nuclear Operations Services  
Northeast Utilities Service Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

S. E. Scace, Vice President  
Millstone Nuclear Power Station  
Northeast Nuclear Energy Company  
Post Office Box 128  
Waterford, Connecticut 06385

Kevin McCarthy, Director  
Radiation Control Unit  
Department of Environmental Protection  
State Office Building  
Hartford, Connecticut 06106

Regional Administrator  
Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406

Allan Johanson, Assistant Director  
Office of Policy and Management  
Policy Development and Planning Division  
80 Washington Street  
Hartford, Connecticut 06106

Board of Selectmen  
Town Office Building  
Haddam, Connecticut 06438

J. P. Stetz, Vice President  
Haddam Neck Plant  
Connecticut Yankee Atomic Power Company  
362 Injun Hollow Road  
East Hampton, Connecticut 06424-3099

Resident Inspector  
Haddam Neck Plant  
c/o U.S. Nuclear Regulatory Commission  
361 Injun Hollow Road  
East Hampton, Connecticut 06424-3099

D. J. Ray  
Haddam Neck Unit Director  
Connecticut Yankee Atomic Power Company  
362 Injun Hollow Road  
East Hampton, Connecticut 06424-3099

Nicholas S. Reynolds  
Winston & Strawn  
1400 L Street, NW  
Washington, DC 20005-3502

G. H. Bouchard, Director  
Nuclear Quality Services  
Northeast Utilities Service Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270