



May 21, 1993

Docket No. STN 52-001

Chet Poslusny, Senior Project Manager
Standardization Project Directorate
Associate Directorate for Advanced Reactors
and License Renewal
Office of the Nuclear Reactor Regulation

Subject: Submittal Supporting Accelerated ABWR Review Schedule - Clarification of Responses to DFSEER Outstanding Items

Dear Chet:

In my cover letter dated April 30, 1993, I failed to make reference to Open Item 7.1.3.3-1, Confirmatory Item 7.2.8-1 and COL Action Item 7.2.8-1 all of which were included in that transmittal. In addition, I inadvertently omitted Open Item 7.2.6-3 in both the cover letter and as an enclosure. A discussion of closure of this item is enclosed.

Please provide a copy of this transmittal to Jim Stewart.

Sincerely,

Jack Fox
Advanced Reactor Programs

cc: Norman Fletcher (DOE)
Barry Simon (GE)

270038

JPRG-168

9306010141 930521
PDR ADOCK 05200001
A PDR

2050 /

DFSER No. 7.2.6-3 (OPEN)

ISSUE

- a. Shared use of EMS
- b. Insufficient information to operator and not enough time to manually mitigate an accident; remote shutdown station may not be acceptable.

CLOSURE

GE has committed to provide a certain number of hardwired displays and controls sufficient to support adequate time response for the operator in the event of any Chapter 15 accident in conjunction with an undetected common-mode failure of the essential multiplexing system or SSLC. This commitment has been made in the submittal of February 26, 1993. Also see the response to DFSER No. 7.2.6-2 for closure of this issue. (April 30, 1993)