

. .

1. 8

Innessee Valley Authority Post Othor Box 2000, Decator, Mabama 35609

MAY 1 8 1993

U.S. Euclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555

Gentlemen:

In the Matter of Tennessee Valley Authority Docket Nos. 50-259 50-260 50-296

2030

BROWNS FERRY NUCLEAR PLANT (BFN) - CONTROL ROOM EMERGENCY VENTILATION SYSTEM (CREVS) CORRECTIVE ACTIONS (TAC NOS. M83348, M83349, AND M83350)

- References: 1) TVA letter to NRC, dated July 31, 1992, Resolution of Control Room Emergency Ventilation System (CREVS) Issues
 - 2) TVA letter to NRC, dated March 1, 1993, Control Room Emergency Ventilation System (CREVS) Corrective Actions

In References 1 and 2, TVA provided its proposed resolution for the previously identified deficiencies with the CREVS. In response to a verbal request for additional information, the enclosure to this letter contains a comparison between the previous CREVS and current CREVS and a summary of the latest surveillance test results.

250041

9306020044 9305 PDR ADOCK 0500

U. S. Nuclear Regulatory Commission

There are no additional commitments contained in this letter. If you have any questions, please telephone me at (205) 729-2636.

Sincerely,

Pedro Salas Manager of Site Licensing

Enclosure cc (Enclosure): NRC Resident Inspector Browns Ferry Nuclear Plant Route 12, Box 637 Athens, Alabama 35611

> Mr. Thierry M. Ross, Project Manager U.S. Nuclear Regulatory Commission One White Flint, North 11555 Rockville Pike Rockville, Maryland 20852

> U.S. Nuclear Regulatory Commission Region II 101 Marietta Street, NW, Suite 2900 Atlanta, Georgia 30323

U.S. Nuclear Regulatory Commission

MAY 18 1993

GMM: SMK Enclosure cc (Enclosure): R. R. Baron, PSB 1K-BFN D. L. Brannen, C18 ATH3-BFN M. J. Burzynski, LP 5B-C E. S. Christenbury, ET 11H-K W. R. Cobean, Jr., LP 3B-C L. M. Cuoco, LP 5B-C R. M. Eytchison, LP 3B-C M. J. Fecht, LP 5B-C R. W. Huston, Rockville Licensing Office T. J. McGrath, LP 3B-C G. R. Mullee, BR 5D-C D. E. Nunn, LP 3B-C J. R. Rupert, MOD 2C-BFN J. A. Scalice, POB 2C-BFN O. J. Zeringue, PAB 1E-BFN RIMS, MR 2F-C

3

ENCLOSURE BROWNS FERRY NUCLEAR PLANT (BFN) CONTROL ROOM EMERGENCY VENTILATION SYSTEM (CREVS)

BACKGROUND:

The previous Control Room Emergency Ventilation System (CREVS) was designed to protect the control room operators by automatically starting upon receipt of a control room isolation signal and pressurizing the main control bay habitability zone (CBHZ) with filtered outdoor air during accident conditions that could result in radioactive releases. The CREVS uses charcoal adsorbers to assure the removal of radioactive iodine from the air and high efficiency particulate absolute (HEPA) filters for removing radioactive particulate matter.

During the Unit 2 Cycle 5 outage, an employee concern identified a specific condition that could impact the ability of the CREVS to provide an environment suitable for personnel occupancy. The Control Building air supply ducts are not designed or fabricated to be leak tight. Unfiltered outside air could leak from the seams/joints of the supply air ducts that traverse the control bay habitability zone. This duct leakage could result in outside air bypassing the CREVS and introducing potentially contaminated and unfiltered outside air into the control bay habitability zone.

In References 1 and 2, TVA provided its proposed resolution for the identified deficiencies with the CREVS. In response to a verbal request for additional information, the enclosure to this letter contains a comparison between the previous CREVS and current CREVS and a summary of the latest surveillance test results.

COMPARISON:

Attached are simplified diagrams of the previous CREVS (Figure 1) and current CREVS (Figure 2). Also listed below is a comparison of major design aspects of the previous CREVS and the current CREVS:

PREVIOUS CREVS

CURRENT CREVS

Two 500 cfm CREVS trains and units.

Two 3,000 cfm CREVS trains and units.

Each train power by a separate, diesel backed, electrical division.

Same.

Page 2 of 8

ENCLOSURE BROWNS FERRY NUCLEAR PLANT (BFN) CONTROL ROOM EMERGENCY VENTILATION SYSTEM (CREVS) (CONTINUED)

PREVIOUS CPEVS

Each train contained a fan unit, drawer type charcoal filter.

Each CREVS train took supply air from separate portions of ductwork that serve the electric board rooms located in the Reactor Building. This supply ductwork transverses the CBHZ.

Supply ductwork in the control bay vent towers was not tornado missile protected.

Both CREVS trains automatically started upon receipt of a control room isolation signal.

Each CREVS train was designed A single CREVS train will to maintain the CBHZ at a slight positive pressure and to ensure essentially zero unfiltered inleakage.

CURRENT CREVS

Both trains share a common upstream HEPA filter. Each adsorber, and down stream HEPA CREVS unit contains a relative humidity heater, fan unit, drawer type charcoal adsorber, and an after-filter.

> Each CREVS train takes suction from separate building intake ducts that are located on the East and West sides of the Turbine Building. This new ductwork is fabricated from three-sixteenth inch plate (Correction from TVA's March 1, 1993 letter, which stated it was a three-eighth inch plate), which is heavier than the normal requirements for three psi ductwork. The ducts serving CREVS become a common header at the Unit 2 vent tower.

The supply ductwork serving CREVS is not tornado missile protected.

Only one of the CREVS trains starts upon receipt of a control room isolation signal.

assist other sources of pressurization in maintaining the CBHZ at a half inch water gauge positive pressure.

Page 3 of 8

ENCLOSURE BROWNS FERRY NUCLEAR PLANT (BFN) CONTROL ROOM EMERGENCY VENTILATION SYSTEM (CREVS) (CONTINUED)

TEST RESULTS:

The control bay habitability zone (CBHZ) is located on the top floor of the Control Building. The CBHZ contains the Units 1, 2, and 3 control rooms, equipment rooms, relay room, lunch room, rest rooms, and office spaces. The Control Bay ventilation towers, located on the north wall of the reactor building, provide the outside air for the Control Building supply ductwork. Ventilation supply fans, which are located in the ventilation towers, pressurize this supply ductwork, including the ductwork that traverses the main control bay habitability zone. Some of the fans operate during the accident recovery period (30 days) to supply necessary cooling for essential equipment. In addition, the cable spreading room ventilation system, while not required to operate after an accident, is not prohibited from functioning after an accident. This could also contribute to the unfiltered inleakage into the habitability zone.

Surveillance Instruction 0-SI-4.7.E.7, Control Bay Habitability Zone Leakage Rate Test, was conducted on May 16, 1993 to determine the unfiltered inleakage rate into the CBHZ. This surveillance was conducted by isolating the CBHZ, including the supply and exhaust fans and ductwork that provide ventilation air to and from the outside, isolating the CREVS, and pressurizing the CBHZ by using a test fan (door mounted fan).

TVA determined the amount of flow necessary to maintain the CBHZ at various positive pressures. Readings were taken from an average CBHZ pressure of 0.09 inches water gauge to 0.41 inches water gauge, using a single door fan. Two test fans were used to bring the CBHZ pressure up to a half inch water gauge. However, the data with two test fans in operation was determined not to be credible. Hence, an extrapolation of the previous test data was used to determine the unfiltered inleakage rate at a CBHZ pressure of a half inch water gauge (Figure 3).

Page 4 of 8

ENCLOSURE BROWNS FERRY NUCLEAR PLANT (BFN) CONTROL ROOM EMERGENCY VENTILATION SYSTEM (CREVS) (CONTINUED)

The maximum unfiltered inleakage into the CBHZ was assumed to be the flow rate required to maintain the CBHZ at a half inch water gauge. The control room operator dose was calculated using this extrapolated unfiltered inleakage rate and this calculation is considered to be conservative. The CREVS units and the special test fan were not running simultaneously. Pressurization of the habitability zone from the CREVS units, which would occur during post-accident habitability zone isolation conditions, would result in a decrease in the rate of unfiltered inleakage. Since the habitability zone would be at a relatively higher pressure compared to adjacent areas, all other leakage would be out of the habitability zone.

The major parameters/data from the CBHZ surveillance test are shown in the attached table. The results of the test were:

- The outleakage is linear with respect to CBHZ boundary pressure. This was concluded from a linear plot of the log of the CBHZ pressure versus the log of the pressurizing flow rate.
- * An extrapolation of the log-log plot showed an unfiltered inleakage rate of 3835 cfm at a CBHZ pressure of 0.51 inches water gauge. This compared favorably to an estimated value of 3717 cfm at a pressure of 0.50 inches water gauge as discussed in Reference 1. The resulting thyroid dose to the control room operator is less than the 18.0 REM stated in TVA's March 1, 1993 letter to NRC since, during the current Unit 2 Cycle 6 outage, TVA replaced the manually operated stack isolation dampers with automatically closing backdraft dampers. This modification lessened the amount of ground level release from the base of the stack, and hence, lowered the overall dose.

Page 5 of 8

ENCLOSURE BROWNS FERRY NUCLEAR PLANT (BFN)

TABLE CONTROL BAY HABITABILITY ZONE SURVEILLANCE TEST RESULTS

		Average Pressure (inches w.g.)	Average Pressure (P.)				Unit 1/2 Mech.
Fan Flow Rate (cfm)	Fan Flow Rate (M ³ /S)			Door Fan (inches w.g.)	Unit 1 Manometer (inches w.g.)	Unit 3 Manometer (inches w.g.)	Equipment Room. Manometer (inches w.g.)
1,639	0.77	0.09	22	0.05	0.10	0.08	0.12
1,919	0.91	0.13	33	0.10	0.15	0.12	0.15
2,256	1.07	0.18	45	0.15	0.20	0.17	0.20
2,571	1.21	0.23	58	0.20	0.24	0.22	0.25
2,764	1.30	0.27	68	0.25	0.29	0.26	0.29
2,958	1.40	0.32	80	0.31	0.33	0.30	0.33
3,191	1.51	0.35	88	0.35	0.36	0.33	0.37
3,469	1.64	0.41	103	0.40	0.41	0.39	0.42
3,835	1.81	0.51	128	0.51	0.52	0.48	0.52
3,189(2)	-	0.34		-	0.35	0.30	0.36

Footnotes:

() - Value extrapolated from log-log plot of the data.

 $^{(2)}$ - Values with CREVS running in lieu of the test fan.

Page 6 of 8

ENCLOSURE BROWNS FERRY NUCLEAR PLANT (BFN)





SCHEMATIC: 500CFM CREVS UNITS (ABANDONED)

Page 7 of 8

ENCLOSURE BROWNS FERRY NUCLEAR PLANT (BFN)





SCHEMATIC: CREVS FILTER SYSTEM

ENCLOSURE BROWNS FERRY NUCLEAR PLANT (BFN)

FIGURE 3 SURVEILLANCE TEST RESULTS LOG-PRESSURE VERSUS LOG-FLOW



Page 8 of 8