



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

June 16, 1993

Docket No. 50-410

Mr. B. Ralph Sylvia
Executive Vice President, Nuclear
Niagara Mohawk Power Corporation
301 Plainfield Road
Syracuse, New York 13212

Dear Mr. Sylvia:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING NINE MILE POINT NUCLEAR
STATION, UNIT 2 RESPONSE TO GENERIC LETTER 92-08, "THERMO-LAG 330-1
FIRE BARRIERS," (TAC NO. M85575)

By letter dated April 13, 1993, Niagara Mohawk Power Corporation (NMPC) provided a response to Generic Letter (GL) 92-08 for Nine Mile Point Nuclear Station, Unit 2 (NMP-2). Although the response stated that the Thermo-Lag 330-1 fire barriers installed at NMP-2 were not qualified by conducting individual specific fire endurance tests for the exact installed configurations, NMPC's response stated that the barriers were qualified to requirements and industry practice applicable at the time of installation. The response stated that the governing criteria for the installation of these barriers were Thermal Science Incorporated (TSI) Technical note 20684 (Thermo-Lag 330 Fire Barrier System, Installation Procedures Manual, Power Generating Plant Applications), Revision V, November 1985 and TSI Form 1082 (500).

NMPC's response further stated that deviations from the tested configurations have not been evaluated. The Thermo-Lag 330-1 fire barrier configurations installed in NMP-2 were designed and constructed by Stone and Webster Engineering Corporation (SWEC), the Architect Engineer for NMP-2. NMPC reviewed and accepted the work of SWEC. The response stated that the fire barrier installations do not deviate from TSI's guidance. However, the response did not specify the acceptance criteria or describe the test methods used for establishing the 3-hour ratings. Please provide information regarding the acceptance criteria and test methods used for establishing the 3-hour ratings in NMPC's response to this request for additional information (RAI).

Although Thermo-Lag barriers were evaluated and may have been considered qualified, the results of recent tests and inspections indicate that further actions are now necessary to address fire endurance and ampacity derating of Thermo-Lag barriers. NMPC's response states that appropriate actions to resolve these concerns are being developed through an industry program coordinated by NUMARC and NMPC would apply the results of the industry program, when completed, to the Thermo-Lag 330-1 installations at NMP-2.

9306210100 930616
PDR ADDCK 05000410
P PDR

NRC FILE CENTER COPY

2 F01
110

June 16, 1993


Compensatory measures for inoperable barriers are in place and will remain in place until the fire barriers can be declared operable.

NMPC's April 13, 1993, response stated that Power Cable 2SWPAGK017 which is routed through 17 feet of Thermo-Lag protected 1 1/2-inch diameter conduit 2CK201GL has been derated 67.5%. In NMPC's response to this RAI, please provide all test reports that document the ampacity derating characteristics of the fire barrier installed and state what ampacity derating margin exclusive of typical derating factors (i.e., ambient temperature, cable fill) is available for Thermo-Lag 330-1 related ampacity derating factors.

In NMPC's response to GL 92-08, NMPC indicated that the actions necessary to restore (or confirm) the operability of these barriers will be based on the results of the NUMARC program. The NRC staff expects that licensees referencing the NUMARC program will review the results and, within 30 days after the completion of the program, inform the NRC of the actions necessary and the schedule for restoring the operability of these fire barriers including plant specific or unique fire barrier configurations that are not bound by the NUMARC program. In accordance with the reporting requirements of GL 92-08, NMPC is also to confirm, in writing, completion of the corrective actions.

The information requested by this letter is within the scope of the overall burden estimate in GL 92-08, which was an average of 300 person-hours for each addressee's response. This request is covered by Office of Management and Budget Clearance Number 3150-0011, which expires June 30, 1994.

Sincerely,



John E. Menning, Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

cc: See next page

Mr. B. Ralph Sylvia
Niagara Mohawk Power Corporation

Nine Mile Point Nuclear Station
Unit No. 2

cc:

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street, NW.
Washington, DC 20005-3502

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Richard Goldsmith
Syracuse University
College of Law
E. I. White Hall Campus
Syracuse, New York 12223

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, New York 10271

Resident Inspector
Nine Mile Point Nuclear Station
P. O. Box 126
Lycoming, New York 13093

Mr. Richard M. Kessel
Chair and Executive Director
State Consumer Protection Board
99 Washington Avenue
Albany, New York 12210

Gary D. Wilson, Esquire
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Mr. Martin J. McCormick Jr.
Plant Manager, Unit 2
Nine Mile Point Nuclear Station
Niagara Mohawk Power Corporation
P. O. Box 32
Lycoming, New York 13093

Mr. David K. Greene
Manager Licensing
Niagara Mohawk Power Corporation
301 Plainfield Road
Syracuse, New York 13212

Mr. Neil S. Carns
Vice President - Nuclear Generation
Nine Mile Point Nuclear Station
Niagara Mohawk Power Corporation
P. O. Box 32
Lycoming, New York 13093

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, New York 12223

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, New York 13126

June 16, 1993

Compensatory measures for inoperable barriers are in place and will remain in place until the fire barriers can be declared operable.

NMPC's April 13, 1993, response stated that Power Cable 2SWPAGK017 which is routed through 17 feet of Thermo-Lag protected 1 1/2-inch diameter conduit 2CK201GL has been derated 67.5%. In NMPC's response to this RAI, please provide all test reports that document the ampacity derating characteristics of the fire barrier installed and state what ampacity derating margin exclusive of typical derating factors (i.e., ambient temperature, cable fill) is available for Thermo-Lag 330-1 related ampacity derating factors.

In NMPC's response to GL 92-08, NMPC indicated that the actions necessary to restore (or confirm) the operability of these barriers will be based on the results of the NUMARC program. The NRC staff expects that licensees referencing the NUMARC program will review the results and, within 30 days after the completion of the program, inform the NRC of the actions necessary and the schedule for restoring the operability of these fire barriers including plant specific or unique fire barrier configurations that are not bound by the NUMARC program. In accordance with the reporting requirements of GL 92-08, NMPC is also to confirm, in writing, completion of the corrective actions.

The information requested by this letter is within the scope of the overall burden estimate in GL 92-08, which was an average of 300 person-hours for each addressee's response. This request is covered by Office of Management and Budget Clearance Number 3150-0011, which expires June 30, 1994.

Sincerely,

Original Signed By:

John E. Menning, Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

cc: See next page

Distribution:

Docket File

NRC & Local PDRs

PDI-1 Reading

SVarga

CMiller, (Acting AD)

RACapra

CVogan

DBrinkman

JMenning

ACRS (10)

CCowgill, RGN-I

AMasciantonio, 13/D/18

CMcCracken, 8/D/1

CBerlinger, 7/E/4

OGC

LA:PDI-1	PM:PDI-1	PM:FDI-1	PDIII-1 <i>asm</i>	SPLB <i>asm</i>	EELB <i>CN/13</i>
CVogan <i>CV</i>	DBrinkman: <i>DAB</i> <i>smm</i>	JMenning <i>JK</i>	AMasciantonio	CMcCracken	CBerlinger
6/1/93	6/2/93	6/2/93	6/3/93	6/4/93	6/16/93
D:PDI-1					
RACapra <i>RAC</i>					
6/16/93					

OFFICIAL RECORD COPY
FILENAME: NM285575.LTR