



P.O. Box 300
Seabrook, NH 03874
Telephone (603) 474-9521
Facsimile (603) 474-2987
Ted C. Feigenbaum
Senior Vice President and
Chief Nuclear Officer

NYN- 93095

June 21, 1993

United States Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Document Control Desk

- References: (a) Facility Operating License No. NPF-86, Docket No. 50-443
(b) Licensee Event Report (LER) 93-02-00: "Potential Premature Opening of CBS Sump Isolation Valves", dated February 8, 1993

Subject: Licensee Event Report (LER) 93-02-01: "Potential Premature Opening of CBS Sump Isolation Valves"

Gentlemen:

Enclosed is Licensee Event Report (LER) No. 93-02-01 for Seabrook Station. This submittal supplements LER 93-02-00 and provides additional information regarding an event that was reported on February 8, 1993 [Reference (b)].

Should you require further information regarding this matter, please contact Mr. James M. Peschel, Regulatory Compliance Manager at (603) 474-9521 extension 3772.

Very truly yours,

Ted C. Feigenbaum

TCF:MDO/tad

Enclosures: NRC Forms 366/366A

280040

9306290290 930621
PDR ADCK 05000443
S PDR

member of the Northeast Utilities system

United States Nuclear Regulatory Commission
Attention: Document Control Desk

June 21, 1993
Page two

cc: Mr. Thomas T. Martin
Regional Administrator
United States Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Mr. Albert W. De Agazio, Sr. Project Manager
Project Directorate I-4
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Noel Dudley
NRC Senior Resident Inspector
P.O. Box 1149
Seabrook, NH 03874

INPO
Records Center
700 Galleria Parkway
Atlanta, GA 30339-5957