



Consumers
Power

**POWERING
MICHIGAN'S PROGRESS**

Big Rock Point Nuclear Plant, 10269 US-31 North, Charlevoix, MI 49720

Patrick M Donnelly
Plant Manager

July 1, 1993

Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Dear Sir:

Enclosed please find the statistical data for the Big Rock Point Nuclear Plant covering the period of June 1, 1993 through June 30, 1993.

Sincerely,

P M Donnelly
Plant Manager

Enclosures

cc: Administrator Region III, Nuclear Regulatory Commission
DRHahn, Department of Public Health
JRPadgett, Michigan Public Service Commission
RAben, Michigan Department of Labor
MPCass, American Nuclear Insures
FYost, Research Services Utility Data Institute
INPO Records Center
NRC Resident Inspector
Document Control, Big Rock Point, 740/22*35*10
DPHoffman, P24-117A
RJAlexander, Big Rock Point
File

9307070379 930630
PDR ADOCK 05000150
R PDR

A CMS ENERGY COMPANY

JE24 11



NUCLEAR OPERATIONS DEPARTMENT Unit Shutdowns and Power Reductions

Report Month <i>June 1993</i>	Docket Number <i>55-150</i>	Unit <i>Big Rock Point Plant</i>	Date <i>July 1, 1993</i>	Completed by <i>JR JOHNSTON</i>	Telephone <i>(616) 547-8223</i>
----------------------------------	--------------------------------	-------------------------------------	-----------------------------	------------------------------------	------------------------------------

Number	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down ³ Reactor	Licensee Event Report Number	System Code ⁴	Component Code ⁵	Cause and Corrective Action To Prevent Recurrence
93-07	05/21/93 thru 06/26/93	F	0.0	H	4	-----	-----	-----	On 05/21/93 at 14:18; started the coast down towards the refueling outage June 26, 1993, with "ALL RODS - ALL OUT".
93-08	06/26/93 thru 06/30/93	S	116.5 Hrs	C	1	-----	-----	-----	On 06/26/93 at 03:27; Started Refueling Outage for 1993. (Total hrs = 116.5)

¹F = Forced
S = Scheduled

²Reason:
A = Equipment Failure (Explain)
B = Maintenance of Test
C = Refueling
D = Regulatory Restriction
E = Operator Training and License Examination
F = Administrative
G = Operational Error (Explain)
H = Other (Explain)

³Method:
1 = Manual
2 = Manual Scram
3 = Automatic Scram
4 = Other (Explain)

⁴Exhibit G = Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

⁵Exhibit I = Same Source

GREYBOOK OPERATING DATA REPORT

DOCKET NO. 50-155 DATE: 7 / 1 / 93
 BY: JR. JOHNSTON
 PHONE: 412-547-6537 EXT 223

OPERATING STATUS

1. UNIT NAME: BIG ROCK POINT NUCLEAR PLANT

2. REPORTING PERIOD: 6 / 93

3. LICENSED THERMAL POWER (MW): 240

4. NAMEPLATE RATING (GROSS MWE): 75

5. DESIGN ELECTRICAL RATING (NET MWE): 72

6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 71.0

7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 67.0

8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THRU 7) SINCE LAST REPORT, GIVE REASONS:

9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE):

10. REASONS FOR RESTRICTIONS, IF ANY:

	THIS MONTH	YEAR-TO-DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	720.0	4243.0	265242.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL	603.5	4112.8	192272.4
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
14. HOURS GENERATOR ON-LINE	603.5	4104.9	187250.6
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
16. GROSS THERMAL ENERGY GENERATED (MMWH)	102753.0	808630.0	36303337.0
17. GROSS ELECTRICAL ENERGY GENERATED (MMWH)	33294.0	257599.0	11525684.0
18. NET ELECTRICAL ENERGY GENERATED (MMWH)	31278.8	243542.5	10906722.9
19. UNIT SERVICE FACTOR	83.8%	94.5%	71.4%
20. UNIT AVAILABILITY FACTOR	83.8%	94.5%	71.4%
21. UNIT CAPACITY FACTOR (USING MDC NET)	64.8%	83.7%	61.1%
22. UNIT CAPACITY FACTOR (USING DER NET)	60.3%	77.8%	57.1%
23. UNIT FORCED OUTAGE RATE	0.0%	0.0%	11.5%

24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, & DURATION OF EACH):

25. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: AUGUST 15, 1993

DAY	AVERAGE DAILY POWER (FWT)	(MLEN)	(6/93)	(CLE)	26
1	178.42	54.50			
2	179.00	54.25			
3	177.17	54.05			
4	177.83	53.88			
5	175.17	53.56			
6	175.58	53.39			
7	174.83	53.22			
8	173.37	53.02			
9	172.62	52.85			
10	172.75	52.60			
11	171.92	52.40			
12	170.96	52.24			
13	170.58	52.00			
14	170.12	51.93			
15	168.54	51.46			
16	169.37	51.42			
17	167.62	51.21			
18	167.00	51.00			
19	165.33	50.76			
20	165.83	50.60			
21	166.04	50.34			
22	163.42	50.05			
23	163.83	49.76			
24	163.25	49.55			
25	161.96	49.26			
26	18.83	3.96			
27	0.00	0.00			
28	0.00	0.00			
29	0.00	0.00			
30	0.00	0.00			

Refueling Information Request

1. Facility Name: Big Rock Point Plant
2. Scheduled date for next refueling shutdown: June, 1993
3. Scheduled date for restart following shutdown: August, 1993
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? No

If yes, explain:

If no, has the reload fuel design and core configuration been reviewed by Plant Safety Review Committee to determine whether any unreviewed safety questions as associated with the core reload (Reference 10 CFR, Section 50.59)? Yes

If no review has taken place, when is it scheduled?

5. Scheduled date(s) for submittal of proposed licensing action and supporting information:
6. Important licensing considerations associated with refueling, eg. new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design new operating procedures:
7. Number of fuel assemblies in: core 72 ; spent fuel pool storage 306; new fuel storage 22.
8. Present licensed spent fuel pool storage capacity: 441

Size of any increase in licensed storage capacity that has been requested or planned (in number of fuel assemblies): 0
9. Projected date of last refueling that can be discharged to spent fuel pool assuming the present license capacity: 1996

Operating Status Report - Nuclear Regulatory Commission

Prepared by: James JohnstonDate: 7/1/1993Reviewed by: T. C. MottDate: 7/2/93

(Reactor Engineer or Alternate)

Copy to be sent to the following by the seventh day of each month:

Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Fred Yost
Director, Research Services
Utility Data Institute
1700 K Street, N.W.
Suite 400
Washington, DC 20006

Administrator
Region III - USNRC
799 Roosevelt Road
Glen Ellyn, IL 60137

DR Hahn, NFEM
Division of Radiological Health
Department of Public Health
3500 North Logan
Lansing, MI 48906

JR Padgett
Michigan Public Service Commission
PO Box 30221
Lansing, MI 48909

Institute of Nuclear Power Operations
Plant Analysis Department
700 Galleria Parkway
Atlanta, GA 30339-5957

Robert Aben, Assistant Chief
Bureau of Construction Codes
Michigan Department of Labor
7150 Harris Drive, Box 30015
Lansing, MI 48909

American Nuclear Insurers
Att: MP Cass
Town Center, Suite 300S
29 South Main Street
West Hartford, CT 06107-2445

Routing Copy:

DP Hoffman, P26-117A
SM McIntyre, P13-121
JL Lampman, Big Rock Point Plant
RC Joba, Big Rock Point Plant
NRC Resident Inspector, Big Rock Point Plant
Document Control Center, Big Rock Point Plant
DCC 740*22*35*10
(740*22*10*04) Cross Reference