UNITED STATES



NUCLEAR REGULATORY COMMISSION

REGIONIV

611 RYAN PLAZA DRIVE, SUITE 400 ARLINGTON, TEXAS 76011-8064

JUN 3 0 1993

Dockets: 50-498

50-499

Licenses: NPF-76

NPF-80

EA 93-160

Houston Lighting & Power Company ATTN: William T. Cottle, Group

Vice President, Nuclear

P.O. Box 1700

Houston, Texas 77251

SUBJECT: NRC INSPECTION REPORT NO. 50-498/93-21; 50-499/93-21 (NOTICE OF

VIOLATION)

This refers to the inspection conducted by Mr. J. I. Tapia of this office on May 10 through June 10, 1993. The inspection included a review of activities authorized for your South Texas Project, Units 1 and 2, facility. At the conclusion of the inspection, the findings were discussed with you and those members of your staff identified in the enclosed report.

Areas examined during the inspection are identified in the report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations of activities in progress. The purpose of the inspection was to determine whether activities authorized by the license were conducted safely and in accordance with NRC requirements.

Based on the results of this inspection, certain of your activities appeared to be in violation of NRC requirements, as specified in the enclosed Notice of Violation (Notice). The violation is of concern because it involved the failure to ensure that the seismic qualification of the Qualified Display Processing System (QDPS) was maintained by taking prompt and effective corrective action to evaluate the effect of missing fasteners identified in the card cages and power supply racks. This condition, originally identified by your system engineer on January 4, 1993, did not receive an evaluation for system operability until April 29, 1993, after identification of the condition by a member of the NRC Diagnostic Evaluation Team. Your operability evaluation subsequently determined that two Technical Specification governed safety-related components, the Steam Generator Power Operated Relief Valves and the Reactor Coolant System Subcooling Monitor, should have been declared inoperable as a result of these missing fasteners. Thus, your failure to take adequate corrective action resulted in potential violations of Technical Specifications 3.7.1.6 and Technical Specification 3.3.3.6.

9307080008 930630 PDR ADDCK 05000498 G PDR JEH!

This violation was determined to be similar to previous violations concerning your failure to take prompt and effective actions to correct problems. We understand HL&P is already taking significant action to resolve weaknesses in its corrective action program as a result of this and other significant enforcement actions. For this reason, no response to the Notice is required.

In addition to the violation, a previously identified unresolved item was reviewed. This unresolved item involved the operation of both units in apparent violation of various Technical Specifications. These conditions resulted from errors in the methodology for adjusting the trip settings on molded case circuit breakers and are of concern because inadequate maintenance instructions resulted in 12 breakers, and subsequently the Technical Specification governed motor-operated valves that were powered from these breakers being considered inoperable. At the end of this inspection an engineering evaluation was being performed by your staff to determine if the adjustments made to these circuit breakers were acceptable and the motor-operated valves were operable. This issue will remain unresolved pending further NRC review.

In accordance with 10 CFR Section 2.790 of the NRC's "Rules of Practice," a copy of this letter and its enclosures will be placed in the NRC Public Document Room.

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

A. Bill Beach, Director Division of Reactor Projects

Enclosure:

1. Appendix A - Notice of Violation
2. Appendix B - NRC Inspection Report

50-498/93-21; 50-499/93-21 w/attachment

cc w/enclosure:

Houston Lighting & Power Company ATTN: William J. Jump, General Manager Nuclear Licensing

P.O. Box 289

Wadsworth, Texas 77483

City of Austin Electric Utility Department ATTN: J. C. Lanier/M. B. Lee 721 Barton Springs Road Austin, Texas 78767

City Public Service Board ATTN: R. J. Costello/M. T. Hardt P.O. Box 1771 San Antonio, Texas 78296

Newman & Holtzinger, P. C. ATTN: Jack R. Newman, Esq. 1615 L Street, NW Washington, D.C. 20036

Central Power and Light Company ATTN: D. E. Ward/T. M. Puckett P.O. Box 2121 Corpus Christi, Texas 78403

INPO Records Center 700 Galleria Parkway Atlanta, Georgia 30339-5957

Mr. Joseph M. Hendrie 50 Bellport Lane Bellport, New York 11713

Bureau of Radiation Control State of Texas 1101 West 49th Street Austin, Texas 78756

Judge, Matagorda County Matagorda County Courthouse 1700 Seventh Street Bay City, Texas 77414

Licensing Representative Houston Lighting & Power Company Suite 610 Three Metro Center Bethesda, Maryland 20814 Houston Lighting & Power Company ATTN: Rufus S. Scott, Associate General Counsel P.O. Box 61867 Houston, Texas 77208

bcc to DMB (IE14)

bcc distrib. by RIV:
J. L. Milhoan
DRP
Lisa Shea, RM/ALF, MS: MNBB 4503
DRSS-FIPS
Project Engineer (DRP/A)
DRS
Section Chief (DRP/TSS)
W. L. Brown
G. A. Pick, SRI, WC

Resident Inspector Section Chief (DRP/A) MIS System RIV File R. Bachmann, OGC, MS: 15-B-18 G. F. Sanborn, EO J. Lieberman, OE, MS: 7-H-5 A. B. Beach, D:DRP

*RIV:SRI *DRP:PE *DRP/D EØ D:DEP JITapia/1r MASatorius WDJohnson GESANborn ABBeach 6/11/93 6/17/93 6/ /93 6/27/93 6/20/93 bcc to DMB (IE14)

bcc distrib. by RIV:
J. L. Milhoan
DRP
Lisa Shea, RM/ALF, MS: MNBB 4503
DRSS-FIPS
Project Engineer (DRP/A)
DRS
Section Chief (DRP/TSS)
W. L. Brown
G. A. Pick, SRI, WC

Resident Inspector Section Chief (DRP/A) MIS System RIV File R. Bachmann, OGC, MS: 15-B-18 G. F. Sanborn, EO J. Lieberman, OE, MS: 7-H-5 A. B. Beach, D:DRP

*RIV:SRI *DRP:PE *DRP/D E0 D:DP JITapia/lr MASatorius WDJohnson GESanborn ABBeach 6/11/93 6/17/93 6/ /93 6/28/93 6/26/93

^{*}Previously concurred