



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

June 21, 1993

The Honorable Richard H. Lehman, Chairman
Subcommittee on Energy and Mineral Resources
Committee on Natural Resources
United States House of Representatives
Washington, DC 20515

Dear Mr. Chairman:

Enclosed for the information of the subcommittee is a copy of a Notice of Final Rulemaking to be published in the Federal Register. The Nuclear Regulatory Commission is amending its regulations to change the time interval that nuclear power plant licensees have for reviewing the performance of maintenance programs from annually to at least every refueling cycle provided the time between evaluations does not exceed 24 months. The Commission believes that the quantity and quality of data obtained during refueling outages will be substantially greater than that available on an annual basis and would provide a more meaningful basis for the recognition and interpretation of trends. This action should result in greater licensee flexibility and greater assurance that nuclear power plants will operate safely.

This final rule should reduce the regulatory burden on power plant licensees while at the same time maintaining the health and safety of the public and the common defense and security.

Sincerely,

A handwritten signature in dark ink, appearing to read "Dennis K. Rathbun", is written over a horizontal line.

Dennis K. Rathbun, Director
Office of Congressional Affairs

Enclosure:
Federal Register Notice

cc: Representative Barbara Vucanovich

CC52



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

June 21, 1993

The Honorable Philip R. Sharp, Chairman
Subcommittee on Energy and Power
Committee on Energy and Commerce
United States House of Representatives
Washington, DC 20515

Dear Mr. Chairman:

Enclosed for the information of the subcommittee is a copy of a Notice of Final Rulemaking to be published in the Federal Register. The Nuclear Regulatory Commission is amending its regulations to change the time interval that nuclear power plant licensees have for reviewing the performance of maintenance programs from annually to at least every refueling cycle provided the time between evaluations does not exceed 24 months. The Commission believes that the quantity and quality of data obtained during refueling outages will be substantially greater than that available on an annual basis and would provide a more meaningful basis for the recognition and interpretation of trends. This action should result in greater licensee flexibility and greater assurance that nuclear power plants will operate safely.

This final rule should reduce the regulatory burden on power plant licensees while at the same time maintaining the health and safety of the public and the common defense and security.

Sincerely,

A handwritten signature in dark ink, appearing to read "Dennis K. Rathbun", is written over a horizontal line.

Dennis K. Rathbun, Director
Office of Congressional Affairs

Enclosure:
Federal Register Notice

cc: Representative Michael Bilirakis



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

June 21, 1993

The Honorable Joseph Lieberman, Chairman
Subcommittee on Clean Air and Nuclear Regulation
Committee on Environment and Public Works
United States Senate
Washington, DC 20510

Dear Mr. Chairman:

Enclosed for the information of the subcommittee is a copy of a Notice of Final Rulemaking to be published in the Federal Register. The Nuclear Regulatory Commission is amending its regulations to change the time interval that nuclear power plant licensees have for reviewing the performance of maintenance programs from annually to at least every refueling cycle provided the time between evaluations does not exceed 24 months. The Commission believes that the quantity and quality of data obtained during refueling outages will be substantially greater than that available on an annual basis and would provide a more meaningful basis for the recognition and interpretation of trends. This action should result in greater licensee flexibility and greater assurance that nuclear power plants will operate safely.

This final rule should reduce the regulatory burden on power plant licensees while at the same time maintaining the health and safety of the public and the common defense and security.

Sincerely,

A handwritten signature in dark ink, appearing to read "Dennis K. Rathbun", is written over a horizontal line.

Dennis K. Rathbun, Director
Office of Congressional Affairs

Enclosure:
Federal Register Notice

cc: Senator Alan K. Simpson

June 21, 1993

The Honorable Richard H. Lehman, Chairman
Subcommittee on Energy and Mineral Resources
Committee on Natural Resources
United States House of Representatives
Washington, DC 20515

Dear Mr. Chairman:

Enclosed for the information of the subcommittee is a copy of a Notice of Final Rulemaking to be published in the Federal Register. The Nuclear Regulatory Commission is amending its regulations to change the time interval that nuclear power plant licensees have for reviewing the performance of maintenance programs from annually to at least every refueling cycle provided the time between evaluations does not exceed 24 months. The Commission believes that the quantity and quality of data obtained during refueling outages will be substantially greater than that available on an annual basis and would provide a more meaningful basis for the recognition and interpretation of trends. This action should result in greater licensee flexibility and greater assurance that nuclear power plants will operate safely.

This final rule should reduce the regulatory burden on power plant licensees while at the same time maintaining the health and safety of the public and the common defense and security.

Sincerely,

Original signed by/

Dennis K. Rathbun, Director
Office of Congressional Affairs

Enclosure:
Federal Register Notice

cc: Representative Barbara Vucanovich
Distribution: [Lehman.JM]

subj-circ-chron

Reading Files

DRathbun, OCA

ESBeckjord

CJHeltemes

TPSpeis

BMorris

FCostanzi

tRiani

Offc:RDB:DR	RDB:DRA	RDB:DRA	DD:DRA:RES	D:DRA:RES	DD/GIR:RES	D:RES
Name:JMate:	RAuluck	SBahadur	FCostanzi	BMorris	CJHeltemes	ESBeckjord
Date: 5/24/93	5/24/93	5/25/93	5/24/93	5/24/93	5/24/93	5/24/93

Offc:OCA
Name:DKRathbun
Date: 6/21/93

OFFICIAL RECORD COPY

June 21, 1993

The Honorable Philip R. Sharp, Chairman
Subcommittee on Energy and Power
Committee on Energy and Commerce
United States House of Representatives
Washington, DC 20515

Dear Mr. Chairman:

Enclosed for the information of the subcommittee is a copy of a Notice of Final Rulemaking to be published in the Federal Register. The Nuclear Regulatory Commission is amending its regulations to change the time interval that nuclear power plant licensees have for reviewing the performance of maintenance programs from annually to at least every refueling cycle provided the time between evaluations does not exceed 24 months. The Commission believes that the quantity and quality of data obtained during refueling outages will be substantially greater than that available on an annual basis and would provide a more meaningful basis for the recognition and interpretation of trends. This action should result in greater licensee flexibility and greater assurance that nuclear power plants will operate safely.

This final rule should reduce the regulatory burden on power plant licensees while at the same time maintaining the health and safety of the public and the common defense and security.

Sincerely,

Original signed by/

Dennis K. Rathbun, Director
Office of Congressional Affairs

Enclosure:
Federal Register Notice

cc: Representative Michael Bilirakis

Distribution: [SHARP.JM]

subj-circ-chron

Reading Files

DRathbun, OCA

ESBeckjord

CJHeltemes

TPSpeis

BMorris

FCostanzi

LRiani

Offc: RDB:DRA
Name: JMate:
Date: 5/24/93

RDB:DRA
RAuluck
5/24/93

RDB:DRA
SBahadur
5/25/93

DD:DRA:RES
FCostanzi
5/24/93

D:DRA:RES
BMorris
5/24/93

DD:DRA:RES
CJHeltemes
5/24/93

D:DRA:RES
ESBeckjord
5/24/93

Offc: OCA
Name: DKRathbun
Date: 5/24/93

OFFICIAL RECORD COPY

June 21, 1993

The Honorable Joseph Lieberman, Chairman
Subcommittee on Clean Air and Nuclear Regulation
Committee on Environment and Public Works
United States Senate
Washington, DC 20510

Dear Mr. Chairman:

Enclosed for the information of the subcommittee is a copy of a Notice of Final Rulemaking to be published in the Federal Register. The Nuclear Regulatory Commission is amending its regulations to change the time interval that nuclear power plant licensees have for reviewing the performance of maintenance programs from annually to at least every refueling cycle provided the time between evaluations does not exceed 24 months. The Commission believes that the quantity and quality of data obtained during refueling outages will be substantially greater than that available on an annual basis and would provide a more meaningful basis for the recognition and interpretation of trends. This action should result in greater licensee flexibility and greater assurance that nuclear power plants will operate safely.

This final rule should reduce the regulatory burden on power plant licensees while at the same time maintaining the health and safety of the public and the common defense and security.

Sincerely,

Original signed by/

Dennis K. Rathbun, Director
Office of Congressional Affairs

Enclosure:
Federal Register Notice

cc: Senator Alan K. Simpson
Distribution: [Lieberman.JM]
subj-circ-chron
Reading Files
DRathbun, OCA
ESBeckjord
CJHeltemes
TPSpeis
BMorris
FCostanzi
LRizna

Offc:RDB:DRA
Name:JMate
Date: 5/24/93

RDB:DRA
RAuluck
5/24/93

RDB:DRA
SBahadur
5/25/93

DD:DRA:RES
FCostanzi
5/24/93

D:DRA:RES
BMorris
5/24/93

DD:DRA:RES
CJHeltemes
5/24/93

D:RES
ESBeckjord
5/24/93

Offc:OCA
Name:DKRathbun
Date: / /93

OFFICIAL RECORD COPY