

Duke Power Company
Catawba Nuclear Generation Department
4800 Concord Road
York, SC 29745

D. L. REHN
Vice President
(803)831-3205 Office
(803)831-3426 Fax



DUKE POWER


June 30, 1993

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Subject: Catawba Nuclear Station, Unit 1
Docket No. 50-413
Special Report
Vibration and Loose Parts Monitoring System

Pursuant to Technical Specification 3.3.3.9, find attached a Special Report concerning the inoperability of the Unit 1 Vibration and Loose Parts Monitoring System channels 9 (Steam Generator A) and 11 (Steam Generator C).

Very truly yours,



D. L. Rehn

KEN/SR063093.LPM

Attachment

xc: S. D. Ebnetter
Regional Administrator, Region II

R. E. Martin, ONRR

R. J. Freudenberger
Senior Resident Inspector

9307150120 930630
PDR ADOCK 05000413
S PDR

IE22
11

SPECIAL REPORT

CATAWBA NUCLEAR STATION, UNIT 1

Vibration and Loose Parts Monitoring System Channels 9 and 11

On May 26, 1993, channel 9 (S/G A Channel 2) and 11 (S/G C Channel 2) were declared inoperable. Both channels failed acceptance criteria for background noise. A work request (#93018325) has been written to repair these channels during a future outage of sufficient length. The following channel is operable and providing coverage as noted:

Channel 7: Steam Generator C

Since these channels have been inoperable for more than 30 days, they are reportable to the NRC pursuant to Technical Specification 3.3.3.9.