

ATTACHMENT 2

ENVIRONMENTAL PROTECTION PLAN PAGES WITH PEN AND INK CHANGES

LICENSE AMENDMENT APPLICATION 93-15, NLR-N93095
REMOVAL OF PAGES 4-1a AND 4-1b FROM ENVIRONMENTAL PROTECTION PLAN
FACILITY OPERATING LICENSE NPF-57
HOPE CREEK GENERATING STATION
DOCKET NO. 50-354

The following Environmental Protection Plan Pages have
been revised to reflect the proposed changes:

<u>EPP Section</u>	<u>Page</u>
Section 4.2.1	Page 4-1a
Section 4.2.1	Page 4-1b

In accordance with Section 7 (a) of the Endangered Species Act, on January 2, 1991, the NMFS issued a Section 7 Consultation Biological Opinion related to the operation of Hope Creek Generating Station. This Section 7 Consultation entitled, "Reinitiation of a consultation in accordance with Section 7 (a) of the Endangered Species Act regarding continued operation of the Salem and Hope Creek Nuclear Generating Stations on the eastern shore of the Delaware River in New Jersey," concluded that "... continued operation is not likely to jeopardize the continued existence of listed species."

In accordance with Attachment 1, Incidental Take Statement, to this Biological Opinion, and all subsequent amendments as may be approved by the National Marine Fisheries Service, PSE&G shall:

- (1) Inspect the Hope Creek Generating Station service water intake trash bars once per day and clean as necessary from June 1 through September 30.
- (2) Make use of dip nets and other equipment whenever possible to remove smaller sea turtles from intake water trash racks to reduce trauma caused by the existing cleaning mechanism.

- (3) Implement the sea turtle resuscitation procedures for comatose turtles described in Appendix I of the Section 7 Biological Opinion. These procedures and related materials shall be posted in appropriate areas.
- (4) The monitoring and reporting system established in 1981 and modified in Appendix II of the Section 7 Biological Opinion shall continue. These reports shall be sent to the NMFS, North East Region (NER) within 30 days of the incidental take. Notification and reporting to the NRC shall be in accordance with Section 4.1 of this plan.

Attachment 2, Conservation Recommendations, to this Biological Opinion suggests conservation recommendations for implementation by Hope Creek Generating Station. The Station shall implement these recommendations to the satisfaction of the National Marine Fisheries Service.