

PSEG

Public Service Electric and Gas Company P.O. Box 238 Hancocks Bridge, New Jersey 08038
Hope Creek Generating Station

July 21, 1993

Chief George Corporale
Bureau of Information Systems
P. O. Box CN-029
Trenton, N. J. 08625

RE: NEW JERSEY POLLUTANT DISCHARGE
ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT
HOPE CREEK GENERATING STATION
NJPDES PERMIT N. 0025411


Dear Sir:

Attached is the Discharge Monitoring Report for the Hope Creek Generating Station for the month of June 1993.

This report is required by and prepared specifically for the Environmental Protection Agency (EPA) and the New Jersey Department of Environmental Protection (NJDEP). It presents only the observed results of measurements and analysis required to be performed by the above agencies. The choice of the measurement devices and analytical methods are controlled by the EPA and the NJDEP, not by the company, and there are limitations on the accuracy of such measurement devices and analytical techniques even when used and maintained as required. Accordingly, this report is not intended as an assertion that any instrument has measured, or that any reading analytical result represents the true value with absolute accuracy, nor is it an endorsement of the suitability of any analytical or measurement procedure.

If you have any questions concerning this report, please feel free to contact Mr. C. E. White.

Sincerely,



Robert J. Hovey
General Manager -
Hope Creek Operations

280679
9307290211 930630
PDR ADUCK 05000354
R PDR

JK33 1
95-21 125M 02-89

NJPDES

2

7/21/93

fr
CW:ej
Attachments

C Executive Director, DRBC
USEPA - Dr. Richard Baker
USNRC

NJPDES
Explanation of conditions
June 1993

7/21/93

The following explanations are included to clarify possible deviation from permit conditions.

General - The columns labeled "No. Ex", on the enclosed DMR, tabulate the number of daily discharge values outside the indicated limits.

Data reporting and accuracy reflect the working environment, the design capabilities and reliability of the monitoring instruments and operating equipment.

Analytical values performed by the following NJDEP certified laboratories:

NET Atlantic, Inc. (08153)
Hope Creek Generating Station (17451)
Talbot Laboratory, Inc. (77535)
South Jersey Testing, Inc. (06431)
Princeton Testing Laboratory, Inc. (11118)

Deviations from required sampling, analysis monitoring and reporting methods and periodicities are noted on the respective transmittal sheet.

Frequency for discharge point 461A, the Cooling Tower Blowdown, and the River were done at approximately 5 hour intervals to provide for the cycles of concentration in the system.

As per the Administrative Consent Order the TSS limit for discharge points 462A, 463A and 464 have been lifted and the interim thermal limits for discharge point 461A have been changed to 443 MBTU/hr (June - September) and 731 MBTU/hr (October - May).

Results reported on the Discharge Monitoring Report forms are consistent with permit limits, data supplied from contract laboratories, the February 1993 revision of the NJDEP DMR Instruction manual and specific guidance from DEP personnel.

NJPDES
Explanation of Exceedances
June 1993

7/21/93


The following exceedances are included in the attached report and explained below. Exclusions have not endangered nor significantly impacted public health or the environment.

DSN No.	EXPLANATION
	No Exceedances


COUNTY OF SALEM
STATE OF NEW JERSEY

I, Robert J. Hovey, of full age, being duly sworn according to law, upon my oath depose and say:

1. I am the General Manager of the Hope Creek Generating Station, and as such am authorized to sign Discharge Monitoring Reports submitted to the New Jersey Department of Environmental Protection pursuant to the Station's New Jersey Pollutant Discharge Elimination System permit.
2. I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.
3. The signature on the attached Discharge Monitoring Reports is my signature and I am submitting this affidavit in satisfaction of the requirement that my signature be notarized.


Robert J. Hovey
General Manager -
Hope Creek Operations

Sworn and subscribed before me
this 21st day of July 1993.



BETTY LOU McKEICH
NOTARY PUBLIC OF NEW JERSEY
MY COMMISSION EXPIRES DEC. 6, 1998

NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATER RESOURCES

MONITORING REPORT - TRANSMITTAL SHEET

NJPDES NO.

REPORTING PERIOD

MO. YR. MO. YR.

[0] [0] [2] [5] [4] [1] [1]

[0] [6] [9] [3] THRU [0] [6] [9] [3]

PERMITTEE: Name Public Service Electric & Gas

Address P.O. Box 236

Hancocks Bridge, NJ 08038

FACILITY: Name Hope Creek Generating Station

Address P.O. Box 236

Hancocks Bridge, NJ (County) Salem

Telephone (609) 339-3463

FORMS ATTACHED (*Indicate Quantity of Each*)

SLUDGE REPORTS - SANITARY

T-VWX-007 T-VWX-008 T-VWX-009

SLUDGE REPORTS - INDUSTRIAL

T-VWX-010A T-VWX-010B

WASTEWATER REPORTS

T-VWX-011 T-VWX-012 T-VWX-013

GROUNDWATER REPORTS

VWX-015(A,B) VWX-016 VWX-017

NPDES DISCHARGE MONITORING REPORT

EPA FORM 3320-1

OPERATING-EXCEPTIONS

YES NO

DYE TESTING

TEMPORARY BYPASSING

DISINFECTION INTERRUPTION

MONITORING MALFUNCTIONS

UNITS OUT OF OPERATION

OTHER

*(Detail any "Yes" on reverse side
in appropriate space.)*

*NOTE: The "Hours Attended at Plant" on the
reverse of this sheet must also be completed.*

AUTHENTICATION - I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.

LICENSED OPERATOR

Name (Printed) Peter Rocco La Sala

Grade & Registry No. (N-2) N-0939

Signature Peter Rocco La Sala

Date 7/21/93

PRINCIPAL EXECUTIVE OFFICER or
DULY AUTHORIZED REPRESENTATIVE

Name (Printed) Robert J. Hovey

General Manager
Hope Creek Operations

Title (Printed) Manager

Signature R.J. Hovey

Date 7/21/93

ADDENDA TO MONITORING REPORT - TRANSMITTAL SHEET

DISCHARGE NUMBER

PAGE	PARAMETER	NOTES	COMMENTS
<u>461A</u>			
1	00400 1 0	*	Sample frequency was 3/wk for week ending 6/6.
2	00665 2 1	*	NET values calculated from grab samples.
2	00680 2 1		
<u>461C</u>			
6	00680 1 1	*	Samples obtained were composites in accordance with permit requirements.
<u>462A</u>			
8	All Parameters	*	Several rain events (squalls) were observed during the monitoring period, none of which resulted in discharge events. NODI entered IAW DMR Instruction Manual.
<u>462B</u>			
9	00530 1 0	*	Sample frequency was 2/month for the monitoring period.
<u>463A</u>			
11	All Parameters	*	Several rain events (squalls) were observed during the monitoring period, none of which resulted in discharge events. NODI entered IAW DMR Instruction Manual.
<u>464A</u>			
12	All Parameters	*	Several rain events (squalls) were observed during the monitoring period, none of which resulted in discharge events. NODI entered IAW DMR Instruction Manual.

NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATER RESOURCESMONITORING REPORT - TRANSMITTAL SHEET

NPDES NO.

REPORTING PERIOD

MO. YR. MO. YR.

[0025411]

[061993] THRU [061993]

PERMITTEE: Name Public Service Electric & GasAddress P.O. Box 236Hancock's Bridge, N.J. 08038FACILITY: Name Hope Creek Generating StationAddress P.O. Box 236Hancock's Bridge (County) SalemTelephone (609) 339-3463

FORMS ATTACHED (Indicate Quantity of Each)

SLUDGE REPORTS - SANITARY

 T-VWX-007 T-VWX-008 T-VWX-009

SLUDGE REPORTS - INDUSTRIAL

 T-VWX-010A T-VWX-010B

WASTEWATER REPORTS

 T-VWX-011 T-VWX-012 T-VWX-013

GROUNDWATER REPORTS

 VWX-015(A,B) VWX-016 VWX-017

NPDES DISCHARGE MONITORING REPORT

 EPA FORM 3320-1

OPERATING EXCEPTIONS

YES NO

DYE TESTING TEMPORARY BYPASSING DISINFECTION INTERRUPTION MONITORING MALFUNCTIONS UNITS OUT OF OPERATION OTHER (Detail any "Yes" on reverse side
in appropriate space.)NOTE: The "Hours Attended at Plant" on the
reverse of this sheet must also be completed.

AUTHENTICATION - I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.

LICENSED OPERATOR

PRINCIPAL EXECUTIVE OFFICER or
DULY AUTHORIZED REPRESENTATIVEName (Printed) Andres NurkName (Printed) Robert J. RoveyGrade & Registry No. S-4 (S4542)

General Manager

Signature Andres Nurk

Hope Creek Operations

Date 7/21/93Signature RJR Date 7/21/93

PERMITTEE NAME/ADDRESS /Include
Facility Name/Location if different)

NAME PSEG
ADDRESS P.O. BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

NJ0025411
PERMIT NUMBER

461A
DISCHARGE NUMBER

Form Approved.
OMB No. 2040-0004.
Approval expires 6-30-91.

FACILITY PSEG HOPE CREEK GENERATING ST
LOCATION LOWER ALLOWAYS CREEK, NJ 08038

DMR NUMBER: 93061511

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	93	06	01		93	06	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

COOLING TOWER BLOWDOWN
MAJOR SALEM
SOUTHERN REGION
NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) (46-53)		QUANTITY OR LOADING (34-61)		(4 Card Only) (38-45)		QUALITY OR CONCENTRATION (46-53)		(34-61)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (54-68)	SAMPLE TYPE (69-70)	
		X	V	X	M	X	M	X	M	X	M				
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 1	SAMPLE MEASUREMENT	0000000		0000000		0000000		30.2		33.6			0	CONTIN OUS	
EFFLUENT GROSS VALUE	PRIORITY REQUIREMENT	0000000		0000000		0000000		REPORT MTH AVG	35.66000	DLY MAX		DEG-C		CONTIN OUS	
TEMPERATURE, WATER DEG. CENTIGRADE 00010 7 1	SAMPLE MEASUREMENT	0000000		0000000		0000000		20.9		25.5			0	CONTIN OUS	
INTAKE FROM STREAM	PRIORITY REQUIREMENT	0000000		0000000		0000000		REPORT MTH AVG	REPORT DLY MAX			DEG-C		CONTIN OUS	
PH 00400 1 0	SAMPLE MEASUREMENT	0000000		0000000		8		0000000		8			0	TWICE/ WEEK *	GRAB
EFFLUENT GROSS VALUE	PRIORITY REQUIREMENT	0000000		0000000		0000000		6.00000	0000000	9.00000		SU		TWICE/GRAB WEEK	
SOLIDS, TOTAL SUSPENDED 00530 1 0	SAMPLE MEASUREMENT	0000000		0000000		0000000		MINIMUM		116			0	TWICE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PRIORITY REQUIREMENT	0000000		0000000		0000000		REPORT MTH AVG	REPORT DLY MAX			MG/L		TWICE/GRAB MONTH	
SOLIDS, TOTAL SUSPENDED 00530 2 0	SAMPLE MEASUREMENT	0000000		0000000		0000000		56		60			0	TWICE/ MONTH	CALCTD
EFFLUENT NET VALUE	PRIORITY REQUIREMENT	0000000		0000000		0000000		REPORT MTH AVG	REPORT DLY MAX			MG/L		TWICE/CALCTD MONTH	
SOLIDS, TOTAL SUSPENDED 00530 7 0	SAMPLE MEASUREMENT	0000000		0000000		0000000		60		92			0	TWICE/ MONTH	GRAB
INTAKE FROM STREAM	PRIORITY REQUIREMENT	0000000		0000000		0000000		REPORT MTH AVG	REPORT DLY MAX			MG/L		TWICE/GRAB MONTH	
HYDROCARBONS, IN H2O, IR, CC14 EXT. CHROMAT 00551 1 0	SAMPLE MEASUREMENT	0000000		0000000		0000000		0.1		0.2			0	TWICE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PRIORITY REQUIREMENT	0000000		0000000		0000000		REPORT MTH AVG	REPORT DLY MAX			MG/L		TWICE/GRAB MONTH	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

Robert J. Hovey
General Manager
Hope Creek Operations

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED
AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED
ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR
OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION
IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT
PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING
THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND
33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000
and/or maximum imprisonment of between 6 months and 5 years.)

111
M
SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
609	339-3463	93	07	21
AREA CODE	NUMBER	YEAR	MO	DAY

SAMPLING FOR CU, ZN, & CR IS REQUIRED ONLY IF MAINTENANCE CHEMICALS CONTAINING THESE METALS ARE USED. IF
NOT USED, ENTER "NODI" FOR THESE METALS. *Please refer to Transmittal Sheet Addenda.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME PSEG

ADDRESS P.O. BOX 236/N21

HANCOCKS BRIDGE, NJ 08038

FACILITY PSEG HOPE CREEK GENERATING ST
LOCATION LOWER ALLOWAYS CREEK, NJ 08038

DMR NUMBER: 93061511

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

NJ0025411

PERMIT NUMBER

461A

DISCHARGE NUMBER

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	93	06	01		93	06	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

COOLING TOWER BLOWDOWN

MAJOR

SALEM

SOUTHERN REGION

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-51)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		MINIMUM	AVERAGE	MAXIMUM	MINIMUM	AVERAGE	MAXIMUM			
HYDROCARBONS, IN H2O, IR, CC14 EXT. CHROMAT 00551 2 0	SAMPLE MEASUREMENT	000000	000000		000000	0	<0.10	0	TWICE/ MONTH	CALCTD
	PERMIT REQUIREMENT	000000	000000	-	0000	000000	REPORT MNTH AVG		000000	000000
EFFLUENT NET VALUE	SAMPLE MEASUREMENT	000000	000000		000000	0.10	0.2	0	TWICE/ MONTH	GRAB
	PERMIT REQUIREMENT	000000	000000	-	0000	000000	REPORT MNTH AVG		000000	000000
HYDROCARBONS, IN H2O, IR, CC14 EXT. CHROMAT 00551 7 0	SAMPLE MEASUREMENT	000000	000000		000000	0.21	0.26	0	TWICE/ MONTH	GRAB
	PERMIT REQUIREMENT	000000	000000	-	0000	000000	REPORT MNTH AVG		000000	000000
INTAKE FROM STREAM PHOSPHORUS, TOTAL (AS P) 00665 1 1	SAMPLE MEASUREMENT	000000	000000		000000	0.07	0.08	0	TWICE/ MONTH	*CALCTD
	PERMIT REQUIREMENT	000000	000000	-	0000	000000	REPORT MNTH AVG		000000	000000
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	000000	000000		000000	0.14	0.19	0	TWICE/ MONTH	GRAB
	PERMIT REQUIREMENT	000000	000000	-	0000	000000	REPORT MNTH AVG		000000	000000
PHOSPHORUS, TOTAL (AS P) 00665 2 1	SAMPLE MEASUREMENT	000000	000000		000000	10	14	0	TWICE/ MONTH	GRAB
	PERMIT REQUIREMENT	000000	000000	-	0000	000000	REPORT MNTH AVG		000000	000000
EFFLUENT NET VALUE	SAMPLE MEASUREMENT	000000	000000		000000	4	6	0	TWICE/ MONTH	* CALCTD
	PERMIT REQUIREMENT	000000	000000	-	0000	000000	REPORT MNTH AVG		000000	000000
INTAKE FROM STREAM CARBON, TOT ORGANIC (TOC) 00680 1 1	SAMPLE MEASUREMENT	000000	000000		000000	000000	000000	0	TWICE/ MONTH	GRAB
	PERMIT REQUIREMENT	000000	000000	-	0000	000000	REPORT MNTH AVG		000000	000000
CARBON, TOT ORGANIC (TOC) 00680 2 1	SAMPLE MEASUREMENT	000000	000000		000000	000000	000000	0	TWICE/ MONTH	* CALCTD
	PERMIT REQUIREMENT	000000	000000	-	0000	000000	REPORT MNTH AVG		000000	000000
EFFLUENT NET VALUE	SAMPLE MEASUREMENT	000000	000000		000000	000000	000000	0	TWICE/ MONTH	GRAB
	PERMIT REQUIREMENT	000000	000000	-	0000	000000	REPORT MNTH AVG		000000	000000

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 3 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE	DATE
609 339-3463	93 07 21
AREA CODE	NUMBER
YEAR	MO
DAY	

SMELTING EXPLANATION OF ZINC & TIN IS REQUIRED ONLY IF MAINTENANCE CHEMICALS CONTAINING THESE METALS ARE USED. IF NOT USED, ENTER "NODIT" FOR THESE METALS.

* Refer to Transmittal Sheet Addenda.

Form Approved
OMB No. 2040-0004.
Approval expires 6-30-91.

PERMITTER'S NAME/ADDRESS (Include Facility Name/Location if different)

NAME PSEG

ADDRESS P.O. BOX 236/N21

HANCOCKS BRIDGE, NJ 08038

FACILITY PSEG HOPE CREEK GENERATING ST

LOCATION LOWER ALLOWAYS CREEK, NJ 08038

DMR NUMBER: 93061511

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

NJ0025411

PERMIT NUMBER

461A

DISCHARGE NUMBER

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	93	06	01		93	06	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

COOLING TOWER BLOWDOWN


MAJOR

SALEM

SOUTHERN REGION

NOTE: Read instructions before completing this form.

Form Approved.
OMB No. 2040-0004.
Approval expires 6-30-91.

PARAMETER (32-37)	(3 Card Only) (46-53)		QUANTITY OR LOADING (54-61)		(4 Card Only) (38-45)		QUALITY OR CONCENTRATION (46-53)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)			
	SAMPLE MEASUREMENT	PERMIT REQUIREMENT	Xxxxxxxxxxxxx	Xxxxxxxxxxxxx	UNITS	Xxxxxxxxxxxxx	Xxxxxxxxxxxxx	Xxxxxxxxxxxxx				UNITS		
CARBON, TOT ORGANIC (TOC) 00680 7 1 INTAKE FROM STREAM	SAMPLE MEASUREMENT	0000000	0000000		0000000	6.0	8.0		0	TWICE/ MONTH	GRAB			
	PERMIT REQUIREMENT	0000000	0000000		0000000	REPORT MNTH AVG	REPORT DLY MAX		MG/L	TWICE/GRAB MONTH				
CHROMIUM, TOTAL (AS CR) 01034 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	0000000	0000000		0000000	NODI	NODI			-	-			
	PERMIT REQUIREMENT	0000000	0000000		0000000	REPORT MNTH AVG	REPORT DLY MAX		MG/L	TWICE/GRAB MONTH				
CHROMIUM, TOTAL (AS CR) 01034 2 0 EFFLUENT NET VALUE	SAMPLE MEASUREMENT	0000000	0000000		0000000	NODI	NODI			-	-			
	PERMIT REQUIREMENT	0000000	0000000		0000000	REPORT MNTH AVG	+20000 DLY MAX		MG/L	TWICE/CALCTD MONTH				
CHROMIUM, TOTAL (AS CR) 01034 7 0 INTAKE FROM STREAM	SAMPLE MEASUREMENT	0000000	0000000		0000000	NODI	NODI			-	-			
	PERMIT REQUIREMENT	0000000	0000000		0000000	REPORT MNTH AVG	REPORT DLY MAX		MG/L	TWICE/GRAB MONTH				
COPPER, TOTAL (AS CU) 01042 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	0000000	0000000		0000000	NODI	NODI			-	-			
	PERMIT REQUIREMENT	0000000	0000000		0000000	REPORT MNTH AVG	REPORT DLY MAX		MG/L	TWICE/GRAB MONTH				
COPPER, TOTAL (AS CU) 01042 2 0 EFFLUENT NET VALUE	SAMPLE MEASUREMENT	0000000	0000000		0000000	NODI	NODI			-	-			
	PERMIT REQUIREMENT	0000000	0000000		0000000	REPORT MNTH AVG	+20000 DLY MAX		MG/L	TWICE/CALCTD MONTH				
COPPER, TOTAL (AS CU) 01042 7 0 INTAKE FROM STREAM	SAMPLE MEASUREMENT	0000000	0000000		0000000	NODI	NODI			-	-			
	PERMIT REQUIREMENT	0000000	0000000		0000000	REPORT MNTH AVG	REPORT DLY MAX		MG/L	TWICE/GRAB MONTH				
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 5 months and 5 years.)								TELEPHONE	DATE			
Robert J. Hovey General Manager Hope Creek Operations										609	339-346393	07	21	
TYPED OR PRINTED										AREA CODE	NUMBER	YEAR	MO	DAY

SAMPLING AND EXPLANATION OF ANY VIOLATIONS: *Revised 10-1-90*
Sampling for Cu, Zn, & Cr is required only if maintenance chemicals containing these metals are used. If not used, enter "NODI" for these metals.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME PSEG

ADDRESS P.O. BOX 236/N21

HANCOCKS BRIDGE, NJ 08038

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-6)

(17-19)

NJ0025411
PERMIT NUMBER

461A
DISCHARGE NUMBER


Ferm Approved.
OMB No. 2040-0004.
Approval expires 6-30-91.

FACILITY PSEG HOPE CREEK GENERATING ST
LOCATION LOWER ALLOWAYS CREEK, NJ 08038

DMR NUMBER: 93061511

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	93	06	01		93	06	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

COOLING TOWER BLOWDOWN
MAJOR SALEM
SOUTHERN REGION
NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)		(4 Card Only) QUALITY OR CONCENTRATION (38-45)		(46-53)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (54-68)	SAMPLE TYPE (69-70)		
		AVERAGE XXXXXX	MAXIMUM XXXXXX	UNITS	MINIMUM XXXXXX	AVERAGE XXXXXX	MAXIMUM XXXXXX				UNITS	
ZINC, TOTAL (AS ZN) 01092 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	000000	000000		000000	NODI	NODI	-	-	-		
	PERMIT REQUIREMENT	000000	000000	0000	000000	REPORT MNTH AVG	REPORT DLY MAX	MG/L	TWICE/GRAB MONTH			
ZINC, TOTAL (AS ZN) 01092 2 0 EFFLUENT NET VALUE	SAMPLE MEASUREMENT	000000	000000		000000	NODI	NODI	-	-	-		
	PERMIT REQUIREMENT	000000	000000	0000	000000	REPORT MNTH AVG	60000 DLY MAX	MG/L	TWICE/CALCTD MONTH			
ZINC, TOTAL (AS ZN) 01092 7 0 INTAKE FROM STREAM	SAMPLE MEASUREMENT	000000	000000		000000	NODI	NODI	-	-	-		
	PERMIT REQUIREMENT	000000	000000	0000	000000	REPORT MNTH AVG	REPORT DLY MAX	MG/L	TWICE/GRAB MONTH			
ASBESTOS (FIBROUS) 34225 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	000000	000000		000000	<0.000007	<0.000007	0	TWICE/GRAB MONTH			
	PERMIT REQUIREMENT	000000	000000	0000	000000	REPORT MNTH AVG	REPORT DLY MAX	UG/L	TWICE/GRAB MONTH			
ASBESTOS (FIBROUS) 34225 2 0 EFFLUENT NET VALUE	SAMPLE MEASUREMENT	000000	000000		000000	<0.000007	<0.000007	0	TWICE/CALCTD MONTH			
	PERMIT REQUIREMENT	000000	000000	0000	000000	REPORT MNTH AVG	REPORT DLY MAX	UG/L	TWICE/CALCTD MONTH			
ASBESTOS (FIBROUS) 34225 7 0 INTAKE FROM STREAM	SAMPLE MEASUREMENT	000000	000000		000000	<0.000004	<0.000004	0	TWICE/GRAB MONTH			
	PERMIT REQUIREMENT	000000	000000	0000	000000	REPORT MNTH AVG	REPORT DLY MAX	UG/L	TWICE/GRAB MONTH			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	47.72	57.30		000000	000000	000000	0	CONTIN OUS			
	PERMIT REQUIREMENT	REPORT MNTH AVG	REPORT DLY MAX	MGD	000000	000000	000000	0	CONTIN OUS			
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)						14 	TELEPHONE	DATE			
Robert J. Hovey General Manager Hope Creek Operations								609	339-3463	93	07	21
TYPED OR PRINTED							AREA CODE	NUMBER	YEAR	MO	DAY	

COMPLIANCE EXPLANATION OF ANY VIOLATIONS: (Refer to all applicable laws and regulations)
Sampling for Cu, Zn, & Cr is required only if maintenance chemicals containing these metals are used. If not used, enter "NODIM" for these metals.

FACILITY NAME/ADDRESS (Include
Facility Name/Location if different)NAME PSEG
ADDRESS P.O. BOX 236/N21
HANCOCKS BRIDGE, NJ 08038NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2/16)

(17/19)

NJ0025411

PERMIT NUMBER

461A

DISCHARGE NUMBER

Form Approved.
OMB No. 2040-0004.
Approval expires 6-30-91.FACILITY PSEG HOPE CREEK GENERATING ST
LOCATION LOWER ALLOWAYS CREEK, NJ 08038

DMR NUMBER: 93061511

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	93	06	01		93	06	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)


COOLING TOWER BLOWDOWN
MAJOR
SALEM
SOUTHERN REGION
NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (52-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE XXXXXX	MAXIMUM XXXXXX	UNITS	MINIMUM XXXXXX	AVERAGE XXXXXX	MAXIMUM XXXXXX			
CHLDRINE, TOTAL RESIDUAL 50060 1 0	SAMPLE MEASUREMENT	000000	000000		000000	<0.10	<0.10			CONTIN UOUS
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	000000	000000	0000	000000	200000	500000	MG/L		CONTIN UOUS
HEAT (SUMMER) (PER HOUR)	SAMPLE MEASUREMENT	273	422		000000	000000	000000		0	CONTIN UOUS CALCTD
81386 2 1 (ADMIN)	PERMIT REQUIREMENT	REPORT MNTH AVG	443.66000	MBTU/ HR	000000	200000	800000		0000	CONTIN CALCTD UOUS
EFFLUENT NET VALUE	SAMPLE MEASUREMENT								000	
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

Robert J. Hovey
General Manager
Hope Creek Operations

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED
AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED
ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR
OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION
IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIG-
NIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING
THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND
33 USC § 1319. (Penalties under these statutes may include fines up to \$100,000
and/or maximum imprisonment of between 5 months and 5 years.)
SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE DATE

609 339-3463 93 07 21

AREA NUMBER YEAR MO DAY

COMPLAINING INFORMATION OF ANY VIOLATION. THIS FORM IS REQUIRED ONLY IF MAINTENANCE CHEMICALS CONTAINING THESE METALS ARE USED. IF
NOT USED, ENTER "NODIR" FOR THESE METALS.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME PSEG

ADDRESS P.O. BOX 236/N21

HANCOCKS BRIDGE, NJ 08038

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

NJ0025411

PERMIT NUMBER

461C

DISCHARGE NUMBER

Form Approved.
OMB No. 2040-0004.
Approval expires 6-30-91.

FACILITY PSEG HOPE CREEK GENERATING ST

LOCATION LOWER ALLOWAYS CREEK, NJ 08038

DMR NUMBER: 93061511

LOW VOLUME WW SYSTEM

SALEM

SOUTHERN REGION

NOTE: Read instructions before completing this form.

MONITORING PERIOD		
FROM	TO	
YEAR 93 (20-21)	MO 06 (22-23)	DAY 01 (24-25)
YEAR 93 (26-27)	MO 06 (28-29)	DAY 30 (30-31)

PARAMETER (32-37)	(3 Card Only) QUANTITY OR LOADING (34-61)		(4 Card Only) QUALITY OR CONCENTRATION (38-45)		(46-51)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	SAMPLE MEASUREMENT	PERMIT REQUIREMENT	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 1	SAMPLE MEASUREMENT 0000000	PERMIT REQUIREMENT 0000000	0000000	0000000	19.6	21.5	DEG.C	0	WEEKLY GRAB
EFFLUENT GROSS VALUE PH 00400 1 0	SAMPLE MEASUREMENT 0000000	PERMIT REQUIREMENT 0000000	0000000	0000000	REPORT MNTH AVG	REPORT DLY MAX		WEEKLY	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0	SAMPLE MEASUREMENT 0000000	PERMIT REQUIREMENT 0000000	0000000	0000000	7	0000000	SU	0	WEEKLY GRAB
EFFLUENT GROSS VALUE HYDROCARBONS, IN H2O IR, CC14 EXT. CHROMAT 00551 1 0	SAMPLE MEASUREMENT 0000000	PERMIT REQUIREMENT 0000000	0000000	0000000	6.00E000 MINIMUM	9.00E000 MAXIMUM		WEEKLY	GRAB
NITROGEN, AMMONIA TOTAL (AS N) 00610 1 0	SAMPLE MEASUREMENT 0000000	PERMIT REQUIREMENT 0000000	0000000	0000000	30.00000 MNTH AVG	100.00000 DLY MAX	MG/L	TWICE/ MONTH	COMPOS
EFFLUENT GROSS VALUE CARBON, TOT ORGANIC (TOC) 00680 1 1	SAMPLE MEASUREMENT 0000000	PERMIT REQUIREMENT 0000000	0000000	0000000	0000000	0		TWICE/ MONTH	GRAB
EFFLUENT GROSS VALUE COPPER, TOTAL (AS CU) 01042 1 0	SAMPLE MEASUREMENT 0000000	PERMIT REQUIREMENT 0000000	0000000	0000000	0000000	10.00000 MNTH AVG	MG/L	TWICE/ MONTH	GRAB
EFFLUENT GROSS VALUE 0000000	SAMPLE MEASUREMENT 0000000	PERMIT REQUIREMENT 0000000	0000000	0000000	0000000	15.00000 DLY MAX		TWICE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

Robert J. Hovey
General Manager
Hope Creek Manager
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 16 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 4 months and 5 years.)


SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE DATE

609	339-3463	93	07	21
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* Refer to Transmittal Sheet Addenda.

PERMITTER NAME/ADDRESS /Include
Facility Name/Location if different:

NAME PSEG
ADDRESS P.O. BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

NJ0025411
PERMIT NUMBER

461C
DISCHARGE NUMBER

Form Approved.
OMB No. 2040-0004.
Approval expires 6-30-91.

FACILITY PSEG HOPE CREEK GENERATING ST
LOCATION LOWER ALLOWAYS CREEK, NJ 08038

DMR NUMBER: 93061511

MONITORING PERIOD						
FROM	YEAR	MO	DAY	TO	YEAR	MO
	93	05	01		93	06
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)
						(30-31)

LOW VOLUME WW SYSTEM

MAJOR

SALEM

SOUTHERN REGION

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(3 Card Only) QUANTITY OR LOADING (34-61)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGEXXXX	MAXIMUMXXXX	UNITS	MINIMUMXXXX	MEDIANXXXX	MAXIMUMXXXX			
IRON, TOTAL (AS FE) 01045 1 0	SAMPLE MEASUREMENT	000000	000000	000000	0.86	0.90	MG/L	0	TWICE/ MONTH
EFFLUENT GROSS VALUE FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0	PERMIT REQUIREMENT	000000	000000	000000	REPORT MNTH AVG	REPORT DLY MAX			TWICE/GRAB MONTH
	SAMPLE MEASUREMENT	0.05	0.08	000000	000000	000000		0	CONTIN UOUS
	PERMIT REQUIREMENT	REPORT MNTH-AVG	*45600X	000000	000000	000000		0000	CONTIN UOUS
	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

Robert J. Hovey
General manager
Hope Creek Operations
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED
AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED
ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR
OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION
IS TRUE ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIG-
NIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING
THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND
33 USC § 1319. Penalties under these statutes may include fines up to \$10,000
and/or maximum imprisonment of between 6 months and 5 years.

[Signature]
SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE	DATE		
609 339-3463	93	07	21
AREA CODE	NUMBER	YEAR	MO

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include
Facility Name/Location if different)

NAME PSEG
ADDRESS P.O. BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2/8)

(17/19)

NJ0025411

PERMIT NUMBER

462A

DISCHARGE NUMBER

FACILITY PSEG HOPE CREEK GENERATING ST
LOCATION LOWER ALLOWAYS CREEK, NJ 08038

DMR NUMBER: 93061511

NORTH STORM DRAIN

MAJOR

SALEM

SOUTHERN REGION

NOTE: Read instructions before completing this form.

PARAMETER (33-37)	(3) Card Only) QUANTITY OR LOADING (46-53)			(4) Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (52-53)	FREQUENCY OF ANALYSIS (54-58)	SAMPLE TYPE (69-70)
	AVERAGE XXXXXX	MAXIMUM XXXXXX	UNITS	MINIMUM XXXXXX	AVERAGE XXXXXX	MAXIMUM XXXXXX			
PH	SAMPLE MEASUREMENT	0000000	0000000	NODI	0000000	NODI	*	-	-
	PERMIT REQUIREMENT	0000000	0000000		5.00000	0000000			
00400 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	0000000	0000000	0000000	0000000	NODI	*	-	-
	PERMIT REQUIREMENT	0000000	0000000		0000000	REPORT MTH AVG			
00530 1 1 (ADMIN) EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	0000000	0000000	0000000	0000000	NODI	*	-	-
	PERMIT REQUIREMENT	0000000	0000000		0000000	REPORT MTH AVG			
HYDROCARBONS, IN H2O, IR, CC14 EXT. CHROMAT	SAMPLE MEASUREMENT	0000000	0000000	0000000	0000000	NODI	*	-	-
	PERMIT REQUIREMENT	0000000	0000000		0000000	REPORT MTH AVG			
00551 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	0000000	0000000	0000000	0000000	NODI	*	-	-
	PERMIT REQUIREMENT	0000000	0000000		0000000	REPORT MTH AVG			
CARBON, TOT ORGANIC (TOC)	SAMPLE MEASUREMENT	0000000	0000000	0000000	0000000	NODI	*	-	-
	PERMIT REQUIREMENT	0000000	0000000		0000000	REPORT MTH AVG			
00680 1 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	0000000	0000000	0000000	0000000	NODI	*	-	-
	PERMIT REQUIREMENT	0000000	0000000		0000000	REPORT MTH AVG			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	NODI	NODI	0000000	0000000	0000000	*	-	-
	PERMIT REQUIREMENT	REPORT MTH AVG	REPORT DLY MAX		0000000	0000000			
50050 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT			0000000	0000000	0000000	*	-	-
	PERMIT REQUIREMENT				0000000	0000000			
	SAMPLE MEASUREMENT			0000000	0000000	0000000	*	-	-
	PERMIT REQUIREMENT				0000000	0000000			

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

Robert J. Hovey
General Manager
Hope Creek Operations

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED
AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED
ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR
OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION
IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIG-
NIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING
THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND
33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000
and/or maximum imprisonment of between 6 months and 5 years.)

141
RULL
SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

609 339-3463 93 07 21

AREA
CODE

NUMBER

YEAR

MO

DAY

SAMPLES TO BE TAKEN DURING A "DISCHARGE" EVENT, EXCEPT FOR PET HC FOR WHICH SAMPLES SHALL BE TAKEN DURING
THE 1ST PRECIPITATION EVENT OF MONTH WHICH CAUSES DISCHARGE DURING WORKING HRS & IS PRECEDED BY MINIMUM
DRY PERIOD OF 72 HRS. * Please refer to Transmittal Sheet Addenda.

Form Approved.
OMB No. 2040-0004.
Approval expires 6-30-91.

PERMITTING NAME/ADDRESS (Include Facility Name/Location if different)

NAME PSEG
ADDRESS P.O. BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

NJ0025411
PERMIT NUMBER

462B
DISCHARGE NUMBER

Form Approved.
OMB No. 2040-0004.
Approval expires 6-30-91.

FACILITY PSEG HOPE CREEK GENERATING ST
LOCATION LOWER ALLOWAYS CREEK, NJ 08038
DMR NUMBER: 93061511

SEWAGE W.W.
MAJOR
SOUTHERN REGION
NOTE: Read Instructions before completing this form.

SALEM

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53) (34-61)			(4 Card Only) QUALITY OR CONCENTRATION (38-45) (46-53) (34-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		XAVGXXXX	XMAXIMUMXXX	UNITS	XMINIMUMXXX	XAVGXXXX	XMAXIMUMXXX			
BOD, 5-DAY (20 DEG. C) 00310 G 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	28.7	28.7	KG/ DAY	000000	236	236	MG/L	0	ONCE/ MONTH
	PERMIT REQUIREMENT	REPORT MNTH AVG	REPORT DLY MAX		000000	REPORT MNTH AVG	REPORT DLY MAX			
BOD, 5-DAY (20 DEG. C) 00310 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	2.7	2.7	KG/ DAY	000000	22	22	MG/L	0	ONCE/ MONTH
	PERMIT REQUIREMENT	6.00000 MNTH AVG	REPORT DLY MAX		000000	REPORT MNTH AVG	REPORT DLY MAX			
PH 00400 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	000000	000000	SU	7.1	000000	7.6	TWICE/ WEEK	0	GRAB
	PERMIT REQUIREMENT	0000000	0000000		6.00000 MINIMUM	0000000	9.00000 MAXIMUM			
SOLIDS, TOTAL SUSPENDED 00530 G 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	000000	000000	MG/L	000000	298	298	COMPOS	0	ONCE/ MONTH
	PERMIT REQUIREMENT	000000	000000		000000	REPORT MNTH AVG	REPORT DLY MAX			
SOLIDS, TOTAL SUSPENDED 00530 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	000000	000000	MG/L	000000	21	31	COMPOS	0	ONCE/ MONTH
	PERMIT REQUIREMENT	000000	000000		000000	30400000 MNTH AVG	100.000000 DLY MAX			
OIL AND GREASE FREON EXTR-GRAV METH 00556 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	000000	000000	MG/L	000000	2	2	GRAB	0	ONCE/ MONTH
	PERMIT REQUIREMENT	000000	000000		000000	10.000000 MNTH AVG	15.000000 DLY MAX			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	0.025	0.041	MGD	000000	000000	000000	DAILY	0	FLOIND
	PERMIT REQUIREMENT	REPORT MNTH AVG	REPORT DLY MAX		000000	000000	000000			

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

Robert J. Hovey
General Manager
Hope Creek Operations

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$100,000 and maximum imprisonment of between 6 months and 5 years.)

RJH
Signature of Principal Executive Officer or Authorized Agent

TELEPHONE	DATE		
609 339-3463	93	07	21
AREA CODE	NUMBER	YEAR	MO

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* Please refer to Transmittal Sheet Addenda.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME PSEG
ADDRESS P.O. BOX 236/N21
HANCOCKS BRIDGE, NJ 08036

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

NJ0025411
PERMIT NUMBER

462B
DISCHARGE NUMBER

FACILITY PSEG HOPE CREEK GENERATING ST
LOCATION LOWER ALLOWAYS CREEK, NJ 08036

DMR NUMBER: 93061511

MONITORING PERIOD

FROM	YEAR 93	MO 06	DAY 01	TO	YEAR 93	MO 06	DAY 30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

SEWAGE W.W.

MAJOR

SOUTHERN REGION

NOTE: Read instructions before completing this form.

SALEM

Form Approved.
OMB No. 2040-0004.
Approval expires 6-30-91.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-51)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVG	MAXIMUM	UNITS	MINIMUM	AVG	MAXIMUM				UNITS
COLIFORM, FECAL GENERAL 74055 1 0	SAMPLE MEASUREMENT	XXXXXX	XXXXXX	000000	000000	<1	<1	1/100	0 MONTH	ONCE/ MONTH	
	PERMIT REQUIREMENT	000000	000000		000000	200.00000	400.00000				MONTH GEO WKLY GEO
EFFLUENT GROSS VALUE BOD, 5-DAY PERCENT REMOVAL 81010 K 0	SAMPLE MEASUREMENT	000000	000000	000000	90.7	90.7	000000	PERCE NT	0 MONTH	ONCE/ MONTH	
	PERMIT REQUIREMENT	000000	000000		000000	87.50000	REPORT AVERAGE				000000
SOLIDS, SUSPENDED PERCENT REMOVAL 81011 K 0	SAMPLE MEASUREMENT	000000	000000	000000	90	90	000000	PERCE NT	0 MONTH	ONCE/ MONTH	
	PERMIT REQUIREMENT	000000	000000		000000	65.00000	REPORT AVERAGE				000000
OXYGEN DEMAND FIRST STAGE 82210 1 0	SAMPLE MEASUREMENT	3.2	3.2	KG/ DAY	000000	26.4	26.4	MG/L	0 MONTH	ONCE/ MONTH	
	PERMIT REQUIREMENT	8.20000X MNT H AVG	REPORT DLY MAX		000000	REPORT MNT H AVG	REPORT DLY MAX				
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT				000000						
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT				000000						
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT				000000						
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Robert J. Hovey General Manager Hope Creek Operations TYPED OR PRINTED		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 16 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)						V R.J. Hovey Signature of Principal Executive Officer or Authorized Agent		TELEPHONE 609 339-3463 AREA CODE NUMBER YEAR MO DAY	
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)											

PERMITTER NAME/ADDRESS (Include Facility Name/Location if different)

NAME PSEG
ADDRESS P.O. BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

NJ0025411

PERMIT NUMBER

463A

DISCHARGE NUMBER

FACILITY PSEG HOPE CREEK GENERATING ST
LOCATION LOWER ALLOWAYS CREEK, NJ 08038

DMR NUMBER: 93061511

Form Approved.
OMB No. 2040-0004.
Approval expires 6-30-91.


SOUTH STORM DRAIN

SALEM

SOUTHERN REGION

NOTE: Read Instructions before completing this form.

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	93	06	01		93	06	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

PARAMETER (32-37)	(3) Card Only) QUANTITY OR LOADING (46-53)		(4) Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)			
	AVERAGE XXXXXXX	MAXIMUM XXXXXXX	UNITS	MINIMUM XXXXXXX	AVERAGE XXXXXXX				MAXIMUM XXXXXXX	UNITS	
PH	SAMPLE MEASUREMENT	000000	000000		NODI	000000	NODI	*			
00400 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	000000	000000		000000	6.000000	9.000000	SU			
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	000000	000000		000000	MINIMUM	MAXIMUM				
00530 1 1 (ADMIN) EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	000000	000000		000000	REPORT MNTH AVG	REPORT DLY MAX	MG/L			
HYDROCARBONS, IN H2O IR, CC14 EXT. CHROMAT	SAMPLE MEASUREMENT	000000	000000		000000	NODI	NODI	*			
00551 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	000000	000000		000000	REPORT MNTH AVG	15.000000	MG/L			
CARBON, TOT ORGANIC (TOC)	SAMPLE MEASUREMENT	000000	000000		000000	NODI	NODI	*			
00680 1 1 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	000000	000000		000000	REPORT MNTH AVG	50.000000	MG/L			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	NODI	NODI		000000	000000	000000	*			
50050 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MNTH AVG	REPORT DLY MAX	MGD	000000	000000	000000	0000 000			
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)							TELEPHONE	DATE		
Robert J. Hovey General Manager Hope Creek Operations						SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	609 AREA CODE	339-3463	93 YEAR	07 MO	21 DAY
TYPED OR PRINTED											

SAMPLES TO BE TAKEN DURING A DISCHARGE EVENT, EXCEPT FOR PET HC FOR WHICH SAMPLES SHALL BE TAKEN DURING THE 1ST PRECIPITATION EVENT OF MONTH WHICH CAUSES DISCHARGE DURING WORKING HRS & IS PRECEDED BY MINIMUM DRY PERIOD OF 72 HRS. * Please refer to Transmittal Sheet Addenda.

PERMITTEE NAME/ ADDRESS (Include Facility Name/ Location if different)

NAME PSEG
ADDRESS P.O. BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

NJ0025411

PERMIT NUMBER

464A

DISCHARGE NUMBER

FACILITY PSEG HOPE CREEK GENERATING ST
LOCATION LOWER ALLOWAYS CREEK, NJ 08038

DMR NUMBER: 93061511

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
93	06	01	93	06	30
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

PERIM STORM DRAIN

MAJOR

SALEM

SOUTHERN REGION

NOTE: Read Instructions before completing this form.


PARAMETER (32-37)	(3 Card Only) (46-51)		QUANTITY OR LOADING (54-67)		(4 Card Only) (38-45)		QUALITY OR CONCENTRATION (46-51)		(34-61) (54-67)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	X	X	X	X	X	X	X	X	X	X			
PH	SAMPLE MEASUREMENT	0000000	0000000			NODI	0000000	NODI	*	-	-	-	-
00400 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	0000000	0000000	0000	6.000000	REPORT MNTH AVG	9.000000	REPORT DLY MAX	SU	ONCE/ MONTH	GRAB		
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	0000000	0000000		0000000	NODI	NODI	NODI	*	-	-	-	-
00530 1 1 (ADMIN) EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	0000000	0000000	0000	0000000	REPORT MNTH AVG	15.000000	REPORT DLY MAX	MG/L	ONCE/ MONTH	GRAB		
HYDROCARBONS, IN H2O IR, CC14 EXT. CHROMA	SAMPLE MEASUREMENT	0000000	0000000		0000000	NODI	NODI	NODI	*	-	-	-	-
00551 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	0000000	0000000	0000	0000000	REPORT MNTH AVG	50.000000	REPORT DLY MAX	MG/L	ONCE/ MONTH	GRAB-3		
CARBON, TOT ORGANIC (TOC)	SAMPLE MEASUREMENT	0000000	0000000		0000000	NODI	NODI	NODI	*	-	-	-	-
00680 1 1 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	0000000	0000000	0000	0000000	REPORT MNTH AVG	0000000	REPORT DLY MAX	MG/L	ONCE/ MONTH	GRAB		
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	NODI	NODI		0000000	0000000	0000000	0000000	*	-	-	-	-
50050 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MNTH AVG	REPORT DLY MAX	MGD	0000000	0000000	0000000	0000000	0000	ONCE/ MONTH			
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

Robert J. Hovey
General Manager
Hope Creek Operations

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 3 years.


SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE	DATE				
*	609	339-3463	93	07	21
AREA CODE	NUMBER	YEAR	MO	DAY	

SAMPLES TO BE TAKEN DURING A "DISCHARGE" EVENT, EXCEPT FOR PET HC FOR WHICH SAMPLES SHALL BE TAKEN DURING THE 1ST PRECIPITATION EVENT OF MONTH WHICH CAUSES DISCHARGE DURING WORKING HRS & IS PRECEDED BY MINIMUM DRY PERIOD OF 72 HRS. * Please refer to Transmittal Sheet Addenda.

Form Approved.
OMB No. 2040-0004.
Approval expires 6-30-91.