



Tennessee Valley Authority, 1101 Market Street, Chattanooga, Tennessee 37402

93 AUG 5 AM:0

April 16, 1993

U.S. Nuclear Regulatory Commission
ATTN: Chief, Emergency Preparedness Section
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Gentlemen:

In the Matter of) Docket Nos. 50-327
Tennessee Valley Authority) 50-328

SEQUOYAH NUCLEAR PLANT (SQN) - GOALS AND OBJECTIVES FOR THE
JUNE 1993 RADIOLOGICAL EMERGENCY PLAN (REP) EXERCISE

Enclosed are TVA's goals and objectives for the June 1993 SQN REP exercise. These are supplied in accordance with an October 11, 1984, NRC letter asking for utility submittal of REP exercise objectives 75 days before the exercise date. The SQN exercise is currently scheduled for the week of June 27, 1993.

If you have any questions, please telephone E. G. McKeown of my staff at (615) 751-4888.

Sincerely,

for Mark J. Burzynski
Manager
Nuclear Licensing and Regulatory Affairs

Enclosure: Provided to NRC addressee only
cc: See page 2

0901:

9308100100 930416
PDR ADDCK 05000327
F FDR

IE35

U.S. Nuclear Regulatory Commission
Page 2
April 16, 1993

DVW:EGM: SJF

cc: Mr. D. E. LaBarge, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy Daisy, Tennessee 37379

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

SEQUOYAH NUCLEAR PLANT (SQN) 1993 EMERGENCY PLAN EXERCISE

GOALS AND OBJECTIVES

The 1993 SQN Radiological Emergency Plan Exercise will be a full scale exercise consisting of full participation by TVA and partial participation by the State and Local Government emergency agencies.

EXERCISE GOALS

TVA's goals for the 1993 SQN exercise are as follows.

1. Allow plant and offsite personnel to demonstrate and test the capabilities of the emergency response organization to protect the health and safety of plant personnel and the general public in accordance with the Nuclear Power - Radiological Emergency Plan (NP-REP), SQN Emergency Plan Implementing Procedures (EPIPs), and the Central Emergency Control Center (CECC) EPIPs.
2. Provide an interactive exercise to ensure proficiency is maintained in onsite and offsite emergency response capabilities.
3. To provide training for emergency response personnel.
4. To identify emergency response capabilities that are in need of improvement or revision.

EXERCISE OBJECTIVES

A. Control Room/Simulator

1. Demonstrate ability of the Shift Operations Supervisor to recognize conditions, classify emergencies, make required notifications in a timely manner, and assume the initial responsibilities of the Site Emergency director.
2. Demonstrate ability of the Shift Operations Supervisor to maintain effective command and control of control room activities, prevent interference with classification analysis, dispatch and track response teams as needed prior to Technical Support Center activation, and periodically inform the control room staff of the status of the emergency situation.
3. Demonstrate ability of the control room staff to make timely determination of the cause of the incident, perform mitigating actions, keep onsite personnel informed of the emergency situation through periodic PA announcements prior to Technical Support Center activation, and a precise and clear transfer of responsibilities from the Control Room Staff to the Technical Support Center Staff.
4. Demonstrate ability of the control room staff to use proper procedures, maintain an accurate chronological account of events, and defer problems that cannot be quickly resolved to the Technical Support Center for resolution.
5. Demonstrate adequacy of the control room facilities, resources, equipment, and communication systems to support emergency operations.

6. Demonstrate ability of the control room staff to continuously evaluate information, redefine/confirm conditions and event classifications, establish an effective flow of information between the Control Room, Technical Support Center, Operations Support Center, Central Emergency Control Center, and NRC.

B. Technical Support Center (TSC)

1. Demonstrate ability to alert and mobilize TSC emergency response personnel, activate the TSC in a timely manner, perform a precise and clear transfer of responsibilities from the control room staff to the TSC staff, and assume the primary responsibilities of the Central Emergency Control Center (CECC) prior to CECC activation.
2. Demonstrate the Site Emergency Director's (SED) ability to provide effective direction, command and control, to manage activities in a manner to prevent interference with classification, analysis, or mitigation of an event, and to perform periodic briefings for TSC/OSC staff and personnel.
3. Demonstrate ability of the TSC staff to use proper procedures, solve problems related to incident identification and mitigation, and maintain an accurate account of events through detailed chronological log keeping.
4. Demonstrate the TSC's ability to determine the appropriate sampling and monitoring required to support accident mitigation, perform timely assessments of onsite radiological conditions, and formulate, coordinate, implement, and track on site protective actions.
5. Demonstrate adequacy of the TSC facilities, resources, equipment, and communication systems to support emergency operations.
6. Demonstrate the TSC's ability to maintain effective communication between the Operations Support Center (OSC), Control Room, CECC, NRC, and between various groups within the TSC.
7. Demonstrate ability of the TSC to continuously evaluate available information, redefine/confirm plant conditions and event classifications, if required assemble onsite personnel within the site area, and provide an accountability report to the SED within thirty minutes of sounding the emergency siren.
8. Demonstrate the Site Vice President's proficiency serving as a corporate interface for the SED.
9. Demonstrate Site Security's ability to maintain effective site and control room access control.
10. Demonstrate ability of the TSC to timely and effectively activate and establish communication with the environmental monitoring vans.

C. Operations Support Center (OSC)

1. Demonstrate the ability to alert and mobilize OSC personnel and activate the OSC in a timely manner.
2. Demonstrate ability of the OSC Manager, through effective command and control, to coordinate and initiate activities in a timely manner, maintain effective communications between various groups within the OSC, and use of proper procedures in the coordination and initiation of activities.
3. Demonstrate ability of the OSC staff to properly plan required tasks, promptly dispatch response teams, track the response teams, and maintain communication with the response teams.
4. Demonstrate ability of the OSC response teams to quickly and effectively enter the plant, make necessary repairs or inspections, and perform an adequate de-brief upon returning to the OSC.

5. Demonstrate ability of the OSC staff to maintain status board information accurate, maintain an accurate account of equipment, plant, and response team status through detailed chronological logs, and effective transfer of information between the OSC, TSC, RADCON laboratory, and Chemistry laboratory.
6. Demonstrate adequacy of the OSC resources, facilities, equipment, and communication systems to support emergency operations.
7. Demonstrate ability of the RADCON personnel to use proper procedures and follow good RADCON and ALARA practices to effectively support accident mitigation efforts, ensure adequate worker protection, and perform effective implant and site boundary surveys during radiological emergencies.
8. Demonstrate ability of the OSC to track changing radiological conditions through survey results and/or implant monitors, control internal and external exposures and personnel contamination of onsite emergency workers, and incorporate the information into personnel protective actions and exposure tracking.
9. Demonstrate the ability to conduct habitability surveys for the TSC, OSC, and the control room.

D. Central Emergency Control Center

1. Demonstrate ability of the Operations Duty Specialist to make initial notifications to State agencies in a timely manner.
2. Demonstrate ability to alert and mobilize CECC emergency response personnel, to activate the CECC in a timely manner, and perform precise and clear transfer of responsibilities from the TSC staff to the CECC staff.
3. Demonstrate ability of the CECC Director to maintain effective command and control within the CECC and establish and maintain effective communication between various groups within the CECC.
4. Demonstrate ability of the CECC to perform, update, coordinate offsite activities with the STATE and provide protective action recommendations in a timely manner.
5. Demonstrate ability of Environmental Monitoring Vans to support emergency operations by effectively utilizing their procedures to perform dose rate surveys, collect and analyze radiological samples, conduct other prescribed radiological activities, and adhere to appropriate contamination control procedures in field conditions.
6. Demonstrate ability to effectively transfer radiological survey information from the field, keep the field teams informed of emergency conditions, and adequately monitor and control the exposure levels of offsite personnel.
7. Demonstrate ability of the CECC staff to maintain detailed chronological log of plant status, ongoing activities, external TVA correspondence, corrective actions taken, protective action recommendations and to continuously evaluate available information and redefine/confirm the conditions and event classifications.
8. Demonstrate ability of the CECC staff to effectively call upon and obtain TVA corporate, vendor, or other outside support resources as appropriate or needed. (technical, logistics, financial, federal, industrial, ect.)
9. Demonstrate ability of the CECC staff to effectively dispatch and control Radiological/Environmental Monitoring Teams, coordinate with the State when applicable, and obtain, analyze, and utilize meteorological, onsite and offsite radiological conditions, and source term information to develop dose assessments in a timely manner.

10. Demonstrate ability of the CECC staff to establish and maintain effective communication between the various emergency centers (Control Room, TSC, RMCC, State/Local EOC) and NRC including NRC responders.
11. Demonstrate adequacy of the CECC facilities, resources, equipment, and communication systems to support emergency operations.
12. Demonstrate ability of the CECC staff to analyze current plant conditions, identify projected trends, determine the potential consequences, and maintain CECC status board information accurate.
13. Demonstrate ability to establish and maintain adequate security access control for the CECC.
14. Demonstrate proficiency of the CECC staff with emergency procedures, equipment, and methods.

E. The following drills will be conducted during the exercise:

1. Accountability Drill
2. CECC/State Communication Drill
3. TSC/CECC Communication Drill
4. Plant RADCON Drill
5. Plant Radiological Monitoring Drill (Environs Monitoring)

SEQUOYAH NUCLEAR PLANT (SQN) 1993 EMERGENCY PLAN EXERCISE

GOALS AND OBJECTIVES

The 1993 SQN Radiological Emergency Plan Exercise will be a full scale exercise consisting of full participation by TVA and partial participation by the State and Local Government emergency agencies.

EXERCISE GOALS

TVA's goals for the 1993 SQN exercise are as follows:

1. Allow plant and offsite personnel to demonstrate and test the capabilities of the emergency response organization to protect the health and safety of plant personnel and the general public in accordance with the Nuclear Power - Radiological Emergency Plan (NP-REP), SQN Emergency Plan Implementing Procedures (EPIPs), and the Central Emergency Control Center (CECC) EPIPs.
2. Provide an interactive exercise to ensure proficiency is maintained in onsite and offsite emergency response capabilities.
3. To provide training for emergency response personnel.
4. To identify emergency response capabilities that are in need of improvement or revision.

EXERCISE OBJECTIVES

A. Control Room/Simulator

1. Demonstrate ability of the Shift Operations Supervisor to recognize conditions, classify emergencies, make required notifications in a timely manner, and assume the initial responsibilities of the Site Emergency director.
2. Demonstrate ability of the Shift Operations Supervisor to maintain effective command and control of control room activities, prevent interference with classification analysis, dispatch and track response teams as needed prior to Technical Support Center activation, and periodically inform the control room staff of the status of the emergency situation.
3. Demonstrate ability of the control room staff to make timely determination of the cause of the incident, perform mitigating actions, keep onsite personnel informed of the emergency situation through periodic PA announcements prior to Technical Support Center activation, and a precise and clear transfer of responsibilities from the Control Room Staff to the Technical Support Center Staff.
4. Demonstrate ability of the control room staff to use proper procedures, maintain an accurate chronological account of events, and defer problems that cannot be quickly resolved to the Technical Support Center for resolution.
5. Demonstrate adequacy of the control room facilities, resources, equipment, and communication systems to support emergency operations.

6. Demonstrate ability of the control room staff to continuously evaluate information, redefine/confirm conditions and event classifications, establish an effective flow of information between the Control Room, Technical Support Center, Operations Support Center, Central Emergency Control Center, and NRC.

B. Technical Support Center (TSC)

1. Demonstrate ability to alert and mobilize TSC emergency response personnel, activate the TSC in a timely manner, perform a precise and clear transfer of responsibilities from the control room staff to the TSC staff, and assume the primary responsibilities of the Central Emergency Control Center (CECC) prior to CECC activation.
2. Demonstrate the Site Emergency Director's (SED) ability to provide effective direction, command and control, to manage activities in a manner to prevent interference with classification, analysis, or mitigation of an event and to perform periodic briefings for TSC/OSC staff and personnel.
3. Demonstrate ability of the TSC staff to use proper procedures, solve problems related to incident identification and mitigation, and maintain an accurate account of events through detailed chronological log keeping.
4. Demonstrate the TSC's ability to determine the appropriate sampling and monitoring required to support accident mitigation, perform timely assessments of onsite radiological conditions, and formulate, coordinate, implement, and track on site protective actions.
5. Demonstrate adequacy of the TSC facilities, resources, equipment, and communication systems to support emergency operations.
6. Demonstrate the TSC's ability to maintain effective communication between the Operations Support Center (OSC), Control Room, CECC, NRC, and between various groups within the TSC.
7. Demonstrate ability of the TSC to continuously evaluate available information, redefine/confirm plant conditions and event classifications, if required assemble onsite personnel within the site area, and provide an accountability report to the SED within thirty minutes of sounding the emergency siren.
8. Demonstrate the Site Vice President's proficiency serving as a corporate interface for the SED.
9. Demonstrate Site Security's ability to maintain effective site and control room access control.
10. Demonstrate ability of the TSC to timely and effectively activate and establish communication with the environmental monitoring vans.

C. Operations Support Center (OSC)

1. Demonstrate the ability to alert and mobilize OSC personnel and activate the OSC in a timely manner.
2. Demonstrate ability of the OSC Manager, through effective command and control, to coordinate and initiate activities in a timely manner, maintain effective communications between various groups within the OSC, and use of proper procedures in the coordination and initiation of activities.
3. Demonstrate ability of the OSC staff to properly plan required tasks, promptly dispatch response teams, track the response teams, and maintain communication with the response teams.
4. Demonstrate ability of the OSC response teams to quickly and effectively enter the plant, make necessary repairs or inspections, and perform an adequate de-brief upon returning to the OSC.

5. Demonstrate ability of the OSC staff to maintain status board information accurate, maintain an accurate account of equipment, plant, and response team status through detailed chronological logs, and effective transfer of information between the OSC, TSC, RADCON laboratory, and Chemistry laboratory.
6. Demonstrate adequacy of the OSC resources, facilities, equipment, and communication systems to support emergency operations.
7. Demonstrate ability of the RADCON personnel to use proper procedures and follow good RADCON and ALARA practices to effectively support accident mitigation efforts, ensure adequate worker protection, and perform effective inplant and site boundary surveys during radiological emergencies.
8. Demonstrate ability of the OSC to track changing radiological conditions through survey results and/or inplant monitors, control internal and external exposures and personnel contamination of onsite emergency workers, and incorporate the information into personnel protective actions and exposure tracking.
9. Demonstrate the ability to conduct habitability surveys for the TSC, OSC, and the control room.

D. Central Emergency Control Center

1. Demonstrate ability of the Operations Duty Specialist to make initial notifications to State agencies in a timely manner.
2. Demonstrate ability to alert and mobilize CECC emergency response personnel, to activate the CECC in a timely manner, and perform precise and clear transfer of responsibilities from the TSC staff to the CECC staff.
3. Demonstrate ability of the CECC Director to maintain effective command and control within the CECC and establish and maintain effective communication between various groups within the CECC.
4. Demonstrate ability of the CECC to perform, update, coordinate offsite activities with the STATE and provide protective action recommendations in a timely manner.
5. Demonstrate ability of Environmental Monitoring Vans to support emergency operations by effectively utilizing their procedures to perform dose rate surveys, collect and analyze radiological samples, conduct other prescribed radiological activities, and adhere to appropriate contamination control procedures in field conditions.
6. Demonstrate ability to effectively transfer radiological survey information from the field, keep the field teams informed of emergency conditions, and adequately monitor and control the exposure levels of offsite personnel.
7. Demonstrate ability of the CECC staff to maintain detailed chronological logs of plant status, ongoing activities, external TVA correspondence, corrective actions taken, protective action recommendations and to continuously evaluate available information and redefine/confirm the conditions and event classifications.
8. Demonstrate ability of the CECC staff to effectively call upon and obtain TVA corporate, vendor, or other outside support resources as appropriate or needed. (technical, logistics, financial, federal, industrial, ect.)
9. Demonstrate ability of the CECC staff to effectively dispatch and control Radiological/Environmental Monitoring Teams, coordinate with the State when applicable, and obtain, analyze, and utilize meteorological, onsite and offsite radiological conditions, and source term information to develop dose assessments in a timely manner.

10. Demonstrate ability of the CECC staff to establish and maintain effective communication between the various emergency centers (Contr. Room, TSC, RMCC, State/Local EOC) and NRC including NRC responders.
11. Demonstrate adequacy of the CECC facilities, resources, equipment, and communication systems to support emergency operations.
12. Demonstrate ability of the CECC staff to analyze current plant conditions, identify projected trends, determine the potential consequences, and maintain CECC status board information accurate.
13. Demonstrate ability to establish and maintain adequate security access control for the CECC.
14. Demonstrate proficiency of the CECC staff with emergency procedures, equipment, and methods.

E. The following drills will be conducted during the exercise:

1. Accountability Drill
2. CECC/State Communication Drill
3. TSC/CECC Communication Drill
4. Plant RACON Drill
5. Plant Radiological Monitoring Drill (Environs Monitoring)

PLAYER MESSAGE

TO: All Players

FROM: Controllers

LOCATION:

CLOCK TIME:

DATE: Initial Conditions

ELAPSED TIME:

-MESSAGE-

THIS IS A DRILL

DO NOT INITIATE ACTIONS EFFECTING NORMAL PLANT OPERATIONS

The 1993 SQN Radiological Emergency Plan (REP) Graded Exercise will begin soon.

Please prefix all messages and notifications which you make or are responsible for making with the words - "THIS IS A DRILL. NO REAL EMERGENCY EXISTS." If at any time during this exercise a real emergency occurs, the Site Emergency Director may terminate the exercise if he feels continuation of the exercise may adversely effect the plant response to the real emergency.

No actions will actually be taken which may alter the operations of the site (nor will personnel enter High Radiation or Contamination areas). Valves, pumps, switches, and other equipment will be physically located but verbal descriptions will be given instead of actual operations which may impact site operations. Actions which will not effect operations (such as wearing protective clothing and using supplies) will usually be performed.

Mock-ups of equipment for repair may be used in this exercise. For purposes of this exercise the SQN Simulator will be used as the Control Room. The SPDS data being displayed during the exercise is derived from the Simulator's calculations. Because the Simulator does not adequately model the plant's radiological monitors for all situations do not use the SPDS radiation monitor data for any exercise purposes, instead use the printed radiation monitor data which will be provided in the Simulator and the Actual Control Room.

PLAYER MESSAGE

TO: All Players

FROM: Controllers

LOCATION:

CLOCK TIME:

DATE: Initial Conditions

ELAPSED TIME:

-MESSAGE-

THIS IS A DRILL

DO NOT INITIATE ACTIONS EFFECTING NORMAL PLANT OPERATIONS

INITIAL CONDITIONS

Unit 1

- * Shutdown for 7 days in mode 5 preparing for Steam Generator(SG) sludgelancing. Sludgelancing is being done due to the introduction of a chemical contaminant (NaOH) into the SGs. All SGs have been drained and the hand holes have been removed. Sludgelancing equipment is being installed.
- * FE 3-90, FE 3-48, FE 3-35, FE 3-103 are removed for steam cleaning.
- * The cavitating venturi for the 1A-A and 1B-B motor driven auxiliary feedwater pumps have been removed for inspection.
- * RHR 1B-B pump has just been shutdown after being used for cooldown.

Unit 2

- * Currently on day 141 of a continuous run at 100% power.

Common

- * Floor Drain Collector Tank(FDCT) is full and the Auxiliary Building Waste Evaporator Feed Pumps are tagged out due to locked rotors.
- * The Auxiliary Building Floor and Equipment Drain Sump has been aligned to the Tritiated Drain Tank(TDT). The TDT is half full.
- * TVA's Board member and some VIPs are on site having a tour and demonstration of SG sludgelancing.

Operations, Maintenance, Chemistry, Radiological Conditions as attached.

OPERATIONS SHIFT TURNOVER
06-00-93
DAYSHIFT
TRAIN WEEK A
UNIT 1

Mode 5 Power Level/Megawatts 0 Percent/0 MWe

Surveillance Instruction (SI)-137.0

1. SIGNIFICANT PARAMETER TRENDING

- a. I-IV vital inverter abnormal alarm (fan failure) - WR C174217 available. The fan is running (monitoring).
- b. Maintain all surveillances ready for return to power.

2. SIGNIFICANT ACTIVITIES COMPLETED

None

3. MAJOR WORK ACTIVITIES

- a. Main feedwater (MFW) flow elements removed for cleaning.
- b. 1A and 1B AFW pumps cavitating venturies removed for cleaning.
- c. Sludge lancing in progress on all four steam generators (due to introduction of chemical contaminants).

4. SIGNIFICANT SIS OR PROCEDURES

None

5. SIGNIFICANT EQUIPMENT PROBLEMS

- a. 1A and 1C condenser circulating water (CCW) traveling screen has operating permit. FDCN to install stainless steel screens (N.E.).
- b. 1B Amertap System will not come out of backwash mode--WR C130198/C130199 (07-01-93).

6. LIT ANNUNCIATORS

- a. 125-V DC vital battery board, five (5) supply (I or II).

OPERATIONS SHIFT TURNOVER
UNIT 2

Mode 1 Power Level/Megawatts 100 Percent/1168 MWe

SI-137.0 - .00 identified .00 unidentified approximately 0330
hours/06/00/93

1. SIGNIFICANT PARAMETER TRENDING

- a. 2A containment spray heater exchange needs layup.
- b. VCT hydrogen maintains 20 psig--WR C129947 on pressure regulator.

2. SIGNIFICANT ACTIVITIES COMPLETED

- a. 2A-A CCP casing and discharge vent

3. MAJOR WORK ACTIVITIES

None

4. SIGNIFICANT SIS OR PROCEDURES

- a. O-PI-OPS-000-12.2 status files

5. SIGNIFICANT EQUIPMENT PROBLEMS

- a. C074943 2B-B RHR pump room cooler leak. Next 'B' train week.
Scheduled 07-15-93
- b. C130026 2B Amertap OOS (losing balls when in service) need
schedule date. (WCG)
- c. Steam dump valve 1-103 isolated due to packing leak. Need RTV
to stop condenser inleakage.
- d. 2A-A lower compartment cooler tube leak. Less than 1 gpm.
WR C074587. Scheduled 07-10-93.

6. LIT ANNUNCIATORS

- a. 125-V DC vital battery B5 supply (I or II).
- b. No. 7 HD tank pump A motor winding temperature HI. WR C128489.

OPERATIONS SHIFT TURNOVER
COMMON

1. SIGNIFICANT PARAMETER TRENDING

- a. Maintain HPFP running until RSWT header pressure issue is resolved. Reduce setpoint four (4) psi and add time-delay to alarm. Need schedule date.
- b. Vital battery II spared out for annual discharge test. Scheduled 07-01-93.

2. SIGNIFICANT ACTIVITIES COMPLETED

- a. Main control room (MCR) AHU A-A operable (technical specification has been calibrated and PMT completed).

3. MAJOR WORK ACTIVITIES

- a. WR C054262/C125961 'A' Electrical board room chiller. Work in progress.

4. SIGNIFICANT SIS OR PROCEDURES

- a. O-PI-OPS-000-012.2

5. SIGNIFICANT EQUIPMENT PROBLEMS

- a. N-B ERCW pump tagged for refurbishment.
- b. 'A' EBR chiller AHU high vibration. Bearing replacement by 06-28-93.
- c. 'G' WGDT tagged to prevent using tank. WR C130209 to be worked next week.

6. MAKEUP DEMINERALIZER STATUS

Train 1 I/S		
Train 2 in Regen	::	DWST 63 percent

7. CONDI STATUS

Unit 1 - One polisher in service	:: Four in standby
Unit 2 - Two polishers in service	:: Three in standby
Charge 14 in receiving tank, ready for regen.	

OPERATIONS SHIFT TURNOVER
COMMON

2 RADWASTE STATUS

a. RAD DI OOS

9. PAINTING PERMITS

a. AB: None

b. CB: None

10. LIT ANNUNCIATORS

a. Fire pump 1A-A running

HJB:EAM
PL195104/951

***** LCO LOG ***

June , 1993 ~ 0600

LCO	Time/Date of Entry	Time/Date of Expiration	Description
Common LCOs			
3.3.3.8	1040 3/14	Jumper installed in the Pyrotronics panel 612 per TACF D-92-12-13 to disable zone 16 (Cask Loading Area) to support U2C5 outage work.
3.7.12	Fire barrier penetrations. **Roving firewatch**

Unit 1 LCOs

3.3.3.8 1720 5/5 Zone 364 on Panel 631 (No. 3 RCP) has a trouble alarm in. WR C076437.

Unit 2 LCOs

NONE

ODCM Compliance/Info Only

0-FT-27-175 ----- Inop use D-LS-27-225. CHECK RED LIGHT 1/4 hrs.
Need new flow element and modifier. WR C075017, SCHEDULED 6/28

1-RM-90-400B ----- Mid-range inoperable and removed from service/WR C130237--Low range meeting ODCM requirements

**** LCD LOG ***

June , 1993 a 0610

Common Information Only

3.1.2.2 Heat trace circuit 56 (Boric Acid Filter Housing) temperature less than 145 °F. WR C079212. SCHEDULED 6/25/92.

3.8.2.3 125-V vital battery IV, cell 18 strapped out - passed SI-100. C075275 to replace.

Unit 1 Info Only

3.1.2.3 When HO No. 1-92-17 is picked up, 1-SI-SXP-062-001.A or B must be run immediately on the PD pump check valve.
3.1.2.4 | Enter the applicable LCD actions when untagged.
3.5.2 |
3.5.3 |

Unit 2 Info Only

3.1.2.3 When HO No. 2-92-9 is picked up, 2-SI-SXP-062-001.A or B must be run immediately on the PD pump checkvalve. Enter the applicable LCD actions when untagged.
3.1.2.4 |
3.5.2 |
3.5.3 |
3.3.1 1000 5/23 2 and 3 S/G level TTD. Only one T-Cold operable (EAM rack only). WR C050893. SCHEDULED U2C5 RFD.
3.3.2 |

ODCM Compliance Info

NONE

HJB:EAM

PL195104/479

THIS IS A DRILL THIS IS A DRILL THIS IS A DRILL

DESCRIPTION: U-1 Reactor Coolant liquid

Scenario Elapsed Time: 0:00

Time Collected: 08:30

Sample Analyzed

Volume Collected: 0 Liters

	ISOTOPE	CONC	MPC	MPC	FRACTION
1	Kr-85M	< 1.00E-10	6.00E-06	<LLD	
2	Kr-85	< 1.00E-10	1.00E-05	<LLD	
3	Kr-87	< 1.00E-10	1.00E-06	<LLD	
4	Kr-88	< 1.00E-10	1.00E-06	<LLD	
5	Xe-133	< 1.00E-10	1.00E-05	<LLD	
6	Xe-135	< 1.00E-10	4.00E-06	<LLD	
7	I-131	2.75E-03	3.00E-07	9.17E+03	
8	I-132	< 1.00E-10	8.00E-06	<LLD	
9	I-133	5.89E-03	1.00E-06	5.89E+03	
10	I-134	< 1.00E-10	2.00E-05	<LLD	
11	I-135	< 1.00E-10	4.00E-06	<LLD	
12	Fe-59	< 1.00E-10	5.00E-06	<LLD	
13	Co-56	< 1.00E-10	3.00E-06	<LLD	
14	Co-58	2.75E-04	9.00E-05	3.06E+00	
15	Co-60	1.35E-04	3.00E-05	4.50E+00	
16	Rb-86	< 1.00E-10	2.00E-05	<LLD	
17	Rb-88	< 1.00E-10	3.00E-06	<LLD	
18	Sr-89	< 1.00E-10	3.00E-05	<LLD	
19	Sr-90	< 1.00E-10	4.00E-05	<LLD	
20	Sr-91	< 1.00E-10	5.00E-05	<LLD	
21	Y-90	< 1.00E-10	2.00E-05	<LLD	
22	Y-91	< 1.00E-10	3.00E-05	<LLD	
23	Zr-95	< 1.00E-10	6.00E-05	<LLD	
24	Zr-97	< 1.00E-10	2.00E-05	<LLD	
	Nb-95	< 1.00E-10	1.00E-04	<LLD	
	Mo-99	< 1.00E-10	4.00E-05	<LLD	
27	Tc-99M	< 1.00E-10	5.00E-07	<LLD	
28	Ru-103	< 1.00E-10	8.00E-05	<LLD	
29	Ru-105	< 1.00E-10	1.00E-04	<LLD	
30	Ru-106	< 1.00E-10	1.00E-05	<LLD	
31	Rh-105	< 1.00E-10	1.00E-04	<LLD	
32	Sb-127	< 1.00E-10	3.00E-06	<LLD	
33	Sb-129	< 1.00E-10	3.00E-06	<LLD	
34	Te127M	< 1.00E-10	5.00E-05	<LLD	
35	Te-127	< 1.00E-10	2.00E-04	<LLD	
36	Te129M	< 1.00E-10	2.00E-05	<LLD	
37	Te-129	< 1.00E-10	8.00E-04	<LLD	
38	Te131M	< 1.00E-10	4.00E-05	<LLD	
39	Te-132	< 1.00E-10	2.00E-05	<LLD	
40	Cs-134	9.93E-04	9.00E-06	1.10E+02	
41	Cs-135	< 1.00E-10	1.00E-04	<LLD	
42	Cs-136	1.28E-04	6.00E-05	2.13E+00	
43	Cs-137	1.14E-03	2.00E-05	5.70E+01	
44	Ba-140	1.91E-03	2.00E-05	9.55E+01	
45	La-140	2.27E-03	2.00E-05	1.14E+02	
46	Ce-141	< 1.00E-10	9.00E-05	<LLD	
47	Ce-143	< 1.00E-10	4.00E-05	<LLD	
48	Ce-144	< 1.00E-10	1.00E-05	<LLD	
49	Pr-143	< 1.00E-10	5.00E-05	<LLD	
50	Np-239	< 1.00E-10	3.00E-05	<LLD	

Formation of MPC Fractions = 1.54E+04

Reactor Coolant Liquid Sample

THIS IS A DRILL

THIS IS A DRILL

THIS IS A DRILL

DESCRIPTION: U-1 Reactor Coolant dissolved gas

Scenario Elapsed Time: 0:00 Sample Analyzed

Time Collected: 08:30 Volume Collected: 0 Liters

CONC MPC MPC

#	ISOTOPE	uCi/cc	10CFR20	FRACTION
1	Kr-85M	< 1.00E-10	6.00E-06	<LLD
2	Kr-85	< 1.00E-10	1.00E-05	<LLD
3	Kr-87	< 1.00E-10	1.00E-06	<LLD
4	Kr-88	< 1.00E-10	1.00E-06	<LLD
5	Xe-133	5.90E-03	1.00E-05	5.90E+02
6	Xe-135	< 1.00E-10	4.00E-06	<LLD
7	I-131	< 1.00E-10	3.00E-07	<LLD
8	I-132	< 1.00E-10	8.00E-06	<LLD
9	I-133	< 1.00E-10	1.00E-06	<LLD
10	I-134	< 1.00E-10	2.00E-05	<LLD
11	I-135	< 1.00E-10	4.00E-06	<LLD
12	Fe-59	< 1.00E-10	5.00E-06	<LLD
13	Co-56	< 1.00E-10	3.00E-06	<LLD
14	Co-58	< 1.00E-10	9.00E-05	<LLD
15	Co-60	< 1.00E-10	3.00E-05	<LLD
16	Rb-86	< 1.00E-10	2.00E-05	<LLD
17	Rb-88	< 1.00E-10	3.00E-06	<LLD
18	Sr-89	< 1.00E-10	3.00E-05	<LLD
19	Sr-90	< 1.00E-10	4.00E-05	<LLD
20	Sr-91	< 1.00E-10	5.00E-05	<LLD
21	Y-90	< 1.00E-10	2.00E-05	<LLD
22	Y-91	< 1.00E-10	3.00E-05	<LLD
23	Zr-95	< 1.00E-10	6.00E-05	<LLD
24	Zr-97	< 1.00E-10	2.00E-05	<LLD
25	Nb-95	< 1.00E-10	1.00E-04	<LLD
26	Mo-99	< 1.00E-10	4.00E-05	<LLD
27	Tc-99M	< 1.00E-10	5.00E-07	<LLD
28	Ru-103	< 1.00E-10	8.00E-05	<LLD
29	Ru-105	< 1.00E-10	1.00E-04	<LLD
30	Ru-106	< 1.00E-10	1.00E-05	<LLD
31	Rh-105	< 1.00E-10	1.00E-04	<LLD
32	Sb-127	< 1.00E-10	3.00E-06	<LLD
33	Sb-129	< 1.00E-10	3.00E-06	<LLD
34	Te127M	< 1.00E-10	5.00E-05	<LLD
35	Te-127	< 1.00E-10	2.00E-04	<LLD
36	Te129M	< 1.00E-10	2.00E-05	<LLD
37	Te-129	< 1.00E-10	8.00E-04	<LLD
38	Te131M	< 1.00E-10	4.00E-05	<LLD
39	Te-132	< 1.00E-10	2.00E-05	<LLD
40	Cs-134	< 1.00E-10	9.00E-06	<LLD
41	Cs-135	< 1.00E-10	1.00E-04	<LLD
42	Cs-136	< 1.00E-10	6.00E-05	<LLD
43	Cs-137	< 1.00E-10	2.00E-05	<LLD
44	Ba-140	< 1.00E-10	2.00E-05	<LLD
45	La-140	< 1.00E-10	2.00E-05	<LLD
46	Ce-141	< 1.00E-10	9.00E-05	<LLD
47	Ce-143	< 1.00E-10	4.00E-05	<LLD
48	Ce-144	< 1.00E-10	1.00E-05	<LLD
49	Pr-143	< 1.00E-10	5.00E-05	<LLD
50	Np-239	< 1.00E-10	3.00E-05	<LLD

Summation of MPC Fractions = 5.90E+02
Reactor Coolant Gases Sample

SEQUOYAH NUCLEAR PLANT				RADIATION MONITOR DRILL DATA				ELAPSED SCENARIO TIME: 00:00			
RM90-1	0.10	RM90-124	1.0E+1	Common Radiation Monitors				RM90-1	0.10	RM90-124	1.0E+1
RM90-6	0.10	RM90-130	1.0E+1					RM90-6	1.0E-1	RM90-130	1.0E+1
RM90-7	0.10	RM90-131	1.0E+1	<--- Unit 1 --->				RM90-7	0.10	RM90-131	1.0E+1
RM90-8	0.10	RM90-255	0.10	v				RM90-8	0.10	RM90-255	0.10
RM90-10	0.10	RM90-256	1.0E+3					RM90-10	0.10	RM90-256	1.0E+3
RM90-14	1.0E+7	RM90-260	0.10	RM90-11				RM90-14	1.0E+1	RM90-260	0.10
RM90-60	0.10	RM90-261	1.0E+3	RM90-12				RM90-60	0.10	RM90-261	1.0E+3
RM90-61	0.10	RM90-271	1.0E+0	RM90-15				RM90-61	0.10	RM90-271	1.0E+0
RM90-62	1.0E+1	RM90-272	1.0E+0	RM90-16				RM90-62	1.0E+1	RM90-272	1.0E+0
RM90-99	1.0E+1	RM90-273	1.0E+0	RM90-17				RM90-99	1.0E+1	RM90-273	1.0E+0
RM90-170	1.0E-2	RM90-274	1.0E+0	RM90-101A				RM90-170	1.0E-2	RM90-274	1.0E+0
RM90-106A	1.0E+1	RM90-280	0.10	RM90-101B				RM90-106A	1.0E+1	RM90-280	0.10
RM90-106B	1.0E+1	RM90-290	1.0E-1	RM90-101C				RM90-106B	1.0E+1	RM90-290	1.0E-1
RM90-106C	1.0E+1	RM90-291	1.0E+3	RM90-102				RM90-106C	1.0E+1	RM90-291	1.0E+3
RM90-112A	1.0E+1	RM90-292	3.0E-1	RM90-103				RM90-112A	1.0E+1	RM90-292	1.0E-1
RM90-112B	1.0E+1	RM90-293	1.0E+3	RM90-105				RM90-112B	1.0E+1	RM90-293	1.0E+3
RM90-112C	1.0E+1	RM90-400	9.9E-3	RM90-118				RM90-112C	1.0E+1	RM90-400	9.9E-3
RM90-119	1.0E+1	RM90-421	2.8E-4	RM90-122				RM90-119	1.0E+1	RM90-421	3.1E-4
RM90-120	1.0E+1	RM90-422	2.8E-4	RM90-125				RM90-120	1.0E+1	RM90-422	3.1E-4
RM90-121	1.0E+1	RM90-423	2.8E-4	RM90-125				RM90-121	1.0E+1	RM90-423	3.1E-4
RM90-123	1.0E+1	RM90-424	2.8E-4	<--- Unit 1 --->				RM90-123	1.0E+1	RM90-424	3.1E-4
				v							
				Unit 2 --->							

PLAYER MESSAGE

TO: Security Personnel
FROM: Security Controller
LOCATION: SQN site
DATE: June 30, 1993

CLOCK TIME: 19:00
ELAPSED TIME: 00:00

-MESSAGE-

THIS IS A DRILL

DO NOT INITIATE ACTIONS EFFECTING NORMAL PLANT OPERATIONS

You have just received a radio communication from Jim Hill, a helicopter pilot requesting permission to land and pickup some VIPs. You have been expecting this helicopter to arrive and pickup the visiting VIPs. The VIPs are TVA Board member Mr. Kennoy and the prospective TVA board members Mr. Crowell and Mr. Hayes.

PLAYER MESSAGE

TO: Control Room SOS

FROM: Control Room Controller

LOCATION: Simulator Control Room

CLOCK TIME: 19:07

DATE: June 30, 1993

ELAPSED TIME: 00:07

-MESSAGE-

THIS IS A DRILL

DO NOT INITIATE ACTIONS EFFECTING NORMAL PLANT OPERATIONS

You have just received a telephone call from Nuclear Security. He said that the helicopter arriving to pick up the VIPs while approaching the site apparently had engine problems. The pilot attempted to land on the road to the ERCW building but the helicopter's engine failed and the helicopter fell about 25 feet crashing on the road in the site area. No one was injured. The pilot got out and walked away. The helicopter sustained damage to its landing supports and undercarriage. A security officer is with the pilot near the accident scene. Because the VIPs had to get to the airport to go to Washington D.C. another Nuclear Security officer is driving them to Lovell field.

06/28/93

THIS IS A DRILL

PAGE 4

PLAYER MESSAGE

TO: SOS

FROM: Control Room Controller

LOCATION: Simulator Control Room

CLOCK TIME: 19:20

DATE: June 30, 1993

ELAPSED TIME: 00:20

-CONTINGENCY MESSAGE-

THIS IS A DRILL

DO NOT INITIATE ACTIONS EFFECTING NORMAL PLANT OPERATIONS

* Note to Controller: Notify the Lead Control Room Controller and the Exercise Coordinator prior to issuing this message.

If the SOS has not declared an ALERT or is not in the process of doing so then prompt him to make a declaration of an ALERT based on HA3, aircraft crash within the site area.

06/25/93

THIS IS A DRILL

PAGE 5

PLAYER MESSAGE

TO: UO or ASOS

FROM: Control Room Controller

LOCATION: Simulator Control Room

CLOCK TIME: 19:23

DATE: June 30, 1993

ELAPSED TIME: 00:23

-MESSAGE-

THIS IS A DRILL

DO NOT INITIATE ACTIONS EFFECTING NORMAL PLANT OPERATIONS

You have just received a call from some one at the U-1 690 control point who said that an airline ruptured inside containment causing dust to become airborne in lower containment. Radcon is evacuating everyone from containment until they can get an airsample.

06/25/93

THIS IS A DRILL

PAGE 6

PLAYER MESSAGE

TO: UO or ASOS

FROM: Control Room Controller

LOCATION: Simulator Control Room

CLOCK TIME: 19:52

DATE: June 30, 1993

ELAPSED TIME: 00:52

-MESSAGE-

THIS IS A DRILL

DO NOT INITIATE ACTIONS EFFECTING NORMAL PLANT OPERATIONS

You have just received a call from an AUO who said that while performing routine surveillance on elevation 653 he had entered RHR 1A-A pump room about two minutes ago and a small leak suddenly began spraying water from the left rear corner probably from the shutdown cooling suction line. He exited immediately and did not think he had gotten wet. He said he was going to go frisk and then see Radcon.

06/25/93

THIS IS A DRILL

PAGE 7

PLAYER MESSAGE

TO: AUO

FROM: Control Room Controller

LOCATION: Flood Alarm Panel, Aux. Bldg.

CLOCK TIME: >19:55

DATE: June 30, 1993

ELAPSED TIME: >00:55

-MESSAGE-

THIS IS A DRILL

DO NOT INITIATE ACTIONS EFFECTING NORMAL PLANT OPERATIONS

LS-40-29 is Alarming!

06/25/93

THIS IS A DRILL

PAGE 8

PLAYER MESSAGE

TO: Person responding to 1A-A RHR pump room flood alarm

FROM: Controller

LOCATION: 1A-A RHR pump room in the Aux. Bldg.

CLOCK TIME: >19:55

DATE: June 30, 1993

ELAPSED TIME: >00:55

-MESSAGE-

THIS IS A DRILL

DO NOT INITIATE ACTIONS EFFECTING NORMAL PLANT OPERATIONS

Water in the coffer dam area is approximately _____ inches deep.
(Determine value from the appropriate flood calculation package at the exact time that they check)

If the leak is still occurring, then let them know that they can hear a sound like water spraying and falling into standing water.

The air in the pump room is warm and humid.

06/25/93

THIS IS A DRILL

PAGE 9

PLAYER MESSAGE

TO: 1 A-A RHR leak repair team

FROM: Controller

LOCATION: 1A-A RHR pump room in the Aux. Bldg.

CLOCK TIME: >19:55

DATE: June 30, 1993

ELAPSED TIME: >00:55

-MESSAGE-

THIS IS A DRILL

DO NOT INITIATE ACTIONS EFFECTING NORMAL PLANT OPERATIONS

Water in the coffer dam area is approximately ____ inches deep.
(Determine value from the appropriate flood calculation package at the exact time that they check)

If the leak is still occurring, then let them know that they can hear a sound like water spraying and falling into standing water.

The air in the pump room is warm and humid.

06/25/93

THIS IS A DRILL

PAGE 10

PLAYER MESSAGE

TO: 1 A-A RHR leak repair team

FROM: Controller

LOCATION: 1A-A RHR pump room in the Aux. Bldg.

CLOCK TIME: 21:05

DATE: June 30, 1993

ELAPSED TIME: 02:05

-MESSAGE-

THIS IS A DRILL

DO NOT INITIATE ACTIONS EFFECTING NORMAL PLANT OPERATIONS

Water in the coffer dam area is approximately ____ inches deep.
(Determine value from the appropriate flood calculation package at the exact time that they check)

If the leak is still occurring, the let them know that they can hear an increase in the sound of water spraying and falling into standing water.

The air in the pump room is warm and humid.

06/25/93

THIS IS A DRILL

PAGE 11

PLAYER MESSAGE

TO: UO

FROM: Control Room Controller

LOCATION: Simulator Control Room

CLOCK TIME: _____

DATE: June 30, 1993

ELAPSED TIME: _____

-MESSAGE-

THIS IS A DRILL

DO NOT INITIATE ACTIONS EFFECTING NORMAL PLANT OPERATIONS

Note to Controller: Determine the appropriate flood calculation package to use (i.e. A-1 through A-15). Then based on the time to issue the message as indicated below, first write the appropriate times in the clock and elapsed time slots above and then issue the message at the appropriate time.

You have just received a telephone call from an AUO who said that the Tritiated Drain Tank high level alarm LA-77-31 has just come in on the local panel.

Flood Calculation Package	Issue message at Elapsed Time
A-1, A-2, A-3, A-4, A-5, A-6	Do not issue
A-7, A-8, A-9, A-10, A-11, A-12, A-13, A-14, A-15	03:50

06/25/93

THIS IS A DRILL

PAGE 12

PLAYER MESSAGE

TO: Simulator Operator

FROM: Control Room Controller

LOCATION: Simulator Control Room

CLOCK TIME: _____

DATE: June 30, 1993

ELAPSED TIME: _____

-MESSAGE-

THIS IS A DRILL

DO NOT INITIATE ACTIONS EFFECTING NORMAL PLANT OPERATIONS

Note to Controller: Determine the appropriate flood calculation package to use (i.e. A-1 through A-15). Then based on the time to issue the message as indicated below, first write the appropriate times in the clock and elapsed time slots above and then issue the message at the appropriate time.

The following Aux. Bldg. Floor and Equipment Drain Sump pump has just started:

Flood Calculation Package	Pump 1 at Elapsed Time
A-1	Do not issue
A-2,A-3	01:40
A-4,A-5,A-6	
A-7,A-8,A-9,	
A-10,A-11,A-12,	
A-13,A-14,A-15	

PLAYER MESSAGE

TO: Simulator Operator

FROM: Control Room Controller

LOCATION: Simulator Control Room

CLOCK TIME: _____

DATE: June 30, 1993

ELAPSED TIME: _____

-MESSAGE-

THIS IS A DRILL

DO NOT INITIATE ACTIONS EFFECTING NORMAL PLANT OPERATIONS

Note to Controller: Determine the appropriate flood calculation package to use (i.e. A-1 through A-15). Then based on the time to issue the message as indicated below, first write the appropriate times in the clock and elapsed time slots above and then issue the message at the appropriate time.

The following Aux. Bldg. Floor and Equipment Drain Sump pump has just stopped:

Flood Calculation Package	Pump 1 at Elapsed Time
A-1	Do not issue
A-2	02:30
A-3	03:05
A-4	03:35
A-5	04:10
A-6	03:45
A-7	04:05
A-8	04:20
A-9, A-10, A-11, A-12, A-13, A-14, A-15	Do not issue

PLAYER MESSAGE

TO: Simulator Operator

FROM: Control Room Controller

LOCATION: Simulator Control Room

CLOCK TIME: _____

DATE: June 30, 1993

ELAPSED TIME: _____

-MESSAGE-

THIS IS A DRILL

DO NOT INITIATE ACTIONS EFFECTING NORMAL PLANT OPERATIONS

Note to Controller: Determine the appropriate flood calculation package to use (i.e. A-1 through A-15). Then based on the time to issue the message as indicated below, first write the appropriate times in the clock and elapsed time slots above and then issue the message at the appropriate time.

The following Aux. Bldg. Floor and Equipment Drain Sump pump has just started:

Flood Calculation Package	Pump 2 at Elapsed Time
A-1, A-2, A-3 A-4, A-5	Do not issue
A-6, A-7, A-8, A-9, A-10, A-11, A-12, A-13, A-14, A-15	02:55

*****:*****:*****:*****:*****:*****:*****:*****:*****:*****:*****:*****

*****:*****:*****:*****:*****:*****:*****:*****:*****:*****:*****:*****

PLAYER MESSAGE

TO: Simulator Operator

FROM: Control Room Controller

LOCATION: Simulator Control Room

CLOCK TIME: _____

DATE: June 30, 1993

ELAPSED TIME: _____

-MESSAGE-

THIS IS A DRILL

DO NOT INITIATE ACTIONS EFFECTING NORMAL PLANT OPERATIONS

Note to Controller: Determine the appropriate flood calculation package to use (i.e. A-1 through A-15). Then based on the time to issue the message as indicated below, first write the appropriate times in the clock and elapsed time slots above and then issue the message at the appropriate time.

The following Aux. Bldg. Floor and Equipment Drain Sump pump has just stopped:

Flood Calculation Package	Pump 2 at Elapsed Time
A-1, A-2, A-3 A-4, A-5	Do not issue
A-6	03:45
A-7	04:05
A-8	04:20
A-9, A-10, A-11, A-12, A-13, A-14, A-15	Do not issue

06/25/93

THIS IS A DRILL


PAGE 16

SQN 1993 Graded Exercise
Flooding Calculation Package
Decision Tree

RHR1A-A = RHR1A-A SHUT DOWN COOLING SUPPLY

T = TIME LEAK STOPPED IF SO

T = SCENARIO TIME IF LEAK NOT STOPPED



A-1

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=01:05

RHR1A-A Elev. 653

Elapsed Time	Pipe Leakage	Main Rm H2O lvl	Door H2O lvl	Flood Al LS-40-29 O=N;1=Y	Main H2O lvl	Flood Al LS-40-25 O=N;1=Y	TDT H2O lvl	Rm
HR:MIN	gpm	inches	inches		inches			inches
00:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:50	68.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:55	68.02	2.22	0.00	1.00	0.00	0.00	0.00	0.00
01:00	68.02	4.43	0.00	1.00	0.00	0.00	0.00	0.00
01:05	68.02	6.64	0.00	1.00	0.00	0.00	0.00	0.00
01:10	0.00	6.00	0.00	1.00	0.00	0.00	0.00	0.00
01:15	0.00	5.99	0.00	1.00	0.00	0.00	0.00	0.00
01:20	0.00	5.99	0.00	1.00	0.00	0.00	0.00	0.00
01:25	0.00	5.98	0.00	1.00	0.00	0.00	0.00	0.00
01:30	0.00	5.97	0.00	1.00	0.00	0.00	0.00	0.00
01:35	0.00	5.97	0.00	1.00	0.00	0.00	0.00	0.00
01:40	0.00	5.96	0.00	1.00	0.00	0.00	0.00	0.00
01:45	0.00	5.95	0.00	1.00	0.00	0.00	0.00	0.00
01:50	0.00	5.94	0.00	1.00	0.00	0.00	0.00	0.00
01:55	0.00	5.94	0.00	1.00	0.00	0.00	0.00	0.00
02:00	0.00	5.93	0.00	1.00	0.00	0.00	0.00	0.00
02:05	0.00	5.92	0.00	1.00	0.00	0.00	0.00	0.00
02:10	0.00	5.92	0.00	1.00	0.00	0.00	0.00	0.00
02:15	0.00	5.91	0.00	1.00	0.00	0.00	0.00	0.00
02:20	0.00	5.90	0.00	1.00	0.00	0.00	0.00	0.00
02:25	0.00	5.90	0.00	1.00	0.00	0.00	0.00	0.00
02:30	0.00	5.89	0.00	1.00	0.00	0.00	0.00	0.00
02:35	0.00	5.88	0.00	1.00	0.00	0.00	0.00	0.00
02:40	0.00	5.88	0.00	1.00	0.00	0.00	0.00	0.00
02:45	0.00	5.87	0.00	1.00	0.00	0.00	0.00	0.00
02:50	0.00	5.86	0.00	1.00	0.00	0.00	0.00	0.00
02:55	0.00	5.85	0.00	1.00	0.00	0.00	0.00	0.00
03:00	0.00	5.85	0.00	1.00	0.00	0.00	0.00	0.00
03:05	0.00	5.84	0.00	1.00	0.00	0.00	0.00	0.00
03:10	0.00	5.83	0.00	1.00	0.00	0.00	0.00	0.00
03:15	0.00	5.83	0.00	1.00	0.00	0.00	0.00	0.00
03:20	0.00	5.82	0.00	1.00	0.00	0.00	0.00	0.00
03:25	0.00	5.81	0.00	1.00	0.00	0.00	0.00	0.00
03:30	0.00	5.81	0.00	1.00	0.00	0.00	0.00	0.00
03:35	0.00	5.80	0.00	1.00	0.00	0.00	0.00	0.00
03:40	0.00	5.79	0.00	1.00	0.00	0.00	0.00	0.00
03:45	0.00	5.79	0.00	1.00	0.00	0.00	0.00	0.00
03:50	0.00	5.78	0.00	1.00	0.00	0.00	0.00	0.00
03:55	0.00	5.77	0.00	1.00	0.00	0.00	0.00	0.00
04:00	0.00	5.77	0.00	1.00	0.00	0.00	0.00	0.00
04:05	0.00	5.76	0.00	1.00	0.00	0.00	0.00	0.00
04:10	0.00	5.75	0.00	1.00	0.00	0.00	0.00	0.00
04:15	0.00	5.74	0.00	1.00	0.00	0.00	0.00	0.00
04:20	0.00	5.74	0.00	1.00	0.00	0.00	0.00	0.00
04:25	0.00	5.73	0.00	1.00	0.00	0.00	0.00	0.00
04:30	0.00	5.72	0.00	1.00	0.00	0.00	0.00	0.00
04:35	0.00	5.72	0.00	1.00	0.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=01:05

Elapsed Time HR:MIN	AuxBldg sm.sump feet	sm.sump 1st pmp gpm	sm.sump 2nd pmp gpm	sm.sump Hi lvl 0=N;1=Y	TDT H2O volume	TDT Hi lvl 0=N;1=Y	AuxBldg pas.sump feet
00:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:30	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:45	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:50	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:55	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:05	641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:10	641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:15	641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:20	641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:25	641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:30	641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:35	641.20	0.00	0.00	0.00	51.00	0.00	0.00
01:40	641.20	0.00	0.00	0.00	51.00	0.00	0.00
01:45	641.20	0.00	0.00	0.00	51.00	0.00	0.00
01:50	641.20	0.00	0.00	0.00	51.00	0.00	0.00
01:55	641.20	0.00	0.00	0.00	51.00	0.00	0.00
02:00	641.20	0.00	0.00	0.00	51.00	0.00	0.00
02:05	641.20	0.00	0.00	0.00	51.00	0.00	0.00
02:10	641.21	0.00	0.00	0.00	51.00	0.00	0.00
02:15	641.21	0.00	0.00	0.00	51.00	0.00	0.00
02:20	641.21	0.00	0.00	0.00	51.00	0.00	0.00
02:25	641.21	0.00	0.00	0.00	51.00	0.00	0.00
02:30	641.21	0.00	0.00	0.00	51.00	0.00	0.00
02:35	641.21	0.00	0.00	0.00	51.00	0.00	0.00
02:40	641.21	0.00	0.00	0.00	51.00	0.00	0.00
02:45	641.22	0.00	0.00	0.00	51.00	0.00	0.00
02:50	641.22	0.00	0.00	0.00	51.00	0.00	0.00
02:55	641.22	0.00	0.00	0.00	51.00	0.00	0.00
03:00	641.22	0.00	0.00	0.00	51.00	0.00	0.00
03:05	641.22	0.00	0.00	0.00	51.00	0.00	0.00
03:10	641.22	0.00	0.00	0.00	51.00	0.00	0.00
03:15	641.22	0.00	0.00	0.00	51.00	0.00	0.00
03:20	641.23	0.00	0.00	0.00	51.00	0.00	0.00
03:25	641.23	0.00	0.00	0.00	51.00	0.00	0.00
03:30	641.23	0.00	0.00	0.00	51.00	0.00	0.00
03:35	641.23	0.00	0.00	0.00	51.00	0.00	0.00
03:40	641.23	0.00	0.00	0.00	51.00	0.00	0.00
03:45	641.23	0.00	0.00	0.00	51.00	0.00	0.00
03:50	641.23	0.00	0.00	0.00	51.00	0.00	0.00
03:55	641.24	0.00	0.00	0.00	51.00	0.00	0.00
04:00	641.24	0.00	0.00	0.00	51.00	0.00	0.00
04:05	641.24	0.00	0.00	0.00	51.00	0.00	0.00
04:10	641.24	0.00	0.00	0.00	51.00	0.00	0.00
04:15	641.24	0.00	0.00	0.00	51.00	0.00	0.00
04:20	641.24	0.00	0.00	0.00	51.00	0.00	0.00
04:25	641.24	0.00	0.00	0.00	51.00	0.00	0.00
04:30	641.24	0.00	0.00	0.00	51.00	0.00	0.00
04:35	641.25	0.00	0.00	0.00	51.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=01:05

RHR1A-A

Elev. 653

Elapsed Time H:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
04:40	0.00	5.71	0.00	1.00	0.00	0.00	0.00
04:45	0.00	5.70	0.00	1.00	0.00	0.00	0.00
04:50	0.00	5.70	0.00	1.00	0.00	0.00	0.00
04:55	0.00	5.69	0.00	1.00	0.00	0.00	0.00
05:00	0.00	5.68	0.00	1.00	0.00	0.00	0.00
05:05	0.00	5.68	0.00	1.00	0.00	0.00	0.00
05:10	0.00	5.67	0.00	1.00	0.00	0.00	0.00
05:15	0.00	5.66	0.00	1.00	0.00	0.00	0.00
05:20	0.00	5.66	0.00	1.00	0.00	0.00	0.00
05:25	0.00	5.65	0.00	1.00	0.00	0.00	0.00
05:30	0.00	5.64	0.00	1.00	0.00	0.00	0.00
05:35	0.00	5.64	0.00	1.00	0.00	0.00	0.00
05:40	0.00	5.63	0.00	1.00	0.00	0.00	0.00
05:45	0.00	5.62	0.00	1.00	0.00	0.00	0.00
05:50	0.00	5.62	0.00	1.00	0.00	0.00	0.00
05:55	0.00	5.61	0.00	1.00	0.00	0.00	0.00
06:00	0.00	5.60	0.00	1.00	0.00	0.00	0.00
06:05	0.00	5.60	0.00	1.00	0.00	0.00	0.00
06:10	0.00	5.59	0.00	1.00	0.00	0.00	0.00
06:15	0.00	5.58	0.00	1.00	0.00	0.00	0.00
06:20	0.00	5.58	0.00	1.00	0.00	0.00	0.00
06:25	0.00	5.57	0.00	1.00	0.00	0.00	0.00
06:30	0.00	5.56	0.00	1.00	0.00	0.00	0.00
06:35	0.00	5.56	0.00	1.00	0.00	0.00	0.00
06:40	0.00	5.55	0.00	1.00	0.00	0.00	0.00
06:45	0.00	5.54	0.00	1.00	0.00	0.00	0.00
06:50	0.00	5.53	0.00	1.00	0.00	0.00	0.00
06:55	0.00	5.53	0.00	1.00	0.00	0.00	0.00
07:00	0.00	5.52	0.00	1.00	0.00	0.00	0.00
07:05	0.00	5.51	0.00	1.00	0.00	0.00	0.00
07:10	0.00	5.51	0.00	1.00	0.00	0.00	0.00
07:15	0.00	5.50	0.00	1.00	0.00	0.00	0.00
07:20	0.00	5.49	0.00	1.00	0.00	0.00	0.00
07:25	0.00	5.49	0.00	1.00	0.00	0.00	0.00
07:30	0.00	5.48	0.00	1.00	0.00	0.00	0.00
07:35	0.00	5.47	0.00	1.00	0.00	0.00	0.00
07:40	0.00	5.47	0.00	1.00	0.00	0.00	0.00
07:45	0.00	5.46	0.00	1.00	0.00	0.00	0.00
07:50	0.00	5.45	0.00	1.00	0.00	0.00	0.00
07:55	0.00	5.45	0.00	1.00	0.00	0.00	0.00
08:00	0.00	5.44	0.00	1.00	0.00	0.00	0.00
08:05	0.00	5.43	0.00	1.00	0.00	0.00	0.00
08:10	0.00	5.43	0.00	1.00	0.00	0.00	0.00
08:15	0.00	5.42	0.00	1.00	0.00	0.00	0.00
08:20	0.00	5.42	0.00	1.00	0.00	0.00	0.00
08:25	0.00	5.41	0.00	1.00	0.00	0.00	0.00
08:30	0.00	5.40	0.00	1.00	0.00	0.00	0.00
08:35	0.00	5.40	0.00	1.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=01:05

Elapsed Time	AuxBldg sm.sump feet	sm.sump 1st pmp gpm	sm.sump 2nd pmp gpm	sm.sump Hi lvl 0=N;1=Y	TDT H2O volume	TDT Hi lvl 0=N;1=Y	AuxBldg pas.sump feet
04:40	641.25	0.00	0.00	0.00	51.00	0.00	0.00
04:45	641.25	0.00	0.00	0.00	51.00	0.00	0.00
04:50	641.25	0.00	0.00	0.00	51.00	0.00	0.00
04:55	641.25	0.00	0.00	0.00	51.00	0.00	0.00
05:00	641.25	0.00	0.00	0.00	51.00	0.00	0.00
05:05	641.25	0.00	0.00	0.00	51.00	0.00	0.00
05:10	641.26	0.00	0.00	0.00	51.00	0.00	0.00
05:15	641.26	0.00	0.00	0.00	51.00	0.00	0.00
05:20	641.26	0.00	0.00	0.00	51.00	0.00	0.00
05:25	641.26	0.00	0.00	0.00	51.00	0.00	0.00
05:30	641.26	0.00	0.00	0.00	51.00	0.00	0.00
05:35	641.26	0.00	0.00	0.00	51.00	0.00	0.00
05:40	641.26	0.00	0.00	0.00	51.00	0.00	0.00
05:45	641.27	0.00	0.00	0.00	51.00	0.00	0.00
05:50	641.27	0.00	0.00	0.00	51.00	0.00	0.00
05:55	641.27	0.00	0.00	0.00	51.00	0.00	0.00
06:00	641.27	0.00	0.00	0.00	51.00	0.00	0.00
06:05	641.27	0.00	0.00	0.00	51.00	0.00	0.00
06:10	641.27	0.00	0.00	0.00	51.00	0.00	0.00
06:15	641.27	0.00	0.00	0.00	51.00	0.00	0.00
06:20	641.28	0.00	0.00	0.00	51.00	0.00	0.00
06:25	641.28	0.00	0.00	0.00	51.00	0.00	0.00
06:30	641.28	0.00	0.00	0.00	51.00	0.00	0.00
06:35	641.28	0.00	0.00	0.00	51.00	0.00	0.00
06:40	641.28	0.00	0.00	0.00	51.00	0.00	0.00
06:45	641.28	0.00	0.00	0.00	51.00	0.00	0.00
06:50	641.28	0.00	0.00	0.00	51.00	0.00	0.00
06:55	641.29	0.00	0.00	0.00	51.00	0.00	0.00
07:00	641.29	0.00	0.00	0.00	51.00	0.00	0.00
07:05	641.29	0.00	0.00	0.00	51.00	0.00	0.00
07:10	641.29	0.00	0.00	0.00	51.00	0.00	0.00
07:15	641.29	0.00	0.00	0.00	51.00	0.00	0.00
07:20	641.29	0.00	0.00	0.00	51.00	0.00	0.00
07:25	641.29	0.00	0.00	0.00	51.00	0.00	0.00
07:30	641.29	0.00	0.00	0.00	51.00	0.00	0.00
07:35	641.30	0.00	0.00	0.00	51.00	0.00	0.00
07:40	641.30	0.00	0.00	0.00	51.00	0.00	0.00
07:45	641.30	0.00	0.00	0.00	51.00	0.00	0.00
07:50	641.30	0.00	0.00	0.00	51.00	0.00	0.00
07:55	641.30	0.00	0.00	0.00	51.00	0.00	0.00
08:00	641.30	0.00	0.00	0.00	51.00	0.00	0.00
08:05	641.30	0.00	0.00	0.00	51.00	0.00	0.00
08:10	641.31	0.00	0.00	0.00	51.00	0.00	0.00
08:15	641.31	0.00	0.00	0.00	51.00	0.00	0.00
08:20	641.31	0.00	0.00	0.00	51.00	0.00	0.00
08:25	641.31	0.00	0.00	0.00	51.00	0.00	0.00
08:30	641.31	0.00	0.00	0.00	51.00	0.00	0.00
08:35	641.31	0.00	0.00	0.00	51.00	0.00	0.00

A-2

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=01:35

RHR1A-A

Elev. 653

Elapsed Time R:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
00:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:50	68.02	0.00	0.00	0.00	0.00	0.00	0.00
00:55	68.02	2.22	0.00	1.00	0.00	0.00	0.00
01:00	68.02	4.43	0.00	1.00	0.00	0.00	0.00
01:05	68.02	6.64	0.00	1.00	0.00	0.00	0.00
01:10	68.02	6.74	0.00	1.00	0.00	0.00	0.00
01:15	68.02	6.82	0.00	1.00	0.00	0.00	0.00
01:20	68.02	6.89	0.00	1.00	0.00	0.00	0.00
01:25	68.02	6.95	0.00	1.00	0.00	0.00	0.00
01:30	68.02	7.00	0.00	1.00	0.00	0.00	0.00
01:35	68.02	7.04	0.00	1.00	0.00	0.00	0.00
01:40	0.00	6.00	0.00	1.00	0.00	0.00	0.00
01:45	0.00	5.99	0.00	1.00	0.00	0.00	0.00
01:50	0.00	5.99	0.00	1.00	0.00	0.00	0.00
01:55	0.00	5.98	0.00	1.00	0.00	0.00	0.00
02:00	0.00	5.97	0.00	1.00	0.00	0.00	0.00
02:05	0.00	5.97	0.00	1.00	0.00	0.00	0.00
02:10	0.00	5.96	0.00	1.00	0.00	0.00	0.00
02:15	0.00	5.95	0.00	1.00	0.00	0.00	0.00
02:20	0.00	5.94	0.00	1.00	0.00	0.00	0.00
02:25	0.00	5.94	0.00	1.00	0.00	0.00	0.00
02:30	0.00	5.93	0.00	1.00	0.00	0.00	0.00
02:35	0.00	5.92	0.00	1.00	0.00	0.00	0.00
02:40	0.00	5.92	0.00	1.00	0.00	0.00	0.00
02:45	0.00	5.91	0.00	1.00	0.00	0.00	0.00
02:50	0.00	5.90	0.00	1.00	0.00	0.00	0.00
02:55	0.00	5.90	0.00	1.00	0.00	0.00	0.00
03:00	0.00	5.89	0.00	1.00	0.00	0.00	0.00
03:05	0.00	5.88	0.00	1.00	0.00	0.00	0.00
03:10	0.00	5.88	0.00	1.00	0.00	0.00	0.00
03:15	0.00	5.87	0.00	1.00	0.00	0.00	0.00
03:20	0.00	5.86	0.00	1.00	0.00	0.00	0.00
03:25	0.00	5.85	0.00	1.00	0.00	0.00	0.00
03:30	0.00	5.85	0.00	1.00	0.00	0.00	0.00
03:35	0.00	5.84	0.00	1.00	0.00	0.00	0.00
03:40	0.00	5.83	0.00	1.00	0.00	0.00	0.00
03:45	0.00	5.83	0.00	1.00	0.00	0.00	0.00
03:50	0.00	5.82	0.00	1.00	0.00	0.00	0.00
03:55	0.00	5.81	0.00	1.00	0.00	0.00	0.00
04:00	0.00	5.81	0.00	1.00	0.00	0.00	0.00
04:05	0.00	5.80	0.00	1.00	0.00	0.00	0.00
04:10	0.00	5.79	0.00	1.00	0.00	0.00	0.00
04:15	0.00	5.79	0.00	1.00	0.00	0.00	0.00
04:20	0.00	5.78	0.00	1.00	0.00	0.00	0.00
04:25	0.00	5.77	0.00	1.00	0.00	0.00	0.00
04:30	0.00	5.77	0.00	1.00	0.00	0.00	0.00
04:35	0.00	5.76	0.00	1.00	0.00	0.00	0.00

SONGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=01:35

Elapsed Time HR:MIN	AuxBldg sm.sump feet	sm.sump 1st pmp gpm	sm.sump 2nd pmp gpm	sm.sump Hi lvl 0=N;1=Y	TDT H2O volume	TDT Hi lvl 0=N;1=Y	AuxBldg pas.sump feet
00:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:30	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:45	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:50	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:55	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:05	641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:10	641.63	0.00	0.00	0.00	51.00	0.00	0.00
01:15	642.07	0.00	0.00	0.00	51.00	0.00	0.00
01:20	642.51	0.00	0.00	0.00	51.00	0.00	0.00
01:25	642.95	0.00	0.00	0.00	51.00	0.00	0.00
01:30	643.40	0.00	0.00	0.00	51.00	0.00	0.00
01:35	643.85	0.00	0.00	0.00	51.00	0.00	0.00
01:40	643.51	50.00	0.00	0.00	52.00	0.00	0.00
01:45	643.18	50.00	0.00	0.00	53.00	0.00	0.00
01:50	642.85	50.00	0.00	0.00	54.00	0.00	0.00
01:55	642.52	50.00	0.00	0.00	55.00	0.00	0.00
02:00	642.18	50.00	0.00	0.00	56.00	0.00	0.00
02:05	641.85	50.00	0.00	0.00	57.00	0.00	0.00
02:10	641.52	50.00	0.00	0.00	58.00	0.00	0.00
02:15	641.18	50.00	0.00	0.00	59.00	0.00	0.00
02:20	640.85	50.00	0.00	0.00	60.00	0.00	0.00
02:25	640.52	50.00	0.00	0.00	61.00	0.00	0.00
02:30	640.52	0.00	0.00	0.00	61.00	0.00	0.00
02:35	640.52	0.00	0.00	0.00	61.00	0.00	0.00
02:40	640.52	0.00	0.00	0.00	61.00	0.00	0.00
02:45	640.52	0.00	0.00	0.00	61.00	0.00	0.00
02:50	640.53	0.00	0.00	0.00	61.00	0.00	0.00
02:55	640.53	0.00	0.00	0.00	61.00	0.00	0.00
03:00	640.53	0.00	0.00	0.00	61.00	0.00	0.00
03:05	640.53	0.00	0.00	0.00	61.00	0.00	0.00
03:10	640.53	0.00	0.00	0.00	61.00	0.00	0.00
03:15	640.53	0.00	0.00	0.00	61.00	0.00	0.00
03:20	640.53	0.00	0.00	0.00	61.00	0.00	0.00
03:25	640.54	0.00	0.00	0.00	61.00	0.00	0.00
03:30	640.54	0.00	0.00	0.00	61.00	0.00	0.00
03:35	640.54	0.00	0.00	0.00	61.00	0.00	0.00
03:40	640.54	0.00	0.00	0.00	61.00	0.00	0.00
03:45	640.54	0.00	0.00	0.00	61.00	0.00	0.00
03:50	640.54	0.00	0.00	0.00	61.00	0.00	0.00
03:55	640.54	0.00	0.00	0.00	61.00	0.00	0.00
04:00	640.55	0.00	0.00	0.00	61.00	0.00	0.00
04:05	640.55	0.00	0.00	0.00	61.00	0.00	0.00
04:10	640.55	0.00	0.00	0.00	61.00	0.00	0.00
04:15	640.55	0.00	0.00	0.00	61.00	0.00	0.00
04:20	640.55	0.00	0.00	0.00	61.00	0.00	0.00
04:25	640.55	0.00	0.00	0.00	61.00	0.00	0.00
04:30	640.55	0.00	0.00	0.00	61.00	0.00	0.00
04:35	640.56	0.00	0.00	0.00	61.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=01:35

RHR1A-A

Elev. 653

Elapsed Time H:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT H2O lvl inches
04:40	0.00	5.75	0.00	1.00	0.00	0.00	0.00
04:45	0.00	5.74	0.00	1.00	0.00	0.00	0.00
04:50	0.00	5.74	0.00	1.00	0.00	0.00	0.00
04:55	0.00	5.73	0.00	1.00	0.00	0.00	0.00
05:00	0.00	5.72	0.00	1.00	0.00	0.00	0.00
05:05	0.00	5.72	0.00	1.00	0.00	0.00	0.00
05:10	0.00	5.71	0.00	1.00	0.00	0.00	0.00
05:15	0.00	5.70	0.00	1.00	0.00	0.00	0.00
05:20	0.00	5.70	0.00	1.00	0.00	0.00	0.00
05:25	0.00	5.69	0.00	1.00	0.00	0.00	0.00
05:30	0.00	5.68	0.00	1.00	0.00	0.00	0.00
05:35	0.00	5.68	0.00	1.00	0.00	0.00	0.00
05:40	0.00	5.67	0.00	1.00	0.00	0.00	0.00
05:45	0.00	5.66	0.00	1.00	0.00	0.00	0.00
05:50	0.00	5.66	0.00	1.00	0.00	0.00	0.00
05:55	0.00	5.65	0.00	1.00	0.00	0.00	0.00
06:00	0.00	5.64	0.00	1.00	0.00	0.00	0.00
06:05	0.00	5.64	0.00	1.00	0.00	0.00	0.00
06:10	0.00	5.63	0.00	1.00	0.00	0.00	0.00
06:15	0.00	5.62	0.00	1.00	0.00	0.00	0.00
06:20	0.00	5.62	0.00	1.00	0.00	0.00	0.00
06:25	0.00	5.61	0.00	1.00	0.00	0.00	0.00
06:30	0.00	5.60	0.00	1.00	0.00	0.00	0.00
06:35	0.00	5.60	0.00	1.00	0.00	0.00	0.00
06:40	0.00	5.59	0.00	1.00	0.00	0.00	0.00
06:45	0.00	5.58	0.00	1.00	0.00	0.00	0.00
06:50	0.00	5.58	0.00	1.00	0.00	0.00	0.00
06:55	0.00	5.57	0.00	1.00	0.00	0.00	0.00
07:00	0.00	5.56	0.00	1.00	0.00	0.00	0.00
07:05	0.00	5.56	0.00	1.00	0.00	0.00	0.00
07:10	0.00	5.55	0.00	1.00	0.00	0.00	0.00
07:15	0.00	5.54	0.00	1.00	0.00	0.00	0.00
07:20	0.00	5.53	0.00	1.00	0.00	0.00	0.00
07:25	0.00	5.53	0.00	1.00	0.00	0.00	0.00
07:30	0.00	5.52	0.00	1.00	0.00	0.00	0.00
07:35	0.00	5.51	0.00	1.00	0.00	0.00	0.00
07:40	0.00	5.51	0.00	1.00	0.00	0.00	0.00
07:45	0.00	5.50	0.00	1.00	0.00	0.00	0.00
07:50	0.00	5.49	0.00	1.00	0.00	0.00	0.00
07:55	0.00	5.49	0.00	1.00	0.00	0.00	0.00
08:00	0.00	5.48	0.00	1.00	0.00	0.00	0.00
08:05	0.00	5.47	0.00	1.00	0.00	0.00	0.00
08:10	0.00	5.47	0.00	1.00	0.00	0.00	0.00
08:15	0.00	5.46	0.00	1.00	0.00	0.00	0.00
08:20	0.00	5.45	0.00	1.00	0.00	0.00	0.00
08:25	0.00	5.45	0.00	1.00	0.00	0.00	0.00
08:30	0.00	5.44	0.00	1.00	0.00	0.00	0.00
08:35	0.00	5.43	0.00	1.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=01:35

Elapsed Time	AuxBldg	sm.sump	sm.sump	sm.sump	TDT H2O	TDT	AuxBldg
R:MIN	feet	1st pmp	2nd pmp	Hi lvl 0=N;1=Y	volume %	Hi lvl 0=N;1=Y	pas.sump feet
	gpm	gpm					
04:40	640.56	0.00	0.00	0.00	61.00	0.00	0.00
04:45	640.56	0.00	0.00	0.00	61.00	0.00	0.00
04:50	640.56	0.00	0.00	0.00	61.00	0.00	0.00
04:55	640.56	0.00	0.00	0.00	61.00	0.00	0.00
05:00	640.56	0.00	0.00	0.00	61.00	0.00	0.00
05:05	640.56	0.00	0.00	0.00	61.00	0.00	0.00
05:10	640.57	0.00	0.00	0.00	61.00	0.00	0.00
05:15	640.57	0.00	0.00	0.00	61.00	0.00	0.00
05:20	640.57	0.00	0.00	0.00	61.00	0.00	0.00
05:25	640.57	0.00	0.00	0.00	61.00	0.00	0.00
05:30	640.57	0.00	0.00	0.00	61.00	0.00	0.00
05:35	640.57	0.00	0.00	0.00	61.00	0.00	0.00
05:40	640.57	0.00	0.00	0.00	61.00	0.00	0.00
05:45	640.58	0.00	0.00	0.00	61.00	0.00	0.00
05:50	640.58	0.00	0.00	0.00	61.00	0.00	0.00
05:55	640.58	0.00	0.00	0.00	61.00	0.00	0.00
06:00	640.58	0.00	0.00	0.00	61.00	0.00	0.00
06:05	640.58	0.00	0.00	0.00	61.00	0.00	0.00
06:10	640.58	0.00	0.00	0.00	61.00	0.00	0.00
06:15	640.58	0.00	0.00	0.00	61.00	0.00	0.00
06:20	640.59	0.00	0.00	0.00	61.00	0.00	0.00
06:25	640.59	0.00	0.00	0.00	61.00	0.00	0.00
06:30	640.59	0.00	0.00	0.00	61.00	0.00	0.00
06:35	640.59	0.00	0.00	0.00	61.00	0.00	0.00
06:40	640.59	0.00	0.00	0.00	61.00	0.00	0.00
06:45	640.59	0.00	0.00	0.00	61.00	0.00	0.00
06:50	640.59	0.00	0.00	0.00	61.00	0.00	0.00
06:55	640.59	0.00	0.00	0.00	61.00	0.00	0.00
07:00	640.60	0.00	0.00	0.00	61.00	0.00	0.00
07:05	640.60	0.00	0.00	0.00	61.00	0.00	0.00
07:10	640.60	0.00	0.00	0.00	61.00	0.00	0.00
07:15	640.60	0.00	0.00	0.00	61.00	0.00	0.00
07:20	640.60	0.00	0.00	0.00	61.00	0.00	0.00
07:25	640.60	0.00	0.00	0.00	61.00	0.00	0.00
07:30	640.60	0.00	0.00	0.00	61.00	0.00	0.00
07:35	640.61	0.00	0.00	0.00	61.00	0.00	0.00
07:40	640.61	0.00	0.00	0.00	61.00	0.00	0.00
07:45	640.61	0.00	0.00	0.00	61.00	0.00	0.00
07:50	640.61	0.00	0.00	0.00	61.00	0.00	0.00
07:55	640.61	0.00	0.00	0.00	61.00	0.00	0.00
08:00	640.61	0.00	0.00	0.00	61.00	0.00	0.00
08:05	640.61	0.00	0.00	0.00	61.00	0.00	0.00
08:10	640.62	0.00	0.00	0.00	61.00	0.00	0.00
08:15	640.62	0.00	0.00	0.00	61.00	0.00	0.00
08:20	640.62	0.00	0.00	0.00	61.00	0.00	0.00
08:25	640.62	0.00	0.00	0.00	61.00	0.00	0.00
08:30	640.62	0.00	0.00	0.00	61.00	0.00	0.00
08:35	640.62	0.00	0.00	0.00	61.00	0.00	0.00

A-3

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=02:05

RHR1A-A

Elev. 653

Elapsed Time H:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
00:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:50	68.02	0.00	0.00	0.00	0.00	0.00	0.00
00:55	68.02	2.22	0.00	1.00	0.00	0.00	0.00
01:00	68.02	4.43	0.00	1.00	0.00	0.00	0.00
01:05	68.02	6.64	0.00	1.00	0.00	0.00	0.00
01:10	68.02	6.74	0.00	1.00	0.00	0.00	0.00
01:15	68.02	6.82	0.00	1.00	0.00	0.00	0.00
01:20	68.02	6.89	0.00	1.00	0.00	0.00	0.00
01:25	68.02	6.95	0.00	1.00	0.00	0.00	0.00
01:30	68.02	7.00	0.00	1.00	0.00	0.00	0.00
01:35	68.02	7.04	0.00	1.00	0.00	0.00	0.00
01:40	68.02	7.07	0.00	1.00	0.00	0.00	0.00
01:45	68.02	7.10	0.00	1.00	0.00	0.00	0.00
01:50	68.02	7.13	0.00	1.00	0.00	0.00	0.00
01:55	68.02	7.15	0.00	1.00	0.00	0.00	0.00
02:00	68.02	7.16	0.00	1.00	0.00	0.00	0.00
02:05	68.02	7.18	0.00	1.00	0.00	0.00	0.00
02:10	0.00	6.00	0.00	1.00	0.00	0.00	0.00
02:15	0.00	5.99	0.00	1.00	0.00	0.00	0.00
02:20	0.00	5.99	0.00	1.00	0.00	0.00	0.00
02:25	0.00	5.98	0.00	1.00	0.00	0.00	0.00
02:30	0.00	5.97	0.00	1.00	0.00	0.00	0.00
02:35	0.00	5.97	0.00	1.00	0.00	0.00	0.00
02:40	0.00	5.96	0.00	1.00	0.00	0.00	0.00
02:45	0.00	5.95	0.00	1.00	0.00	0.00	0.00
02:50	0.00	5.94	0.00	1.00	0.00	0.00	0.00
02:55	0.00	5.94	0.00	1.00	0.00	0.00	0.00
03:00	0.00	5.93	0.00	1.00	0.00	0.00	0.00
03:05	0.00	5.92	0.00	1.00	0.00	0.00	0.00
03:10	0.00	5.92	0.00	1.00	0.00	0.00	0.00
03:15	0.00	5.91	0.00	1.00	0.00	0.00	0.00
03:20	0.00	5.90	0.00	1.00	0.00	0.00	0.00
03:25	0.00	5.90	0.00	1.00	0.00	0.00	0.00
03:30	0.00	5.89	0.00	1.00	0.00	0.00	0.00
03:35	0.00	5.88	0.00	1.00	0.00	0.00	0.00
03:40	0.00	5.88	0.00	1.00	0.00	0.00	0.00
03:45	0.00	5.87	0.00	1.00	0.00	0.00	0.00
03:50	0.00	5.86	0.00	1.00	0.00	0.00	0.00
03:55	0.00	5.85	0.00	1.00	0.00	0.00	0.00
04:00	0.00	5.85	0.00	1.00	0.00	0.00	0.00
04:05	0.00	5.84	0.00	1.00	0.00	0.00	0.00
04:10	0.00	5.83	0.00	1.00	0.00	0.00	0.00
04:15	0.00	5.83	0.00	1.00	0.00	0.00	0.00
04:20	0.00	5.82	0.00	1.00	0.00	0.00	0.00
04:25	0.00	5.81	0.00	1.00	0.00	0.00	0.00
04:30	0.00	5.81	0.00	1.00	0.00	0.00	0.00
04:35	0.00	5.80	0.00	1.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=02:05

Elapsed Time HR:MIN	AuxBldg sm.sump feet	sm.sump 1st pmp gpm	sm.sump 2nd pmp gpm	sm.sump Hi lvl 0=N;1=Y	TDT H2O volume	TDT Hi lvl 0=N;1=Y	AuxBldg pas.sump feet
00:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:30	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:45	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:50	640.75	0.00	0.	0.00	51.00	0.00	0.00
00:55	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:05	641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:10	641.63	0.00	0.00	0.00	51.00	0.00	0.00
01:15	642.07	0.00	0.00	0.00	51.00	0.00	0.00
01:20	642.51	0.00	0.00	0.00	51.00	0.00	0.00
01:25	642.95	0.00	0.00	0.00	51.00	0.00	0.00
01:30	643.40	0.00	0.00	0.00	51.00	0.00	0.00
01:35	643.85	0.00	0.00	0.00	51.00	0.00	0.00
01:40	643.96	50.00	0.00	0.00	52.00	0.00	0.00
01:45	644.08	50.00	0.00	0.00	53.00	0.00	0.00
01:50	644.19	50.00	0.00	0.00	54.00	0.00	0.00
01:55	644.31	50.00	0.00	0.00	55.00	0.00	0.00
02:00	644.43	50.00	0.00	0.00	56.00	0.00	0.00
02:05	644.55	50.00	0.00	0.00	57.00	0.00	0.00
02:10	644.21	50.00	0.00	0.00	58.00	0.00	0.00
02:15	643.88	50.00	0.00	0.00	59.00	0.00	0.00
02:20	643.55	50.00	0.00	0.00	60.00	0.00	0.00
02:25	643.21	50.00	0.00	0.00	61.00	0.00	0.00
02:30	642.88	50.00	0.00	0.00	62.00	0.00	0.00
02:35	642.55	50.00	0.00	0.00	64.00	0.00	0.00
02:40	642.22	50.00	0.00	0.00	65.00	0.00	0.00
02:45	641.88	50.00	0.00	0.00	66.00	0.00	0.00
02:50	641.55	50.00	0.00	0.00	67.00	0.00	0.00
02:55	641.22	50.00	0.00	0.00	68.00	0.00	0.00
03:00	640.88	50.00	0.00	0.00	69.00	0.00	0.00
03:05	640.55	50.00	0.00	0.00	70.00	0.00	0.00
03:10	640.55	0.00	0.00	0.00	70.00	0.00	0.00
03:15	640.55	0.00	0.00	0.00	70.00	0.00	0.00
03:20	640.56	0.00	0.00	0.00	70.00	0.00	0.00
03:25	640.56	0.00	0.00	0.00	70.00	0.00	0.00
03:30	640.56	0.00	0.00	0.00	70.00	0.00	0.00
03:35	640.56	0.00	0.00	0.00	70.00	0.00	0.00
03:40	640.56	0.00	0.00	0.00	70.00	0.00	0.00
03:45	640.56	0.00	0.00	0.00	70.00	0.00	0.00
03:50	640.56	0.00	0.00	0.00	70.00	0.00	0.00
03:55	640.57	0.00	0.00	0.00	70.00	0.00	0.00
04:00	640.57	0.00	0.00	0.00	70.00	0.00	0.00
04:05	640.57	0.00	0.00	0.00	70.00	0.00	0.00
04:10	640.57	0.00	0.00	0.00	70.00	0.00	0.00
04:15	640.57	0.00	0.00	0.00	70.00	0.00	0.00
04:20	640.57	0.00	0.00	0.00	70.00	0.00	0.00
04:25	640.57	0.00	0.00	0.00	70.00	0.00	0.00
04:30	640.58	0.00	0.00	0.00	70.00	0.00	0.00
04:35	640.58	0.00	0.00	0.00	70.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=02:05

RHR1A-A

Elev. 653

Elapsed Time R:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
04:40	0.00	5.79	0.00	1.00	0.00	0.00	0.00
04:45	0.00	5.79	0.00	1.00	0.00	0.00	0.00
04:50	0.00	5.78	0.00	1.00	0.00	0.00	0.00
04:55	0.00	5.77	0.00	1.00	0.00	0.00	0.00
05:00	0.00	5.77	0.00	1.00	0.00	0.00	0.00
05:05	0.00	5.76	0.00	1.00	0.00	0.00	0.00
05:10	0.00	5.75	0.00	1.00	0.00	0.00	0.00
05:15	0.00	5.74	0.00	1.00	0.00	0.00	0.00
05:20	0.00	5.74	0.00	1.00	0.00	0.00	0.00
05:25	0.00	5.73	0.00	1.00	0.00	0.00	0.00
05:30	0.00	5.72	0.00	1.00	0.00	0.00	0.00
05:35	0.00	5.72	0.00	1.00	0.00	0.00	0.00
05:40	0.00	5.71	0.00	1.00	0.00	0.00	0.00
05:45	0.00	5.70	0.00	1.00	0.00	0.00	0.00
05:50	0.00	5.7^	0.00	1.00	0.00	0.00	0.00
05:55	0.00	5.69	0.00	1.00	0.00	0.00	0.00
06:00	0.00	5.68	0.00	1.00	0.00	0.00	0.00
06:05	0.00	5.68	0.00	1.00	0.00	0.00	0.00
06:10	0.00	5.67	0.00	1.00	0.00	0.00	0.00
06:15	0.00	5.66	0.00	1.00	0.00	0.00	0.00
06:20	0.00	5.66	0.00	1.00	0.00	0.00	0.00
06:25	0.00	5.65	0.00	1.00	0.00	0.00	0.00
06:30	0.00	5.64	0.00	1.00	0.00	0.00	0.00
06:35	0.00	5.64	0.00	1.00	0.00	0.00	0.00
06:40	0.00	5.63	0.00	1.00	0.00	0.00	0.00
06:45	0.00	5.62	0.00	1.00	0.00	0.00	0.00
06:50	0.00	5.62	0.00	1.00	0.00	0.00	0.00
06:55	0.00	5.61	0.00	1.00	0.00	0.00	0.00
07:00	0.00	5.60	0.00	1.00	0.00	0.00	0.00
07:05	0.00	5.60	0.00	1.00	0.00	0.00	0.00
07:10	0.00	5.59	0.00	1.00	0.00	0.00	0.00
07:15	0.00	5.58	0.00	1.00	0.00	0.00	0.00
07:20	0.00	5.58	0.00	1.00	0.00	0.00	0.00
07:25	0.00	5.57	0.00	1.00	0.00	0.00	0.00
07:30	0.00	5.56	0.00	1.00	0.00	0.00	0.00
07:35	0.00	5.56	0.00	1.00	0.00	0.00	0.00
07:40	0.00	5.55	0.00	1.00	0.00	0.00	0.00
07:45	0.00	5.54	0.00	1.00	0.00	0.00	0.00
07:50	0.00	5.53	0.00	1.00	0.00	0.00	0.00
07:55	0.00	5.53	0.00	1.00	0.00	0.00	0.00
08:00	0.00	5.52	0.00	1.00	0.00	0.00	0.00
08:05	0.00	5.51	0.00	1.00	0.00	0.00	0.00
08:10	0.00	5.51	0.00	1.00	0.00	0.00	0.00
08:15	0.00	5.50	0.00	1.00	0.00	0.00	0.00
08:20	0.00	5.49	0.00	1.00	0.00	0.00	0.00
08:25	0.00	5.49	0.00	1.00	0.00	0.00	0.00
08:30	0.00	5.48	0.00	1.00	0.00	0.00	0.00
08:35	0.00	5.47	0.00	1.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=02:05

Elapsed Time	AuxBldg	sm.sump	sm.sump	sm.sump	TDT H2O	TDT	AuxBldg
HR:MIN	sm.sump	1st pmp	2nd pmp	Hi lvl	volume	Hi lvl	pas.sump
	feet	gpm	gpm	O=N;1=Y	%	O=N;1=Y	feet
04:40	640.58	0.00	0.00	0.00	70.00	0.00	0.00
04:45	640.58	0.00	0.00	0.00	70.00	0.00	0.00
04:50	640.58	0.00	0.00	0.00	70.00	0.00	0.00
04:55	640.58	0.00	0.00	0.00	70.00	0.00	0.00
05:00	640.58	0.00	0.00	0.00	70.00	0.00	0.00
05:05	640.59	0.00	0.00	0.00	70.00	0.00	0.00
05:10	640.59	0.00	0.00	0.00	70.00	0.00	0.00
05:15	640.59	0.00	0.00	0.00	70.00	0.00	0.00
05:20	640.59	0.00	0.00	0.00	70.00	0.00	0.00
05:25	640.59	0.00	0.00	0.00	70.00	0.00	0.00
05:30	640.59	0.00	0.00	0.00	70.00	0.00	0.00
05:35	640.59	0.00	0.00	0.00	70.00	0.00	0.00
05:40	640.60	0.00	0.00	0.00	70.00	0.00	0.00
05:45	640.60	0.00	0.00	0.00	70.00	0.00	0.00
05:50	640.60	0.00	0.00	0.00	70.00	0.00	0.00
05:55	640.60	0.00	0.00	0.00	70.00	0.00	0.00
06:00	640.60	0.00	0.00	0.00	70.00	0.00	0.00
06:05	640.60	0.00	0.00	0.00	70.00	0.00	0.00
06:10	640.60	0.00	0.00	0.00	70.00	0.00	0.00
06:15	640.60	0.00	0.00	0.00	70.00	0.00	0.00
06:20	640.61	0.00	0.00	0.00	70.00	0.00	0.00
06:25	640.61	0.00	0.00	0.00	70.00	0.00	0.00
06:30	640.61	0.00	0.00	0.00	70.00	0.00	0.00
06:35	640.61	0.00	0.00	0.00	70.00	0.00	0.00
06:40	640.61	0.00	0.00	0.00	70.00	0.00	0.00
06:45	640.61	0.00	0.00	0.00	70.00	0.00	0.00
06:50	640.61	0.00	0.00	0.00	70.00	0.00	0.00
06:55	640.62	0.00	0.00	0.00	70.00	0.00	0.00
07:00	640.62	0.00	0.00	0.00	70.00	0.00	0.00
07:05	640.62	0.00	0.00	0.00	70.00	0.00	0.00
07:10	640.62	0.00	0.00	0.00	70.00	0.00	0.00
07:15	640.62	0.00	0.00	0.00	70.00	0.00	0.00
07:20	640.62	0.00	0.00	0.00	70.00	0.00	0.00
07:25	640.62	0.00	0.00	0.00	70.00	0.00	0.00
07:30	640.63	0.00	0.00	0.00	70.00	0.00	0.00
07:35	640.63	0.00	0.00	0.00	70.00	0.00	0.00
07:40	640.63	0.00	0.00	0.00	70.00	0.00	0.00
07:45	640.63	0.00	0.00	0.00	70.00	0.00	0.00
07:50	640.63	0.00	0.00	0.00	70.00	0.00	0.00
07:55	640.63	0.00	0.00	0.00	70.00	0.00	0.00
08:00	640.63	0.00	0.00	0.00	70.00	0.00	0.00
08:05	640.64	0.00	0.00	0.00	70.00	0.00	0.00
08:10	640.64	0.00	0.00	0.00	70.00	0.00	0.00
08:15	640.64	0.00	0.00	0.00	70.00	0.00	0.00
08:20	640.64	0.00	0.00	0.00	70.00	0.00	0.00
08:25	640.64	0.00	0.00	0.00	70.00	0.00	0.00
08:30	640.64	0.00	0.00	0.00	70.00	0.00	0.00
08:35	640.64	0.00	0.00	0.00	70.00	0.00	0.00

A-4

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=02:20

RHR1A-A

Elev. 653

Elapsed Time HR:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
00:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:50	68.02	0.00	0.00	0.00	0.00	0.00	0.00
00:55	68.02	2.22	0.00	1.00	0.00	0.00	0.00
01:00	68.02	4.43	0.00	1.00	0.00	0.00	0.00
01:05	68.02	6.64	0.00	1.00	0.00	0.00	0.00
01:10	68.02	6.74	0.00	1.00	0.00	0.00	0.00
01:15	68.02	6.82	0.00	1.00	0.00	0.00	0.00
01:20	68.02	6.89	0.00	1.00	0.00	0.00	0.00
01:25	68.02	6.95	0.00	1.00	0.00	0.00	0.00
01:30	68.02	7.00	0.00	1.00	0.00	0.00	0.00
01:35	68.02	7.04	0.00	1.00	0.00	0.00	0.00
01:40	68.02	7.07	0.00	1.00	0.00	0.00	0.00
01:45	68.02	7.10	0.00	1.00	0.00	0.00	0.00
01:50	68.02	7.13	0.00	1.00	0.00	0.00	0.00
01:55	68.02	7.15	0.00	1.00	0.00	0.00	0.00
02:00	68.02	7.16	0.00	1.00	0.00	0.00	0.00
02:05	68.02	7.18	0.00	1.00	0.00	0.00	0.00
02:10	104.34	8.38	0.00	1.00	0.00	0.00	0.00
02:15	104.34	9.40	0.00	1.00	0.00	0.00	0.00
02:20	104.34	10.28	0.00	1.00	0.00	0.00	0.00
02:25	0.00	7.64	0.00	1.00	0.00	0.00	0.00
02:30	0.00	6.00	0.00	1.00	0.00	0.00	0.00
02:35	0.00	5.99	0.00	1.00	0.00	0.00	0.00
02:40	0.00	5.99	0.00	1.00	0.00	0.00	0.00
02:45	0.00	5.98	0.00	1.00	0.00	0.00	0.00
02:50	0.00	5.97	0.00	1.00	0.00	0.00	0.00
02:55	0.00	5.97	0.00	1.00	0.00	0.00	0.00
03:00	0.00	5.96	0.00	1.00	0.00	0.00	0.00
03:05	0.00	5.95	0.00	1.00	0.00	0.00	0.00
03:10	0.00	5.94	0.00	1.00	0.00	0.00	0.00
03:15	0.00	5.94	0.00	1.00	0.00	0.00	0.00
03:20	0.00	5.93	0.00	1.00	0.00	0.00	0.00
03:25	0.00	5.92	0.00	1.00	0.00	0.00	0.00
03:30	0.00	5.92	0.00	1.00	0.00	0.00	0.00
03:35	0.00	5.91	0.00	1.00	0.00	0.00	0.00
03:40	0.00	5.90	0.00	1.00	0.00	0.00	0.00
03:45	0.00	5.90	0.00	1.00	0.00	0.00	0.00
03:50	0.00	5.89	0.00	1.00	0.00	0.00	0.00
03:55	0.00	5.88	0.00	1.00	0.00	0.00	0.00
04:00	0.00	5.88	0.00	1.00	0.00	0.00	0.00
04:05	0.00	5.87	0.00	1.00	0.00	0.00	0.00
04:10	0.00	5.86	0.00	1.00	0.00	0.00	0.00
04:15	0.00	5.85	0.00	1.00	0.00	0.00	0.00
04:20	0.00	5.85	0.00	1.00	0.00	0.00	0.00
04:25	0.00	5.84	0.00	1.00	0.00	0.00	0.00
04:30	0.00	5.83	0.00	1.00	0.00	0.00	0.00
04:35	0.00	5.83	0.00	1.00	0.00	0.00	0.00

SQNGE93 FLOODI

ALCS FOR RHR1A-A LEAK STOPING AT T=02:20

Elapsed HR:MIN	AuxBldg Time	sm.sump feet	sm.sump 1st pmp gpm	sm.sump 2nd pmp gpm	sm.sump Hi lvl 0=N;1=Y	TDT H2O volume %	TDT Hi lvl 0=N;1=Y	AuxBldg pas.sump feet
0:00		640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:30		640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:45		640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:50		640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:55		640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:00		640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:05		641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:10		641.63	0.00	0.00	0.00	51.00	0.00	0.00
01:15		642.07	0.00	0.00	0.00	51.00	0.00	0.00
01:20		642.51	0.00	0.00	0.00	51.00	0.00	0.00
01:25		642.95	0.00	0.00	0.00	51.00	0.00	0.00
01:30		643.40	0.00	0.00	0.00	51.00	0.00	0.00
01:35		643.85	0.00	0.00	0.00	51.00	0.00	0.00
01:40		643.96	50.00	0.00	0.00	52.00	0.00	0.00
01:45		644.08	50.00	0.00	0.00	53.00	0.00	0.00
01:50		644.19	50.00	0.00	0.00	54.00	0.00	0.00
01:55		644.31	50.00	0.00	0.00	55.00	0.00	0.00
02:00		644.43	50.00	0.00	0.00	56.00	0.00	0.00
02:05		644.55	50.00	0.00	0.00	57.00	0.00	0.00
02:10		644.70	50.00	0.00	0.00	58.00	0.00	0.00
02:15		644.88	50.00	0.00	0.00	59.00	0.00	0.00
02:20		645.09	50.00	0.00	0.00	60.00	0.00	0.00
02:25		645.22	50.00	0.00	0.00	61.00	0.00	0.00
02:30		644.89	50.00	0.00	0.00	62.00	0.00	0.00
02:35		644.56	50.00	0.00	0.00	64.00	0.00	0.00
02:40		644.22	50.00	0.00	0.00	65.00	0.00	0.00
02:45		643.89	50.00	0.00	0.00	66.00	0.00	0.00
02:50		643.56	50.00	0.00	0.00	67.00	0.00	0.00
02:55		643.22	50.00	0.00	0.00	68.00	0.00	0.00
03:00		642.89	50.00	0.00	0.00	69.00	0.00	0.00
03:05		642.56	50.00	0.00	0.00	70.00	0.00	0.00
03:10		642.23	50.00	0.00	0.00	71.00	0.00	0.00
03:15		641.89	50.00	0.00	0.00	72.00	0.00	0.00
03:20		641.56	50.00	0.00	0.00	73.00	0.00	0.00
03:25		641.23	50.00	0.00	0.00	74.00	0.00	0.00
03:30		640.89	50.00	0.00	0.00	75.00	0.00	0.00
03:35		640.56	50.00	0.00	0.00	76.00	0.00	0.00
03:40		640.56	0.00	0.00	0.00	76.00	0.00	0.00
03:45		640.56	0.00	0.00	0.00	76.00	0.00	0.00
03:50		640.57	0.00	0.00	0.00	76.00	0.00	0.00
03:55		640.57	0.00	0.00	0.00	76.00	0.00	0.00
04:00		640.57	0.00	0.00	0.00	76.00	0.00	0.00
04:05		640.57	0.00	0.00	0.00	76.00	0.00	0.00
04:10		640.57	0.00	0.00	0.00	76.00	0.00	0.00
04:15		640.57	0.00	0.00	0.00	76.00	0.00	0.00
04:20		640.57	0.00	0.00	0.00	76.00	0.00	0.00
04:25		640.58	0.00	0.00	0.00	76.00	0.00	0.00
04:30		640.58	0.00	0.00	0.00	76.00	0.00	0.00
04:35		640.58	0.00	0.00	0.00	76.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=02:20

RHR1A-A

Elev. 653

Elapsed Time R:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
04:40	0.00	5.82	0.00	1.00	0.00	0.00	0.00
04:45	0.00	5.81	0.00	1.00	0.00	0.00	0.00
04:50	0.00	5.81	0.00	1.00	0.00	0.00	0.00
04:55	0.00	5.80	0.00	1.00	0.00	0.00	0.00
05:00	0.00	5.79	0.00	1.00	0.00	0.00	0.00
05:05	0.00	5.79	0.00	1.00	0.00	0.00	0.00
05:10	0.00	5.78	0.00	1.00	0.00	0.00	0.00
05:15	0.00	5.77	0.00	1.00	0.00	0.00	0.00
05:20	0.00	5.77	0.00	1.00	0.00	0.00	0.00
05:25	0.00	5.76	0.00	1.00	0.00	0.00	0.00
05:30	0.00	5.75	0.00	1.00	0.00	0.00	0.00
05:35	0.00	5.74	0.00	1.00	0.00	0.00	0.00
05:40	0.00	5.74	0.00	1.00	0.00	0.00	0.00
05:45	0.00	5.73	0.00	1.00	0.00	0.00	0.00
05:50	0.00	5.72	0.00	1.00	0.00	0.00	0.00
05:55	0.00	5.72	0.00	1.00	0.00	0.00	0.00
06:00	0.00	5.71	0.00	1.00	0.00	0.00	0.00
06:05	0.00	5.70	0.00	1.00	0.00	0.00	0.00
06:10	0.00	5.70	0.00	1.00	0.00	0.00	0.00
06:15	0.00	5.69	0.00	1.00	0.00	0.00	0.00
06:20	0.00	5.68	0.00	1.00	0.00	0.00	0.00
06:25	0.00	5.68	0.00	1.00	0.00	0.00	0.00
06:30	0.00	5.67	0.00	1.00	0.00	0.00	0.00
06:35	0.00	5.66	0.00	1.00	0.00	0.00	0.00
06:40	0.00	5.66	0.00	1.00	0.00	0.00	0.00
06:45	0.00	5.65	0.00	1.00	0.00	0.00	0.00
06:50	0.00	5.64	0.00	1.00	0.00	0.00	0.00
06:55	0.00	5.64	0.00	1.00	0.00	0.00	0.00
07:00	0.00	5.63	0.00	1.00	0.00	0.00	0.00
07:05	0.00	5.62	0.00	1.00	0.00	0.00	0.00
07:10	0.00	5.62	0.00	1.00	0.00	0.00	0.00
07:15	0.00	5.61	0.00	1.00	0.00	0.00	0.00
07:20	0.00	5.60	0.00	1.00	0.00	0.00	0.00
07:25	0.00	5.60	0.00	1.00	0.00	0.00	0.00
07:30	0.00	5.59	0.00	1.00	0.00	0.00	0.00
07:35	0.00	5.58	0.00	1.00	0.00	0.00	0.00
07:40	0.00	5.58	0.00	1.00	0.00	0.00	0.00
07:45	0.00	5.57	0.00	1.00	0.00	0.00	0.00
07:50	0.00	5.56	0.00	1.00	0.00	0.00	0.00
07:55	0.00	5.56	0.00	1.00	0.00	0.00	0.00
08:00	0.00	5.55	0.00	1.00	0.00	0.00	0.00
08:05	0.00	5.54	0.00	1.00	0.00	0.00	0.00
08:10	0.00	5.53	0.00	1.00	0.00	0.00	0.00
08:15	0.00	5.53	0.00	1.00	0.00	0.00	0.00
08:20	0.00	5.52	0.00	1.00	0.00	0.00	0.00
08:25	0.00	5.51	0.00	1.00	0.00	0.00	0.00
08:30	0.00	5.51	0.00	1.00	0.00	0.00	0.00
08:35	0.00	5.50	0.00	1.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=02:20

Elapsed Time HR:MIN	AuxBldg sm.sump feet	sm.sump 1st pmp gpm	sm.sump 2nd pmp gpm	sm.sump Hi lvl 0=N;1=Y	TDT H2O volume	TDT Hi lvl 0=N;1=Y	AuxBldg pas.sump feet
04:40	640.58	0.00	0.00	0.00	76.00	0.00	0.00
04:45	640.58	0.00	0.00	0.00	76.00	0.00	0.00
04:50	640.58	0.00	0.00	0.00	76.00	0.00	0.00
04:55	640.58	0.00	0.00	0.00	76.00	0.00	0.00
05:00	640.59	0.00	0.00	0.00	76.00	0.00	0.00
05:05	640.59	0.00	0.00	0.00	76.00	0.00	0.00
05:10	640.59	0.00	0.00	0.00	76.00	0.00	0.00
05:15	640.59	0.00	0.00	0.00	76.00	0.00	0.00
05:20	640.59	0.00	0.00	0.00	76.00	0.00	0.00
05:25	640.59	0.00	0.00	0.00	76.00	0.00	0.00
05:30	640.59	0.00	0.00	0.00	76.00	0.00	0.00
05:35	640.60	0.00	0.00	0.00	76.00	0.00	0.00
05:40	640.60	0.00	0.00	0.00	76.00	0.00	0.00
05:45	640.60	0.00	0.00	0.00	76.00	0.00	0.00
05:50	640.60	0.00	0.00	0.00	76.00	0.00	0.00
05:55	640.60	0.00	0.00	0.00	76.00	0.00	0.00
06:00	640.60	0.00	0.00	0.00	76.00	0.00	0.00
06:05	640.60	0.00	0.00	0.00	76.00	0.00	0.00
06:10	640.61	0.00	0.00	0.00	76.00	0.00	0.00
06:15	640.61	0.00	0.00	0.00	76.00	0.00	0.00
06:20	640.61	0.00	0.00	0.00	76.00	0.00	0.00
06:25	640.61	0.00	0.00	0.00	76.00	0.00	0.00
06:30	640.61	0.00	0.00	0.00	76.00	0.00	0.00
06:35	640.61	0.00	0.00	0.00	76.00	0.00	0.00
06:40	640.61	0.00	0.00	0.00	76.00	0.00	0.00
06:45	640.62	0.00	0.00	0.00	76.00	0.00	0.00
06:50	640.62	0.00	0.00	0.00	76.00	0.00	0.00
06:55	640.62	0.00	0.00	0.00	76.00	0.00	0.00
07:00	640.62	0.00	0.00	0.00	76.00	0.00	0.00
07:05	640.62	0.00	0.00	0.00	76.00	0.00	0.00
07:10	640.62	0.00	0.00	0.00	76.00	0.00	0.00
07:15	640.62	0.00	0.00	0.00	76.00	0.00	0.00
07:20	640.62	0.00	0.00	0.00	76.00	0.00	0.00
07:25	640.63	0.00	0.00	0.00	76.00	0.00	0.00
07:30	640.63	0.00	0.00	0.00	76.00	0.00	0.00
07:35	640.63	0.00	0.00	0.00	76.00	0.00	0.00
07:40	640.63	0.00	0.00	0.00	76.00	0.00	0.00
07:45	640.63	0.00	0.00	0.00	76.00	0.00	0.00
07:50	640.63	0.00	0.00	0.00	76.00	0.00	0.00
07:55	640.63	0.00	0.00	0.00	76.00	0.00	0.00
08:00	640.64	0.00	0.00	0.00	76.00	0.00	0.00
08:05	640.64	0.00	0.00	0.00	76.00	0.00	0.00
08:10	640.64	0.00	0.00	0.00	76.00	0.00	0.00
08:15	640.64	0.00	0.00	0.00	76.00	0.00	0.00
08:20	640.64	0.00	0.00	0.00	76.00	0.00	0.00
08:25	640.64	0.00	0.00	0.00	76.00	0.00	0.00
08:30	640.64	0.00	0.00	0.00	76.00	0.00	0.00
08:35	640.65	0.00	0.00	0.00	76.00	0.00	0.00

A-5

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=02:35

RHR1A-A

Elev. 653

Elapsed Time R:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT H2O lvl inches
00:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:50	68.02	0.00	0.00	0.00	0.00	0.00	0.00
00:55	68.02	2.22	0.00	1.00	0.00	0.00	0.00
01:00	68.02	4.43	0.00	1.00	0.00	0.00	0.00
01:05	68.02	6.64	0.00	1.00	0.00	0.00	0.00
01:10	68.02	6.74	0.00	1.00	0.00	0.00	0.00
01:15	68.02	6.82	0.00	1.00	0.00	0.00	0.00
01:20	68.02	6.89	0.00	1.00	0.00	0.00	0.00
01:25	68.02	6.95	0.00	1.00	0.00	0.00	0.00
01:30	68.02	7.00	0.00	1.00	0.00	0.00	0.00
01:35	68.02	7.04	0.00	1.00	0.00	0.00	0.00
01:40	68.02	7.07	0.00	1.00	0.00	0.00	0.00
01:45	68.02	7.10	0.00	1.00	0.00	0.00	0.00
01:50	68.02	7.13	0.00	1.00	0.00	0.00	0.00
01:55	68.02	7.15	0.00	1.00	0.00	0.00	0.00
02:00	68.02	7.16	0.00	1.00	0.00	0.00	0.00
02:05	68.02	7.18	0.00	1.00	0.00	0.00	0.00
02:10	104.34	8.38	0.00	1.00	0.00	0.00	0.00
02:15	104.34	9.40	0.00	1.00	0.00	0.00	0.00
02:20	104.34	10.28	0.00	1.00	0.00	0.00	0.00
02:25	104.34	11.04	0.00	1.00	0.00	0.00	0.00
02:30	104.34	11.71	0.00	1.00	0.00	0.00	0.00
02:35	104.34	12.29	10.59	1.00	0.05	0.00	0.00
02:40	0.00	8.89	1.00	1.00	0.00	0.00	0.00
02:45	0.00	6.44	1.00	1.00	0.00	0.00	0.00
02:50	0.00	6.00	1.00	1.00	0.00	0.00	0.00
02:55	0.00	5.99	1.00	1.00	0.00	0.00	0.00
03:00	0.00	5.99	1.00	1.00	0.00	0.00	0.00
03:05	0.00	5.98	1.00	1.00	0.00	0.00	0.00
03:10	0.00	5.97	1.00	1.00	0.00	0.00	0.00
03:15	0.00	5.97	1.00	1.00	0.00	0.00	0.00
03:20	0.00	5.96	1.00	1.00	0.00	0.00	0.00
03:25	0.00	5.95	1.00	1.00	0.00	0.00	0.00
03:30	0.00	5.94	1.00	1.00	0.00	0.00	0.00
03:35	0.00	5.94	1.00	1.00	0.00	0.00	0.00
03:40	0.00	5.93	1.00	1.00	0.00	0.00	0.00
03:45	0.00	5.92	1.00	1.00	0.00	0.00	0.00
03:50	0.00	5.92	1.00	1.00	0.00	0.00	0.00
03:55	0.00	5.91	1.00	1.00	0.00	0.00	0.00
04:00	0.00	5.90	1.00	1.00	0.00	0.00	0.00
04:05	0.00	5.90	1.00	1.00	0.00	0.00	0.00
04:10	0.00	5.89	1.00	1.00	0.00	0.00	0.00
04:15	0.00	5.88	1.00	1.00	0.00	0.00	0.00
04:20	0.00	5.88	1.00	1.00	0.00	0.00	0.00
04:25	0.00	5.87	1.00	1.00	0.00	0.00	0.00
04:30	0.00	5.86	1.00	1.00	0.00	0.00	0.00
04:35	0.00	5.85	1.00	1.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=02:35

Elapsed Time	AuxBldg	sm.sump	sm.sump	sm.sump	TDT H2O	TDT	AuxBldg
HR:MIN	sm.sump	1st pmp	2nd pmp	Hi lvl	volume	Hi lvl	pas.sump
	feet	gpm	gpm	0=N;1=Y	%	0=N;1=Y	feet
00:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:30	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:45	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:50	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:55	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:05	641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:10	641.63	0.00	0.00	0.00	51.00	0.00	0.00
01:15	642.07	0.00	0.00	0.00	51.00	0.00	0.00
01:20	642.51	0.00	0.00	0.00	51.00	0.00	0.00
01:25	642.95	0.00	0.00	0.00	51.00	0.00	0.00
01:30	643.40	0.00	0.00	0.00	51.00	0.00	0.00
01:35	643.85	0.00	0.00	0.00	51.00	0.00	0.00
01:40	643.96	50.00	0.00	0.00	52.00	0.00	0.00
01:45	644.08	50.00	0.00	0.00	53.00	0.00	0.00
01:50	644.19	50.00	0.00	0.00	54.00	0.00	0.00
01:55	644.31	50.00	0.00	0.00	55.00	0.00	0.00
02:00	644.43	50.00	0.00	0.00	56.00	0.00	0.00
02:05	644.55	50.00	0.00	0.00	57.00	0.00	0.00
02:10	644.70	50.00	0.00	0.00	58.00	0.00	0.00
02:15	644.88	50.00	0.00	0.00	59.00	0.00	0.00
02:20	645.09	50.00	0.00	0.00	60.00	0.00	0.00
02:25	645.32	50.00	0.00	0.00	61.00	0.00	0.00
02:30	645.56	50.00	0.00	0.00	62.00	0.00	0.00
02:35	645.82	50.00	0.00	0.00	64.00	0.00	0.00
02:40	646.14	50.00	0.00	0.00	65.00	0.00	0.00
02:45	646.23	50.00	0.00	0.00	66.00	0.00	0.00
02:50	645.90	50.00	0.00	0.00	67.00	0.00	0.00
02:55	645.57	50.00	0.00	0.00	68.00	0.00	0.00
03:00	645.23	50.00	0.00	0.00	69.00	0.00	0.00
03:05	644.90	50.00	0.00	0.00	70.00	0.00	0.00
03:10	644.57	50.00	0.00	0.00	71.00	0.00	0.00
03:15	644.24	50.00	0.00	0.00	72.00	0.00	0.00
03:20	643.90	50.00	0.00	0.00	73.00	0.00	0.00
03:25	643.57	50.00	0.00	0.00	74.00	0.00	0.00
03:30	643.24	50.00	0.00	0.00	75.00	0.00	0.00
03:35	642.90	50.00	0.00	0.00	76.00	0.00	0.00
03:40	642.57	50.00	0.00	0.00	77.00	0.00	0.00
03:45	642.24	50.00	0.00	0.00	78.00	0.00	0.00
03:50	641.91	50.00	0.00	0.00	79.00	0.00	0.00
03:55	641.57	50.00	0.00	0.00	80.00	0.00	0.00
04:00	641.24	50.00	0.00	0.00	81.00	0.00	0.00
04:05	640.91	50.00	0.00	0.00	82.00	0.00	0.00
04:10	640.58	50.00	0.00	0.00	83.00	0.00	0.00
04:15	640.58	0.00	0.00	0.00	83.00	0.00	0.00
04:20	640.58	0.00	0.00	0.00	83.00	0.00	0.00
04:25	640.58	0.00	0.00	0.00	83.00	0.00	0.00
04:30	640.58	0.00	0.00	0.00	83.00	0.00	0.00
04:35	640.58	0.00	0.00	0.00	83.00	0.00	0.00

SQN93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=02:35

RHR1A-A

Elev. 653

Elapsed Time H:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
04:40	0.00	5.85	1.00	1.00	0.00	0.00	0.00
04:45	0.00	5.84	1.00	1.00	0.00	0.00	0.00
04:50	0.00	5.83	1.00	1.00	0.00	0.00	0.00
04:55	0.00	5.83	1.00	1.00	0.00	0.00	0.00
05:00	0.00	5.82	1.00	1.00	0.00	0.00	0.00
05:05	0.00	5.81	1.00	1.00	0.00	0.00	0.00
05:10	0.00	5.81	1.00	1.00	0.00	0.00	0.00
05:15	0.00	5.80	1.00	1.00	0.00	0.00	0.00
05:20	0.00	5.79	1.00	1.00	0.00	0.00	0.00
05:25	0.00	5.79	1.00	1.00	0.00	0.00	0.00
05:30	0.00	5.78	1.00	1.00	0.00	0.00	0.00
05:35	0.00	5.77	1.00	1.00	0.00	0.00	0.00
05:40	0.00	5.77	1.00	1.00	0.00	0.00	0.00
05:45	0.00	5.76	1.00	1.00	0.00	0.00	0.00
05:50	0.00	5.75	1.00	1.00	0.00	0.00	0.00
05:55	0.00	5.74	1.00	1.00	0.00	0.00	0.00
06:00	0.00	5.74	1.00	1.00	0.00	0.00	0.00
06:05	0.00	5.73	1.00	1.00	0.00	0.00	0.00
06:10	0.00	5.72	1.00	1.00	0.00	0.00	0.00
06:15	0.00	5.72	1.00	1.00	0.00	0.00	0.00
06:20	0.00	5.71	1.00	1.00	0.00	0.00	0.00
06:25	0.00	5.70	1.00	1.00	0.00	0.00	0.00
06:30	0.00	5.70	1.00	1.00	0.00	0.00	0.00
06:35	0.00	5.69	1.00	1.00	0.00	0.00	0.00
06:40	0.00	5.68	1.00	1.00	0.00	0.00	0.00
06:45	0.00	5.68	1.00	1.00	0.00	0.00	0.00
06:50	0.00	5.67	1.00	1.00	0.00	0.00	0.00
06:55	0.00	5.66	1.00	1.00	0.00	0.00	0.00
07:00	0.00	5.66	1.00	1.00	0.00	0.00	0.00
07:05	0.00	5.65	1.00	1.00	0.00	0.00	0.00
07:10	0.00	5.64	1.00	1.00	0.00	0.00	0.00
07:15	0.00	5.64	1.00	1.00	0.00	0.00	0.00
07:20	0.00	5.63	1.00	1.00	0.00	0.00	0.00
07:25	0.00	5.62	1.00	1.00	0.00	0.00	0.00
07:30	0.00	5.62	1.00	1.00	0.00	0.00	0.00
07:35	0.00	5.61	1.00	1.00	0.00	0.00	0.00
07:40	0.00	5.60	1.00	1.00	0.00	0.00	0.00
07:45	0.00	5.60	1.00	1.00	0.00	0.00	0.00
07:50	0.00	5.59	1.00	1.00	0.00	0.00	0.00
07:55	0.00	5.58	1.00	1.00	0.00	0.00	0.00
08:00	0.00	5.58	1.00	1.00	0.00	0.00	0.00
08:05	0.00	5.57	1.00	1.00	0.00	0.00	0.00
08:10	0.00	5.56	1.00	1.00	0.00	0.00	0.00
08:15	0.00	5.56	1.00	1.00	0.00	0.00	0.00
08:20	0.00	5.55	1.00	1.00	0.00	0.00	0.00
08:25	0.00	5.54	1.00	1.00	0.00	0.00	0.00
08:30	0.00	5.53	1.00	1.00	0.00	0.00	0.00
08:35	0.00	5.53	1.00	1.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=02:35

Elapsed Time	AuxBldg HR:MIN	sm.sump feet	sm.sump 1st pmp gpm	sm.sump 2nd pmp gpm	sm.sump Hi lvl 0=N;1=Y	TDT H2O volume	TDT Hi lvl 0=N;1=Y	AuxBldg pas.sump feet
04:40		640.58	0.00	0.00	0.00	83.00	0.00	0.00
04:45		640.59	0.00	0.00	0.00	83.00	0.00	0.00
04:50		640.59	0.00	0.00	0.00	83.00	0.00	0.00
04:55		640.59	0.00	0.00	0.00	83.00	0.00	0.00
05:00		640.59	0.00	0.00	0.00	83.00	0.00	0.00
05:05		640.59	0.00	0.00	0.00	83.00	0.00	0.00
05:10		640.59	0.00	0.00	0.00	83.00	0.00	0.00
05:15		640.59	0.00	0.00	0.00	83.00	0.00	0.00
05:20		640.60	0.00	0.00	0.00	83.00	0.00	0.00
05:25		640.60	0.00	0.00	0.00	83.00	0.00	0.00
05:30		640.60	0.00	0.00	0.00	83.00	0.00	0.00
05:35		640.60	0.00	0.00	0.00	83.00	0.00	0.00
05:40		640.60	0.00	0.00	0.00	83.00	0.00	0.00
05:45		640.60	0.00	0.00	0.00	83.00	0.00	0.00
05:50		640.60	0.00	0.00	0.00	83.00	0.00	0.00
05:55		640.60	0.00	0.00	0.00	83.00	0.00	0.00
06:00		640.61	0.00	0.00	0.00	83.00	0.00	0.00
06:05		640.61	0.00	0.00	0.00	83.00	0.00	0.00
06:10		640.61	0.00	0.00	0.00	83.00	0.00	0.00
06:15		640.61	0.00	0.00	0.00	83.00	0.00	0.00
06:20		640.61	0.00	0.00	0.00	83.00	0.00	0.00
06:25		640.61	0.00	0.00	0.00	83.00	0.00	0.00
06:30		640.61	0.00	0.00	0.00	83.00	0.00	0.00
06:35		640.62	0.00	0.00	0.00	83.00	0.00	0.00
06:40		640.62	0.00	0.00	0.00	83.00	0.00	0.00
06:45		640.62	0.00	0.00	0.00	83.00	0.00	0.00
06:50		640.62	0.00	0.00	0.00	83.00	0.00	0.00
06:55		640.62	0.00	0.00	0.00	83.00	0.00	0.00
07:00		640.62	0.00	0.00	0.00	83.00	0.00	0.00
07:05		640.62	0.00	0.00	0.00	83.00	0.00	0.00
07:10		640.63	0.00	0.00	0.00	83.00	0.00	0.00
07:15		640.63	0.00	0.00	0.00	83.00	0.00	0.00
07:20		640.63	0.00	0.00	0.00	83.00	0.00	0.00
07:25		640.63	0.00	0.00	0.00	83.00	0.00	0.00
07:30		640.63	0.00	0.00	0.00	83.00	0.00	0.00
07:35		640.63	0.00	0.00	0.00	83.00	0.00	0.00
07:40		640.63	0.00	0.00	0.00	83.00	0.00	0.00
07:45		640.64	0.00	0.00	0.00	83.00	0.00	0.00
07:50		640.64	0.00	0.00	0.00	83.00	0.00	0.00
07:55		640.64	0.00	0.00	0.00	83.00	0.00	0.00
08:00		640.64	0.00	0.00	0.00	83.00	0.00	0.00
08:05		640.64	0.00	0.00	0.00	83.00	0.00	0.00
08:10		640.64	0.00	0.00	0.00	83.00	0.00	0.00
08:15		640.64	0.00	0.00	0.00	83.00	0.00	0.00
08:20		640.65	0.00	0.00	0.00	83.00	0.00	0.00
08:25		640.65	0.00	0.00	0.00	83.00	0.00	0.00
08:30		640.65	0.00	0.00	0.00	83.00	0.00	0.00
08:35		640.65	0.00	0.00	0.00	83.00	0.00	0.00

A-6

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=02:50

RHR1A-A

Elev. 653

Elapsed Time R:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT H2O lvl inches
00:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:50	68.02	0.00	0.00	0.00	0.00	0.00	0.00
00:55	68.02	2.22	0.00	1.00	0.00	0.00	0.00
01:00	68.02	4.43	0.00	1.00	0.00	0.00	0.00
01:05	68.02	6.64	0.00	1.00	0.00	0.00	0.00
01:10	68.02	6.74	0.00	1.00	0.00	0.00	0.00
01:15	68.02	6.82	0.00	1.00	0.00	0.00	0.00
01:20	68.02	6.89	0.00	1.00	0.00	0.00	0.00
01:25	68.02	6.95	0.00	1.00	0.00	0.00	0.00
01:30	68.02	7.00	0.00	1.00	0.00	0.00	0.00
01:35	68.02	7.04	0.00	1.00	0.00	0.00	0.00
01:40	68.02	7.07	0.00	1.00	0.00	0.00	0.00
01:45	68.02	7.10	0.00	1.00	0.00	0.00	0.00
01:50	68.02	7.13	0.00	1.00	0.00	0.00	0.00
01:55	68.02	7.15	0.00	1.00	0.00	0.00	0.00
02:00	68.02	7.16	0.00	1.00	0.00	0.00	0.00
02:05	68.02	7.18	0.00	1.00	0.00	0.00	0.00
02:10	104.34	8.38	0.00	1.00	0.00	0.00	0.00
02:15	104.34	9.40	0.00	1.00	0.00	0.00	0.00
02:20	104.34	10.28	0.00	1.00	0.00	0.00	0.00
02:25	104.34	11.04	0.00	1.00	0.00	0.00	0.00
02:30	104.34	11.71	0.00	1.00	0.00	0.00	0.00
02:35	104.34	12.29	10.59	1.00	0.05	0.00	0.00
02:40	104.34	12.29	7.81	1.00	0.02	0.00	0.00
02:45	104.34	12.29	10.12	1.00	0.03	0.00	0.00
02:50	104.34	12.29	8.26	1.00	0.02	0.00	0.00
02:55	0.00	8.89	1.00	1.00	0.00	0.00	0.00
03:00	0.00	6.44	1.00	1.00	0.00	0.00	0.00
03:05	0.00	6.00	1.00	1.00	0.00	0.00	0.00
03:10	0.00	5.99	1.00	1.00	0.00	0.00	0.00
03:15	0.00	5.99	1.00	1.00	0.00	0.00	0.00
03:20	0.00	5.98	1.00	1.00	0.00	0.00	0.00
03:25	0.00	5.97	1.00	1.00	0.00	0.00	0.00
03:30	0.00	5.97	1.00	1.00	0.00	0.00	0.00
03:35	0.00	5.96	1.00	1.00	0.00	0.00	0.00
03:40	0.00	5.95	1.00	1.00	0.00	0.00	0.00
03:45	0.00	5.94	1.00	1.00	0.00	0.00	0.00
03:50	0.00	5.94	1.00	1.00	0.00	0.00	0.00
03:55	0.00	5.93	1.00	1.00	0.00	0.00	0.00
04:00	0.00	5.92	1.00	1.00	0.00	0.00	0.00
04:05	0.00	5.92	1.00	1.00	0.00	0.00	0.00
04:10	0.00	5.91	1.00	1.00	0.00	0.00	0.00
04:15	0.00	5.90	1.00	1.00	0.00	0.00	0.00
04:20	0.00	5.90	1.00	1.00	0.00	0.00	0.00
04:25	0.00	5.89	1.00	1.00	0.00	0.00	0.00
04:30	0.00	5.88	1.00	1.00	0.00	0.00	0.00
04:35	0.00	5.88	1.00	1.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=02:50

Elapsed Time	AuxBldg	sm.sump	sm.sump	sm.sump	TDT H2O	TDT	AuxBldg
HR:MIN	sm.sump	1st pmp	2nd pmp	Hi lvl	volume	Hi lvl	pas.sump
	feet	gpm	gpm	0=N;1=Y	%	0=N;1=Y	feet
0:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:30	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:45	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:50	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:55	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:05	641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:10	641.63	0.00	0.00	0.00	51.00	0.00	0.00
01:15	642.07	0.00	0.00	0.00	51.00	0.00	0.00
01:20	642.51	0.00	0.00	0.00	51.00	0.00	0.00
01:25	642.95	0.00	0.00	0.00	51.00	0.00	0.00
01:30	643.40	0.00	0.00	0.00	51.00	0.00	0.00
01:35	643.85	0.00	0.00	0.00	51.00	0.00	0.00
01:40	643.96	50.00	0.00	0.00	52.00	0.00	0.00
01:45	644.08	50.00	0.00	0.00	53.00	0.00	0.00
01:50	644.19	50.00	0.00	0.00	54.00	0.00	0.00
01:55	644.31	50.00	0.00	0.00	55.00	0.00	0.00
02:00	644.43	50.00	0.00	0.00	56.00	0.00	0.00
02:05	644.55	50.00	0.00	0.00	57.00	0.00	0.00
02:10	644.70	50.00	0.00	0.00	58.00	0.00	0.00
02:15	644.88	50.00	0.00	0.00	59.00	0.00	0.00
02:20	645.09	50.00	0.00	0.00	60.00	0.00	0.00
02:25	645.32	50.00	0.00	0.00	61.00	0.00	0.00
02:30	645.56	50.00	0.00	0.00	62.00	0.00	0.00
02:35	645.82	50.00	0.00	0.00	64.00	0.00	0.00
02:40	646.23	50.00	0.00	0.00	65.00	0.00	0.00
02:45	646.59	50.00	0.00	0.00	66.00	0.00	0.00
02:50	646.97	50.00	0.00	0.00	67.00	0.00	0.00
02:55	646.90	50.00	50.00	0.00	69.00	0.00	0.00
03:00	646.66	50.00	50.00	0.00	71.00	0.00	0.00
03:05	646.00	50.00	50.00	0.00	73.00	0.00	0.00
03:10	645.33	50.00	50.00	0.00	75.00	0.00	0.00
03:15	644.66	50.00	50.00	0.00	77.00	0.00	0.00
03:20	643.99	50.00	50.00	0.00	79.00	0.00	0.00
03:25	643.33	50.00	50.00	0.00	81.00	0.00	0.00
03:30	642.66	50.00	50.00	0.00	83.00	0.00	0.00
03:35	641.99	50.00	50.00	0.00	85.00	0.00	0.00
03:40	641.33	50.00	50.00	0.00	88.00	0.00	0.00
03:45	640.66	50.00	50.00	0.00	90.00	0.00	0.00
03:50	640.66	0.00	0.00	0.00	90.00	0.00	0.00
03:55	640.66	0.00	0.00	0.00	90.00	0.00	0.00
04:00	640.66	0.00	0.00	0.00	90.00	0.00	0.00
04:05	640.66	0.00	0.00	0.00	90.00	0.00	0.00
04:10	640.67	0.00	0.00	0.00	90.00	0.00	0.00
04:15	640.67	0.00	0.00	0.00	90.00	0.00	0.00
04:20	640.67	0.00	0.00	0.00	90.00	0.00	0.00
04:25	640.67	0.00	0.00	0.00	90.00	0.00	0.00
04:30	640.67	0.00	0.00	0.00	90.00	0.00	0.00
04:35	640.67	0.00	0.00	0.00	90.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=02:50

RHR1A-A

Elev. 653

Elapsed Time R:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT H2O lvl inches
04:40	0.00	5.87	1.00	1.00	0.00	0.00	0.00
04:45	0.00	5.86	1.00	1.00	0.00	0.00	0.00
04:50	0.00	5.85	1.00	1.00	0.00	0.00	0.00
04:55	0.00	5.85	1.00	1.00	0.00	0.00	0.00
05:00	0.00	5.84	1.00	1.00	0.00	0.00	0.00
05:05	0.00	5.83	1.00	1.00	0.00	0.00	0.00
05:10	0.00	5.83	1.00	1.00	0.00	0.00	0.00
05:15	0.00	5.82	1.00	1.00	0.00	0.00	0.00
05:20	0.00	5.81	1.00	1.00	0.00	0.00	0.00
05:25	0.00	5.81	1.00	1.00	0.00	0.00	0.00
05:30	0.00	5.80	1.00	1.00	0.00	0.00	0.00
05:35	0.00	5.79	1.00	1.00	0.00	0.00	0.00
05:40	0.00	5.79	1.00	1.00	0.00	0.00	0.00
05:45	0.00	5.78	1.00	1.00	0.00	0.00	0.00
05:50	0.00	5.77	1.00	1.00	0.00	0.00	0.00
05:55	0.00	5.77	1.00	1.00	0.00	0.00	0.00
06:00	0.00	5.76	1.00	1.00	0.00	0.00	0.00
06:05	0.00	5.75	1.00	1.00	0.00	0.00	0.00
06:10	0.00	5.74	1.00	1.00	0.00	0.00	0.00
06:15	0.00	5.74	1.00	1.00	0.00	0.00	0.00
06:20	0.00	5.73	1.00	1.00	0.00	0.00	0.00
06:25	0.00	5.72	1.00	1.00	0.00	0.00	0.00
06:30	0.00	5.72	1.00	1.00	0.00	0.00	0.00
06:35	0.00	5.71	1.00	1.00	0.00	0.00	0.00
06:40	0.00	5.70	1.00	1.00	0.00	0.00	0.00
06:45	0.00	5.70	1.00	1.00	0.00	0.00	0.00
06:50	0.00	5.69	1.00	1.00	0.00	0.00	0.00
06:55	0.00	5.68	1.00	1.00	0.00	0.00	0.00
07:00	0.00	5.68	1.00	1.00	0.00	0.00	0.00
07:05	0.00	5.67	1.00	1.00	0.00	0.00	0.00
07:10	0.00	5.66	1.00	1.00	0.00	0.00	0.00
07:15	0.00	5.66	1.00	1.00	0.00	0.00	0.00
07:20	0.00	5.65	1.00	1.00	0.00	0.00	0.00
07:25	0.00	5.64	1.00	1.00	0.00	0.00	0.00
07:30	0.00	5.64	1.00	1.00	0.00	0.00	0.00
07:35	0.00	5.63	1.00	1.00	0.00	0.00	0.00
07:40	0.00	5.62	1.00	1.00	0.00	0.00	0.00
07:45	0.00	5.62	1.00	1.00	0.00	0.00	0.00
07:50	0.00	5.61	1.00	1.00	0.00	0.00	0.00
07:55	0.00	5.60	1.00	1.00	0.00	0.00	0.00
08:00	0.00	5.60	1.00	1.00	0.00	0.00	0.00
08:05	0.00	5.59	1.00	1.00	0.00	0.00	0.00
08:10	0.00	5.58	1.00	1.00	0.00	0.00	0.00
08:15	0.00	5.58	1.00	1.00	0.00	0.00	0.00
08:20	0.00	5.57	1.00	1.00	0.00	0.00	0.00
08:25	0.00	5.56	1.00	1.00	0.00	0.00	0.00
08:30	0.00	5.56	1.00	1.00	0.00	0.00	0.00
08:35	0.00	5.55	1.00	1.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=02:50

Elapsed Time	AuxBldg sm.sump feet	sm.sump 1st pmp gpm	sm.sump 2nd pmp gpm	sm.sump Hi lvl 0=N;1=Y	TDT H2O volume	TDT Hi lvl 0=N;1=Y	AuxBldg pas.sump feet
04:40	640.67	0.00	0.00	0.00	90.00	0.00	0.00
04:45	640.68	0.00	0.00	0.00	90.00	0.00	0.00
04:50	640.68	0.00	0.00	0.00	90.00	0.00	0.00
04:55	640.68	0.00	0.00	0.00	90.00	0.00	0.00
05:00	640.68	0.00	0.00	0.00	90.00	0.00	0.00
05:05	640.68	0.00	0.00	0.00	90.00	0.00	0.00
05:10	640.68	0.00	0.00	0.00	90.00	0.00	0.00
05:15	640.68	0.00	0.00	0.00	90.00	0.00	0.00
05:20	640.69	0.00	0.00	0.00	90.00	0.00	0.00
05:25	640.69	0.00	0.00	0.00	90.00	0.00	0.00
05:30	640.69	0.00	0.00	0.00	90.00	0.00	0.00
05:35	640.69	0.00	0.00	0.00	90.00	0.00	0.00
05:40	640.69	0.00	0.00	0.00	90.00	0.00	0.00
05:45	640.69	0.00	0.00	0.00	90.00	0.00	0.00
05:50	640.69	0.00	0.00	0.00	90.00	0.00	0.00
05:55	640.70	0.00	0.00	0.00	90.00	0.00	0.00
06:00	640.70	0.00	0.00	0.00	90.00	0.00	0.00
06:05	640.70	0.00	0.00	0.00	90.00	0.00	0.00
06:10	640.70	0.00	0.00	0.00	90.00	0.00	0.00
06:15	640.70	0.00	0.00	0.00	90.00	0.00	0.00
06:20	640.70	0.00	0.00	0.00	90.00	0.00	0.00
06:25	640.70	0.00	0.00	0.00	90.00	0.00	0.00
06:30	640.71	0.00	0.00	0.00	90.00	0.00	0.00
06:35	640.71	0.00	0.00	0.00	90.00	0.00	0.00
06:40	640.71	0.00	0.00	0.00	90.00	0.00	0.00
06:45	640.71	0.00	0.00	0.00	90.00	0.00	0.00
06:50	640.71	0.00	0.00	0.00	90.00	0.00	0.00
06:55	640.71	0.00	0.00	0.00	90.00	0.00	0.00
07:00	640.71	0.00	0.00	0.00	90.00	0.00	0.00
07:05	640.72	0.00	0.00	0.00	90.00	0.00	0.00
07:10	640.72	0.00	0.00	0.00	90.00	0.00	0.00
07:15	640.72	0.00	0.00	0.00	90.00	0.00	0.00
07:20	640.72	0.00	0.00	0.00	90.00	0.00	0.00
07:25	640.72	0.00	0.00	0.00	90.00	0.00	0.00
07:30	640.72	0.00	0.00	0.00	90.00	0.00	0.00
07:35	640.72	0.00	0.00	0.00	90.00	0.00	0.00
07:40	640.73	0.00	0.00	0.00	90.00	0.00	0.00
07:45	640.73	0.00	0.00	0.00	90.00	0.00	0.00
07:50	640.73	0.00	0.00	0.00	90.00	0.00	0.00
07:55	640.73	0.00	0.00	0.00	90.00	0.00	0.00
08:00	640.73	0.00	0.00	0.00	90.00	0.00	0.00
08:05	640.73	0.00	0.00	0.00	90.00	0.00	0.00
08:10	640.73	0.00	0.00	0.00	90.00	0.00	0.00
08:15	640.73	0.00	0.00	0.00	90.00	0.00	0.00
08:20	640.74	0.00	0.00	0.00	90.00	0.00	0.00
08:25	640.74	0.00	0.00	0.00	90.00	0.00	0.00
08:30	640.74	0.00	0.00	0.00	90.00	0.00	0.00
08:35	640.74	0.00	0.00	0.00	90.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=03:05

RHR1A-A

Elev. 653

Elapsed Time HR:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
00:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:50	68.02	0.00	0.00	0.00	0.00	0.00	0.00
00:55	68.02	2.22	0.00	1.00	0.00	0.00	0.00
01:00	68.02	4.43	0.00	1.00	0.00	0.00	0.00
01:05	68.02	6.64	0.00	1.00	0.00	0.00	0.00
01:10	68.02	6.74	0.00	1.00	0.00	0.00	0.00
01:15	68.02	6.82	0.00	1.00	0.00	0.00	0.00
01:20	68.02	6.89	0.00	1.00	0.00	0.00	0.00
01:25	68.02	6.95	0.00	1.00	0.00	0.00	0.00
01:30	68.02	7.00	0.00	1.00	0.00	0.00	0.00
01:35	68.02	7.04	0.00	1.00	0.00	0.00	0.00
01:40	68.02	7.07	0.00	1.00	0.00	0.00	0.00
01:45	68.02	7.10	0.00	1.00	0.00	0.00	0.00
01:50	68.02	7.13	0.00	1.00	0.00	0.00	0.00
01:55	68.02	7.15	0.00	1.00	0.00	0.00	0.00
02:00	68.02	7.16	0.00	1.00	0.00	0.00	0.00
02:05	68.02	7.18	0.00	1.00	0.00	0.00	0.00
02:10	104.34	8.38	0.00	1.00	0.00	0.00	0.00
02:15	104.34	9.40	0.00	1.00	0.00	0.00	0.00
02:20	104.34	10.28	0.00	1.00	0.00	0.00	0.00
02:25	104.34	11.04	0.00	1.00	0.00	0.00	0.00
02:30	104.34	11.71	0.00	1.00	0.00	0.00	0.00
02:35	104.34	12.29	10.59	1.00	0.05	0.00	0.00
02:40	104.34	12.29	7.81	1.00	0.02	0.00	0.00
02:45	104.34	12.29	10.12	1.00	0.03	0.00	0.00
02:50	104.34	12.29	8.26	1.00	0.02	0.00	0.00
02:55	104.34	12.29	9.79	1.00	0.03	0.00	0.00
03:00	104.34	12.29	8.55	1.00	0.02	0.00	0.00
03:05	104.34	12.29	9.57	1.00	0.03	0.00	0.00
03:10	0.00	8.89	1.00	1.00	0.00	0.00	0.00
03:15	0.00	6.44	1.00	1.00	0.00	0.00	0.00
03:20	0.00	6.00	1.00	1.00	0.00	0.00	0.00
03:25	0.00	5.99	1.00	1.00	0.00	0.00	0.00
03:30	0.00	5.99	1.00	1.00	0.00	0.00	0.00
03:35	0.00	5.98	1.00	1.00	0.00	0.00	0.00
03:40	0.00	5.97	1.00	1.00	0.00	0.00	0.00
03:45	0.00	5.97	1.00	1.00	0.00	0.00	0.00
03:50	0.00	5.96	1.00	1.00	0.00	0.00	0.00
03:55	0.00	5.95	1.00	1.00	0.00	0.00	0.00
04:00	0.00	5.94	1.00	1.00	0.00	0.00	0.00
04:05	0.00	5.94	1.00	1.00	0.00	0.00	0.00
04:10	0.00	5.93	1.00	1.00	0.00	0.00	0.00
04:15	0.00	5.92	1.00	1.00	0.00	0.00	0.00
04:20	0.00	5.92	1.00	1.00	0.00	0.00	0.00
04:25	0.00	5.91	1.00	1.00	0.00	0.00	0.00
04:30	0.00	5.90	1.00	1.00	0.00	0.00	0.00
04:35	0.00	5.90	1.00	1.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=03:05

Elapsed Time HR:MIN	AuxBldg sm.sump feet	sm.sump 1st pmp gpm	sm.sump 2nd pmp gpm	sm.sump Hi lvl 0=N;1=Y	TDT H2O volume	TDT Hi lvl 0=N;1=Y	AuxBldg pas.sump feet
0:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:30	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:45	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:50	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:55	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:05	641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:10	641.63	0.00	0.00	0.00	51.00	0.00	0.00
01:15	642.07	0.00	0.00	0.00	51.00	0.00	0.00
01:20	642.51	0.00	0.00	0.00	51.00	0.00	0.00
01:25	642.95	0.00	0.00	0.00	51.00	0.00	0.00
01:30	643.40	0.00	0.00	0.00	51.00	0.00	0.00
01:35	643.85	0.00	0.00	0.00	51.00	0.00	0.00
01:40	643.96	50.00	0.00	0.00	52.00	0.00	0.00
01:45	644.08	50.00	0.00	0.00	53.00	0.00	0.00
01:50	644.19	50.00	0.00	0.00	54.00	0.00	0.00
01:55	644.31	50.00	0.00	0.00	55.00	0.00	0.00
02:00	644.43	50.00	0.00	0.00	56.00	0.00	0.00
02:05	644.55	50.00	0.00	0.00	57.00	0.00	0.00
02:10	644.70	50.00	0.00	0.00	58.00	0.00	0.00
02:15	644.88	50.00	0.00	0.00	59.00	0.00	0.00
02:20	645.09	50.00	0.00	0.00	60.00	0.00	0.00
02:25	645.32	50.00	0.00	0.00	61.00	0.00	0.00
02:30	645.56	50.00	0.00	0.00	62.00	0.00	0.00
02:35	645.82	50.00	0.00	0.00	64.00	0.00	0.00
02:40	646.23	50.00	0.00	0.00	65.00	0.00	0.00
02:45	646.59	50.00	0.00	0.00	66.00	0.00	0.00
02:50	646.97	50.00	0.00	0.00	67.00	0.00	0.00
02:55	646.99	50.00	50.00	0.00	69.00	0.00	0.00
03:00	647.03	50.00	50.00	0.00	71.00	0.00	0.00
03:05	647.06	50.00	50.00	0.00	73.00	0.00	0.00
03:10	647.01	50.00	50.00	0.00	75.00	0.00	0.00
03:15	646.77	50.00	50.00	0.00	77.00	0.00	0.00
03:20	646.10	50.00	50.00	0.00	79.00	0.00	0.00
03:25	645.43	50.00	50.00	0.00	81.00	0.00	0.00
03:30	644.77	50.00	50.00	0.00	83.00	0.00	0.00
03:35	644.10	50.00	50.00	0.00	85.00	0.00	0.00
03:40	643.43	50.00	50.00	0.00	88.00	0.00	0.00
03:45	642.76	50.00	50.00	0.00	90.00	0.00	0.00
03:50	642.10	50.00	50.00	0.00	92.00	1.00	0.00
03:55	641.43	50.00	50.00	0.00	94.00	1.00	0.00
04:00	640.76	50.00	50.00	0.00	96.00	1.00	0.00
04:05	640.10	50.00	50.00	0.00	98.00	1.00	0.00
04:10	640.10	0.00	0.00	0.00	98.00	1.00	0.00
04:15	640.10	0.00	0.00	0.00	98.00	1.00	0.00
04:20	640.10	0.00	0.00	0.00	98.00	1.00	0.00
04:25	640.10	0.00	0.00	0.00	98.00	1.00	0.00
04:30	640.10	0.00	0.00	0.00	98.00	1.00	0.00
04:35	640.10	0.00	0.00	0.00	98.00	1.00	0.00

SQN9E93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=03:05

RHR1A-A

Elev. 653

Elapsed Time H:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT H2O lvl inches	Rm
04:40	0.00	5.89	1.00	1.00	0.00	0.00	0.00	0.00
04:45	0.00	5.88	1.00	1.00	0.00	0.00	0.00	0.00
04:50	0.00	5.88	1.00	1.00	0.00	0.00	0.00	0.00
04:55	0.00	5.87	1.00	1.00	0.00	0.00	0.00	0.00
05:00	0.00	5.86	1.00	1.00	0.00	0.00	0.00	0.00
05:05	0.00	5.85	1.00	1.00	0.00	0.00	0.00	0.00
05:10	0.00	5.85	1.00	1.00	0.00	0.00	0.00	0.00
05:15	0.00	5.84	1.00	1.00	0.00	0.00	0.00	0.00
05:20	0.00	5.83	1.00	1.00	0.00	0.00	0.00	0.00
05:25	0.00	5.83	1.00	1.00	0.00	0.00	0.00	0.00
05:30	0.00	5.82	1.00	1.00	0.00	0.00	0.00	0.00
05:35	0.00	5.81	1.00	1.00	0.00	0.00	0.00	0.00
05:40	0.00	5.81	1.00	1.00	0.00	0.00	0.00	0.00
05:45	0.00	5.80	1.00	1.00	0.00	0.00	0.00	0.00
05:50	0.00	5.79	1.00	1.00	0.00	0.00	0.00	0.00
05:55	0.00	5.79	1.00	1.00	0.00	0.00	0.00	0.00
06:00	0.00	5.78	1.00	1.00	0.00	0.00	0.00	0.00
06:05	0.00	5.77	1.00	1.00	0.00	0.00	0.00	0.00
06:10	0.00	5.77	1.00	1.00	0.00	0.00	0.00	0.00
06:15	0.00	5.76	1.00	1.00	0.00	0.00	0.00	0.00
06:20	0.00	5.75	1.00	1.00	0.00	0.00	0.00	0.00
06:25	0.00	5.74	1.00	1.00	0.00	0.00	0.00	0.00
06:30	0.00	5.74	1.00	1.00	0.00	0.00	0.00	0.00
06:35	0.00	5.73	1.00	1.00	0.00	0.00	0.00	0.00
06:40	0.00	5.72	1.00	1.00	0.00	0.00	0.00	0.00
06:45	0.00	5.72	1.00	1.00	0.00	0.00	0.00	0.00
06:50	0.00	5.71	1.00	1.00	0.00	0.00	0.00	0.00
06:55	0.00	5.70	1.00	1.00	0.00	0.00	0.00	0.00
07:00	0.00	5.70	1.00	1.00	0.00	0.00	0.00	0.00
07:05	0.00	5.69	1.00	1.00	0.00	0.00	0.00	0.00
07:10	0.00	5.68	1.00	1.00	0.00	0.00	0.00	0.00
07:15	0.00	5.68	1.00	1.00	0.00	0.00	0.00	0.00
07:20	0.00	5.67	1.00	1.00	0.00	0.00	0.00	0.00
07:25	0.00	5.66	1.00	1.00	0.00	0.00	0.00	0.00
07:30	0.00	5.66	1.00	1.00	0.00	0.00	0.00	0.00
07:35	0.00	5.65	1.00	1.00	0.00	0.00	0.00	0.00
07:40	0.00	5.64	1.00	1.00	0.00	0.00	0.00	0.00
07:45	0.00	5.64	1.00	1.00	0.00	0.00	0.00	0.00
07:50	0.00	5.63	1.00	1.00	0.00	0.00	0.00	0.00
07:55	0.00	5.62	1.00	1.00	0.00	0.00	0.00	0.00
08:00	0.00	5.62	1.00	1.00	0.00	0.00	0.00	0.00
08:05	0.00	5.61	1.00	1.00	0.00	0.00	0.00	0.00
08:10	0.00	5.60	1.00	1.00	0.00	0.00	0.00	0.00
08:15	0.00	5.60	1.00	1.00	0.00	0.00	0.00	0.00
08:20	0.00	5.59	1.00	1.00	0.00	0.00	0.00	0.00
08:25	0.00	5.58	1.00	1.00	0.00	0.00	0.00	0.00
08:30	0.00	5.58	1.00	1.00	0.00	0.00	0.00	0.00
08:35	0.00	5.57	1.00	1.00	0.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=03:05

Elapsed Time	AuxBldg sm.sump feet	sm.sump 1st pmp gpm	sm.sump 2nd pmp gpm	sm.sump Hi lvl 0=N;1=Y	TDT H2O volume	TDT Hi lvl 0=N;1=Y	AuxBldg pas.sump feet
04:40	640.11	0.00	0.00	0.00	98.00	1.00	0.00
04:45	640.11	0.00	0.00	0.00	98.00	1.00	0.00
04:50	640.11	0.00	0.00	0.00	98.00	1.00	0.00
04:55	640.11	0.00	0.00	0.00	98.00	1.00	0.00
05:00	640.11	0.00	0.00	0.00	98.00	1.00	0.00
05:05	640.11	0.00	0.00	0.00	98.00	1.00	0.00
05:10	640.11	0.00	0.00	0.00	98.00	1.00	0.00
05:15	640.12	0.00	0.00	0.00	98.00	1.00	0.00
05:20	640.12	0.00	0.00	0.00	98.00	1.00	0.00
05:25	640.12	0.00	0.00	0.00	98.00	1.00	0.00
05:30	640.12	0.00	0.00	0.00	98.00	1.00	0.00
05:35	640.12	0.00	0.00	0.00	98.00	1.00	0.00
05:40	640.12	0.00	0.00	0.00	98.00	1.00	0.00
05:45	640.12	0.00	0.00	0.00	98.00	1.00	0.00
05:50	640.13	0.00	0.00	0.00	98.00	1.00	0.00
05:55	640.13	0.00	0.00	0.00	98.00	1.00	0.00
06:00	640.13	0.00	0.00	0.00	98.00	1.00	0.00
06:05	640.13	0.00	0.00	0.00	98.00	1.00	0.00
06:10	640.13	0.00	0.00	0.00	98.00	1.00	0.00
06:15	640.13	0.00	0.00	0.00	98.00	1.00	0.00
06:20	640.13	0.00	0.00	0.00	98.00	1.00	0.00
06:25	640.14	0.00	0.00	0.00	98.00	1.00	0.00
06:30	640.14	0.00	0.00	0.00	98.00	1.00	0.00
06:35	640.14	0.00	0.00	0.00	98.00	1.00	0.00
06:40	640.14	0.00	0.00	0.00	98.00	1.00	0.00
06:45	640.14	0.00	0.00	0.00	98.00	1.00	0.00
06:50	640.14	0.00	0.00	0.00	98.00	1.00	0.00
06:55	640.14	0.00	0.00	0.00	98.00	1.00	0.00
07:00	640.15	0.00	0.00	0.00	98.00	1.00	0.00
07:05	640.15	0.00	0.00	0.00	98.00	1.00	0.00
07:10	640.15	0.00	0.00	0.00	98.00	1.00	0.00
07:15	640.15	0.00	0.00	0.00	98.00	1.00	0.00
07:20	640.15	0.00	0.00	0.00	98.00	1.00	0.00
07:25	640.15	0.00	0.00	0.00	98.00	1.00	0.00
07:30	640.15	0.00	0.00	0.00	98.00	1.00	0.00
07:35	640.15	0.00	0.00	0.00	98.00	1.00	0.00
07:40	640.16	0.00	0.00	0.00	98.00	1.00	0.00
07:45	640.16	0.00	0.00	0.00	98.00	1.00	0.00
07:50	640.16	0.00	0.00	0.00	98.00	1.00	0.00
07:55	640.16	0.00	0.00	0.00	98.00	1.00	0.00
08:00	640.16	0.00	0.00	0.00	98.00	1.00	0.00
08:05	640.16	0.00	0.00	0.00	98.00	1.00	0.00
08:10	640.16	0.00	0.00	0.00	98.00	1.00	0.00
08:15	640.17	0.00	0.00	0.00	98.00	1.00	0.00
08:20	640.17	0.00	0.00	0.00	98.00	1.00	0.00
08:25	640.17	0.00	0.00	0.00	98.00	1.00	0.00
08:30	640.17	0.00	0.00	0.00	98.00	1.00	0.00
08:35	640.17	0.00	0.00	0.00	98.00	1.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=03:20

RHR1A-A

Elev. 653

Elapsed Time HR:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT H2O lvl inches
00:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:50	68.02	0.00	0.00	0.00	0.00	0.00	0.00
00:55	68.02	2.22	0.00	1.00	0.00	0.00	0.00
01:00	68.02	4.43	0.00	1.00	0.00	0.00	0.00
01:05	68.02	6.64	0.00	1.00	0.00	0.00	0.00
01:10	68.02	6.74	0.00	1.00	0.00	0.00	0.00
01:15	68.02	6.82	0.00	1.00	0.00	0.00	0.00
01:20	68.02	6.89	0.00	1.00	0.00	0.00	0.00
01:25	68.02	6.95	0.00	1.00	0.00	0.00	0.00
01:30	68.02	7.00	0.00	1.00	0.00	0.00	0.00
01:35	68.02	7.04	0.00	1.00	0.00	0.00	0.00
01:40	68.02	7.07	0.00	1.00	0.00	0.00	0.00
01:45	68.02	7.10	0.00	1.00	0.00	0.00	0.00
01:50	68.02	7.13	0.00	1.00	0.00	0.00	0.00
01:55	68.02	7.15	0.00	1.00	0.00	0.00	0.00
02:00	68.02	7.16	0.00	1.00	0.00	0.00	0.00
02:05	68.02	7.18	0.00	1.00	0.00	0.00	0.00
02:10	104.34	8.38	0.00	1.00	0.00	0.00	0.00
02:15	104.34	9.40	0.00	1.00	0.00	0.00	0.00
02:20	104.34	10.28	0.00	1.00	0.00	0.00	0.00
02:25	104.34	11.04	0.00	1.00	0.00	0.00	0.00
02:30	104.34	11.71	0.00	1.00	0.00	0.00	0.00
02:35	104.34	12.29	10.59	1.00	0.05	0.00	0.00
02:40	104.34	12.29	7.81	1.00	0.02	0.00	0.00
02:45	104.34	12.29	10.12	1.00	0.03	0.00	0.00
02:50	104.34	12.29	8.26	1.00	0.02	0.00	0.00
02:55	104.34	12.29	9.79	1.00	0.03	0.00	0.00
03:00	104.34	12.29	8.55	1.00	0.02	0.00	0.00
03:05	104.34	12.29	9.57	1.00	0.03	0.00	0.00
03:10	104.34	12.29	8.74	1.00	0.02	0.00	0.00
03:15	104.34	12.29	9.43	1.00	0.03	0.00	0.00
03:20	104.34	12.29	8.87	1.00	0.02	0.00	0.00
03:25	0.00	8.89	1.00	1.00	0.00	0.00	0.00
03:30	0.00	6.44	1.00	1.00	0.00	0.00	0.00
03:35	0.00	6.00	1.00	1.00	0.00	0.00	0.00
03:40	0.00	5.99	1.00	1.00	0.00	0.00	0.00
03:45	0.00	5.99	1.00	1.00	0.00	0.00	0.00
03:50	0.00	5.98	1.00	1.00	0.00	0.00	0.00
03:55	0.00	5.97	1.00	1.00	0.00	0.00	0.00
04:00	0.00	5.97	1.00	1.00	0.00	0.00	0.00
04:05	0.00	5.96	1.00	1.00	0.00	0.00	0.00
04:10	0.00	5.95	1.00	1.00	0.00	0.00	0.00
04:15	0.00	5.94	1.00	1.00	0.00	0.00	0.00
04:20	0.00	5.94	1.00	1.00	0.00	0.00	0.00
04:25	0.00	5.93	1.00	1.00	0.00	0.00	0.00
04:30	0.00	5.92	1.00	1.00	0.00	0.00	0.00
04:35	0.00	5.92	1.00	1.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=03:20

Elapsed Time	AuxBldg	sm.sump	sm.sump	sm.sump	TDT H2O	TDT	AuxBldg	
HR:MIN		sm.sump feet	1st pmp gpm	2nd pmp gpm	Hi lvl 0=N;1=Y	volume %	Hi lvl 0=N;1=Y	pas.sump feet
00:00		640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:30		640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:45		640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:50		640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:55		640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:00		640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:05		641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:10		641.63	0.00	0.00	0.00	51.00	0.00	0.00
01:15		642.07	0.00	0.00	0.00	51.00	0.00	0.00
01:20		642.51	0.00	0.00	0.00	51.00	0.00	0.00
01:25		642.95	0.00	0.00	0.00	51.00	0.00	0.00
01:30		643.40	0.00	0.00	0.00	51.00	0.00	0.00
01:35		643.85	0.00	0.00	0.00	51.00	0.00	0.00
01:40		643.96	50.00	0.00	0.00	52.00	0.00	0.00
01:45		644.08	50.00	0.00	0.00	53.00	0.00	0.00
01:50		644.19	50.00	0.00	0.00	54.00	0.00	0.00
01:55		644.31	50.00	0.00	0.00	55.00	0.00	0.00
02:00		644.43	50.00	0.00	0.00	56.00	0.00	0.00
02:05		644.55	50.00	0.00	0.00	57.00	0.00	0.00
02:10		644.70	50.00	0.00	0.00	58.00	0.00	0.00
02:15		644.88	50.00	0.00	0.00	59.00	0.00	0.00
02:20		645.09	50.00	0.00	0.00	60.00	0.00	0.00
02:25		645.32	50.00	0.00	0.00	61.00	0.00	0.00
02:30		645.56	50.00	0.00	0.00	62.00	0.00	0.00
02:35		645.82	50.00	0.00	0.00	64.00	0.00	0.00
02:40		646.23	50.00	0.00	0.00	65.00	0.00	0.00
02:45		646.59	50.00	0.00	0.00	66.00	0.00	0.00
02:50		646.97	50.00	0.00	0.00	67.00	0.00	0.00
02:55		646.99	50.00	50.00	0.00	69.00	0.00	0.00
03:00		647.03	50.00	50.00	0.00	71.00	0.00	0.00
03:05		647.06	50.00	50.00	0.00	73.00	0.00	0.00
03:10		647.10	50.00	50.00	0.00	75.00	0.00	0.00
03:15		647.12	50.00	50.00	0.00	77.00	0.00	0.00
03:20		647.16	50.00	50.00	0.00	79.00	0.00	0.00
03:25		647.09	50.00	50.00	0.00	81.00	0.00	0.00
03:30		646.85	50.00	50.00	0.00	83.00	0.00	0.00
03:35		646.18	50.00	50.00	0.00	85.00	0.00	0.00
03:40		645.52	50.00	50.00	0.00	88.00	0.00	0.00
03:45		644.85	50.00	50.00	0.00	90.00	0.00	0.00
03:50		644.18	50.00	50.00	0.00	92.00	1.00	0.00
03:55		643.52	50.00	50.00	0.00	94.00	1.00	0.00
04:00		642.85	50.00	50.00	0.00	96.00	1.00	0.00
04:05		642.18	50.00	50.00	0.00	98.00	1.00	0.00
04:10		641.52	50.00	50.00	0.00	100.00	1.00	0.00
04:15		640.85	50.00	50.00	0.00	102.00	1.00	0.00
04:20		640.18	50.00	50.00	0.00	102.00	1.00	0.00
04:25		640.85	0.00	0.00	0.00	102.00	1.00	0.00
04:30		640.85	0.00	0.00	0.00	102.00	1.00	0.00
04:35		640.85	0.00	0.00	0.00	102.00	1.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=03:20

RHR1A-A

Elev. 3

Elapsed Time	Pipe Leakage	Main Rm H2O lvl	Door H2O lvl	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl
HR:MIN	gpm	inches	inches		inches		inches
04:40	0.00	5.91	1.00	1.00	0.00	0.00	0.00
04:45	0.00	5.90	1.00	1.00	0.00	0.00	0.00
04:50	0.00	5.90	1.00	1.00	0.00	0.00	0.00
04:55	0.00	5.89	1.00	1.00	0.00	0.00	0.00
05:00	0.00	5.88	1.00	1.00	0.00	0.00	0.00
05:05	0.00	5.88	1.00	1.00	0.00	0.00	0.00
05:10	0.00	5.87	1.00	1.00	0.00	0.00	0.00
05:15	0.00	5.86	1.00	1.00	0.00	0.00	0.00
05:20	0.00	5.85	1.00	1.00	0.00	0.00	0.00
05:25	0.00	5.85	1.00	1.00	0.00	0.00	0.00
05:30	0.00	5.84	1.00	1.00	0.00	0.00	0.00
05:35	0.00	5.83	1.00	1.00	0.00	0.00	0.00
05:40	0.00	5.83	1.00	1.00	0.00	0.00	0.00
05:45	0.00	5.82	1.00	1.00	0.00	0.00	0.00
05:50	0.00	5.81	1.00	1.00	0.00	0.00	0.00
05:55	0.00	5.81	1.00	1.00	0.00	0.00	0.00
06:00	0.00	5.80	1.00	1.00	0.00	0.00	0.00
06:05	0.00	5.79	1.00	1.00	0.00	0.00	0.00
06:10	0.00	5.79	1.00	1.00	0.00	0.00	0.00
06:15	0.00	5.78	1.00	1.00	0.00	0.00	0.00
06:20	0.00	5.77	1.00	1.00	0.00	0.00	0.00
06:25	0.00	5.77	1.00	1.00	0.00	0.00	0.00
06:30	0.00	5.76	1.00	1.00	0.00	0.00	0.00
06:35	0.00	5.75	1.00	1.00	0.00	0.00	0.00
06:40	0.00	5.74	1.00	1.00	0.00	0.00	0.00
06:45	0.00	5.74	1.00	1.00	0.00	0.00	0.00
06:50	0.00	5.73	1.00	1.00	0.00	0.00	0.00
06:55	0.00	5.72	1.00	1.00	0.00	0.00	0.00
07:00	0.00	5.72	1.00	1.00	0.00	0.00	0.00
07:05	0.00	5.71	1.00	1.00	0.00	0.00	0.00
07:10	0.00	5.70	1.00	1.00	0.00	0.00	0.00
07:15	0.00	5.70	1.00	1.00	0.00	0.00	0.00
07:20	0.00	5.69	1.00	1.00	0.00	0.00	0.00
07:25	0.00	5.68	1.00	1.00	0.00	0.00	0.00
07:30	0.00	5.68	1.00	1.00	0.00	0.00	0.00
07:35	0.00	5.67	1.00	1.00	0.00	0.00	0.00
07:40	0.00	5.66	1.00	1.00	0.00	0.00	0.00
07:45	0.00	5.66	1.00	1.00	0.00	0.00	0.00
07:50	0.00	5.65	1.00	1.00	0.00	0.00	0.00
07:55	0.00	5.64	1.00	1.00	0.00	0.00	0.00
08:00	0.00	5.64	1.00	1.00	0.00	0.00	0.00
08:05	0.00	5.63	1.00	1.00	0.00	0.00	0.00
08:10	0.00	5.62	1.00	1.00	0.00	0.00	0.00
08:15	0.00	5.62	1.00	1.00	0.00	0.00	0.00
08:20	0.00	5.61	1.00	1.00	0.00	0.00	0.00
08:25	0.00	5.60	1.00	1.00	0.00	0.00	0.00
08:30	0.00	5.60	1.00	1.00	0.00	0.00	0.00
08:35	0.00	5.59	1.00	1.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=03:20

Elapsed Time	AuxBldg	sm.sump	sm.sump	sm.sump	TDT H2O	TDT	AuxBldg
HR:MIN	feet	1st pmp	2nd pmp	Hi lvl	volume	Hi lvl	pas.sump
	gpm	gpm	0=N;1=Y	%	0=N;1=Y	feet	
04:40	640.86	0.00	0.00	0.00	102.00	1.00	0.00
04:45	640.86	0.00	0.00	0.00	102.00	1.00	0.00
04:50	640.86	0.00	0.00	0.00	102.00	1.00	0.00
04:55	640.86	0.00	0.00	0.00	102.00	1.00	0.00
05:00	640.86	0.00	0.00	0.00	102.00	1.00	0.00
05:05	640.86	0.00	0.00	0.00	102.00	1.00	0.00
05:10	640.86	0.00	0.00	0.00	102.00	1.00	0.00
05:15	640.87	0.00	0.00	0.00	102.00	1.00	0.00
05:20	640.87	0.00	0.00	0.00	102.00	1.00	0.00
05:25	640.87	0.00	0.00	0.00	102.00	1.00	0.00
05:30	640.87	0.00	0.00	0.00	102.00	1.00	0.00
05:35	640.87	0.00	0.00	0.00	102.00	1.00	0.00
05:40	640.87	0.00	0.00	0.00	102.00	1.00	0.00
05:45	640.87	0.00	0.00	0.00	102.00	1.00	0.00
05:50	640.88	0.00	0.00	0.00	102.00	1.00	0.00
05:55	640.88	0.00	0.00	0.00	102.00	1.00	0.00
06:00	640.88	0.00	0.00	0.00	102.00	1.00	0.00
06:05	640.88	0.00	0.00	0.00	102.00	1.00	0.00
06:10	640.88	0.00	0.00	0.00	102.00	1.00	0.00
06:15	640.88	0.00	0.00	0.00	102.00	1.00	0.00
06:20	640.88	0.00	0.00	0.00	102.00	1.00	0.00
06:25	640.89	0.00	0.00	0.00	102.00	1.00	0.00
06:30	640.89	0.00	0.00	0.00	102.00	1.00	0.00
06:35	640.89	0.00	0.00	0.00	102.00	1.00	0.00
06:40	640.89	0.00	0.00	0.00	102.00	1.00	0.00
06:45	640.89	0.00	0.00	0.00	102.00	1.00	0.00
06:50	640.89	0.00	0.00	0.00	102.00	1.00	0.00
06:55	640.89	0.00	0.00	0.00	102.00	1.00	0.00
07:00	640.89	0.00	0.00	0.00	102.00	1.00	0.00
07:05	640.90	0.00	0.00	0.00	102.00	1.00	0.00
07:10	640.90	0.00	0.00	0.00	102.00	1.00	0.00
07:15	640.90	0.00	0.00	0.00	102.00	1.00	0.00
07:20	640.90	0.00	0.00	0.00	102.00	1.00	0.00
07:25	640.90	0.00	0.00	0.00	102.00	1.00	0.00
07:30	640.90	0.00	0.00	0.00	102.00	1.00	0.00
07:35	640.90	0.00	0.00	0.00	102.00	1.00	0.00
07:40	640.91	0.00	0.00	0.00	102.00	1.00	0.00
07:45	640.91	0.00	0.00	0.00	102.00	1.00	0.00
07:50	640.91	0.00	0.00	0.00	102.00	1.00	0.00
07:55	640.91	0.00	0.00	0.00	102.00	1.00	0.00
08:00	640.91	0.00	0.00	0.00	102.00	1.00	0.00
08:05	640.91	0.00	0.00	0.00	102.00	1.00	0.00
08:10	640.91	0.00	0.00	0.00	102.00	1.00	0.00
08:15	640.92	0.00	0.00	0.00	102.00	1.00	0.00
08:20	640.92	0.00	0.00	0.00	102.00	1.00	0.00
08:25	640.92	0.00	0.00	0.00	102.00	1.00	0.00
08:30	640.92	0.00	0.00	0.00	102.00	1.00	0.00
08:35	640.92	0.00	0.00	0.00	102.00	1.00	0.00

A-9

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=03:35

RHR1A-A

Elev. 653

Elapsed Time HR:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
00:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:50	68.02	0.00	0.00	0.00	0.00	0.00	0.00
00:55	68.02	2.22	0.00	1.00	0.00	0.00	0.00
01:00	68.02	4.43	0.00	1.00	0.00	0.00	0.00
01:05	68.02	6.64	0.00	1.00	0.00	0.00	0.00
01:10	68.02	6.74	0.00	1.00	0.00	0.00	0.00
01:15	68.02	6.82	0.00	1.00	0.00	0.00	0.00
01:20	68.02	6.89	0.00	1.00	0.00	0.00	0.00
01:25	68.02	6.95	0.00	1.00	0.00	0.00	0.00
01:30	68.02	7.00	0.00	1.00	0.00	0.00	0.00
01:35	68.02	7.04	0.00	1.00	0.00	0.00	0.00
01:40	68.02	7.07	0.00	1.00	0.00	0.00	0.00
01:45	68.02	7.10	0.00	1.00	0.00	0.00	0.00
01:50	68.02	7.13	0.00	1.00	0.00	0.00	0.00
01:55	68.02	7.15	0.00	1.00	0.00	0.00	0.00
02:00	68.02	7.16	0.00	1.00	0.00	0.00	0.00
02:05	68.02	7.18	0.00	1.00	0.00	0.00	0.00
02:10	104.34	8.38	0.00	1.00	0.00	0.00	0.00
02:15	104.34	9.40	0.00	1.00	0.00	0.00	0.00
02:20	104.34	10.28	0.00	1.00	0.00	0.00	0.00
02:25	104.34	11.04	0.00	1.00	0.00	0.00	0.00
02:30	104.34	11.71	0.00	1.00	0.00	0.00	0.00
02:35	104.34	12.29	10.59	1.00	0.05	0.00	0.00
02:40	104.34	12.29	7.81	1.00	0.02	0.00	0.00
02:45	104.34	12.29	10.12	1.00	0.03	0.00	0.00
02:50	104.34	12.29	8.26	1.00	0.02	0.00	0.00
02:55	104.34	12.29	9.79	1.00	0.03	0.00	0.00
03:00	104.34	12.29	8.55	1.00	0.02	0.00	0.00
03:05	104.34	12.29	9.57	1.00	0.03	0.00	0.00
03:10	104.34	12.29	8.74	1.00	0.02	0.00	0.00
03:15	104.34	12.29	9.43	1.00	0.03	0.00	0.00
03:20	104.34	12.29	8.87	1.00	0.02	0.00	0.00
03:25	104.34	12.29	9.33	1.00	0.03	0.00	0.00
03:30	104.34	12.29	8.95	1.00	0.02	0.00	0.00
03:35	104.34	12.29	9.26	1.00	0.03	0.00	0.00
03:40	0.00	8.89	1.00	1.00	0.00	0.00	0.00
03:45	0.00	6.44	1.00	1.00	0.00	0.00	0.00
03:50	0.00	6.00	1.00	1.00	0.00	0.00	0.00
03:55	0.00	5.99	1.00	1.00	0.00	0.00	0.00
04:00	0.00	5.99	1.00	1.00	0.00	0.00	0.00
04:05	0.00	5.98	1.00	1.00	0.00	0.00	0.00
04:10	0.00	5.97	1.00	1.00	0.00	0.00	0.00
04:15	0.00	5.97	1.00	1.00	0.00	0.00	0.00
04:20	0.00	5.96	1.00	1.00	0.00	0.00	0.00
04:25	0.00	5.95	1.00	1.00	0.00	0.00	0.00
04:30	0.00	5.94	1.00	1.00	0.00	0.00	0.00
04:35	0.00	5.94	1.00	1.00	0.00	0.00	0.00

A-9

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=03:35									
Elapsed Time	AuxBldg	sm.sump	sm.sump	sm.sump	TDT H2O	TDT		AuxBldg	
R:MIN	feet	gpm	gpm	Hi lvl 0=N;1=Y	volume	Hi lvl 0=N;1=Y	pas.sump	feet	
00:00	640.75	0.00	0.00	0.00	51.00	0.00		0.00	
00:30	640.75	0.00	0.00	0.00	51.00	0.00		0.00	
00:45	640.75	0.00	0.00	0.00	51.00	0.00		0.00	
00:50	640.75	0.00	0.00	0.00	51.00	0.00		0.00	
00:55	640.75	0.00	0.00	0.00	51.00	0.00		0.00	
01:00	640.75	0.00	0.00	0.00	51.00	0.00		0.00	
01:05	641.19	0.00	0.00	0.00	51.00	0.00		0.00	
01:10	641.63	0.00	0.0	0.00	51.00	0.00		0.00	
01:15	642.07	0.00	0.00	0.00	51.00	0.00		0.00	
01:20	642.51	0.00	0.00	0.00	51.00	0.00		0.00	
01:25	642.95	0.00	0.00	0.00	51.00	0.00		0.00	
01:30	643.40	0.00	0.00	0.00	51.00	0.00		0.00	
01:35	643.85	0.00	0.00	0.00	51.00	0.00		0.00	
01:40	643.96	50.00	0.00	0.00	52.00	0.00		0.00	
01:45	644.08	50.00	0.00	0.00	53.00	0.00		0.00	
01:50	644.19	50.00	0.00	0.00	54.00	0.00		0.00	
01:55	644.31	50.00	0.00	0.00	55.00	0.00		0.00	
02:00	644.43	50.00	0.00	0.00	56.00	0.00		0.00	
02:05	644.55	50.00	0.00	0.00	57.00	0.00		0.00	
02:10	644.70	50.00	0.00	0.00	58.00	0.00		0.00	
02:15	644.88	50.00	0.00	0.00	59.00	0.00		0.00	
02:20	645.09	50.00	0.00	0.00	60.00	0.00		0.00	
02:25	645.32	50.00	0.00	0.00	61.00	0.00		0.00	
02:30	645.56	50.00	0.00	0.00	62.00	0.00		0.00	
02:35	645.82	50.00	0.00	0.00	64.00	0.00		0.00	
02:40	646.23	50.00	0.00	0.00	65.00	0.00		0.00	
02:45	646.59	50.00	0.00	0.00	66.00	0.00		0.00	
02:50	646.97	50.00	0.00	0.00	67.00	0.00		0.00	
02:55	646.99	50.00	50.00	0.00	69.00	0.00		0.00	
03:00	647.03	50.00	50.00	0.00	71.00	0.00		0.00	
03:05	647.06	50.00	50.00	0.00	73.00	0.00		0.00	
03:10	647.10	50.00	50.00	0.00	75.00	0.00		0.00	
03:15	647.12	50.00	50.00	0.00	77.00	0.00		0.00	
03:20	647.16	50.00	50.00	0.00	79.00	0.00		0.00	
03:25	647.18	50.00	50.00	0.00	81.00	0.00		0.00	
03:30	647.22	50.00	50.00	0.00	83.00	0.00		0.00	
03:35	647.24	50.00	50.00	0.00	85.00	0.00		0.00	
03:40	647.19	50.00	50.00	0.00	88.00	0.00		0.00	
03:45	646.95	50.00	50.00	0.00	90.00	0.00		0.00	
03:50	646.28	50.00	50.00	0.00	92.00	1.00		0.00	
03:55	645.61	50.00	50.00	0.00	94.00	1.00		0.00	
04:00	644.95	50.00	50.00	0.00	96.00	1.00		0.00	
04:05	644.28	50.00	50.00	0.00	98.00	1.00		0.00	
04:10	643.61	50.00	50.00	0.00	100.00	1.00		0.00	
04:15	642.94	50.00	50.00	0.00	102.00	1.00		0.00	
04:20	642.28	50.00	50.00	0.00	102.00	1.00		0.00	
04:25	642.28	50.00	50.00	0.00	102.00	1.00		0.00	
04:30	642.28	50.00	50.00	0.00	102.00	1.00		0.00	
04:35	642.28	50.00	50.00	0.00	102.00	1.00		0.00	

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=03:35

RHR1A-A

Elev. 653

Elapsed Time HR:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
04:40	0.00	5.93	1.00	1.00	0.00	0.00	0.00
04:45	0.00	5.92	1.00	1.00	0.00	0.00	0.00
04:50	0.00	5.92	1.00	1.00	0.00	0.00	0.00
04:55	0.00	5.91	1.00	1.00	0.00	0.00	0.00
05:00	0.00	5.90	1.00	1.00	0.00	0.00	0.00
05:05	0.00	5.90	1.00	1.00	0.00	0.00	0.00
05:10	0.00	5.89	1.00	1.00	0.00	0.00	0.00
05:15	0.00	5.88	1.00	1.00	0.00	0.00	0.00
05:20	0.00	5.88	1.00	1.00	0.00	0.00	0.00
05:25	0.00	5.87	1.00	1.00	0.00	0.00	0.00
05:30	0.00	5.86	1.00	1.00	0.00	0.00	0.00
05:35	0.00	5.85	1.00	1.00	0.00	0.00	0.00
05:40	0.00	5.85	1.00	1.00	0.00	0.00	0.00
05:45	0.00	5.84	1.00	1.00	0.00	0.00	0.00
05:50	0.00	5.83	1.00	1.00	0.00	0.00	0.00
05:55	0.00	5.83	1.00	1.00	0.00	0.00	0.00
06:00	0.00	5.82	1.00	1.00	0.00	0.00	0.00
06:05	0.00	5.81	1.00	1.00	0.00	0.00	0.00
06:10	0.00	5.81	1.00	1.00	0.00	0.00	0.00
06:15	0.00	5.80	1.00	1.00	0.00	0.00	0.00
06:20	0.00	5.79	1.00	1.00	0.00	0.00	0.00
06:25	0.00	5.79	1.00	1.00	0.00	0.00	0.00
06:30	0.00	5.78	1.00	1.00	0.00	0.00	0.00
06:35	0.00	5.77	1.00	1.00	0.00	0.00	0.00
06:40	0.00	5.77	1.00	1.00	0.00	0.00	0.00
06:45	0.00	5.76	1.00	1.00	0.00	0.00	0.00
06:50	0.00	5.75	1.00	1.00	0.00	0.00	0.00
06:55	0.00	5.74	1.00	1.00	0.00	0.00	0.00
07:00	0.00	5.74	1.00	1.00	0.00	0.00	0.00
07:05	0.00	5.73	1.00	1.00	0.00	0.00	0.00
07:10	0.00	5.72	1.00	1.00	0.00	0.00	0.00
07:15	0.00	5.72	1.00	1.00	0.00	0.00	0.00
07:20	0.00	5.71	1.00	1.00	0.00	0.00	0.00
07:25	0.00	5.70	1.00	1.00	0.00	0.00	0.00
07:30	0.00	5.70	1.00	1.00	0.00	0.00	0.00
07:35	0.00	5.69	1.00	1.00	0.00	0.00	0.00
07:40	0.00	5.68	1.00	1.00	0.00	0.00	0.00
07:45	0.00	5.68	1.00	1.00	0.00	0.00	0.00
07:50	0.00	5.67	1.00	1.00	0.00	0.00	0.00
07:55	0.00	5.66	1.00	1.00	0.00	0.00	0.00
08:00	0.00	5.66	1.00	1.00	0.00	0.00	0.00
08:05	0.00	5.65	1.00	1.00	0.00	0.00	0.00
08:10	0.00	5.64	1.00	1.00	0.00	0.00	0.00
08:15	0.00	5.64	1.00	1.00	0.00	0.00	0.00
08:20	0.00	5.63	1.00	1.00	0.00	0.00	0.00
08:25	0.00	5.62	1.00	1.00	0.00	0.00	0.00
08:30	0.00	5.62	1.00	1.00	0.00	0.00	0.00
08:35	0.00	5.61	1.00	1.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=03:35

Elapsed Time HR:MIN	AuxBldg sm.sump feet	sm.sump 1st pmp gpm	sm.sump 2nd pmp gpm	sm.sump Hi lvl O=N;1=Y	TDT H2O volume	TDT Hi lvl O=N;1=Y	AuxBldg pas.sump feet
04:40	642.28	50.00	50.00	0.00	102.00	1.00	0.00
04:45	642.28	50.00	50.00	0.00	102.00	1.00	0.00
04:50	642.29	50.00	50.00	0.00	102.00	1.00	0.00
04:55	642.29	50.00	50.00	0.00	102.00	1.00	0.00
05:00	642.29	50.00	50.00	0.00	102.00	1.00	0.00
05:05	642.29	50.00	50.00	0.00	102.00	1.00	0.00
05:10	642.29	50.00	50.00	0.00	102.00	1.00	0.00
05:15	642.29	50.00	50.00	0.00	102.00	1.00	0.00
05:20	642.29	50.00	50.00	0.00	102.00	1.00	0.00
05:25	642.30	50.00	50.00	0.00	102.00	1.00	0.00
05:30	642.30	50.00	50.00	0.00	102.00	1.00	0.00
05:35	642.30	50.00	50.00	0.00	102.00	1.00	0.00
05:40	642.30	50.00	50.00	0.00	102.00	1.00	0.00
05:45	642.30	50.00	50.00	0.00	102.00	1.00	0.00
05:50	642.30	50.00	50.00	0.00	102.00	1.00	0.00
05:55	642.30	50.00	50.00	0.00	102.00	1.00	0.00
06:00	642.31	50.00	50.00	0.00	102.00	1.00	0.00
06:05	642.31	50.00	50.00	0.00	102.00	1.00	0.00
06:10	642.31	50.00	50.00	0.00	102.00	1.00	0.00
06:15	642.31	50.00	50.00	0.00	102.00	1.00	0.00
06:20	642.31	50.00	50.00	0.00	102.00	1.00	0.00
06:25	642.31	50.00	50.00	0.00	102.00	1.00	0.00
06:30	642.31	50.00	50.00	0.00	102.00	1.00	0.00
06:35	642.32	50.00	50.00	0.00	102.00	1.00	0.00
06:40	642.32	50.00	50.00	0.00	102.00	1.00	0.00
06:45	642.32	50.00	50.00	0.00	102.00	1.00	0.00
06:50	642.32	50.00	50.00	0.00	102.00	1.00	0.00
06:55	642.32	50.00	50.00	0.00	102.00	1.00	0.00
07:00	642.32	50.00	50.00	0.00	102.00	1.00	0.00
07:05	642.32	50.00	50.00	0.00	102.00	1.00	0.00
07:10	642.33	50.00	50.00	0.00	102.00	1.00	0.00
07:15	642.33	50.00	50.00	0.00	102.00	1.00	0.00
07:20	642.33	50.00	50.00	0.00	102.00	1.00	0.00
07:25	642.33	50.00	50.00	0.00	102.00	1.00	0.00
07:30	642.33	50.00	50.00	0.00	102.00	1.00	0.00
07:35	642.33	50.00	50.00	0.00	102.00	1.00	0.00
07:40	642.33	50.00	50.00	0.00	102.00	1.00	0.00
07:45	642.33	50.00	50.00	0.00	102.00	1.00	0.00
07:50	642.34	50.00	50.00	0.00	102.00	1.00	0.00
07:55	642.34	50.00	50.00	0.00	102.00	1.00	0.00
08:00	642.34	50.00	50.00	0.00	102.00	1.00	0.00
08:05	642.34	50.00	50.00	0.00	102.00	1.00	0.00
08:10	642.34	50.00	50.00	0.00	102.00	1.00	0.00
08:15	642.34	50.00	50.00	0.00	102.00	1.00	0.00
08:20	642.34	50.00	50.00	0.00	102.00	1.00	0.00
08:25	642.35	50.00	50.00	0.00	102.00	1.00	0.00
08:30	642.35	50.00	50.00	0.00	102.00	1.00	0.00
08:35	642.35	50.00	50.00	0.00	102.00	1.00	0.00

A-10

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=04:05

RHR1A-A

Elev. 653

Elapsed Time HHR:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
00:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:50	68.02	0.00	0.00	0.00	0.00	0.00	0.00
00:55	68.02	2.22	0.00	1.00	0.00	0.00	0.00
01:00	68.02	4.43	0.00	1.00	0.00	0.00	0.00
01:05	68.02	6.64	0.00	1.00	0.00	0.00	0.00
01:10	68.02	6.74	0.00	1.00	0.00	0.00	0.00
01:15	68.02	6.82	0.00	1.00	0.00	0.00	0.00
01:20	68.02	6.89	0.00	1.00	0.00	0.00	0.00
01:25	68.02	6.95	0.00	1.00	0.00	0.00	0.00
01:30	68.02	7.00	0.00	1.00	0.00	0.00	0.00
01:35	68.02	7.04	0.00	1.00	0.00	0.00	0.00
01:40	68.02	7.07	0.00	1.00	0.00	0.00	0.00
01:45	68.02	7.10	0.00	1.00	0.00	0.00	0.00
01:50	68.02	7.13	0.00	1.00	0.00	0.00	0.00
01:55	68.02	7.15	0.00	1.00	0.00	0.00	0.00
02:00	68.02	7.16	0.00	1.00	0.00	0.00	0.00
02:05	68.02	7.18	0.00	1.00	0.00	0.00	0.00
02:10	104.34	8.38	0.00	1.00	0.00	0.00	0.00
02:15	104.34	9.40	0.00	1.00	0.00	0.00	0.00
02:20	104.34	10.28	0.00	1.00	0.00	0.00	0.00
02:25	104.34	11.04	0.00	1.00	0.00	0.00	0.00
02:30	104.34	11.71	0.00	1.00	0.00	0.00	0.00
02:35	104.34	12.29	10.59	1.00	0.05	0.00	0.00
02:40	104.34	12.29	7.81	1.00	0.02	0.00	0.00
02:45	104.34	12.29	10.12	1.00	0.03	0.00	0.00
02:50	104.34	12.29	8.26	1.00	0.02	0.00	0.00
02:55	104.34	12.29	9.79	1.00	0.03	0.00	0.00
03:00	104.34	12.29	8.55	1.00	0.02	0.00	0.00
03:05	104.34	12.29	9.57	1.00	0.03	0.00	0.00
03:10	104.34	12.29	8.74	1.00	0.02	0.00	0.00
03:15	104.34	12.29	9.43	1.00	0.03	0.00	0.00
03:20	104.34	12.29	8.87	1.00	0.02	0.00	0.00
03:25	104.34	12.29	9.33	1.00	0.03	0.00	0.00
03:30	104.34	12.29	8.95	1.00	0.02	0.00	0.00
03:35	104.34	12.29	9.26	1.00	0.03	0.00	0.00
03:40	104.34	12.29	9.01	1.00	0.02	0.00	0.00
03:45	104.34	12.29	9.22	1.00	0.03	0.00	0.00
03:50	104.34	12.29	9.05	1.00	0.02	0.00	0.00
03:55	104.34	12.29	9.19	1.00	0.03	0.00	0.00
04:00	104.34	12.29	9.07	1.00	0.02	0.00	0.00
04:05	104.34	12.29	9.17	1.00	0.03	0.00	0.00
04:10	0.00	8.89	1.00	1.00	0.00	0.00	0.00
04:15	0.00	6.44	1.00	1.00	0.00	0.00	0.00
04:20	0.00	6.00	1.00	1.00	0.00	0.00	0.00
04:25	0.00	5.99	1.00	1.00	0.00	0.00	0.00
04:30	0.00	5.99	1.00	1.00	0.00	0.00	0.00
04:35	0.00	5.98	1.00	1.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=04:05

Elapsed HR:MIN	AuxBldg Time	sm.sump feet	sm.sump 1st pmp gpm	sm.sump 2nd pmp gpm	sm.sump Hi lvl 0=N;1=Y	TDT H2O volume %	TDT Hi lvl 0=N;1=Y	AuxBldg pas.sump feet
00:00		640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:30		640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:45		640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:50		640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:55		640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:00		640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:05		641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:10		641.63	0.00	0.00	0.00	51.00	0.00	0.00
01:15		642.07	0.00	0.00	0.00	51.00	0.00	0.00
01:20		642.51	0.00	0.00	0.00	51.00	0.00	0.00
01:25		642.95	0.00	0.00	0.00	51.00	0.00	0.00
01:30		643.40	0.00	0.00	0.00	51.00	0.00	0.00
01:35		643.85	0.00	0.00	0.00	51.00	0.00	0.00
01:40		643.96	50.00	0.00	0.00	52.00	0.00	0.00
01:45		644.08	50.00	0.00	0.00	53.00	0.00	0.00
01:50		644.19	50.00	0.00	0.00	54.00	0.00	0.00
01:55		644.31	50.00	0.00	0.00	55.00	0.00	0.00
02:00		644.43	50.00	0.00	0.00	56.00	0.00	0.00
02:05		644.55	50.00	0.00	0.00	57.00	0.00	0.00
02:10		644.70	50.00	0.00	0.00	58.00	0.00	0.00
02:15		644.88	50.00	0.00	0.00	59.00	0.00	0.00
02:20		645.09	50.00	0.00	0.00	60.00	0.00	0.00
02:25		645.32	50.00	0.00	0.00	61.00	0.00	0.00
02:30		645.56	50.00	0.00	0.00	62.00	0.00	0.00
02:35		645.82	50.00	0.00	0.00	64.00	0.00	0.00
02:40		646.23	50.00	0.00	0.00	65.00	0.00	0.00
02:45		646.59	50.00	0.00	0.00	66.00	0.00	0.00
02:50		646.97	50.00	0.00	0.00	67.00	0.00	0.00
02:55		646.99	50.00	50.00	0.00	69.00	0.00	0.00
03:00		647.03	50.00	50.00	0.00	71.00	0.00	0.00
03:05		647.06	50.00	50.00	0.00	73.00	0.00	0.00
03:10		647.10	50.00	50.00	0.00	75.00	0.00	0.00
03:15		647.12	50.00	50.00	0.00	77.00	0.00	0.00
03:20		647.16	50.00	50.00	0.00	79.00	0.00	0.00
03:25		647.18	50.00	50.00	0.00	81.00	0.00	0.00
03:30		647.22	50.00	50.00	0.00	83.00	0.00	0.00
03:35		647.24	50.00	50.00	0.00	85.00	0.00	0.00
03:40		647.28	50.00	50.00	0.00	88.00	0.00	0.00
03:45		647.30	50.00	50.00	0.00	90.00	0.00	0.00
03:50		647.33	50.00	50.00	0.00	92.00	1.00	0.00
03:55		647.36	50.00	50.00	0.00	94.00	1.00	0.00
04:00		647.39	50.00	50.00	0.00	96.00	1.00	0.00
04:05		647.42	50.00	50.00	0.00	98.00	1.00	0.00
04:10		647.36	50.00	50.00	0.00	100.00	1.00	0.00
04:15		647.12	50.00	50.00	0.00	102.00	1.00	0.00
04:20		646.46	50.00	50.00	0.00	102.00	1.00	0.00
04:25		646.46	50.00	50.00	0.00	102.00	1.00	0.00
04:30		646.46	50.00	50.00	0.00	102.00	1.00	0.00
04:35		646.46	50.00	50.00	0.00	102.00	1.00	0.00

SQN9E93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=04:05

RHR1A-A

Elev. 653

Elapsed Time R:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
04:40	0.00	5.97	1.00	1.00	0.00	0.00	0.00
04:45	0.00	5.97	1.00	1.00	0.00	0.00	0.00
04:50	0.00	5.96	1.00	1.00	0.00	0.00	0.00
04:55	0.00	5.95	1.00	1.00	0.00	0.00	0.00
05:00	0.00	5.94	1.00	1.00	0.00	0.00	0.00
05:05	0.00	5.94	1.00	1.00	0.00	0.00	0.00
05:10	0.00	5.93	1.00	1.00	0.00	0.00	0.00
05:15	0.00	5.92	1.00	1.00	0.00	0.00	0.00
05:20	0.00	5.92	1.00	1.00	0.00	0.00	0.00
05:25	0.00	5.91	1.00	1.00	0.00	0.00	0.00
05:30	0.00	5.90	1.00	1.00	0.00	0.00	0.00
05:35	0.00	5.90	1.00	1.00	0.00	0.00	0.00
05:40	0.00	5.89	1.00	1.00	0.00	0.00	0.00
05:45	0.00	5.88	1.00	1.00	0.00	0.00	0.00
05:50	0.00	5.88	1.00	1.00	0.00	0.00	0.00
05:55	0.00	5.87	1.00	1.00	0.00	0.00	0.00
06:00	0.00	5.86	1.00	1.00	0.00	0.00	0.00
06:05	0.00	5.85	1.00	1.00	0.00	0.00	0.00
06:10	0.00	5.85	1.00	1.00	0.00	0.00	0.00
06:15	0.00	5.84	1.00	1.00	0.00	0.00	0.00
06:20	0.00	5.83	1.00	1.00	0.00	0.00	0.00
06:25	0.00	5.83	1.00	1.00	0.00	0.00	0.00
06:30	0.00	5.82	1.00	1.00	0.00	0.00	0.00
06:35	0.00	5.81	1.00	1.00	0.00	0.00	0.00
06:40	0.00	5.81	1.00	1.00	0.00	0.00	0.00
06:45	0.00	5.80	1.00	1.00	0.00	0.00	0.00
06:50	0.00	5.79	1.00	1.00	0.00	0.00	0.00
06:55	0.00	5.79	1.00	1.00	0.00	0.00	0.00
07:00	0.00	5.78	1.00	1.00	0.00	0.00	0.00
07:05	0.00	5.77	1.00	1.00	0.00	0.00	0.00
07:10	0.00	5.77	1.00	1.00	0.00	0.00	0.00
07:15	0.00	5.76	1.00	1.00	0.00	0.00	0.00
07:20	0.00	5.75	1.00	1.00	0.00	0.00	0.00
07:25	0.00	5.74	1.00	1.00	0.00	0.00	0.00
07:30	0.00	5.74	1.00	1.00	0.00	0.00	0.00
07:35	0.00	5.73	1.00	1.00	0.00	0.00	0.00
07:40	0.00	5.72	1.00	1.00	0.00	0.00	0.00
07:45	0.00	5.72	1.00	1.00	0.00	0.00	0.00
07:50	0.00	5.71	1.00	1.00	0.00	0.00	0.00
07:55	0.00	5.70	1.00	1.00	0.00	0.00	0.00
08:00	0.00	5.70	1.00	1.00	0.00	0.00	0.00
08:05	0.00	5.69	1.00	1.00	0.00	0.00	0.00
08:10	0.00	5.68	1.00	1.00	0.00	0.00	0.00
08:15	0.00	5.68	1.00	1.00	0.00	0.00	0.00
08:20	0.00	5.67	1.00	1.00	0.00	0.00	0.00
08:25	0.00	5.66	1.00	1.00	0.00	0.00	0.00
08:30	0.00	5.66	1.00	1.00	0.00	0.00	0.00
08:35	0.00	5.65	1.00	1.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=04:05

Elapsed Time	AuxBldg	sm.sump	sm.sump	sm.sump	TDT	H2O	TDT	AuxBldg
HR:MIN		sm.sump	1st pmp	2nd pmp	Hi lvl	volume	Hi lvl	pas.sump
	feet	gpm	gpm	0=N;1=Y	%	0=N;1=Y	feet	
04:40	646.46	50.00	50.00	0.00	102.00	1.00	0.00	
04:45	646.46	50.00	50.00	0.00	102.00	1.00	0.00	
04:50	646.47	50.00	50.00	0.00	102.00	1.00	0.00	
04:55	646.47	50.00	50.00	0.00	102.00	1.00	0.00	
05:00	646.47	50.00	50.00	0.00	102.00	1.00	0.00	
05:05	646.47	50.00	50.00	0.00	102.00	1.00	0.00	
05:10	646.47	50.00	50.00	0.00	102.00	1.00	0.00	
05:15	646.47	50.00	50.00	0.00	102.00	1.00	0.00	
05:20	646.47	50.00	50.00	0.00	102.00	1.00	0.00	
05:25	646.48	50.00	50.00	0.00	102.00	1.00	0.00	
05:30	646.48	50.00	50.00	0.00	102.00	1.00	0.00	
05:35	646.48	50.00	50.00	0.00	102.00	1.00	0.00	
05:40	646.48	50.00	50.00	0.00	102.00	1.00	0.00	
05:45	646.48	50.00	50.00	0.00	102.00	1.00	0.00	
05:50	646.48	50.00	50.00	0.00	102.00	1.00	0.00	
05:55	646.48	50.00	50.00	0.00	102.00	1.00	0.00	
06:00	646.49	50.00	50.00	0.00	102.00	1.00	0.00	
06:05	646.49	50.00	50.00	0.00	102.00	1.00	0.00	
06:10	646.49	50.00	50.00	0.00	102.00	1.00	0.00	
06:15	646.49	50.00	50.00	0.00	102.00	1.00	0.00	
06:20	646.49	50.00	50.00	0.00	102.00	1.00	0.00	
06:25	646.49	50.00	50.00	0.00	102.00	1.00	0.00	
06:30	646.49	50.00	50.00	0.00	102.00	1.00	0.00	
06:35	646.50	50.00	50.00	0.00	102.00	1.00	0.00	
06:40	646.50	50.00	50.00	0.00	102.00	1.00	0.00	
06:45	646.50	50.00	50.00	0.00	102.00	1.00	0.00	
06:50	646.50	50.00	50.00	0.00	102.00	1.00	0.00	
06:55	646.50	50.00	50.00	0.00	102.00	1.00	0.00	
07:00	646.50	50.00	50.00	0.00	102.00	1.00	0.00	
07:05	646.50	50.00	50.00	0.00	102.00	1.00	0.00	
07:10	646.51	50.00	50.00	0.00	102.00	1.00	0.00	
07:15	646.51	50.00	50.00	0.00	102.00	1.00	0.00	
07:20	646.51	50.00	50.00	0.00	102.00	1.00	0.00	
07:25	646.51	50.00	50.00	0.00	102.00	1.00	0.00	
07:30	646.51	50.00	50.00	0.00	102.00	1.00	0.00	
07:35	646.51	50.00	50.00	0.00	102.00	1.00	0.00	
07:40	646.51	50.00	50.00	0.00	102.00	1.00	0.00	
07:45	646.52	50.00	50.00	0.00	102.00	1.00	0.00	
07:50	646.52	50.00	50.00	0.00	102.00	1.00	0.00	
07:55	646.52	50.00	50.00	0.00	102.00	1.00	0.00	
08:00	646.52	50.00	50.00	0.00	102.00	1.00	0.00	
08:05	646.52	50.00	50.00	0.00	102.00	1.00	0.00	
08:10	646.52	50.00	50.00	0.00	102.00	1.00	0.00	
08:15	646.52	50.00	50.00	0.00	102.00	1.00	0.00	
08:20	646.53	50.00	50.00	0.00	102.00	1.00	0.00	
08:25	646.53	50.00	50.00	0.00	102.00	1.00	0.00	
08:30	646.53	50.00	50.00	0.00	102.00	1.00	0.00	
08:35	646.53	50.00	50.00	0.00	102.00	1.00	0.00	

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=04:35

RHR1A-A

Elev. 653

Elapsed Time HR:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
00:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:50	68.02	0.00	0.00	0.00	0.00	0.00	0.00
00:55	68.02	2.22	0.00	1.00	0.00	0.00	0.00
01:00	68.02	4.43	0.00	1.00	0.00	0.00	0.00
01:05	68.02	6.64	0.00	1.00	0.00	0.00	0.00
01:10	68.02	6.74	0.00	1.00	0.00	0.00	0.00
01:15	68.02	6.82	0.00	1.00	0.00	0.00	0.00
01:20	68.02	6.89	0.00	1.00	0.00	0.00	0.00
01:25	68.02	6.95	0.00	1.00	0.07	0.00	0.00
01:30	68.02	7.00	0.00	1.00	0.00	0.00	0.00
01:35	68.02	7.04	0.00	1.00	0.00	0.00	0.00
01:40	68.02	7.07	0.00	1.00	0.00	0.00	0.00
01:45	68.02	7.10	0.00	1.00	0.00	0.00	0.00
01:50	68.02	7.13	0.00	1.00	0.00	0.00	0.00
01:55	68.02	7.15	0.00	1.00	0.00	0.00	0.00
02:00	68.02	7.16	0.00	1.00	0.00	0.00	0.00
02:05	68.02	7.18	0.00	1.00	0.00	0.00	0.00
02:10	104.34	8.38	0.00	1.00	0.00	0.00	0.00
02:15	104.34	9.40	0.00	1.00	0.00	0.00	0.00
02:20	104.34	10.28	0.00	1.00	0.00	0.00	0.00
02:25	104.34	11.04	0.00	1.00	0.00	0.00	0.00
02:30	104.34	11.71	0.00	1.00	0.00	0.00	0.00
02:35	104.34	12.29	10.59	1.00	0.05	0.00	0.00
02:40	104.34	12.29	7.81	1.00	0.02	0.00	0.00
02:45	104.34	12.29	10.12	1.00	0.03	0.00	0.00
02:50	104.34	12.29	8.26	1.00	0.02	0.00	0.00
02:55	104.34	12.29	9.79	1.00	0.03	0.00	0.00
03:00	104.34	12.29	8.55	1.00	0.02	0.00	0.00
03:05	104.34	12.29	9.57	1.00	0.03	0.00	0.00
03:10	104.34	12.29	8.74	1.00	0.02	0.00	0.00
03:15	104.34	12.29	9.43	1.00	0.03	0.00	0.00
03:20	104.34	12.29	8.87	1.00	0.02	0.00	0.00
03:25	104.34	12.29	9.33	1.00	0.03	0.00	0.00
03:30	104.34	12.29	8.95	1.00	0.02	0.00	0.00
03:35	104.34	12.29	9.26	1.00	0.03	0.00	0.00
03:40	104.34	12.29	9.01	1.00	0.02	0.00	0.00
03:45	104.34	12.29	9.22	1.00	0.03	0.00	0.00
03:50	104.34	12.29	9.05	1.00	0.02	0.00	0.00
03:55	104.34	12.29	9.19	1.00	0.03	0.00	0.00
04:00	104.34	12.29	9.07	1.00	0.02	0.00	0.00
04:05	104.34	12.29	9.17	1.00	0.03	0.00	0.00
04:10	104.34	12.29	9.09	1.00	0.02	0.00	0.00
04:15	104.34	12.29	9.15	1.00	0.02	0.00	0.00
04:20	104.34	12.29	9.10	1.00	0.02	0.00	0.00
04:25	104.34	12.29	9.14	1.00	0.02	0.00	0.00
04:30	104.34	12.29	9.11	1.00	0.02	0.00	0.00
04:35	104.34	12.29	9.14	1.00	0.02	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=04:35

Elapsed Time	AuxBldg HR:MIN	sm.sump feet	sm.sump 1st pmp gpm	sm.sump 2nd pmp gpm	sm.sump Hi lvl 0=N;1=Y	TDT H2O volume %	TDT Hi lvl 0=N;1=Y	AuxBldg pas.sump feet
00:00	00:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:30	00:30	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:45	00:45	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:50	00:50	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:55	00:55	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:00	01:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:05	01:05	641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:10	01:10	641.63	0.00	0.00	0.00	51.00	0.00	0.00
01:15	01:15	642.07	0.00	0.00	0.00	51.00	0.00	0.00
01:20	01:20	642.51	0.00	0.00	0.00	51.00	0.00	0.00
01:25	01:25	642.95	0.00	0.00	0.00	51.00	0.00	0.00
01:30	01:30	643.40	0.00	0.00	0.00	51.00	0.00	0.00
01:35	01:35	643.85	0.00	0.00	0.00	51.00	0.00	0.00
01:40	01:40	643.96	50.00	0.00	0.00	52.00	0.00	0.00
01:45	01:45	644.08	50.00	0.00	0.00	53.00	0.00	0.00
01:50	01:50	644.19	50.00	0.00	0.00	54.00	0.00	0.00
01:55	01:55	644.31	50.00	0.00	0.00	55.00	0.00	0.00
02:00	02:00	644.43	50.00	0.00	0.00	56.00	0.00	0.00
02:05	02:05	644.55	50.00	0.00	0.00	57.00	0.00	0.00
02:10	02:10	644.70	50.00	0.00	0.00	58.00	0.00	0.00
02:15	02:15	644.88	50.00	0.00	0.00	59.00	0.00	0.00
02:20	02:20	645.09	50.00	0.00	0.00	60.00	0.00	0.00
02:25	02:25	645.32	50.00	0.00	0.00	61.00	0.00	0.00
02:30	02:30	645.56	50.00	0.00	0.00	62.00	0.00	0.00
02:35	02:35	645.82	50.00	0.00	0.00	64.00	0.00	0.00
02:40	02:40	646.23	50.00	0.00	0.00	65.00	0.00	0.00
02:45	02:45	646.59	50.00	0.00	0.00	66.00	0.00	0.00
02:50	02:50	646.97	50.00	0.00	0.00	67.00	0.00	0.00
02:55	02:55	646.99	50.00	50.00	0.00	69.00	0.00	0.00
03:00	03:00	647.03	50.00	50.00	0.00	71.00	0.00	0.00
03:05	03:05	647.06	50.00	50.00	0.00	73.00	0.00	0.00
03:10	03:10	647.10	50.00	50.00	0.00	75.00	0.00	0.00
03:15	03:15	647.12	50.00	50.00	0.00	77.00	0.00	0.00
03:20	03:20	647.16	50.00	50.00	0.00	79.00	0.00	0.00
03:25	03:25	647.18	50.00	50.00	0.00	81.00	0.00	0.00
03:30	03:30	647.22	50.00	50.00	0.00	83.00	0.00	0.00
03:35	03:35	647.24	50.00	50.00	0.00	85.00	0.00	0.00
03:40	03:40	647.28	50.00	50.00	0.00	88.00	0.00	0.00
03:45	03:45	647.30	50.00	50.00	0.00	90.00	0.00	0.00
03:50	03:50	647.33	50.00	50.00	0.00	92.00	1.00	0.00
03:55	03:55	647.36	50.00	50.00	0.00	94.00	1.00	0.00
04:00	04:00	647.39	50.00	50.00	0.00	96.00	1.00	0.00
04:05	04:05	647.42	50.00	50.00	0.00	98.00	1.00	0.00
04:10	04:10	647.45	50.00	50.00	0.00	100.00	1.00	0.00
04:15	04:15	647.48	50.00	50.00	0.00	102.00	1.00	0.00
04:20	04:20	647.51	50.00	50.00	0.00	102.00	1.00	0.00
04:25	04:25	648.21	50.00	50.00	0.00	102.00	1.00	0.00
04:30	04:30	648.91	50.00	50.00	0.00	102.00	1.00	0.00
04:35	04:35	649.61	50.00	50.00	1.00	102.00	1.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=04:35

RHR1A-A

Elev. 653

Elapsed Time	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
04:40	0.00	8.89	1.00	1.00	0.00	0.00	0.00
04:45	0.00	6.44	1.00	1.00	0.00	0.00	0.00
04:50	0.00	6.00	1.00	1.00	0.00	0.00	0.00
04:55	0.00	5.99	1.00	1.00	0.00	0.00	0.00
05:00	0.00	5.99	1.00	1.00	0.00	0.00	0.00
05:05	0.00	5.98	1.00	1.00	0.00	0.00	0.00
05:10	0.00	5.97	1.00	1.00	0.00	0.00	0.00
05:15	0.00	5.97	1.00	1.00	0.00	0.00	0.00
05:20	0.00	5.96	1.00	1.00	0.00	0.00	0.00
05:25	0.00	5.95	1.00	1.00	0.00	0.00	0.00
05:30	0.00	5.94	1.00	1.00	0.00	0.00	0.00
05:35	0.00	5.94	1.00	1.00	0.00	0.00	0.00
05:40	0.00	5.93	1.00	1.00	0.00	0.00	0.00
05:45	0.00	5.92	1.00	1.00	0.00	0.00	0.00
05:50	0.00	5.92	1.00	1.00	0.00	0.00	0.00
05:55	0.00	5.91	1.00	1.00	0.00	0.00	0.00
06:00	0.00	5.90	1.00	1.00	0.00	0.00	0.00
06:05	0.00	5.90	1.00	1.00	0.00	0.00	0.00
06:10	0.00	5.89	1.00	1.00	0.00	0.00	0.00
06:15	0.00	5.88	1.00	1.00	0.00	0.00	0.00
06:20	0.00	5.88	1.00	1.00	0.00	0.00	0.00
06:25	0.00	5.87	1.00	1.00	0.00	0.00	0.00
06:30	0.00	5.86	1.00	1.00	0.00	0.00	0.00
06:35	0.00	5.85	1.00	1.00	0.00	0.00	0.00
06:40	0.00	5.85	1.00	1.00	0.00	0.00	0.00
06:45	0.00	5.84	1.00	1.00	0.00	0.00	0.00
06:50	0.00	5.83	1.00	1.00	0.00	0.00	0.00
06:55	0.00	5.83	1.00	1.00	0.00	0.00	0.00
07:00	0.00	5.82	1.00	1.00	0.00	0.00	0.00
07:05	0.00	5.81	1.00	1.00	0.00	0.00	0.00
07:10	0.00	5.81	1.00	1.00	0.00	0.00	0.00
07:15	0.00	5.80	1.00	1.00	0.00	0.00	0.00
07:20	0.00	5.79	1.00	1.00	0.00	0.00	0.00
07:25	0.00	5.79	1.00	1.00	0.00	0.00	0.00
07:30	0.00	5.78	1.00	1.00	0.00	0.00	0.00
07:35	0.00	5.77	1.00	1.00	0.00	0.00	0.00
07:40	0.00	5.77	1.00	1.00	0.00	0.00	0.00
07:45	0.00	5.76	1.00	1.00	0.00	0.00	0.00
07:50	0.00	5.75	1.00	1.00	0.00	0.00	0.00
07:55	0.00	5.74	1.00	1.00	0.00	0.00	0.00
08:00	0.00	5.74	1.00	1.00	0.00	0.00	0.00
08:05	0.00	5.73	1.00	1.00	0.00	0.00	0.00
08:10	0.00	5.72	1.00	1.00	0.00	0.00	0.00
08:15	0.00	5.72	1.00	1.00	0.00	0.00	0.00
08:20	0.00	5.71	1.00	1.00	0.00	0.00	0.00
08:25	0.00	5.70	1.00	1.00	0.00	0.00	0.00
08:30	0.00	5.70	1.00	1.00	0.00	0.00	0.00
08:35	0.00	5.69	1.00	1.00	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=04:35

Elapsed Time	AuxBldg	sm.sump	sm.sump	sm.sump	TDT	H2O	TDT	AuxBldg
HR:MIN	sm.sump	1st pmp	2nd pmp	Hi lvl	volume	Hi lvl	pas.sump	feet
	feet	gpm	gpm	O=N;1=Y	%	O=N;1=Y		
04:40	650.22	50.00	50.00	1.00	102.00	1.00	0.00	
04:45	650.64	50.00	50.00	1.00	102.00	1.00	0.00	
04:50	650.64	50.00	50.00	1.00	102.00	1.00	0.00	
04:55	650.65	50.00	50.00	1.00	102.00	1.00	0.00	
05:00	650.65	50.00	50.00	1.00	102.00	1.00	0.00	
05:05	650.65	50.00	50.00	1.00	102.00	1.00	0.00	
05:10	650.65	50.00	50.00	1.00	102.00	1.00	0.00	
05:15	650.65	50.00	50.00	1.00	102.00	1.00	0.00	
05:20	650.65	50.00	50.00	1.00	102.00	1.00	0.00	
05:25	650.65	50.00	50.00	1.00	102.00	1.00	0.00	
05:30	650.66	50.00	50.00	1.00	102.00	1.00	0.00	
05:35	650.66	50.00	50.00	1.00	102.00	1.00	0.00	
05:40	650.66	50.00	50.00	1.00	102.00	1.00	0.00	
05:45	650.66	50.00	50.00	1.00	102.00	1.00	0.00	
05:50	650.66	50.00	50.00	1.00	102.00	1.00	0.00	
05:55	650.66	50.00	50.00	1.00	102.00	1.00	0.00	
06:00	650.66	50.00	50.00	1.00	102.00	1.00	0.00	
06:05	650.67	50.00	50.00	1.00	102.00	1.00	0.00	
06:10	650.67	50.00	50.00	1.00	102.00	1.00	0.00	
06:15	650.67	50.00	50.00	1.00	102.00	1.00	0.00	
06:20	650.67	50.00	50.00	1.00	102.00	1.00	0.00	
06:25	650.67	50.00	50.00	1.00	102.00	1.00	0.00	
06:30	650.67	50.00	50.00	1.00	102.00	1.00	0.00	
06:35	650.67	50.00	50.00	1.00	102.00	1.00	0.00	
06:40	650.68	50.00	50.00	1.00	102.00	1.00	0.00	
06:45	650.68	50.00	50.00	1.00	102.00	1.00	0.00	
06:50	650.68	50.00	50.00	1.00	102.00	1.00	0.00	
06:55	650.68	50.00	50.00	1.00	102.00	1.00	0.00	
07:00	650.68	50.00	50.00	1.00	102.00	1.00	0.00	
07:05	650.68	50.00	50.00	1.00	102.00	1.00	0.00	
07:10	650.68	50.00	50.00	1.00	102.00	1.00	0.00	
07:15	650.69	50.00	50.00	1.00	102.00	1.00	0.00	
07:20	650.69	50.00	50.00	1.00	102.00	1.00	0.00	
07:25	650.69	50.00	50.00	1.00	102.00	1.00	0.00	
07:30	650.69	50.00	50.00	1.00	102.00	1.00	0.00	
07:35	650.69	50.00	50.00	1.00	102.00	1.00	0.00	
07:40	650.69	50.00	50.00	1.00	102.00	1.00	0.00	
07:45	650.69	50.00	50.00	1.00	102.00	1.00	0.00	
07:50	650.70	50.00	50.00	1.00	102.00	1.00	0.00	
07:55	650.70	50.00	50.00	1.00	102.00	1.00	0.00	
08:00	650.70	50.00	50.00	1.00	102.00	1.00	0.00	
08:05	650.70	50.00	50.00	1.00	102.00	1.00	0.00	
08:10	650.70	50.00	50.00	1.00	102.00	1.00	0.00	
08:15	650.70	50.00	50.00	1.00	102.00	1.00	0.00	
08:20	650.70	50.00	50.00	1.00	102.00	1.00	0.00	
08:25	650.71	50.00	50.00	1.00	102.00	1.00	0.00	
08:30	650.71	50.00	50.00	1.00	102.00	1.00	0.00	
08:35	650.71	50.00	50.00	1.00	102.00	1.00	0.00	

A-12

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=05:05

RHR1A-A

Elev. 653

Elapsed Time HR:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
00:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:50	68.02	0.00	0.00	0.00	0.00	0.00	0.00
00:55	68.02	2.22	0.00	1.00	0.00	0.00	0.00
01:00	68.02	4.43	0.00	1.00	0.00	0.00	0.00
01:05	68.02	6.64	0.00	1.00	0.00	0.00	0.00
01:10	68.02	6.74	0.00	1.00	0.00	0.00	0.00
01:15	68.02	6.82	0.00	1.00	0.00	0.00	0.00
01:20	68.02	6.89	0.00	1.00	0.00	0.00	0.00
01:25	68.02	6.95	0.00	1.00	0.00	0.00	0.00
01:30	68.02	7.00	0.00	1.00	0.00	0.00	0.00
01:35	68.02	7.04	0.00	1.00	0.00	0.00	0.00
01:40	68.02	7.07	0.00	1.00	0.00	0.00	0.00
01:45	68.02	7.10	0.00	1.00	0.00	0.00	0.00
01:50	68.02	7.13	0.00	1.00	0.00	0.00	0.00
01:55	68.02	7.15	0.00	1.00	0.00	0.00	0.00
02:00	68.02	7.16	0.00	1.00	0.00	0.00	0.00
02:05	68.02	7.18	0.00	1.00	0.00	0.00	0.00
02:10	104.34	8.38	0.00	1.00	0.00	0.00	0.00
02:15	104.34	9.40	0.00	1.00	0.00	0.00	0.00
02:20	104.34	10.28	0.00	1.00	0.00	0.00	0.00
02:25	104.34	11.04	0.00	1.00	0.00	0.00	0.00
02:30	104.34	11.71	0.00	1.00	0.00	0.00	0.00
02:35	104.34	12.29	10.59	1.00	0.05	0.00	0.00
02:40	104.34	12.29	7.81	1.00	0.02	0.00	0.00
02:45	104.34	12.29	10.12	1.00	0.03	0.00	0.00
02:50	104.34	12.29	8.26	1.00	0.02	0.00	0.00
02:55	104.34	12.29	9.79	1.00	0.03	0.00	0.00
03:00	104.34	12.29	8.55	1.00	0.02	0.00	0.00
03:05	104.34	12.29	9.57	1.00	0.03	0.00	0.00
03:10	104.34	12.29	8.74	1.00	0.02	0.00	0.00
03:15	104.34	12.29	9.43	1.00	0.03	0.00	0.00
03:20	104.34	12.29	8.87	1.00	0.02	0.00	0.00
03:25	104.34	12.29	9.33	1.00	0.03	0.00	0.00
03:30	104.34	12.29	8.95	1.00	0.02	0.00	0.00
03:35	104.34	12.29	9.26	1.00	0.03	0.00	0.00
03:40	104.34	12.29	9.01	1.00	0.02	0.00	0.00
03:45	104.34	12.29	9.22	1.00	0.03	0.00	0.00
03:50	104.34	12.29	9.05	1.00	0.02	0.00	0.00
03:55	104.34	12.29	9.19	1.00	0.03	0.00	0.00
04:00	104.34	12.29	9.07	1.00	0.02	0.00	0.00
04:05	104.34	12.29	9.17	1.00	0.03	0.00	0.00
04:10	104.34	12.29	9.09	1.00	0.02	0.00	0.00
04:15	104.34	12.29	9.15	1.00	0.02	0.00	0.00
04:20	104.34	12.29	9.10	1.00	0.02	0.00	0.00
04:25	104.34	12.29	9.14	1.00	0.02	0.00	0.00
04:30	104.34	12.29	9.11	1.00	0.02	0.00	0.00
04:35	104.34	12.29	9.14	1.00	0.02	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=05:05

Elapsed Time	AuxBldg	sm.sump	sm.sump	sm.sump	TDT H2O	TDT	AuxBldg
HR:MIN	feet	1st pmp	2nd pmp	Hi lvl 0=N;1=Y	volume	Hi lvl 0=N;1=Y	pas.sump feet
	gpm	gpm		%			
00:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:30	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:45	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:50	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:55	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:05	641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:10	641.63	0.00	0.00	0.00	51.00	0.00	0.00
01:15	642.07	0.00	0.00	0.00	51.00	0.00	0.00
01:20	642.51	0.00	0.00	0.00	51.00	0.00	0.00
01:25	642.95	0.00	0.00	0.00	51.00	0.00	0.00
01:30	643.40	0.00	0.00	0.00	51.00	0.00	0.00
01:35	643.85	0.00	0.00	0.00	51.00	0.00	0.00
01:40	643.96	50.00	0.00	0.00	52.00	0.00	0.00
01:45	644.08	50.00	0.00	0.00	53.00	0.00	0.00
01:50	644.19	50.00	0.00	0.00	54.00	0.00	0.00
01:55	644.31	50.00	0.00	0.00	55.00	0.00	0.00
02:00	644.43	50.00	0.00	0.00	56.00	0.00	0.00
02:05	644.55	50.00	0.00	0.00	57.00	0.00	0.00
02:10	644.70	50.00	0.00	0.00	58.00	0.00	0.00
02:15	644.88	50.00	0.00	0.00	59.00	0.00	0.00
02:20	645.09	50.00	0.00	0.00	60.00	0.00	0.00
02:25	645.32	50.00	0.00	0.00	61.00	0.00	0.00
02:30	645.56	50.00	0.00	0.00	62.00	0.00	0.00
02:35	645.82	50.00	0.00	0.00	64.00	0.00	0.00
02:40	646.23	50.00	0.00	0.00	65.00	0.00	0.00
02:45	646.59	50.00	0.00	0.00	66.00	0.00	0.00
02:50	646.97	50.00	0.00	0.00	67.00	0.00	0.00
02:55	646.99	50.00	50.00	0.00	69.00	0.00	0.00
03:00	647.03	50.00	50.00	0.00	71.00	0.00	0.00
03:05	647.06	50.00	50.00	0.00	73.00	0.00	0.00
03:10	647.10	50.00	50.00	0.00	75.00	0.00	0.00
03:15	647.12	50.00	50.00	0.00	77.00	0.00	0.00
03:20	647.16	50.00	50.00	0.00	79.00	0.00	0.00
03:25	647.18	50.00	50.00	0.00	81.00	0.00	0.00
03:30	647.22	50.00	50.00	0.00	83.00	0.00	0.00
03:35	647.24	50.00	50.00	0.00	85.00	0.00	0.00
03:40	647.28	50.00	50.00	0.00	88.00	0.00	0.00
03:45	647.30	50.00	50.00	0.00	90.00	0.00	0.00
03:50	647.33	50.00	50.00	0.00	92.00	1.00	0.00
03:55	647.36	50.00	50.00	0.00	94.00	1.00	0.00
04:00	647.39	50.00	50.00	0.00	96.00	1.00	0.00
04:05	647.42	50.00	50.00	0.00	98.00	1.00	0.00
04:10	647.45	50.00	50.00	0.00	100.00	1.00	0.00
04:15	647.48	50.00	50.00	0.00	102.00	1.00	0.00
04:20	647.51	50.00	50.00	0.00	102.00	1.00	0.00
04:25	648.21	50.00	50.00	0.00	102.00	1.00	0.00
04:30	648.91	50.00	50.00	0.00	102.00	1.00	0.00
04:35	649.61	50.00	50.00	1.00	102.00	1.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=05:05

Elapsed Time	AuxBldg	sm.sump	sm.sump	sm.sump	TDT H2O	TDT	AuxBldg
HR:MIN	feet	1st pmp	2nd pmp	Hi lvl 0=N;1=Y	volume	Hi lvl 0=N;1=Y	pas.sump feet
	gpm	gpm		%			
04:40	650.30	50.00	50.00	1.00	102.00	1.00	0.00
04:45	651.00	50.00	50.00	1.00	102.00	1.00	0.00
04:50	651.68	50.00	50.00	1.00	102.00	1.00	0.00
04:55	651.90	50.00	50.00	1.00	102.00	1.00	0.00
05:00	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:05	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:10	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:15	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:20	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:25	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:30	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:35	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:40	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:45	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:50	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:55	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:00	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:05	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:10	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:15	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:20	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:25	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:30	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:35	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:40	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:45	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:50	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:55	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:00	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:05	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:10	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:15	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:20	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:25	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:30	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:35	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:40	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:45	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:50	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:55	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:00	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:05	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:10	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:15	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:20	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:25	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:30	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:35	652.00	50.00	50.00	1.00	102.00	1.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=05:05

RHR1A-A

Elev. 653

Elapsed Time HR:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
04:40	104.34	12.29	9.11	1.00	0.02	0.00	0.00
04:45	104.34	12.29	9.13	1.00	0.02	0.00	0.00
04:50	104.34	12.29	9.12	1.00	0.02	0.00	0.00
04:55	104.34	12.29	9.13	1.00	0.02	0.00	0.00
05:00	104.34	12.29	9.12	1.00	0.30	0.00	0.14
05:05	104.34	12.29	9.13	1.00	0.51	0.00	0.33
05:10	0.00	8.89	1.00	1.00	0.61	0.00	0.47
05:15	0.00	6.44	1.00	1.00	0.71	0.00	0.60
05:20	0.00	6.00	1.00	1.00	0.65	0.00	0.60
05:25	0.00	5.99	1.00	1.00	0.64	0.00	0.61
05:30	0.00	5.99	1.00	1.00	0.64	0.00	0.61
05:35	0.00	5.98	1.00	1.00	0.64	0.00	0.61
05:40	0.00	5.97	1.00	1.00	0.64	0.00	0.61
05:45	0.00	5.97	1.00	1.00	0.65	0.00	0.61
05:50	0.00	5.96	1.00	1.00	0.65	0.00	0.61
05:55	0.00	5.95	1.00	1.00	0.65	0.00	0.61
06:00	0.00	5.94	1.00	1.00	0.65	0.00	0.61
06:05	0.00	5.94	1.00	1.00	0.65	0.00	0.61
06:10	0.00	5.93	1.00	1.00	0.65	0.00	0.61
06:15	0.00	5.92	1.00	1.00	0.65	0.00	0.61
06:20	0.00	5.92	1.00	1.00	0.65	0.00	0.61
06:25	0.00	5.91	1.00	1.00	0.65	0.00	0.61
06:30	0.00	5.90	1.00	1.00	0.65	0.00	0.61
06:35	0.00	5.90	1.00	1.00	0.65	0.00	0.61
06:40	0.00	5.89	1.00	1.00	0.65	0.00	0.61
06:45	0.00	5.88	1.00	1.00	0.65	0.00	0.61
06:50	0.00	5.88	1.00	1.00	0.65	0.00	0.61
06:55	0.00	5.87	1.00	1.00	0.65	0.00	0.61
07:00	0.00	5.86	1.00	1.00	0.65	0.00	0.61
07:05	0.00	5.85	1.00	1.00	0.65	0.00	0.61
07:10	0.00	5.85	1.00	1.00	0.65	0.00	0.61
07:15	0.00	5.84	1.00	1.00	0.65	0.00	0.61
07:20	0.00	5.83	1.00	1.00	0.65	0.00	0.62
07:25	0.00	5.83	1.00	1.00	0.65	0.00	0.62
07:30	0.00	5.82	1.00	1.00	0.65	0.00	0.62
07:35	0.00	5.81	1.00	1.00	0.65	0.00	0.62
07:40	0.00	5.81	1.00	1.00	0.65	0.00	0.62
07:45	0.00	5.80	1.00	1.00	0.65	0.00	0.62
07:50	0.00	5.79	1.00	1.00	0.65	0.00	0.62
07:55	0.00	5.79	1.00	1.00	0.65	0.00	0.62
08:00	0.00	5.78	1.00	1.00	0.65	0.00	0.62
08:05	0.00	5.77	1.00	1.00	0.66	0.00	0.62
08:10	0.00	5.77	1.00	1.00	0.66	0.00	0.62
08:15	0.00	5.76	1.00	1.00	0.66	0.00	0.62
08:20	0.00	5.75	1.00	1.00	0.66	0.00	0.62
08:25	0.00	5.74	1.00	1.00	0.66	0.00	0.62
08:30	0.00	5.74	1.00	1.00	0.66	0.00	0.62
08:35	0.00	5.73	1.00	1.00	0.66	0.00	0.62

A-13

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=05:35

RHR1A-A Elev. 653

Elapsed Time R:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT H2O lvl inches	Rm
00:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:50	68.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:55	68.02	2.22	0.00	1.00	0.00	0.00	0.00	0.00
01:00	68.02	4.43	0.00	1.00	0.00	0.00	0.00	0.00
01:05	68.02	6.64	0.00	1.00	0.00	0.00	0.00	0.00
01:10	68.02	6.74	0.00	1.00	0.00	0.00	0.00	0.00
01:15	68.02	6.82	0.00	1.00	0.00	0.00	0.00	0.00
01:20	68.02	6.89	0.00	1.00	0.00	0.00	0.00	0.00
01:25	68.02	6.95	0.00	1.00	0.00	0.00	0.00	0.00
01:30	68.02	7.00	0.00	1.00	0.00	0.00	0.00	0.00
01:35	68.02	7.04	0.00	1.00	0.00	0.00	0.00	0.00
01:40	68.02	7.07	0.00	1.00	0.00	0.00	0.00	0.00
01:45	68.02	7.10	0.00	1.00	0.00	0.00	0.00	0.00
01:50	68.02	7.13	0.00	1.00	0.00	0.00	0.00	0.00
01:55	68.02	7.15	0.00	1.00	0.00	0.00	0.00	0.00
02:00	68.02	7.16	0.00	1.00	0.00	0.00	0.00	0.00
02:05	68.02	7.18	0.00	1.00	0.00	0.00	0.00	0.00
02:10	104.34	8.38	0.00	1.00	0.00	0.00	0.00	0.00
02:15	104.34	9.40	0.00	1.00	0.00	0.00	0.00	0.00
02:20	104.34	10.28	0.00	1.00	0.00	0.00	0.00	0.00
02:25	104.34	11.04	0.00	1.00	0.00	0.00	0.00	0.00
02:30	104.34	11.71	0.00	1.00	0.00	0.00	0.00	0.00
02:35	104.34	12.29	10.59	1.00	0.05	0.00	0.00	0.00
02:40	104.34	12.29	7.81	1.00	0.02	0.00	0.00	0.00
02:45	104.34	12.29	10.12	1.00	0.03	0.00	0.00	0.00
02:50	104.34	12.29	8.26	1.00	0.02	0.00	0.00	0.00
02:55	104.34	12.29	9.79	1.00	0.03	0.00	0.00	0.00
03:00	104.34	12.29	8.55	1.00	0.02	0.00	0.00	0.00
03:05	104.34	12.29	9.57	1.00	0.03	0.00	0.00	0.00
03:10	104.34	12.29	8.74	1.00	0.02	0.00	0.00	0.00
03:15	104.34	12.29	9.43	1.00	0.03	0.00	0.00	0.00
03:20	104.34	12.29	8.87	1.00	0.02	0.00	0.00	0.00
03:25	104.34	12.29	9.33	1.00	0.03	0.00	0.00	0.00
03:30	104.34	12.29	8.95	1.00	0.02	0.00	0.00	0.00
03:35	104.34	12.29	9.26	1.00	0.03	0.00	0.00	0.00
03:40	104.34	12.29	9.01	1.00	0.02	0.00	0.00	0.00
03:45	104.34	12.29	9.22	1.00	0.03	0.00	0.00	0.00
03:50	104.34	12.29	9.05	1.00	0.02	0.00	0.00	0.00
03:55	104.34	12.29	9.19	1.00	0.03	0.00	0.00	0.00
04:00	104.34	12.29	9.07	1.00	0.02	0.00	0.00	0.00
04:05	104.34	12.29	9.17	1.00	0.03	0.00	0.00	0.00
04:10	104.34	12.29	9.09	1.00	0.02	0.00	0.00	0.00
04:15	104.34	12.29	9.15	1.00	0.02	0.00	0.00	0.00
04:20	104.34	12.29	9.10	1.00	0.02	0.00	0.00	0.00
04:25	104.34	12.29	9.14	1.00	0.02	0.00	0.00	0.00
04:30	104.34	12.29	9.11	1.00	0.02	0.00	0.00	0.00
04:35	104.34	12.29	9.14	1.00	0.02	0.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=05:35

Elapsed Time	AuxBldg	sm.sump	sm.sump	sm.sump	TDT H2O	TDT	AuxBldg
HR:MIN	feet	1st pmp	2nd pmp	Hi lvl	volume	Hi lvl	pas.sump
	feet	gpm	gpm	0=N;1=Y	%	0=N;1=Y	feet
00:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:30	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:45	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:50	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:55	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:05	641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:10	641.63	0.00	0.00	0.00	51.00	0.00	0.00
01:15	642.07	0.00	0.00	0.00	51.00	0.00	0.00
01:20	642.51	0.00	0.00	0.00	51.00	0.00	0.00
01:25	642.95	0.00	0.00	0.00	51.00	0.00	0.00
01:30	643.40	0.00	0.00	0.00	51.00	0.00	0.00
01:35	643.85	0.00	0.00	0.00	51.00	0.00	0.00
01:40	643.96	50.00	0.00	0.00	52.00	0.00	0.00
01:45	644.08	50.00	0.00	0.00	53.00	0.00	0.00
01:50	644.19	50.00	0.00	0.00	54.00	0.00	0.00
01:55	644.31	50.00	0.00	0.00	55.00	0.00	0.00
02:00	644.43	50.00	0.00	0.00	56.00	0.00	0.00
02:05	644.55	50.00	0.00	0.00	57.00	0.00	0.00
02:10	644.70	50.00	0.00	0.00	58.00	0.00	0.00
02:15	644.88	50.00	0.00	0.00	59.00	0.00	0.00
02:20	645.09	50.00	0.00	0.00	60.00	0.00	0.00
02:25	645.32	50.00	0.00	0.00	61.00	0.00	0.00
02:30	645.56	50.00	0.00	0.00	62.00	0.00	0.00
02:35	645.82	50.00	0.00	0.00	64.00	0.00	0.00
02:40	646.23	50.00	0.00	0.00	65.00	0.00	0.00
02:45	646.59	50.00	0.00	0.00	66.00	0.00	0.00
02:50	646.97	50.00	0.00	0.00	67.00	0.00	0.00
02:55	646.99	50.00	50.00	0.00	69.00	0.00	0.00
03:00	647.03	50.00	50.00	0.00	71.00	0.00	0.00
03:05	647.06	50.00	50.00	0.00	73.00	0.00	0.00
03:10	647.10	50.00	50.00	0.00	75.00	0.00	0.00
03:15	647.12	50.00	50.00	0.00	77.00	0.00	0.00
03:20	647.16	50.00	50.00	0.00	79.00	0.00	0.00
03:25	647.18	50.00	50.00	0.00	81.00	0.00	0.00
03:30	647.22	50.00	50.00	0.00	83.00	0.00	0.00
03:35	647.24	50.00	50.00	0.00	85.00	0.00	0.00
03:40	647.28	50.00	50.00	0.00	88.00	0.00	0.00
03:45	647.30	50.00	50.00	0.00	90.00	0.00	0.00
03:50	647.33	50.00	50.00	0.00	92.00	1.00	0.00
03:55	647.36	50.00	50.00	0.00	94.00	1.00	0.00
04:00	647.39	50.00	50.00	0.00	96.00	1.00	0.00
04:05	647.42	50.00	50.00	0.00	98.00	1.00	0.00
04:10	647.45	50.00	50.00	0.00	100.00	1.00	0.00
04:15	647.48	50.00	50.00	0.00	102.00	1.00	0.00
04:20	647.51	50.00	50.00	0.00	102.00	1.00	0.00
04:25	648.21	50.00	50.00	0.00	102.00	1.00	0.00
04:30	648.91	50.00	50.00	0.00	102.00	1.00	0.00
04:35	649.61	50.00	50.00	1.00	102.00	1.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=05:35

RHR1A-A

Elev. 653

Elapsed Time	Pipe Leakage	Main Rm H2O lvl	Door H2O lvl	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl
04:40	104.34	12.29	9.11	1.00	0.02	0.00	0.00
04:45	104.34	12.29	9.13	1.00	0.02	0.00	0.00
04:50	104.34	12.29	9.12	1.00	0.02	0.00	0.00
04:55	104.34	12.29	9.13	1.00	0.02	0.00	0.00
05:00	104.34	12.29	9.12	1.00	0.02	0.00	0.00
05:05	104.34	12.29	9.13	1.00	0.10	0.00	0.03
05:10	104.34	12.29	9.12	1.00	0.19	0.00	0.09
05:15	104.34	12.29	9.18	1.00	0.28	0.00	0.16
05:20	104.34	12.29	9.19	1.00	0.38	0.00	0.25
05:25	104.34	12.29	9.24	1.00	0.49	0.00	0.36
05:30	104.34	12.29	9.26	1.00	0.61	0.00	0.49
05:35	104.34	12.29	9.32	1.00	0.75	0.00	0.63
05:40	0.00	8.89	1.00	1.00	0.83	0.00	0.75
05:45	0.00	6.44	1.00	1.00	1.00	0.00	1.05
05:50	0.00	6.00	1.00	1.00	0.77	0.00	1.05
05:55	0.00	5.99	1.00	1.00	0.71	0.00	1.05
06:00	0.00	5.99	1.00	1.00	0.67	0.00	1.05
06:05	0.00	5.98	1.00	1.00	0.65	0.00	1.05
06:10	0.00	5.97	1.00	1.00	0.88	0.00	1.21
06:15	0.00	5.97	1.00	1.00	0.72	0.00	1.21
06:20	0.00	5.96	1.00	1.00	0.66	0.00	1.21
06:25	0.00	5.95	1.00	1.00	0.61	0.00	1.21
06:30	0.00	5.94	1.00	1.00	0.60	0.00	1.21
06:35	0.00	5.94	1.00	1.00	0.83	0.00	1.36
06:40	0.00	5.93	1.00	1.00	0.67	0.00	1.36
06:45	0.00	5.92	1.00	1.00	0.60	0.00	1.36
06:50	0.00	5.92	1.00	1.00	0.56	0.00	1.36
06:55	0.00	5.91	1.00	1.00	0.54	0.00	1.36
07:00	0.00	5.90	1.00	1.00	0.77	0.00	1.52
07:05	0.00	5.90	1.00	1.00	0.61	0.00	1.52
07:10	0.00	5.89	1.00	1.00	0.55	0.00	1.52
07:15	0.00	5.88	1.00	1.00	0.50	0.00	1.52
07:20	0.00	5.88	1.00	1.00	0.49	0.00	1.52
07:25	0.00	5.87	1.00	1.00	0.72	0.00	1.67
07:30	0.00	5.86	1.00	1.00	0.56	0.00	1.67
07:35	0.00	5.85	1.00	1.00	0.49	0.00	1.67
07:40	0.00	5.85	1.00	1.00	0.45	0.00	1.67
07:45	0.00	5.84	1.00	1.00	0.43	0.00	1.67
07:50	0.00	5.83	1.00	1.00	0.66	0.00	1.82
07:55	0.00	5.83	1.00	1.00	0.50	0.00	1.82
08:00	0.00	5.82	1.00	1.00	0.44	0.00	1.82
08:05	0.00	5.81	1.00	1.00	0.40	0.00	1.82
08:10	0.00	5.81	1.00	1.00	0.38	0.00	1.82
08:15	0.00	5.80	1.00	1.00	0.61	0.00	1.97
08:20	0.00	5.79	1.00	1.00	0.45	0.00	1.97
08:25	0.00	5.79	1.00	1.00	0.39	0.00	1.97
08:30	0.00	5.78	1.00	1.00	0.34	0.00	1.97
08:35	0.00	5.77	1.00	1.00	0.32	0.00	1.97

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=05:35

Elapsed Time	AuxBldg	sm.sump	sm.sump	sm.sump	TDT	H2O	TDT	AuxBldg
HR:MIN	sm.sump	1st pmp	2nd pmp	Hi lvl	volume	%	Hi lvl	pas.sump
	feet	gpm	gpm	0=N;1=Y			0=N;1=Y	feet
04:40	650.30	50.00	50.00	1.00	102.00		1.00	0.00
04:45	651.00	50.00	50.00	1.00	102.00		1.00	0.00
04:50	651.68	50.00	50.00	1.00	102.00		1.00	0.00
04:55	651.90	50.00	50.00	1.00	102.00		1.00	0.00
05:00	652.00	50.00	50.00	1.00	102.00		1.00	0.00
05:05	652.00	50.00	50.00	1.00	102.00		1.00	0.00
05:10	652.00	50.00	50.00	1.00	102.00		1.00	0.00
05:15	652.00	50.00	50.00	1.00	102.00		1.00	0.00
05:20	652.00	50.00	50.00	1.00	102.00		1.00	0.00
05:25	652.00	50.00	50.00	1.00	102.00		1.00	0.00
05:30	652.00	50.00	50.00	1.00	102.00		1.00	0.00
05:35	652.00	50.00	50.00	1.00	102.00		1.00	0.00
05:40	652.00	50.00	50.00	1.00	102.00		1.00	0.00
05:45	652.00	50.00	50.00	1.00	102.00		1.00	0.00
05:50	652.00	50.00	50.00	1.00	102.00		1.00	0.00
05:55	652.00	50.00	50.00	1.00	102.00		1.00	0.00
06:00	652.00	50.00	50.00	1.00	102.00		1.00	0.00
06:05	652.00	50.00	50.00	1.00	102.00		1.00	0.00
06:10	652.00	50.00	50.00	1.00	102.00		1.00	0.00
06:15	652.00	50.00	50.00	1.00	102.00		1.00	0.00
06:20	652.00	50.00	50.00	1.00	102.00		1.00	0.00
06:25	652.00	50.00	50.00	1.00	102.00		1.00	0.00
06:30	652.00	50.00	50.00	1.00	102.00		1.00	0.00
06:35	652.00	50.00	50.00	1.00	102.00		1.00	0.00
06:40	652.00	50.00	50.00	1.00	102.00		1.00	0.00
06:45	652.00	50.00	50.00	1.00	102.00		1.00	0.00
06:50	652.00	50.00	50.00	1.00	102.00		1.00	0.00
06:55	652.00	50.00	50.00	1.00	102.00		1.00	0.00
07:00	652.00	50.00	50.00	1.00	102.00		1.00	0.00
07:05	652.00	50.00	50.00	1.00	102.00		1.00	0.00
07:10	652.00	50.00	50.00	1.00	102.00		1.00	0.00
07:15	652.00	50.00	50.00	1.00	102.00		1.00	0.00
07:20	652.00	50.00	50.00	1.00	102.00		1.00	0.00
07:25	652.00	50.00	50.00	1.00	102.00		1.00	0.00
07:30	652.00	50.00	50.00	1.00	102.00		1.00	0.00
07:35	652.00	50.00	50.00	1.00	102.00		1.00	0.00
07:40	652.00	50.00	50.00	1.00	102.00		1.00	0.00
07:45	652.00	50.00	50.00	1.00	102.00		1.00	0.00
07:50	652.00	50.00	50.00	1.00	102.00		1.00	0.00
07:55	652.00	50.00	50.00	1.00	102.00		1.00	0.00
08:00	652.00	50.00	50.00	1.00	102.00		1.00	0.00
08:05	652.00	50.00	50.00	1.00	102.00		1.00	0.00
08:10	652.00	50.00	50.00	1.00	102.00		1.00	0.00
08:15	652.00	50.00	50.00	1.00	102.00		1.00	0.00
08:20	652.00	50.00	50.00	1.00	102.00		1.00	0.00
08:25	652.00	50.00	50.00	1.00	102.00		1.00	0.00
08:30	652.00	50.00	50.00	1.00	102.00		1.00	0.00
08:35	652.00	50.00	50.00	1.00	102.00		1.00	0.00

A-14

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=06:05

RHR1A-A

Elev. 653

Elapsed Time HR:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
00:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:50	68.02	0.00	0.00	0.00	0.00	0.00	0.00
00:55	68.02	2.22	0.00	1.00	0.00	0.00	0.00
01:00	68.02	4.43	0.00	1.00	0.00	0.00	0.00
01:05	68.02	6.64	0.00	1.00	0.00	0.00	0.00
01:10	68.02	6.74	0.00	1.00	0.00	0.00	0.00
01:15	68.02	6.82	0.00	1.00	0.00	0.00	0.00
01:20	68.02	6.89	0.00	1.00	0.00	0.00	0.00
01:25	68.02	6.95	0.00	1.00	0.00	0.00	0.00
01:30	68.02	7.00	0.00	1.00	0.00	0.00	0.00
01:35	68.02	7.04	0.00	1.00	0.00	0.00	0.00
01:40	68.02	7.07	0.00	1.00	0.00	0.00	0.00
01:45	68.02	7.10	0.00	1.00	0.00	0.00	0.00
01:50	68.02	7.13	0.00	1.00	0.00	0.00	0.00
01:55	68.02	7.15	0.00	1.00	0.00	0.00	0.00
02:00	68.02	7.16	0.00	1.00	0.00	0.00	0.00
02:05	68.02	7.18	0.00	1.00	0.00	0.00	0.00
02:10	104.34	8.38	0.00	1.00	0.00	0.00	0.00
02:15	104.34	9.40	0.00	1.00	0.00	0.00	0.00
02:20	104.34	10.28	0.00	1.00	0.00	0.00	0.00
02:25	104.34	11.04	0.00	1.00	0.00	0.00	0.00
02:30	104.34	11.71	0.00	1.00	0.00	0.00	0.00
02:35	104.34	12.29	10.59	1.00	0.05	0.00	0.00
02:40	104.34	12.29	7.81	1.00	0.02	0.00	0.00
02:45	104.34	12.29	10.12	1.00	0.03	0.00	0.00
02:50	104.34	12.29	8.26	1.00	0.02	0.00	0.00
02:55	104.34	12.29	9.79	1.00	0.03	0.00	0.00
03:00	104.34	12.29	8.55	1.00	0.02	0.00	0.00
03:05	104.34	12.29	9.57	1.00	0.03	0.00	0.00
03:10	104.34	12.29	8.74	1.00	0.02	0.00	0.00
03:15	104.34	12.29	9.43	1.00	0.03	0.00	0.00
03:20	104.34	12.29	8.87	1.00	0.02	0.00	0.00
03:25	104.34	12.29	9.33	1.00	0.03	0.00	0.00
03:30	104.34	12.29	8.95	1.00	0.02	0.00	0.00
03:35	104.34	12.29	9.26	1.00	0.03	0.00	0.00
03:40	104.34	12.29	9.01	1.00	0.02	0.00	0.00
03:45	104.34	12.29	9.22	1.00	0.03	0.00	0.00
03:50	104.34	12.29	9.05	1.00	0.02	0.00	0.00
03:55	104.34	12.29	9.19	1.00	0.03	0.00	0.00
04:00	104.34	12.29	9.07	1.00	0.02	0.00	0.00
04:05	104.34	12.29	9.17	1.00	0.03	0.00	0.00
04:10	104.34	12.29	9.09	1.00	0.02	0.00	0.00
04:15	104.34	12.29	9.15	1.00	0.02	0.00	0.00
04:20	104.34	12.29	9.10	1.00	0.02	0.00	0.00
04:25	104.34	12.29	9.14	1.00	0.02	0.00	0.00
04:30	104.34	12.29	9.11	1.00	0.02	0.00	0.00
04:35	104.34	12.29	9.14	1.00	0.02	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=06:05

Elapsed Time	AuxBldg	sm.sump	sm.sump	sm.sump	TDT H2O	TDT	AuxBldg	
R:MIN		sm.sump	1st pmp	2nd pmp	Hi lvl	volume	Hi lvl	pas.sump
	feet	gpm	gpm	0=N;1=Y	%	0=N;1=Y	feet	
00:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00	0.00
00:30	640.75	0.00	0.00	0.00	51.00	0.00	0.00	0.00
00:45	640.75	0.00	0.00	0.00	51.00	0.00	0.00	0.00
00:50	640.75	0.00	0.00	0.00	51.00	0.00	0.00	0.00
00:55	640.75	0.00	0.00	0.00	51.00	0.00	0.00	0.00
01:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00	0.00
01:05	641.19	0.00	0.00	0.00	51.00	0.00	0.00	0.00
01:10	641.63	0.00	0.00	0.00	51.00	0.00	0.00	0.00
01:15	642.07	0.00	0.00	0.00	51.00	0.00	0.00	0.00
01:20	642.51	0.00	0.00	0.00	51.00	0.00	0.00	0.00
01:25	642.95	0.00	0.00	0.00	51.00	0.00	0.00	0.00
01:30	643.40	0.00	0.00	0.00	51.00	0.00	0.00	0.00
01:35	643.85	0.00	0.00	0.00	51.00	0.00	0.00	0.00
01:40	643.96	50.00	0.00	0.00	52.00	0.00	0.00	0.00
01:45	644.08	50.00	0.00	0.00	53.00	0.00	0.00	0.00
01:50	644.19	50.00	0.00	0.00	54.00	0.00	0.00	0.00
01:55	644.31	50.00	0.00	0.00	55.00	0.00	0.00	0.00
02:00	644.43	50.00	0.00	0.00	56.00	0.00	0.00	0.00
02:05	644.55	50.00	0.00	0.00	57.00	0.00	0.00	0.00
02:10	644.70	50.00	0.00	0.00	58.00	0.00	0.00	0.00
02:15	644.88	50.00	0.00	0.00	59.00	0.00	0.00	0.00
02:20	645.09	50.00	0.00	0.00	60.00	0.00	0.00	0.00
02:25	645.32	50.00	0.00	0.00	61.00	0.00	0.00	0.00
02:30	645.56	50.00	0.00	0.00	62.00	0.00	0.00	0.00
02:35	645.82	50.00	0.00	0.00	64.00	0.00	0.00	0.00
02:40	646.23	50.00	0.00	0.00	65.00	0.00	0.00	0.00
02:45	646.59	50.00	0.00	0.00	66.00	0.00	0.00	0.00
02:50	646.97	50.00	0.00	0.00	67.00	0.00	0.00	0.00
02:55	646.99	50.00	50.00	0.00	69.00	0.00	0.00	0.00
03:00	647.03	50.00	50.00	0.00	71.00	0.00	0.00	0.00
03:05	647.06	50.00	50.00	0.00	73.00	0.00	0.00	0.00
03:10	647.10	50.00	50.00	0.00	75.00	0.00	0.00	0.00
03:15	647.12	50.00	50.00	0.00	77.00	0.00	0.00	0.00
03:20	647.16	50.00	50.00	0.00	79.00	0.00	0.00	0.00
03:25	647.18	50.00	50.00	0.00	81.00	0.00	0.00	0.00
03:30	647.22	50.00	50.00	0.00	83.00	0.00	0.00	0.00
03:35	647.24	50.00	50.00	0.00	85.00	0.00	0.00	0.00
03:40	647.28	50.00	50.00	0.00	88.00	0.00	0.00	0.00
03:45	647.30	50.00	50.00	0.00	90.00	0.00	0.00	0.00
03:50	647.33	50.00	50.00	0.00	92.00	1.00	0.00	0.00
03:55	647.36	50.00	50.00	0.00	94.00	1.00	0.00	0.00
04:00	647.39	50.00	50.00	0.00	96.00	1.00	0.00	0.00
04:05	647.42	50.00	50.00	0.00	98.00	1.00	0.00	0.00
04:10	647.45	50.00	50.00	0.00	100.00	1.00	0.00	0.00
04:15	647.48	50.00	50.00	0.00	102.00	1.00	0.00	0.00
04:20	647.51	50.00	50.00	0.00	102.00	1.00	0.00	0.00
04:25	648.21	50.00	50.00	0.00	102.00	1.00	0.00	0.00
04:30	648.91	50.00	50.00	0.00	102.00	1.00	0.00	0.00
04:35	649.61	50.00	50.00	1.00	102.00	1.00	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=06:05

RHR1A-A

Elev. 653

Elapsed Time HR:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
04:40	104.34	12.29	9.11	1.00	0.02	0.00	0.00
04:45	104.34	12.29	9.13	1.00	0.02	0.00	0.00
04:50	104.34	12.29	9.12	1.00	0.02	0.00	0.00
04:55	104.34	12.29	9.13	1.00	0.02	0.00	0.00
05:00	104.34	12.29	9.12	1.00	0.02	0.00	0.00
05:05	104.34	12.29	9.13	1.00	0.10	0.00	0.03
05:10	104.34	12.29	9.12	1.00	0.19	0.00	0.09
05:15	104.34	12.29	9.18	1.00	0.28	0.00	0.16
05:20	104.34	12.29	9.19	1.00	0.38	0.00	0.25
05:25	104.34	12.29	9.24	1.00	0.49	0.00	0.36
05:30	104.34	12.29	9.26	1.00	0.61	0.00	0.49
05:35	104.34	12.29	9.32	1.00	0.75	0.00	0.63
05:40	104.34	12.29	9.36	1.00	0.91	0.00	0.80
05:45	104.34	12.29	9.42	1.00	1.00	0.00	1.19
05:50	104.34	12.29	9.48	1.00	1.00	0.00	1.35
05:55	104.34	12.29	9.50	1.00	1.00	0.00	1.53
06:00	104.34	12.29	9.48	1.00	1.00	0.00	1.75
06:05	104.34	12.29	9.49	1.00	1.00	0.00	2.16
06:10	0.00	8.89	1.00	1.00	0.92	0.00	2.27
06:15	0.00	6.44	1.00	1.00	0.99	0.00	2.36
06:20	0.00	6.00	1.00	1.00	0.93	0.00	2.36
06:25	0.00	5.99	1.00	1.00	1.00	0.00	2.54
06:30	0.00	5.99	1.00	1.00	0.83	0.00	2.54
06:35	0.00	5.98	1.00	1.00	0.76	0.00	2.54
06:40	0.00	5.97	1.00	1.00	0.72	0.00	2.54
06:45	0.00	5.97	1.00	1.00	0.70	0.00	2.54
06:50	0.00	5.96	1.00	1.00	0.94	0.00	2.70
06:55	0.00	5.95	1.00	1.00	0.77	0.00	2.70
07:00	0.00	5.94	1.00	1.00	0.71	0.00	2.70
07:05	0.00	5.94	1.00	1.00	0.67	0.00	2.70
07:10	0.00	5.93	1.00	1.00	0.65	0.00	2.70
07:15	0.00	5.92	1.00	1.00	0.88	0.00	2.85
07:20	0.00	5.92	1.00	1.00	0.72	0.00	2.85
07:25	0.00	5.91	1.00	1.00	0.65	0.00	2.85
07:30	0.00	5.90	1.00	1.00	0.61	0.00	2.85
07:35	0.00	5.90	1.00	1.00	0.59	0.00	2.85
07:40	0.00	5.89	1.00	1.00	0.82	0.00	3.01
07:45	0.00	5.88	1.00	1.00	0.66	0.00	3.01
07:50	0.00	5.88	1.00	1.00	0.60	0.00	3.01
07:55	0.00	5.87	1.00	1.00	0.56	0.00	3.01
08:00	0.00	5.86	1.00	1.00	0.54	0.00	3.01
08:05	0.00	5.85	1.00	1.00	0.77	0.00	3.16
08:10	0.00	5.85	1.00	1.00	0.61	0.00	3.16
08:15	0.00	5.84	1.00	1.00	0.54	0.00	3.16
08:20	0.00	5.83	1.00	1.00	0.50	0.00	3.16
08:25	0.00	5.83	1.00	1.00	0.48	0.00	3.16
08:30	0.00	5.82	1.00	1.00	0.71	0.00	3.32
08:35	0.00	5.81	1.00	1.00	0.55	0.00	3.32

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=06:05

Elapsed Time	AuxBldg	sm.sump	sm.sump	sm.sump	TDT H2O	TDT	AuxBldg
HR:MIN	feet	1st pmp	2nd pmp	Hi lvl 0=N;1=Y	volume %	Hi lvl 0=N;1=Y	pas.sump feet
	gpm	gpm					
04:40	650.30	50.00	50.00	1.00	102.00	1.00	0.00
04:45	651.00	50.00	50.00	1.00	102.00	1.00	0.00
04:50	651.68	50.00	50.00	1.00	102.00	1.00	0.00
04:55	651.90	50.00	50.00	1.00	102.00	1.00	0.00
05:00	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:05	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:10	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:15	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:20	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:25	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:30	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:35	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:40	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:45	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:50	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:55	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:00	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:05	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:10	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:15	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:20	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:25	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:30	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:35	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:40	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:45	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:50	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:55	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:00	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:05	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:10	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:15	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:20	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:25	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:30	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:35	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:40	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:45	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:50	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:55	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:00	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:05	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:10	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:15	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:20	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:25	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:30	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:35	652.00	50.00	50.00	1.00	102.00	1.00	0.00

A-15

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=06:35

RHR1A-A

Elev. 653

Elapsed Time HR:MIN	Pipe Leakage gpm	Main Rm H2O lvl inches	Door H2O lvl inches	Flood Al LS-40-29 0=N;1=Y	Main H2O lvl inches	Flood Al LS-40-25 0=N;1=Y	TDT Rm H2O lvl inches
00:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00
00:50	68.02	0.00	0.00	0.00	0.00	0.00	0.00
00:55	68.02	2.22	0.00	1.00	0.00	0.00	0.00
01:00	68.02	4.43	0.00	1.00	0.00	0.00	0.00
01:05	68.02	6.64	0.00	1.00	0.00	0.00	0.00
01:10	68.02	6.74	0.00	1.00	0.00	0.00	0.00
01:15	68.02	6.82	0.00	1.00	0.00	0.00	0.00
01:20	68.02	6.89	0.00	1.00	0.00	0.00	0.00
01:25	68.02	6.95	0.00	1.00	0.00	0.00	0.00
01:30	68.02	7.00	0.00	1.00	0.00	0.00	0.00
01:35	68.02	7.04	0.00	1.00	0.00	0.00	0.00
01:40	68.02	7.07	0.00	1.00	0.00	0.00	0.00
01:45	68.02	7.10	0.00	1.00	0.00	0.00	0.00
01:50	68.02	7.13	0.00	1.00	0.00	0.00	0.00
01:55	68.02	7.15	0.00	1.00	0.00	0.00	0.00
02:00	68.02	7.16	0.00	1.00	0.00	0.00	0.00
02:05	68.02	7.18	0.00	1.00	0.00	0.00	0.00
02:10	104.34	8.38	0.00	1.00	0.00	0.00	0.00
02:15	104.34	9.40	0.00	1.00	0.00	0.00	0.00
02:20	104.34	10.28	0.00	1.00	0.00	0.00	0.00
02:25	104.34	11.04	0.00	1.00	0.00	0.00	0.00
02:30	104.34	11.71	0.00	1.00	0.00	0.00	0.00
02:35	104.34	12.29	10.59	1.00	0.05	0.00	0.00
02:40	104.34	12.29	7.81	1.00	0.02	0.00	0.00
02:45	104.34	12.29	10.12	1.00	0.03	0.00	0.00
02:50	104.34	12.29	8.26	1.00	0.02	0.00	0.00
02:55	104.34	12.29	9.79	1.00	0.03	0.00	0.00
03:00	104.34	12.29	8.55	1.00	0.02	0.00	0.00
03:05	104.34	12.29	9.57	1.00	0.03	0.00	0.00
03:10	104.34	12.29	8.74	1.00	0.02	0.00	0.00
03:15	104.34	12.29	9.43	1.00	0.03	0.00	0.00
03:20	104.34	12.29	8.87	1.00	0.02	0.00	0.00
03:25	104.34	12.29	9.33	1.00	0.03	0.00	0.00
03:30	104.34	12.29	8.95	1.00	0.02	0.00	0.00
03:35	104.34	12.29	9.26	1.00	0.03	0.00	0.00
03:40	104.34	12.29	9.01	1.00	0.02	0.00	0.00
03:45	104.34	12.29	9.22	1.00	0.03	0.00	0.00
03:50	104.34	12.29	9.05	1.00	0.02	0.00	0.00
03:55	104.34	12.29	9.19	1.00	0.03	0.00	0.00
04:00	104.34	12.29	9.07	1.00	0.02	0.00	0.00
04:05	104.34	12.29	9.17	1.00	0.03	0.00	0.00
04:10	104.34	12.29	9.09	1.00	0.02	0.00	0.00
04:15	104.34	12.29	9.15	1.00	0.02	0.00	0.00
04:20	104.34	12.29	9.10	1.00	0.02	0.00	0.00
04:25	104.34	12.29	9.14	1.00	0.02	0.00	0.00
04:30	104.34	12.29	9.11	1.00	0.02	0.00	0.00
04:35	104.34	12.29	9.14	1.00	0.02	0.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=06:35

Elapsed Time	AuxBldg feet	sm.sump 1st pmp gpm	sm.sump 2nd pmp gpm	sm.sump Hi lvl 0=N;1=Y	TDT H2O volume	TDT Hi lvl 0=N;1=Y	AuxBldg pas.sump feet
00:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:30	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:45	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:50	640.75	0.00	0.00	0.00	51.00	0.00	0.00
00:55	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:00	640.75	0.00	0.00	0.00	51.00	0.00	0.00
01:05	641.19	0.00	0.00	0.00	51.00	0.00	0.00
01:10	641.63	0.00	0.00	0.00	51.00	0.00	0.00
01:15	642.07	0.00	0.00	0.00	51.00	0.00	0.00
01:20	642.51	0.00	0.00	0.00	51.00	0.00	0.00
01:25	642.95	0.00	0.00	0.00	51.00	0.00	0.00
01:30	643.40	0.00	0.00	0.00	51.00	0.00	0.00
01:35	643.85	0.00	0.00	0.00	51.00	0.00	0.00
01:40	643.96	50.00	0.00	0.00	52.00	0.00	0.00
01:45	644.08	50.00	0.00	0.00	53.00	0.00	0.00
01:50	644.19	50.00	0.00	0.0J	54.00	0.00	0.00
01:55	644.31	50.00	0.00	0.00	55.00	0.00	0.00
02:00	644.43	50.00	0.00	0.00	56.00	0.00	0.00
02:05	644.55	50.00	0.00	0.00	57.00	0.00	0.00
02:10	644.70	50.00	0.00	0.00	58.00	0.00	0.00
02:15	644.88	50.00	0.00	0.00	59.00	0.00	0.00
02:20	645.09	50.00	0.00	0.00	60.00	0.00	0.00
02:25	645.32	50.00	0.00	0.00	61.00	0.00	0.00
02:30	645.56	50.00	0.00	0.00	62.00	0.00	0.00
02:35	645.82	50.00	0.00	0.00	64.00	0.00	0.00
02:40	646.23	50.00	0.00	0.00	65.00	0.00	0.00
02:45	646.59	50.00	0.00	0.00	66.00	0.00	0.00
02:50	646.97	50.00	0.00	0.00	67.00	0.00	0.00
02:55	646.99	50.00	50.00	0.00	69.00	0.00	0.00
03:00	647.03	50.00	50.00	0.00	71.00	0.00	0.00
03:05	647.06	50.00	50.00	0.00	73.00	0.00	0.00
03:10	647.10	50.00	50.00	0.00	75.00	0.00	0.00
03:15	647.12	50.00	50.00	0.00	77.00	0.00	0.00
03:20	647.16	50.00	50.00	0.00	79.00	0.00	0.00
03:25	647.18	50.00	50.00	0.00	81.00	0.00	0.00
03:30	647.22	50.00	50.00	0.00	83.00	0.00	0.00
03:35	647.24	50.00	50.00	0.00	85.00	0.00	0.00
03:40	647.28	50.00	50.00	0.00	88.00	0.00	0.00
03:45	647.30	50.00	50.00	0.00	90.00	0.00	0.00
03:50	647.33	50.00	50.00	0.00	92.00	1.00	0.00
03:55	647.36	50.00	50.00	0.00	94.00	1.00	0.00
04:00	647.39	50.00	50.00	0.00	96.00	1.00	0.00
04:05	647.42	50.00	50.00	0.00	98.00	1.00	0.00
04:10	647.45	50.00	50.00	0.00	100.00	1.00	0.00
04:15	647.48	50.00	50.00	0.00	102.00	1.00	0.00
04:20	647.51	50.00	50.00	0.00	102.00	1.00	0.00
04:25	648.21	50.00	50.00	0.00	102.00	1.00	0.00
04:30	648.91	50.00	50.00	0.00	102.00	1.00	0.00
04:35	649.61	50.00	50.00	1.00	102.00	1.00	0.00

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=06:35

RHR1A-A

Elev. 653

Elapsed Time	Pipe Leakage	Main Rm H2O lvl	Door H2O lvl	Flood Al 0=N;1=Y	Main H2O lvl	Flood Al 0=N;1=Y	TDT Rm H2O lvl
04:40	104.34	12.29	9.11	1.00	0.02	0.00	0.00
04:45	104.34	12.29	9.13	1.00	0.02	0.00	0.00
04:50	104.34	12.29	9.12	1.00	0.02	0.00	0.00
04:55	104.34	12.29	9.13	1.00	0.02	0.00	0.00
05:00	104.34	12.29	9.12	1.00	0.02	0.00	0.00
05:05	104.34	12.29	9.13	1.00	0.10	0.00	0.03
05:10	104.34	12.29	9.12	1.00	0.19	0.00	0.09
05:15	104.34	12.29	9.18	1.00	0.28	0.00	0.16
05:20	104.34	12.29	9.19	1.00	0.38	0.00	0.25
05:25	104.34	12.29	9.24	1.00	0.49	0.00	0.36
05:30	104.34	12.29	9.26	1.00	0.61	0.00	0.49
05:35	104.34	12.29	9.32	1.00	0.75	0.00	0.63
05:40	104.34	12.29	9.36	1.00	0.91	0.00	0.80
05:45	104.34	12.29	9.42	1.00	1.00	0.00	1.19
05:50	104.34	12.29	9.48	1.00	1.00	0.00	1.35
05:55	104.34	12.29	9.50	1.00	1.00	0.00	1.53
06:00	104.34	12.29	9.48	1.00	1.00	0.00	1.75
06:05	104.34	12.29	9.49	1.00	1.00	0.00	2.16
06:10	104.34	12.29	9.48	1.00	1.00	0.00	2.32
06:15	104.34	12.29	9.49	1.00	1.00	0.00	2.51
06:20	104.34	12.29	9.48	1.00	1.00	0.00	2.91
06:25	104.34	12.29	9.49	1.00	1.00	0.00	3.07
06:30	104.34	12.29	9.49	1.00	1.00	0.00	3.25
06:35	104.34	12.29	9.49	1.00	1.00	0.00	3.66
06:40	0.00	8.89	1.00	1.00	0.92	0.00	3.76
06:45	0.00	6.44	1.00	1.00	0.98	0.00	3.85
06:50	0.00	6.00	1.00	1.00	0.91	0.00	3.85
06:55	0.00	5.99	1.00	1.00	1.00	0.00	4.03
07:00	0.00	5.99	1.00	1.00	0.83	0.00	4.03
07:05	0.00	5.98	1.00	1.00	0.76	0.00	4.03
07:10	0.00	5.97	1.00	1.00	0.72	0.00	4.03
07:15	0.00	5.97	1.00	1.00	0.70	0.00	4.03
07:20	0.00	5.96	1.00	1.00	0.94	0.00	4.18
07:25	0.00	5.95	1.00	1.00	0.77	0.00	4.18
07:30	0.00	5.94	1.00	1.00	0.71	0.00	4.18
07:35	0.00	5.94	1.00	1.00	0.67	0.00	4.18
07:40	0.00	5.93	1.00	1.00	0.65	0.00	4.18
07:45	0.00	5.92	1.00	1.00	0.88	0.00	4.34
07:50	0.00	5.92	1.00	1.00	0.72	0.00	4.34
07:55	0.00	5.91	1.00	1.00	0.65	0.00	4.34
08:00	0.00	5.90	1.00	1.00	0.61	0.00	4.34
08:05	0.00	5.90	1.00	1.00	0.59	0.00	4.34
08:10	0.00	5.89	1.00	1.00	0.82	0.00	4.50
08:15	0.00	5.88	1.00	1.00	0.66	0.00	4.50
08:20	0.00	5.88	1.00	1.00	0.60	0.00	4.50
08:25	0.00	5.87	1.00	1.00	0.55	0.00	4.50
08:30	0.00	5.86	1.00	1.00	0.54	0.00	4.50
08:35	0.00	5.85	1.00	1.00	0.77	0.00	4.65

SQNGE93 FLOODING CALCS FOR RHR1A-A LEAK STOPING AT T=06:35

Elapsed Time	AuxBldg	sm.sump	sm.sump	sm.sump	TDT H2O	TDT	AuxBldg
HR:MIN		1st pmp	2nd pmp	Hi lvl	volume	Hi lvl	pas.sump
	feet	gpm	gpm	O=N;1=Y	%	O=N;1=Y	feet
04:40	650.30	50.00	50.00	1.00	102.00	1.00	0.00
04:45	651.00	50.00	50.00	1.00	102.00	1.00	0.00
04:50	651.68	50.00	50.00	1.00	102.00	1.00	0.00
04:55	651.90	50.00	50.00	1.00	102.00	1.00	0.00
05:00	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:05	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:10	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:15	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:20	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:25	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:30	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:35	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:40	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:45	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:50	652.00	50.00	50.00	1.00	102.00	1.00	0.00
05:55	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:00	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:05	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:10	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:15	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:20	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:25	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:30	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:35	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:40	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:45	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:50	652.00	50.00	50.00	1.00	102.00	1.00	0.00
06:55	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:00	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:05	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:10	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:15	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:20	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:25	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:30	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:35	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:40	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:45	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:50	652.00	50.00	50.00	1.00	102.00	1.00	0.00
07:55	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:00	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:05	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:10	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:15	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:20	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:25	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:30	652.00	50.00	50.00	1.00	102.00	1.00	0.00
08:35	652.00	50.00	50.00	1.00	102.00	1.00	0.00

SEQUOIAH NUCLEAR PLANT

DRILL DATA

OVERALL RADIATION MONITOR LEVELS

MONITORING RADIATION MONITORING BEANLICKS RUMINANTS AS SPECIMENS FOR CEMERAL MONITORING

SEQUOIAH NUCLEAR PLANT

DRILL DATA

LOCATION: post Accident Sampling

CONTAINMENT AIR SAMPLE 70.5°C) ALSO SEE SONPASE'S FOR NOBLE GAS READINGS

CONTAINMENT AIR SAMPLE (0.5 CC) ALSO SEE SQNPASF3 FOR NOBLE GAS READINGS									
PARTICULATE FILTER		SHIELDED PARTICULATE FILTER		TOXINE FILTER		TOXINE FILTER		SHIELDED TOXINE FILTER	
CONTACT	1FOOT	METER	CONTACT	1FOOT	METER	CONTACT	1FOOT	METER	CONTACT
00:00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
00:05	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
00:10	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
00:15	-	-	-	-	-	0.01	0.01	0.01	0.01
00:20	-	-	-	-	-	0.01	0.01	0.01	0.01
00:25	-	-	-	-	-	0.01	0.01	0.01	0.01
00:30	-	-	-	-	-	0.01	0.01	0.01	0.01
00:35	-	-	-	-	-	0.01	0.01	0.01	0.01
00:40	-	-	-	-	-	0.01	0.01	0.01	0.01
00:45	-	-	-	-	-	0.01	0.01	0.01	0.01
00:50	-	-	-	-	-	0.01	0.01	0.01	0.01
00:55	-	-	-	-	-	0.01	0.01	0.01	0.01
01:00	-	-	-	-	-	0.01	0.01	0.01	0.01
01:05	-	-	-	-	-	0.01	0.01	0.01	0.01
01:10	-	-	-	-	-	0.01	0.01	0.01	0.01
01:15	-	-	-	-	-	0.01	0.01	0.01	0.01
01:20	-	-	-	-	-	0.01	0.01	0.01	0.01
01:25	-	-	-	-	-	0.01	0.01	0.01	0.01
01:30	-	-	-	-	-	0.01	0.01	0.01	0.01
01:35	-	-	-	-	-	0.01	0.01	0.01	0.01
01:40	-	-	-	-	-	0.01	0.01	0.01	0.01
01:45	-	-	-	-	-	0.01	0.01	0.01	0.01
01:50	-	-	-	-	-	0.01	0.01	0.01	0.01
01:55	-	-	-	-	-	0.01	0.01	0.01	0.01
02:00	-	-	-	-	-	0.01	0.01	0.01	0.01
02:05	-	-	-	-	-	0.01	0.01	0.01	0.01
02:10	-	-	-	-	-	0.01	0.01	0.01	0.01
02:15	-	-	-	-	-	0.01	0.01	0.01	0.01
02:20	-	-	-	-	-	0.01	0.01	0.01	0.01
02:25	-	-	-	-	-	0.01	0.01	0.01	0.01
02:30	-	-	-	-	-	0.01	0.01	0.01	0.01
02:35	-	-	-	-	-	0.01	0.01	0.01	0.01
02:40	-	-	-	-	-	0.01	0.01	0.01	0.01
02:45	-	-	-	-	-	0.01	0.01	0.01	0.01
02:50	-	-	-	-	-	0.01	0.01	0.01	0.01
02:55	-	-	-	-	-	0.01	0.01	0.01	0.01
03:00	-	-	-	-	-	0.01	0.01	0.01	0.01
03:05	-	-	-	-	-	0.01	0.01	0.01	0.01
03:10	-	-	-	-	-	0.01	0.01	0.01	0.01
03:15	-	-	-	-	-	0.01	0.01	0.01	0.01
03:20	-	-	-	-	-	0.01	0.01	0.01	0.01
03:25	-	-	-	-	-	0.01	0.01	0.01	0.01
03:30	-	-	-	-	-	0.01	0.01	0.01	0.01

04-12-1993 16:00:32
SHOPASPIRE
www.sage.com

LOCATION: Post Accident Sampling

ORILL. DATA

SEQUOIAH NUCLEAR PLANT

SEOUYAH NUCLEAR PLANT

DRILL DATA LOCATION: Post Accident Sampling

TOP OF CASK	REACTOR COOLANT SAMPLE DILUTED 1:1000 (24 ML)			DISSOLVED REACTOR COOLANT GAS DILUTED 1:15000 (14 CC)			
	UNSHIELDED	CONTACT	1 FOOT	1METER	CONTACT	1FOOT	1METER
UNSHIELDED	SHIELDED	SHIELDED	SHIELDED	UNSHIELDED	SHIELDED	SHIELDED	
03:35	0.01	0.01	-	-	-	-	-
03:40	0.01	0.01	-	-	-	-	-
03:45	0.01	0.01	-	-	-	-	-
03:50	0.01	0.01	-	-	-	-	-
03:55	0.01	0.01	-	-	-	-	-
04:00	0.01	0.01	-	-	-	-	-
04:05	0.01	0.01	-	-	-	-	-
04:10	0.01	0.01	-	-	-	-	-
04:15	0.01	0.01	-	-	-	-	-
04:20	0.01	0.01	-	-	-	-	-
04:25	0.01	0.01	-	-	-	-	-
04:30	0.01	0.01	-	-	-	-	-
04:35	0.01	0.01	-	-	-	-	-
04:40	0.01	0.01	-	-	-	-	-
04:45	0.01	0.01	-	-	-	-	-
04:50	0.01	0.01	-	-	-	-	-
04:55	0.01	0.01	-	-	-	-	-
05:00	0.01	0.01	-	-	-	-	-
05:05	0.01	0.01	-	-	-	-	-
05:10	0.01	0.01	-	-	-	-	-
05:15	0.01	0.01	-	-	-	-	-
05:20	0.01	0.01	-	-	-	-	-
05:25	0.01	0.01	-	-	-	-	-
05:30	0.01	0.01	-	-	-	-	-
05:35	0.01	0.01	-	-	-	-	-
05:40	0.01	0.01	-	-	-	-	-
05:45	0.01	0.01	-	-	-	-	-
05:50	0.01	0.01	-	-	-	-	-
05:55	0.01	0.01	-	-	-	-	-
06:00	0.01	0.01	-	-	-	-	-
06:05	0.01	0.01	-	-	-	-	-
06:10	0.01	0.01	-	-	-	-	-
06:15	0.01	0.01	-	-	-	-	-
06:20	0.01	0.01	-	-	-	-	-
06:25	0.01	0.01	-	-	-	-	-
06:30	0.01	0.01	-	-	-	-	-

CONTAINMENT AIR SAMPLE (0.5 CC) ALSO SEE SOPASF3 FOR NOBLE GAS READINGS

PARTICULATE FILTER	CONTAINMENT AIR SAMPLE (0.5 CC)			100INE FILTER			SHIELDED 100INE FILTER		
	CONTACT	1FOOT	1METER	CONTACT	1FOOT	1METER	CONTACT	1FOOT	1METER
03:35	*	*	*	*	0.01	0.01	0.01	0.01	0.01
03:40	*	*	*	*	0.01	0.01	0.01	0.01	0.01
03:45	*	*	*	*	0.01	0.01	0.01	0.01	0.01
03:50	*	*	*	*	0.01	0.01	0.01	0.01	0.01
03:55	*	*	*	*	0.01	0.01	0.01	0.01	0.01
04:00	*	*	*	*	0.01	0.01	0.01	0.01	0.01
04:05	*	*	*	*	0.01	0.01	0.01	0.01	0.01
04:10	*	*	*	*	0.01	0.01	0.01	0.01	0.01
04:15	*	*	*	*	0.01	0.01	0.01	0.01	0.01
04:20	*	*	*	*	0.01	0.01	0.01	0.01	0.01
04:25	*	*	*	*	0.01	0.01	0.01	0.01	0.01
04:30	*	*	*	*	0.01	0.01	0.01	0.01	0.01
04:35	*	*	*	*	0.01	0.01	0.01	0.01	0.01
04:40	*	*	*	*	0.01	0.01	0.01	0.01	0.01
04:45	*	*	*	*	0.01	0.01	0.01	0.01	0.01
04:50	*	*	*	*	0.01	0.01	0.01	0.01	0.01
04:55	*	*	*	*	0.01	0.01	0.01	0.01	0.01
05:00	*	*	*	*	0.01	0.01	0.01	0.01	0.01
05:05	*	*	*	*	0.01	0.01	0.01	0.01	0.01
05:10	*	*	*	*	0.01	0.01	0.01	0.01	0.01
05:15	*	*	*	*	0.01	0.01	0.01	0.01	0.01
05:20	*	*	*	*	0.01	0.01	0.01	0.01	0.01
05:25	*	*	*	*	0.01	0.01	0.01	0.01	0.01
05:30	*	*	*	*	0.01	0.01	0.01	0.01	0.01
05:35	*	*	*	*	0.01	0.01	0.01	0.01	0.01
05:40	*	*	*	*	0.01	0.01	0.01	0.01	0.01
05:45	*	*	*	*	0.01	0.01	0.01	0.01	0.01
05:50	*	*	*	*	0.01	0.01	0.01	0.01	0.01
05:55	*	*	*	*	0.01	0.01	0.01	0.01	0.01
06:00	*	*	*	*	0.01	0.01	0.01	0.01	0.01
06:05	*	*	*	*	0.01	0.01	0.01	0.01	0.01
06:10	*	*	*	*	0.01	0.01	0.01	0.01	0.01
06:15	*	*	*	*	0.01	0.01	0.01	0.01	0.01
06:20	*	*	*	*	0.01	0.01	0.01	0.01	0.01
06:25	*	*	*	*	0.01	0.01	0.01	0.01	0.01
06:30	*	*	*	*	0.01	0.01	0.01	0.01	0.01

NOBLE GAS VIAL		CONTAINMENT AIR SAMPLE (0.5 CC)		ALSO SEE SQNPASF3 FOR NOBLE GAS READINGS	
CONTACT	1FOOT	1METER	CONTACT	1FOOT	1METER
00:00	0.01	0.01	0.01	0.01	0.01
00:05	0.01	0.01	0.01	0.01	0.01
00:10	0.01	0.01	0.01	0.01	0.01
00:15	0.01	0.01	0.01	0.01	0.01
00:20	0.01	0.01	0.01	0.01	0.01
00:25	0.01	0.01	0.01	0.01	0.01
00:30	0.01	0.01	0.01	0.01	0.01
00:35	0.01	0.01	0.01	0.01	0.01
00:40	0.01	0.01	0.01	0.01	0.01
00:45	0.01	0.01	0.01	0.01	0.01
00:50	0.01	0.01	0.01	0.01	0.01
00:55	0.01	0.01	0.01	0.01	0.01
01:00	0.01	0.01	0.01	0.01	0.01
01:05	0.01	0.01	0.01	0.01	0.01
01:10	0.01	0.01	0.01	0.01	0.01
01:15	0.01	0.01	0.01	0.01	0.01
01:20	0.01	0.01	0.01	0.01	0.01
01:25	0.01	0.01	0.01	0.01	0.01
01:30	0.01	0.01	0.01	0.01	0.01
01:35	0.01	0.01	0.01	0.01	0.01
01:40	0.01	0.01	0.01	0.01	0.01
01:45	0.01	0.01	0.01	0.01	0.01
01:50	0.01	0.01	0.01	0.01	0.01
01:55	0.01	0.01	0.01	0.01	0.01
02:00	0.01	0.01	0.01	0.01	0.01
02:05	0.01	0.01	0.01	0.01	0.01
02:10	0.01	0.01	0.01	0.01	0.01
02:15	0.01	0.01	0.01	0.01	0.01
02:20	0.01	0.01	0.01	0.01	0.01
02:25	0.01	0.01	0.01	0.01	0.01
02:30	0.01	0.01	0.01	0.01	0.01
02:35	0.01	0.01	0.01	0.01	0.01
03:00	0.01	0.01	0.01	0.01	0.01
03:05	0.01	0.01	0.01	0.01	0.01
03:10	0.01	0.01	0.01	0.01	0.01
03:15	0.01	0.01	0.01	0.01	0.01
03:20	0.01	0.01	0.01	0.01	0.01
03:25	0.01	0.01	0.01	0.01	0.01
03:30	0.01	0.01	0.01	0.01	0.01



SONPASF3.PRN scr1939e
04-12-1993 16:06:32

SEQUOYAH NUCLEAR PLANT

DRILL DATA LOCATION: Post Accident Sampling

CONTAINMENT AIR SAMPLE (0.5 CC) ALSO SEE SONPASF3 FOR NOBLE GAS READINGS

	NOBLE GAS VIAL		SHIELDED NOBLE GAS VIAL		
CONTACT	1FOOT	1METER	CONTACT	1FOOT	1METER
03:35	0.01	0.01	0.01	0.01	0.01
03:40	0.01	0.01	0.01	0.01	0.01
03:45	0.01	0.01	0.01	0.01	0.01
03:50	0.01	0.01	0.01	0.01	0.01
03:55	0.01	0.01	0.01	0.01	0.01
04:00	0.01	0.01	0.01	0.01	0.01
04:05	0.01	0.01	0.01	0.01	0.01
04:10	0.01	0.01	0.01	0.01	0.01
04:15	0.01	0.01	0.01	0.01	0.01
04:20	0.01	0.01	0.01	0.01	0.01
04:25	0.01	0.01	0.01	0.01	0.01
04:30	0.01	0.01	0.01	0.01	0.01
04:35	0.01	0.01	0.01	0.01	0.01
04:40	0.01	0.01	0.01	0.01	0.01
04:45	0.01	0.01	0.01	0.01	0.01
04:50	0.01	0.01	0.01	0.01	0.01
04:55	0.01	0.01	0.01	0.01	0.01
05:00	0.01	0.01	0.01	0.01	0.01
05:05	0.01	0.01	0.01	0.01	0.01
05:10	0.01	0.01	0.01	0.01	0.01
05:15	0.01	0.01	0.01	0.01	0.01
05:20	0.01	0.01	0.01	0.01	0.01
05:25	0.01	0.01	0.01	0.01	0.01
05:30	0.01	0.01	0.01	0.01	0.01
05:35	0.01	0.01	0.01	0.01	0.01
05:40	0.01	0.01	0.01	0.01	0.01
05:45	0.01	0.01	0.01	0.01	0.01
05:50	0.01	0.01	0.01	0.01	0.01
05:55	0.01	0.01	0.01	0.01	0.01
06:00	0.01	0.01	0.01	0.01	0.01
06:05	0.01	0.01	0.01	0.01	0.01
06:10	0.01	0.01	0.01	0.01	0.01
06:15	0.01	0.01	0.01	0.01	0.01
06:20	0.01	0.01	0.01	0.01	0.01
06:25	0.01	0.01	0.01	0.01	0.01
06:30	0.01	0.01	0.01	0.01	0.01




SQN759 04-07-1993 12:39:42
sqn93ge Airborne Info SEQUOYAH NUCLEAR PLANT DRILL DATA

Data Location: pts. 1-13					
	SURFACE CONTAM		AIR SAMPLE -1m ³		IODINE
	FRISKER	ION	PRE-FILTER	FRISKER	CARTRIDG
	CPM	MR/HR	CPM	MR/HR	MR/HR
Time	100	2.0	100	2.0	0.05
	TO	TO	TO	TO	MIN
	50000	50000	50000	50000	MAX
	CPM	MR/HR	CPM	MR/HR	MR/HR
00:00	100	2.0	100	2.0	0.05
00:15	100	2.0	100	2.0	0.05
00:30	100	2.0	100	2.0	0.05
00:45	100	2.0	100	2.0	0.05
01:00	100	2.0	100	2.0	0.05
01:15	100	2.0	100	2.0	0.05
01:30	100	2.0	100	2.0	0.05
01:45	10^	2.0	100	2.0	0.05
02:00	100	2.0	100	2.0	0.05
02:15	100	2.0	100	2.0	0.05
02:30	100	2.0	100	2.0	0.05
02:45	100	2.0	100	2.0	0.05
03:00	100	2.0	100	2.0	0.05
03:15	100	2.0	100	2.0	0.05
03:30	100	2.0	100	2.0	0.05
03:45	100	2.0	100	2.0	0.05
04:00	100	2.0	100	2.0	0.05
04:15	100	2.0	100	2.0	0.05
04:30	100	2.0	100	2.0	0.05
04:45	100	2.0	100	2.0	0.05
05:00	100	2.0	100	2.0	0.05
05:15	100	2.0	100	2.0	0.05
05:30	100	2.0	100	2.0	0.05
05:45	100	2.0	100	2.0	0.05
06:00	100	2.0	100	2.0	0.05
06:15	100	2.0	100	2.0	0.05
06:30	100	2.0	100	2.0	0.05

0010018068

759



SI
APERTURE
CARD

Also Available On
Aperture Card

9308100100-01

SDN8734 04-07-1993 12:39:42
SDN9330

Meter Readings - Back Side Top Left Quarter

SEQUOYAH NUCLEAR PLANT

SQH734
sqn93-9

SQN734 04-07-1993 12:39:42
sqn93ge

Meter Readings - Back Side Bottom Left Quarter

SEQUOIAH NUCLEAR PLANT

SQN734
5-2008

34 04-07-1993 12:39:42

3ge Meter Readings + Back Side Top Right Quarter

SEQUOYAH NUCLEAR PLANT

SI (

APERTURE
CARD

34 04-07-1993 12:39:42

Age

Meter Readings - Back Side Bottom Right Quarter

SEQUOYAH NUCLEAR PLANT

9308100100-02

SQN759
sqn93ge

04-C7-1,93 12:39:42

Meter Readings - Back Side Top Left Quarter

SEQUOYAH NUCLEAR PLANT

SQN759

sgn93ge

SI
APERTURE
CARD

Also Available On
Aperture Card


04-07-1993 12:39:42

Meter Readings - Back Side Top Right Quarter

SEQUOYAH NUCLEAR PLANT

on 8	Location 9		Location 10		Location 11		Location 12		Location 13		Location 14	
Open Window mr/hr	Closed Window mr/hr	Open Window mr/hr										
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	00:00
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	00:15
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	00:30
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	00:45
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	01:00
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	01:15
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	01:30
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	01:45
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	02:00
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	02:15
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	02:30
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	02:45
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	03:00
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	03:15
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	03:30
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	03:45
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	04:00
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	04:15
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	04:30
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	04:45
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	05:00
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	05:15
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	05:30
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	05:45
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	06:00
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	06:15
0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	06:30

9308100100-03




SQN734 04-07-1993 12:39:42
 sqn93ge Airborne Info SEQUOYAH NUCLEAR PLANT DRILL DATA

Data Location: pts. 1-24

Time	SURFACE CONTAM		AIR SAMPLE - 1m³		IODEINE CARTRIDG	
	FRISKER	ION	FRISKER	ION	GM	
	CPM	MR/HR	CPM	MR/HR	MR/HR	
00:00	100	2.0	100	2.0	0.05	MIN
00:15	100	2.0	100	2.0	0.05	TO
00:30	100	2.0	100	2.0	0.05	MAX
00:45	100	2.0	100	2.0	0.05	UNITS
01:00	100	2.0	100	2.0	0.05	01:00
01:15	100	2.0	100	2.0	0.05	01:15
01:30	100	2.0	100	2.0	0.05	01:30
01:45	100	2.0	100	2.0	0.05	01:45
02:00	100	2.0	100	2.0	0.05	02:00
02:15	100	2.0	100	2.0	0.05	02:15
02:30	100	2.0	100	2.0	0.05	02:30
02:45	100	2.0	100	2.0	0.05	02:45
03:00	100	2.0	100	2.0	0.05	03:00
03:15	100	2.0	100	2.0	0.05	03:15
03:30	100	2.0	100	2.0	0.05	03:30
03:45	100	2.0	100	2.0	0.05	03:45
04:00	100	2.0	100	2.0	0.05	04:00
04:15	100	2.0	100	2.0	0.05	04:15
04:30	100	2.0	100	2.0	0.05	04:30
04:45	100	2.0	100	2.0	0.05	04:45
05:00	100	2.0	100	2.0	0.05	05:00
05:15	100	2.0	100	2.0	0.05	05:15
05:30	100	2.0	100	2.0	0.05	05:30
05:45	100	2.0	100	2.0	0.05	05:45
06:00	100	2.0	100	2.0	0.05	06:00
06:15	100	2.0	100	2.0	0.05	06:15
06:30	100	2.0	100	2.0	0.05	06:30

OSC-24



SQN
734

SI
APERTURE
CARD

Also Available On
Aperture Card

9308100100-04

SDN714
sign93 ge

06-07-1993 12:39:42

Meter Readings : Back Side Top Left Quarter

SEQUOYAH NUCLEAR PLANT

8100SON
sony3ge

SQH714
sqn93ge

04-07-1993 12:39:42

Meter Readings - Back Side Bottom Left Quarter

SEQUOYAH NUCLEAR PLANT

SQN714
sgn93-ge

714 04-07-1993 12:39:42
Meter Readings - Back Side Top Right Quarter

SEQUOYAH NUCLEAR PLANT

SI

APERTURE
CARD

04-07-1993 12:39:42

Meter Readings - Back Side Bottom Right Quarter

SEQUOYAH NUCLEAR PLANT


9308100100-05

sqn9

SQN714 04-07-1993 12:39:42
 sgn93ge Airborne Info SEQUOYAH NUCLEAR PLANT DRILL DATA

Data Location: pts. 1-24						Radcon Controller Notes!
Time	SURFACE CONTAM		AIR SAMPLE -1m ³		IODINE	
	FRISKER CPM	ION MR/HR	FRISKER CPM	PRE-FILTER TO MR/HR	CARTRIDG GM MR/HR	
	100 TO 50000 CPM	2.0 TO 50000 MR/HR	100 TO 50000 CPM	2.0 TO 50000 MR/HR	0.05 TO 999999 MR/HR	
					MIN TO MAX UNITS	
00:00	100	2.0	100	2.0	0.05	00:00
00:15	100	2.0	100	2.0	0.05	00:15
00:30	100	2.0	100	2.0	0.05	00:30
00:45	100	2.0	100	2.0	0.05	00:45
01:00	100	2.0	100	2.0	0.05	01:00
01:15	100	2.0	100	2.0	0.05	01:15
01:30	100	2.0	100	2.0	0.05	01:30
01:45	100	2.0	100	2.0	0.05	01:45
02:00	100	2.0	100	2.0	0.05	02:00
02:15	100	2.0	100	2.0	0.05	02:15
02:30	100	2.0	100	2.0	0.05	02:30
02:45	100	2.0	100	2.0	0.05	02:45
03:00	100	2.0	100	2.0	0.05	03:00
03:15	100	2.0	100	2.0	0.05	03:15
03:30	100	2.0	100	2.0	0.05	03:30
03:45	100	2.0	100	2.0	0.05	03:45
04:00	100	2.0	100	2.0	0.05	04:00
04:15	100	2.0	100	2.0	0.05	04:15
04:30	100	2.0	100	2.0	0.05	04:30
04:45	100	2.0	100	2.0	0.05	04:45
05:00	100	2.0	100	2.0	0.05	05:00
05:15	100	2.0	100	2.0	0.05	05:15
05:30	100	2.0	100	2.0	0.05	05:30
05:45	100	2.0	100	2.0	0.05	05:45
06:00	100	2.0	100	2.0	0.05	06:00
06:15	100	2.0	100	2.0	0.05	06:15
06:30	100	2.0	100	2.0	0.05	06:30

0010015068



SI
APERTURE
CARD

Also Available On
Aperture Card

UNITS

near pt. 3 is alarming!
near pt. 3 is alarming!
pped alarming.

00:00
00:15
00:30
00:45
01:00
01:15
01:30
01:45
02:00
02:15
02:30
02:45
03:00
03:15
03:30
03:45
04:00
04:15
04:30
04:45
05:00
05:15
05:30
05:45
06:00
06:15
06:30

9308100100-06

00N690 04-07-1993 12:39:42 Meter Readings - Back Side Top Left Quarter SEQUOYAH NUCLEAR PLANT
sqn93ge

SQN690
sqn93ge

SQN690 04-07-1993 12:39:42 Meter Readings - Back Side Bottom Left Quarter SEQUOYAH NUCLEAR PLANT
sqn93ge

SQN690
sqn93ge

04-07-1993 12:39:42

Meter Readings - Back Side Top Right Quarter

SEQUOYAH NUCLEAR PLANT

SI

APERTURE
CARD


90 04-07-1993 12:39:42

Meter Readings - Back Side Bottom Right Quarter

SEQUOYAH NUCLEAR PLANT

Also Available On
Aperture Card

9308100100-07




SQN690 04-07-1993 12:39:42
 sqn93ge Airborne Info SEQUOYAH NUCLEAR PLANT DRILL DATA

Data Location: pts. 1-28

Time	SURFACE CONTAM		AIR SAMPLE -1m ³		IODINE
	FRISKER	ION	PRE-FILTER		CARTRIDG
			FRISKER	ION	GM
	CPM	MR/HR	CPM	MR/HR	MR/HR
00:00	100	2.0	100	2.0	0.05
00:15	TO	TO	TO	TO	TO
00:30	50000	50000	50000	50000	999999
00:45	CPM	MR/HR	CPM	MR/HR	MR/HR
01:00	100	2.0	100	2.0	0.05
01:15	100	2.0	100	2.0	0.05
01:30	100	2.0	100	2.0	0.05
01:45	100	2.0	100	2.0	0.05
02:00	100	2.0	100	2.0	0.05
02:15	100	2.0	100	2.0	0.05
02:30	100	2.0	100	2.0	0.05
02:45	100	2.0	100	2.0	0.05
03:00	100	2.0	100	2.0	0.05
03:15	100	2.0	100	2.0	0.05
03:30	100	2.0	100	2.0	0.05
03:45	100	2.0	100	2.0	0.05
04:00	100	2.0	100	2.0	0.05
04:15	100	2.0	100	2.0	0.05
04:30	100	2.0	100	2.0	0.05
04:45	100	2.0	100	2.0	0.05
05:00	100	2.0	100	2.0	0.05
05:15	100	2.0	100	2.0	0.05
05:30	100	2.0	100	2.0	0.05
05:45	100	2.0	100	2.0	0.05
06:00	100	2.0	100	2.0	0.05
06:15	100	2.0	100	2.0	0.05
06:30	100	2.0	100	2.0	0.05

690
SQN

(U-2)



SI
APERTURE
CARD

Also Available On
Aperture Card

9308100100-08

QH669
L97939e

04-07-1993 12:39:42

Meter Readings - Back Side Top Left Quarter

SEQUOYAH NUCLEAR PLANT

SON669
san93ge

sqn669
sqn93ge

04-07-1993 12:39:42

Water Readings - Back Side Bottom Left Quarter

SEQUOYAH NUCLEAR PLANT

SQN669
sqn93ge

04-07-1993 12:39:42

Meter Readings - Back Side Top Right Quarter

SEQUOYAH NUCLEAR PLANT

61

APERTURE
CARD

9 04-07-1993 12:39:42

Meter Readings - Back Side Bottom Right Quarter

SEQUOYAH NUCLEAR PLANT

Also Available On
Aperture Card

9308100100-09

SQN669 04-07-1993 12:39:42
 sqn93ge Airborne Info SEQUOYAH NUCLEAR PLANT DRILL DATA

Data Location: pts. 1-28

Time	SURFACE CONTAM		AIR SAMPLE - 1m ³		IODINE	MIN TO MAX UNITS	
	FRISKER CPM	ION MR/HR	PRE-FILTER	FRISKER CPM	ION MR/HR		
			FRISKER TO 50000 CPM				
00:00	100	2.0	100	2.0	0.05	00:00	
00:15	100	2.0	100	2.0	0.05	00:15	
00:30	100	2.0	100	2.0	0.05	00:30	
00:45	100	2.0	100	2.0	0.05	00:45	
01:00	100	2.0	100	2.0	0.05	01:00	
01:15	100	2.0	100	2.0	0.05	01:15	
01:30	100	2.0	100	2.0	0.05	01:30	
01:45	100	2.0	100	2.0	0.05	01:45	
02:00	100	2.0	100	2.0	0.05	02:00	
02:15	100	2.0	100	2.0	0.05	02:15	
02:30	100	2.0	100	2.0	0.05	02:30	
02:45	100	2.0	100	2.0	0.05	02:45	
03:00	100	2.0	100	2.0	0.05	03:00	
03:15	100	2.0	100	2.0	0.05	03:15	
03:30	100	2.0	100	2.0	0.05	03:30	
03:45	100	2.0	100	2.0	0.05	03:45	
04:00	100	2.0	100	2.0	0.05	04:00	
04:15	100	2.0	100	2.0	0.05	04:15	
04:30	100	2.0	100	2.0	0.05	04:30	
04:45	100	2.0	100	2.0	0.05	04:45	
05:00	100	2.0	100	2.0	0.05	05:00	
05:15	100	2.0	100	2.0	0.05	05:15	
05:30	100	2.0	100	2.0	0.05	05:30	
05:45	100	2.0	100	2.0	0.05	05:45	
06:00	100	2.0	100	2.0	0.05	06:00	
06:15	100	2.0	100	2.0	0.05	06:15	
06:30	100	2.0	100	2.0	0.05	06:30	




23

25

U-2

SQN

669



SI
APERTURE
CARD

Also Available On
Aperture Card

9308100100-10

SQH653 06-24-1993
sqn93ge

Meter Readings - Back Side Top Left Quarter

SEQUOYAH NUCLEAR PLANT

52

SQN653 06-24-1993
sqn93ge

Meter Readings - Back Side Bottom Left Quarter

SEQUOYAH NUCLEAR PLANT

SC

SQN653 04-07-1993 12:39:42
sqn93ge

Meter Readings - Back Side Top Right Quarter

SEQUOYAH NUCLEAR PLANT

Location 8		Location 9		Location 10		Location 11		Location 12		Location 13		Location 14		Also Available On Aperture Card	
Closed Window mr/hr	Open Window mr/hr	00:00	00:05												
11	11	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	00:00	00:05
11	11	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	00:05	00:10
11	11	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	00:15	00:20
11	11	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	00:25	00:30
11	11	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	00:35	00:40
11	11	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	00:45	00:50
11	11	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	00:55	01:00
11	11	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	01:05	01:10
11	11	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	01:15	01:20
12	12	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	01:25	01:30
12	12	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	01:35	01:40
12	12	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	01:45	01:50
12	12	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	01:55	02:00
13	13	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	02:05	02:10
13	13	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	02:15	02:20
13	13	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	02:25	02:30

SQN653 06-24-1993
sqn93ge

Meter Readings - Back Side Bottom Right Quarter

SEQUOYAH NUCLEAR PLANT

Location 22		Location 23		Location 24		Location 25		Location 26		Location 27		Location 28			
Closed Window mr/hr	Open Window mr/hr														
0.05	0.05	0.05	0.05	0.05	0.05	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	00:00	00:05
0.05	0.05	0.05	0.05	0.05	0.05	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	00:10	00:15
0.05	0.05	0.05	0.05	0.05	0.05	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	00:20	00:25
0.05	0.05	0.05	0.05	0.05	0.05	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	00:30	00:35
0.05	0.05	0.05	0.05	0.05	0.05	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	00:40	00:45
0.05	0.05	0.05	0.05	0.05	0.05	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	00:50	00:55
0.05	0.05	0.05	0.05	0.05	0.05	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	01:00	01:05
0.05	0.05	0.05	0.05	0.05	0.05	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	01:10	01:15
0.05	0.05	0.05	0.05	0.05	0.05	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	01:20	01:25
0.05	0.05	0.05	0.05	0.05	0.05	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	01:30	01:35
0.05	0.05	0.05	0.05	0.05	0.05	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	01:40	01:45
0.05	0.05	0.05	0.05	0.05	0.05	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	01:50	01:55
0.05	0.05	0.05	0.05	0.05	0.05	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	02:00	02:05
0.05	0.05	0.05	0.05	0.05	0.05	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	02:10	02:15
0.05	0.05	0.05	0.05	0.05	0.05	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	02:20	02:25
0.05	0.05	0.05	0.05	0.05	0.05	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	02:30	

9308100100-1

SQN653
sqm93ge

06-24-1993


Airborne Info - Front Side Left Half

SEQUOYAH NUCLEAR PLANT

Time	Data Location: RHR1A-A room pt.7					Data Location: all other pts.					Data Location: pts. 8,9				
	SURFACE CONTAM		AIR SAMPLE -1m ³		IODINE CARTRIDGE	SURFACE CONTAM		AIR SAMPLE -1m ³		IODINE CARTRIDGE	SURFACE CONTAM		AIR SAMPLE -1m ³		IODINE CARTRIDGE
	FRISKER CPM	ION MR/HR	FRISKER CPM	ION MR/HR	GM MR/HR	FRISKER CPM	ION MR/HR	FRISKER CPM	ION MR/HR	GM MR/HR	FRISKER CPM	ION MR/HR	FRISKER CPM	ION MR/HR	GM MR/HR
00:00	100	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
00:05	TO	TO	TO	TO	TO	TO	TO	TO	TO	TO	TO	TO	TO	TO	TO
00:10	50000	50000	50000	50000	999999	50000	50000	50000	50000	999999	50000	50000	50000	50000	50000
00:15	CPM	MR/HR	CPM	MR/HR	MR/HR	CPM	MR/HR	CPM	MR/HR	MR/HR	CPM	MR/HR	CPM	MR/HR	CPM
00:20	100	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
00:25	100	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
00:30	100	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
00:35	100	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
00:40	100	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
00:45	100	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
00:50	3300	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
00:55	3300	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
01:00	3300	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
01:05	3300	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
01:10	3300	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
01:15	3200	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
01:20	3200	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
01:25	3200	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
01:30	3200	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
01:35	3200	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
01:40	3100	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
01:45	3100	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
01:50	3100	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
01:55	3100	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
02:00	3100	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
02:05	3000	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
02:10	3000	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
02:15	3000	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
02:20	3000	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
02:25	2900	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100
02:30	2900	2.0	100	2.0	0.05	100	2.0	100	2.0	0.05	100	2.0	100	2.0	100

SQN

653



DRILL DATA

3,12,15,18,20
after T=04:25

PLE - 1m³ LITER	IODINE CARTRIDG GM	MIN TO MAX MR/HR	Time
2.0	0.05	MIN	00:00
TO	TD	TO	00:05
50000	999999	MAX	00:10
MR/HR	MR/HR	UNITS	00:15
2.0	0.05	00:20	00:20
2.0	0.05	00:25	00:25
2.0	0.05	00:30	00:30
2.0	0.05	00:35	00:35
2.0	0.05	00:40	00:40
2.0	0.05	00:45	00:45
2.0	0.05	00:50	00:50
2.0	0.05	00:55	00:55
2.0	0.05	01:00	01:00
2.0	0.05	01:05	01:05
2.0	0.05	01:10	01:10
2.0	0.05	01:15	01:15
2.0	0.05	01:20	01:20
2.0	0.05	01:25	01:25
2.0	0.05	01:30	01:30
2.0	0.05	01:35	01:35
2.0	0.05	01:40	01:40
2.0	0.05	01:45	01:45
2.0	0.05	01:50	01:50
2.0	0.05	01:55	01:55
2.0	0.05	02:00	02:00
2.0	0.05	02:05	02:05
2.0	0.05	02:10	02:10
2.0	0.05	02:15	02:15
2.0	0.05	02:20	02:20
2.0	0.05	02:25	02:25
2.0	0.05	02:30	02:30

Radcon Controller Notes!

The dose rates on Elev. 653 in this package are based upon the assumption that flood calculation package A-15 is valid. If another flood calculation package is valid then the radiological conditions for each point on elev. 653 will remain constant from the time that the leak is stopped if you are unsure check with your lead controller as to what the correct radiological conditions should be for Elev. 653.

SI APERTURE CARD

Also Available On
Aperture Card

Leak begins in RHR1A-A pump room! There are messages that can be given to players that arrive at the scene. Give water levels based upon the correct flood calculation package(your lead controller can assist you in determining the appropriate package).

00:00
00:05
00:10
00:15
00:20
00:25
00:30
00:35
00:40
00:45
00:50
00:55
01:00
01:05
01:10
01:15
01:20
01:25
01:30
01:35
01:40
01:45
01:50
01:55
02:00
02:05
02:10
02:15
02:20
02:25
02:30

9308100100-12

SQN653
sqn93ge

04-07-1993 12:24:08

Meter Readings - Back Side Top Left Quarter

SEQUOYAH NUCLEAR PLANT

SQN
sqn

Time	Location 1		Location 2		Location 3		Location 4		Location 5		Location 6		Location 7	
	Closed Window mr/hr	Open Window mr/hr												
02:35	0.11	0.11	0.22	0.22	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	3.1	3.1
02:40	0.19	0.19	0.39	0.39	0.06	0.06	0.05	0.05	0.05	0.05	0.05	0.05	3.0	3.0
02:45	0.21	0.21	0.42	0.42	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	3.0	3.0
02:50	0.25	0.25	0.50	0.50	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	3.0	3.0
02:55	0.24	0.24	0.48	0.48	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	3.0	3.0
03:00	0.26	0.26	0.52	0.52	0.09	0.09	0.05	0.05	0.05	0.05	0.05	0.05	2.9	2.9
03:05	0.25	0.25	0.50	0.50	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.9	2.9
03:10	0.26	0.26	0.52	0.52	0.09	0.09	0.05	0.05	0.05	0.05	0.05	0.05	2.9	2.9
03:15	0.25	0.25	0.50	0.50	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.9	2.9
03:20	0.25	0.25	0.51	0.51	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.8	2.8
03:25	0.25	0.25	0.50	0.50	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.8	2.8
03:30	0.25	0.25	0.51	0.51	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.8	2.8
03:35	0.25	0.25	0.50	0.50	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.8	2.8
03:40	0.25	0.25	0.50	0.50	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.7	2.7
03:45	0.24	0.24	0.49	0.49	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.7	2.7
03:50	0.24	0.24	0.49	0.49	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.7	2.7
03:55	0.24	0.24	0.48	0.48	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.7	2.7
04:00	0.24	0.24	0.48	0.48	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.7	2.7
04:05	0.24	0.24	0.48	0.48	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.6	2.6
04:10	0.23	0.23	0.47	0.47	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.6	2.6
04:15	0.23	0.23	0.47	0.47	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.6	2.6
04:20	0.23	0.23	0.47	0.47	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.6	2.6
04:25	0.23	0.23	0.46	0.46	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.6	2.6
04:30	0.23	0.23	0.46	0.46	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	2.5	2.5
04:45	0.23	0.23	0.46	0.46	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	2.5	2.5
05:00	2.3	2.3	4.9	4.9	.85	.85	0.05	0.05	0.05	0.05	0.05	0.05	2.4	2.4
05:15	4.6	4.6	9.7	9.7	1.6	1.6	0.05	0.05	0.05	0.05	0.05	0.05	2.4	2.5
05:30	6.6	6.6	13	13	2.3	2.3	0.05	0.05	0.05	0.05	0.05	0.05	2.3	2.5
05:45	6.4	6.4	12	12	2.2	2.2	0.05	0.05	0.05	0.05	0.05	0.05	2.3	2.4
06:00	6.3	6.3	12	12	2.2	2.2	0.05	0.05	0.05	0.05	0.05	0.05	2.2	2.4
06:15	6.1	6.1	12	12	2.1	2.1	0.05	0.05	0.05	0.05	0.05	0.05	2.2	2.3
06:30	6.0	6.0	12	12	2.1	2.1	0.05	0.05	0.05	0.05	0.05	0.05	2.1	2.3

SQN653
06-24-1993
sqn93ge

Meter Readings - Back Side Bottom Left Quarter

SEQUOYAH NUCLEAR PLANT

SQI
sqi

Time	Location 15		Location 16		Location 17		Location 18		Location 19		Location 20		Location 21	
	Closed Window mr/hr	Open Window mr/hr												
02:35	0.07	0.07	0.05	0.05	0.05	0.05	0.14	0.14	0.05	0.05	0.12	0.12	0.05	0.05
02:40	0.12	0.12	0.05	0.05	0.05	0.05	0.25	0.25	0.05	0.05	0.27	0.27	0.05	0.05
02:45	0.13	0.13	0.05	0.05	0.05	0.05	0.27	0.27	0.05	0.05	0.23	0.23	0.05	0.05
02:50	0.16	0.16	0.05	0.05	0.05	0.05	0.32	0.32	0.05	0.05	0.33	0.33	0.05	0.05
02:55	0.15	0.15	0.05	0.05	0.05	0.05	0.32	0.32	0.05	0.05	0.28	0.28	0.05	0.05
03:00	0.17	0.17	0.05	0.05	0.05	0.05	0.34	0.34	0.05	0.05	0.34	0.34	0.05	0.05
03:05	0.16	0.16	0.05	0.05	0.05	0.05	0.33	0.33	0.05	0.05	0.31	0.31	0.05	0.05
03:10	0.17	0.17	0.05	0.05	0.05	0.05	0.34	0.34	0.05	0.05	0.31	0.31	0.05	0.05
03:15	0.16	0.16	0.05	0.05	0.05	0.05	0.33	0.33	0.05	0.05	0.30	0.30	0.05	0.05
03:20	0.16	0.16	0.05	0.05	0.05	0.05	0.33	0.33	0.05	0.05	0.31	0.31	0.05	0.05
03:25	0.16	0.16	0.05	0.05	0.05	0.05	0.32	0.32	0.05	0.05	0.30	0.30	0.05	0.05
03:30	0.16	0.16	0.05	0.05	0.05	0.05	0.32	0.32	0.05	0.05	0.30	0.30	0.05	0.05
03:35	0.16	0.16	0.05	0.05	0.05	0.05	0.32	0.32	0.05	0.05	0.30	0.30	0.05	0.05
03:40	0.16	0.16	0.05	0.05	0.05	0.05	0.32	0.32	0.05	0.05	0.30	0.30	0.05	0.05
03:45	0.16	0.16	0.05	0.05	0.05	0.05	0.32	0.32	0.05	0.05	0.29	0.29	0.05	0.05
03:50	0.16	0.16	0.05	0.05	0.05	0.05	0.31	0.31	0.05	0.05	0.29	0.29	0.05	0.05
03:55	0.15	0.15	0.05	0.05	0.05	0.05	0.31	0.31	0.05	0.05	0.29	0.29	0.05	0.05
04:00	0.15	0.15	0.05	0.05	0.05	0.05	0.31	0.31	0.05	0.05	0.29	0.29	0.05	0.05
04:05	0.15	0.15	0.05	0.05	0.05	0.05	0.31	0.31	0.05	0.05	0.28	0.28	0.05	0.05
04:10	0.15	0.15	0.05	0.05	0.05	0.05	0.31	0.31	0.05	0.05	0.28	0.28	0.05	0.05
04:15	0.15	0.15	0.05	0.05	0.05	0.05	0.30	0.30	0.05	0.05	0.28	0.28	0.05	0.05
04:20	0.15	0.15	0.05	0.05	0.05	0.05	0.30	0.30	0.05	0.05	0.28	0.28	0.05	0.05
04:25	0.14	0.14	0.05	0.05	0.05	0.05	0.30	0.30	0.05	0.05	0.28	0.28	0.05	0.05
04:30	0.14	0.14	0.05	0.05	0.05	0.05	0.30	0.30	0.05	0.05	0.28	0.28	0.05	0.05
04:35	0.14	0.14	0.05	0.05	0.05	0.05	0.30	0.30	0.05	0.05	0.28	0.28	0.05	0.05
05:00	0.64	0.64	0.05	0.05	0.05	0.05	1.3	1.3	0.05	0.05	1.2	1.2	0.05	0.05
05:15	2.0	2.0	0.05	0.05	0.05	0.05	4.4	4.4	0.05	0.05	4.1	2.1	0.05	0.05
05:30	3.6	3.6	0.05	0.05	0.05	0.05	8.0	8.0	0.05	0.05	7.7	3.0	0.05	0.05
05:45	4.2	4.2	0.05	0.05	0.05	0.05	9.8	9.8	0.05	0.05	9.3	6.1	0.05	0.05
06:00	4.1	4.1	0.05	0.05	0.05	0.05	9.5	9.5	0.05	0.05	9.1	9.0	0.05	0.05
06:15	4.0	4.0	0.05	0.05	0.05	0.05	9.3	9.3	0.05	0.05	8.9	8.8	0.05	0.05
06:30	3.9	3.9	0.05	0.05	0.05	0.05	9.1	9.1	0.05	0.05	8.7	8.6	0.05	0.05

-0093-06

ISSN 2334-233X • 1833-0367-007-005

Meter Readings - Back side Top Right Quarter

SEQUOYAH NUCLEAR PLANT

SON653

06-24-1993

Meter Readings - Back Side Bottom Right Quarter

SEQUOYAH NUCLEAR PLANT

9308100100-13

SQN653
sqn93ge

06-24-1993


Airborne Info - Front Side Left Half

SEQUOYAH NUCLEAR PLANT

Time	Data Location: RHR1A-A room pt.7					Data Location: all other pts.					Data Location:					
	SURFACE CONTAM		AIR SAMPLE -1m ³		IODINE	SURFACE CONTAM		AIR SAMPLE -1m ³		IODINE	SURFACE CONTAM		FRISKER		ION	
	FRISKER	ION	PRE-FILTER	FRISKER	ION	GM	FRISKER	ION	PRE-FILTER	FRISKER	ION	GM	CPM	MR/HR	CPM	MR/HR
	100	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	100	2.0		
	TO	TO		TO	TO	TO	TO	TO		TO	TO	TO	TO	TO		
	50000	50000		50000	50000	999999	50000	50000		50000	50000	999999	50000	50000		
	CPM	MR/HR		CPM	MR/HR	HR/HR	CPM	MR/HR		CPM	MR/HR	MR/HR	CPM	MR/HR		
02:35	2900	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	1200	2.0		
02:40	2900	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2000	2.0		
02:45	2800	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2300	2.0		
02:50	2800	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2600	2.0		
02:55	2800	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2700	2.0		
03:00	2800	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2700	2.0		
03:05	2700	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2700	2.0		
03:10	2700	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2700	2.0		
03:15	2700	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2700	2.0		
03:20	2700	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2700	2.0		
03:25	2600	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2700	2.0		
03:30	2600	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2700	2.0		
03:35	2600	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2600	2.0		
03:40	2600	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2600	2.0		
03:45	2600	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2600	2.0		
03:50	2500	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2600	2.0		
03:55	2500	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2600	2.0		
04:00	2500	2.0		100	2.0	0.25	100	2.0		100	2.0	0.05	2500	2.0		
04:05	2500	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2500	2.0		
04:10	2500	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2500	2.0		
04:15	2400	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2500	2.0		
04:20	2400	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2500	2.0		
04:25	2400	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2400	2.0		
04:30	2400	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2400	2.0		
04:45	2400	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2400	2.0		
05:00	2300	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2300	2.0		
05:15	2300	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2200	2.0		
05:30	2300	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2200	2.0		
05:45	2200	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2100	2.0		
06:00	2200	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2100	2.0		
06:15	2100	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2000	2.0		
06:30	2100	2.0		100	2.0	0.05	100	2.0		100	2.0	0.05	2000	2.0		

SQN

653



DRILL DATA

s. 1,2,3,12,15,18,20
 s. 8,9 after T=04:25

AIR SAMPLE -1m ³	100INE PRE-FILTER	CARTRIDGE
FRISKER	ION CPM	GM MR/HR
100	2.0	0.05
TO	TO	TO
50000	50000	999999
CPM	MR/HR	MR/HR
MIN	TO	
MAX	TO	
UNITS		
Time		
100	2.0	0.05
	02:35	02:35
100	2.0	0.05
	02:40	02:40
100	2.0	0.05
	02:45	02:45
100	2.0	0.05
	02:50	02:50
100	2.0	0.05
	02:55	02:55
100	2.0	0.05
	03:00	03:00
100	2.0	0.05
	03:05	03:05
100	2.0	0.05
	03:10	03:10
100	2.0	0.05
	03:15	03:15
100	2.0	0.05
	03:20	03:20
100	2.0	0.05
	03:25	03:25
100	2.0	0.05
	03:30	03:30
100	2.0	0.05
	03:35	03:35
100	2.0	0.05
	03:40	03:40
100	2.0	0.05
	03:45	03:45
100	2.0	0.05
	03:50	03:50
100	2.0	0.05
	03:55	03:55
100	2.0	0.05
	04:00	04:00
100	2.0	0.05
	04:05	04:05
100	2.0	0.05
	04:10	04:10
100	2.0	0.05
	04:15	04:15
100	2.0	0.05
	04:20	04:20
100	2.0	0.05
	04:25	04:25
100	2.0	0.05
	04:30	04:30
100	2.0	0.05
	04:45	04:45
100	2.0	0.05
	05:00	05:00
100	2.0	0.05
	05:15	05:15
100	2.0	0.05
	05:30	05:30
100	2.0	0.05
	05:45	05:45
100	2.0	0.05
	06:00	06:00
100	2.0	0.05
	06:15	06:15
100	2.0	0.05
	06:30	06:30

Radcon Controller Notes:

The dose rates on Elev. 653 in this package are based upon the assumption that flood calculation package A-15 is valid. If another flood calculation package is valid then the radiological conditions for each point on elev. 653 will remain constant from the time that the leak is stopped if you are unsure check with your lead controller as to what the correct radiological conditions should be for Elev. 653.

If using a flood control package A-5 to A-15 then water will begin to leak from RHR1A-A pump room onto the main elev. 653. To determine the correct flood calculation package consult with your lead controller. Give water levels based upon the correct flood calculation package.

SI

APERTURE
CARDAlso Available On
Aperture Card



9308100100-14

5QN669 04-07-1993 12:39:42
 sqn93ge Airborne Info SEQUOYAH NUCLEAR PLANT DRILL DATA

Time	Data Location: pts. 1-28					
	SURFACE CONTAM		AIR SAMPLE -1m ³		IODINE CARTRIDGE	
	FRISKER CPM	ION MR/HR	FRISKER CPM	ION MR/HR	GM	MR/HR
00:00	100 TO 50000 CPM	2.0 TO 50000 MR/HR	100 TO 50000 CPM	2.0 TO 50000 MR/HR	0.05 TO 999999 MR/HR	MIN TO MAX UNITS
00:15	100	2.0	100	2.0	0.05	00:00
00:30	100	2.0	100	2.0	0.05	00:15
00:45	100	2.0	100	2.0	0.05	00:30
01:00	100	2.0	100	2.0	0.05	00:45
01:15	100	2.0	100	2.0	0.05	01:00
01:30	100	2.0	100	2.0	0.05	01:15
01:45	100	2.0	100	2.0	0.05	01:30
02:00	100	2.0	100	2.0	0.05	01:45
02:15	100	2.0	100	2.0	0.05	02:00
02:30	100	2.0	100	2.0	0.05	02:15
02:45	100	2.0	100	2.0	0.05	02:30
03:00	100	2.0	100	2.0	0.05	02:45
03:15	100	2.0	100	2.0	0.05	03:00
03:30	100	2.0	100	2.0	0.05	03:15
03:45	100	2.0	100	2.0	0.05	03:30
04:00	100	2.0	100	2.0	0.05	03:45
04:15	100	2.0	100	2.0	0.05	04:00
04:30	100	2.0	100	2.0	0.05	04:15
04:45	100	2.0	100	2.0	0.05	04:30
05:00	100	2.0	100	2.0	0.05	04:45
05:15	100	2.0	100	2.0	0.05	05:00
05:30	100	2.0	100	2.0	0.05	05:15
05:45	100	2.0	100	2.0	0.05	05:30
06:00	100	2.0	100	2.0	0.05	05:45
06:15	100	2.0	100	2.0	0.05	06:00
06:30	100	2.0	100	2.0	0.05	06:15
						06:30

SQN
669
SI
APERTURE
CARD

Also Available On
Aperture Card



9308100100-15

SDN653
san93g

06-24-1993

Meter Readings - Back Side Top Left Quarter

SEQUOYAH NUCLEAR PLANT

56

SQN653
san93ge

06-24-1993

501
502

SON457

04-07-1993 12:39:42

Meter Readings → Back Side Top Right Quarter

SEQUOYAH NUCLEAR PLANT

30N653

06-24-1993

Meter Readings + Back Side Bottom Right Quarter

SEQUOYAH NUCLEAR PLANT

9308100100 - 16

SQN653
sqn93ge

06-24-1993


Airborne Info - Front Side Left Half

SEQUOYAH NUCLEAR PLANT

Time	Data Location: RHR1A-A room pt.7				Data Location: all other pts.				Data Location: pts. 8, 9, 10				Data Location: pts. 8, 9, 10			
	SURFACE CONTAM		AIR SAMPLE -1m ³		IODINE CARTRIDGE		SURFACE CONTAM		AIR SAMPLE -1m ³		IODINE CARTRIDGE		SURFACE CONTAM		AIR SAMPLE -1m ³	
	FRISKER CPM	ION MR/HR	PRE-FILTER CPM	ION MR/HR	GM CPM	MR/HR	FRISKER CPM	ION MR/HR	PRE-FILTER CPM	ION MR/HR	GM CPM	MR/HR	FRISKER CPM	ION MR/HR	PRE-FILTER CPM	FRISKER CPM
00:00	100 50000	2.0 50000	100 50000	2.0 50000	0.05 999999		100 50000	2.0 50000	100 50000	2.0 50000	0.05 999999		100 50000	2.0 50000	100 50000	2.0 50000
00:05	100	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
00:10	100	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
00:15	100	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
00:20	100	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
00:25	100	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
00:30	100	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
00:35	100	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
00:40	100	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
00:45	100	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
00:50	3300	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
00:55	3300	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
01:00	3300	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
01:05	3300	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
01:10	3300	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
01:15	3200	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
01:20	3200	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
01:25	3200	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
01:30	3200	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
01:35	3200	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
01:40	3100	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
01:45	3100	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
01:50	3100	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
01:55	3100	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
02:00	3100	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
02:05	3000	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
02:10	3000	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
02:15	3000	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
02:20	3000	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
02:25	2900	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0
02:30	2900	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	100	2.0

SQN

653



DRILL DATA
12,15,18,20
ter T=04:25

E - 1m3	100INE	Time
TER	CARTRIDG	
ION	GM	
MR/HR	MR/HR	
2.0	0.05	MIN
TO	TO	TO
50000	999999	MAX
MR/HR	MR/HR	UNITS
2.0	0.05	00:00
2.0	0.05	00:05
2.0	0.05	00:10
2.0	0.05	00:15
2.0	0.05	00:20
2.0	0.05	00:25
2.0	0.05	00:30
2.0	0.05	00:35
2.0	0.05	00:40
2.0	0.05	00:45
2.0	0.05	00:50
2.0	0.05	00:55
2.0	0.05	01:00
2.0	0.05	01:05
2.0	0.05	01:10
2.0	0.05	01:15
2.0	0.05	01:20
2.0	0.05	01:25
2.0	0.05	01:30
2.0	0.05	01:35
2.0	0.05	01:40
2.0	0.05	01:45
2.0	0.05	01:50
2.0	0.05	01:55
2.0	0.05	02:00
2.0	0.05	02:05
2.0	0.05	02:10
2.0	0.05	02:15
2.0	0.05	02:20
2.0	0.05	02:25
2.0	0.05	02:30

Radcon Controller Notes:

The dose rates on Elev. 653 in this package are based upon the assumption that flood calculation package A-15 is valid. If another flood calculation package is valid then the radiological conditions for each point on elev. 653 will remain constant from the time that the leak is stopped if you are unsure check with your lead controller as to what the correct radiological conditions should be for Elev. 653.

SI
APERTURE
CARD

Also Available On
Aperture Card

Leak begins in RHR1-A pump room! There are messages that can be given to players that arrive at the scene. Give water levels based upon the correct flood calculation package(your lead controller can assist you in determining the appropriate package).

00:00
00:05
00:10
00:15
00:20
00:25
00:30
00:35
00:40
00:45
00:50
00:55
01:00
01:05
01:10
01:15
01:20
01:25
01:30
01:35
01:40
01:45
01:50
01:55
02:00
02:05
02:10
02:15
02:20
02:25
02:30

9308100100 - 17

SQN653
sqn93ge

04-07-1993 12:24:08

Meter Readings - Back Side Top Left Quarter

SEQUOYAH NUCLEAR PLANT

Time	Location 1		Location 2		Location 3		Location 4		Location 5		Location 6		Location 7	
	Closed Window mr/hr	Open Window mr/hr												
02:35	0.11	0.11	0.22	0.22	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	3.1	3.1
02:40	0.19	0.19	0.39	0.39	0.06	0.06	0.05	0.05	0.05	0.05	0.05	0.05	3.0	3.0
02:45	0.21	0.21	0.42	0.42	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	3.0	3.0
02:50	0.25	0.25	0.50	0.50	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	3.0	3.0
02:55	0.24	0.24	0.48	0.48	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	3.0	3.0
03:00	0.26	0.26	0.52	0.52	0.09	0.09	0.05	0.05	0.05	0.05	0.05	0.05	2.9	2.9
03:05	0.25	0.25	0.50	0.50	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.9	2.9
03:10	0.26	0.26	0.52	0.52	0.09	0.09	0.05	0.05	0.05	0.05	0.05	0.05	2.9	2.9
03:15	0.25	0.25	0.50	0.50	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.9	2.9
03:20	0.25	0.25	0.51	0.51	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.8	2.8
03:25	0.25	0.25	0.50	0.50	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.8	2.8
03:30	0.25	0.25	0.51	0.51	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.8	2.8
03:35	0.25	0.25	0.50	0.50	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.8	2.8
03:40	0.25	0.25	0.50	0.50	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.7	2.7
03:45	0.24	0.24	0.49	0.49	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.7	2.7
03:50	0.24	0.24	0.49	0.49	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.7	2.7
03:55	0.24	0.24	0.48	0.48	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.7	2.7
04:00	0.24	0.24	0.48	0.48	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.7	2.7
04:05	0.24	0.24	0.48	0.48	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.6	2.6
04:10	0.23	0.23	0.47	0.47	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.6	2.6
04:15	0.23	0.23	0.47	0.47	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.6	2.6
04:20	0.23	0.23	0.47	0.47	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.6	2.6
04:25	0.23	0.23	0.46	0.46	0.08	0.08	0.05	0.05	0.05	0.05	0.05	0.05	2.6	2.6
04:30	0.23	0.23	0.46	0.46	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	2.5	2.5
04:45	0.23	0.23	0.46	0.46	0.07	0.07	0.05	0.05	0.05	0.05	0.05	0.05	2.5	2.5
05:00	2.3	2.3	4.9	4.9	.85	.85	0.05	0.05	0.05	0.05	0.05	0.05	2.4	2.4
05:15	4.6	4.6	9.7	9.7	1.6	1.6	0.05	0.05	0.05	0.05	0.05	0.05	2.4	2.5
05:30	6.6	6.6	13	13	2.3	2.3	0.05	0.05	0.05	0.05	0.05	0.05	2.3	2.5
05:45	6.4	6.4	12	12	2.2	2.2	0.05	0.05	0.05	0.05	0.05	0.05	2.3	2.4
06:00	6.3	6.3	12	12	2.2	2.2	0.05	0.05	0.05	0.05	0.05	0.05	2.2	2.4
06:15	6.1	6.1	12	12	2.1	2.1	0.05	0.05	0.05	0.05	0.05	0.05	2.2	2.3
06:30	6.0	6.0	12	12	2.1	2.1	0.05	0.05	0.05	0.05	0.05	0.05	2.1	2.3

SQN653 06-24-1993

sqn93ge

Meter Readings - Back Side Bottom Left Quarter

SEQUOYAH NUCLEAR PLANT

Time	Location 15		Location 16		Location 17		Location 18		Location 19		Location 20		Location 21	
	Closed Window mr/hr	Open Window mr/hr												
02:35	0.07	0.07	0.05	0.05	0.05	0.05	0.14	0.14	0.05	0.05	0.12	0.12	0.05	0.05
02:40	0.12	0.12	0.05	0.05	0.05	0.05	0.25	0.25	0.05	0.05	0.27	0.27	0.05	0.05
02:45	0.13	0.13	0.05	0.05	0.05	0.05	0.27	0.27	0.05	0.05	0.23	0.23	0.05	0.05
02:50	0.16	0.16	0.05	0.05	0.05	0.05	0.32	0.32	0.05	0.05	0.33	0.33	0.05	0.05
02:55	0.15	0.15	0.05	0.05	0.05	0.05	0.32	0.32	0.05	0.05	0.28	0.28	0.05	0.05
03:00	0.17	0.17	0.05	0.05	0.05	0.05	0.34	0.34	0.05	0.05	0.34	0.34	0.05	0.05
03:05	0.16	0.16	0.05	0.05	0.05	0.05	0.33	0.33	0.05	0.05	0.31	0.31	0.05	0.05
03:10	0.17	0.17	0.05	0.05	0.05	0.05	0.34	0.34	0.05	0.05	0.31	0.31	0.05	0.05
03:15	0.16	0.16	0.05	0.05	0.05	0.05	0.33	0.33	0.05	0.05	0.30	0.30	0.05	0.05
03:20	0.16	0.16	0.05	0.05	0.05	0.05	0.33	0.33	0.05	0.05	0.31	0.31	0.05	0.05
03:25	0.16	0.16	0.05	0.05	0.05	0.05	0.32	0.32	0.05	0.05	0.30	0.30	0.05	0.05
03:30	0.16	0.16	0.05	0.05	0.05	0.05	0.32	0.32	0.05	0.05	0.30	0.30	0.05	0.05
03:35	0.16	0.16	0.05	0.05	0.05	0.05	0.32	0.32	0.05	0.05	0.30	0.30	0.05	0.05
03:40	0.16	0.16	0.05	0.05	0.05	0.05	0.32	0.32	0.05	0.05	0.30	0.30	0.05	0.05
03:45	0.16	0.16	0.05	0.05	0.05	0.05	0.32	0.32	0.05	0.05	0.29	0.29	0.05	0.05
03:50	0.16	0.16	0.05	0.05	0.05	0.05	0.31	0.31	0.05	0.05	0.29	0.29	0.05	0.05
03:55	0.15	0.15	0.05	0.05	0.05	0.05	0.31	0.31	0.05	0.05	0.29	0.29	0.05	0.05
04:00	0.15	0.15	0.05	0.05	0.05	0.05	0.31	0.31	0.05	0.05	0.29	0.29	0.05	0.05
04:05	0.15	0.15	0.05	0.05	0.05	0.05	0.31	0.31	0.05	0.05	0.28	0.28	0.05	0.05
04:10	0.15	0.15	0.05	0.05	0.05	0.05	0.31	0.31	0.05	0.05	0.28	0.28	0.05	0.05
04:15	0.15	0.15	0.05	0.05	0.05	0.05	0.30	0.30	0.05	0.05	0.28	0.28	0.05	0.05
04:20	0.15	0.15	0.05	0.05	0.05	0.05	0.30	0.30	0.05	0.05	0.28	0.28	0.05	0.05
04:25	0.14	0.14	0.05	0.05	0.05	0.05	0.30	0.30	0.05	0.05	0.28	0.28	0.05	0.05
04:30	0.14	0.14	0.05	0.05	0.05	0.05	0.30	0.30	0.05	0.05	0.28	0.28	0.05	0.05
04:45	0.14	0.14	0.05	0.05	0.05	0.05	0.30	0.30	0.05	0.05	0.28	0.28	0.05	0.05
05:00	0.64	0.64	0.05	0.05	0.05	0.05	1.3	1.3	0.05	0.05	1.2	1.2	0.05	0.05
05:15	2.0	2.0	0.05	0.05	0.05	0.05	4.4	4.4	0.05	0.05	4.1	2.1	0.05	0.05
05:30	3.6	3.6	0.05	0.05	0.05	0.05	8.0	8.0	0.05	0.05	7.7	3.0	0.05	0.05
05:45	4.2	4.2	0.05	0.05	0.05	0.05	9.8	9.8	0.05	0.05	9.3	6.1	0.05	0.05
06:00	4.1	4.1	0.05	0.05	0.05	0.05	9.5	9.5	0.05	0.05	9.1	9.0	0.05	0.05
06:15	4.0	4.0	0.05	0.05	0.05	0.05	9.3	9.3	0.05	0.05	8.9	8.8	0.05	0.05
06:30	3.9	3.9	0.05	0.05	0.05	0.05	9.1	9.1	0.05	0.05	8.7	8.6	0.05	0.05

四九三

Meter Readings - Back Side Top Right Quarter

SEQUOYAH NUCLEAR PLANT

5 | 06:30

**APERTURE
CARD**

06-24-1993

sqn93ge

Meter Readings : Back side Bottom Right Quarter

SEQUOYAH NUCLEAR PLANT

02:35 Available
02:40 Departure

02:55
03:00
03:05
03:10
03:15
03:20
03:25
03:30
03:35
03:40
03:45
03:50
03:55
04:00
04:05
04:10
04:15
04:20
04:25
04:30
9308100100- / 8

9308100100- /8

SQN653
sqn93ge

06-24-1993


Airborne Info - Front Side Left Half

SEQUOYAH NUCLEAR PLAN

Time	Data Location: RHR1A-A room pt.7						Data Location: all other pts.						Data Location:		
	SURFACE CONTAM		AIR SAMPLE -1m ³		IODINE	CARTRIDGE	SURFACE CONTAM		AIR SAMPLE -1m ³		IODINE	CARTIDGE	FRISKER	ION	
	FRISKER	ION	PRE-FILTER	GM			FRISKER	ION	PRE-FILTER	GM			CPM	MR/HR	
	CPM	MR/HR	CPM	MR/HR	MR/HR		CPM	MR/HR	CPM	MR/HR	MR/HR		CPM	MR/HR	
02:35	100	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		100	2.0	
02:40	TO	TO	TO	TO	TO		TO	TO	TO	TO	TO		TO	TO	
02:45	50000	50000	50000	50000	999999		50000	50000	50000	50000	999999		50000	50000	
02:50	CPM	MR/HR	CPM	MR/HR	MR/HR		CPM	MR/HR	CPM	MR/HR	MR/HR		CPM	MR/HR	
02:55	2800	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2700	2.0	
03:00	2800	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2700	2.0	
03:05	2700	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2700	2.0	
03:10	2700	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2700	2.0	
03:15	2700	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2700	2.0	
03:20	2700	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2700	2.0	
03:25	2600	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2700	2.0	
03:30	2600	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2700	2.0	
03:35	2600	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2600	2.0	
03:40	2600	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2600	2.0	
03:45	2600	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2600	2.0	
03:50	2500	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2600	2.0	
03:55	2500	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2600	2.0	
04:00	2500	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2500	2.0	
04:05	2500	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2500	2.0	
04:10	2500	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2500	2.0	
04:15	2400	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2500	2.0	
04:20	2400	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2500	2.0	
04:25	2400	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2400	2.0	
04:30	2400	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2400	2.0	
04:45	2400	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2400	2.0	
05:00	2300	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2300	2.0	
05:15	2300	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2200	2.0	
05:30	2300	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2200	2.0	
05:45	2200	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2100	2.0	
06:00	2200	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2100	2.0	
06:15	2100	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2000	2.0	
06:30	2100	2.0	100	2.0	0.05		100	2.0	100	2.0	0.05		2000	2.0	

SQN

653



DRILL DATA

1,2,3,12,15,18,20
8,9 after T=04:25

R SAMPLE	-1m3	IODINE
PRE-FILTER		CARTRIDG
ISKER	ION	GM
CP4	MR/HR	MR/HR
100	2.0	0.05
TO	TO	TO
000	50000	999999
CPM	MR/HR	MR/HR

MIN	TO	MAX	UNITS	Time
02:35				02:35
02:40				02:40
02:45				02:45
02:50				02:50
02:55				02:55
03:00				03:00
03:05				03:05
03:10				03:10
03:15				03:15
03:20				03:20
03:25				03:25
03:30				03:30
03:35				03:35
03:40				03:40
03:45				03:45
03:50				03:50
03:55				03:55
04:00				04:00
04:05				04:05
04:10				04:10
04:15				04:15
04:20				04:20
04:25				04:25
04:30				04:30
04:45				04:45
05:00				05:00
05:15				05:15
05:30				05:30
05:45				05:45
06:00				06:00
06:15				06:15
06:30				06:30

Radcon Controller Notes:

The dose rates on Elev. 653 in this package are based upon the assumption that flood calculation package A-15 is valid. If another flood calculation package is valid then the radiological conditions for each point on elev. 653 will remain constant from the time that the leak is stopped if you are unsure check with your lead controller as to what the correct radiological conditions should be for Elev. 653.

If using a flood control package A-5 to A-15 then water will begin to leak from RHR1A-A pump room onto the main elev. 653. To determine the correct flood calculation package consult with your lead controller. Give water levels based upon the correct flood calculation package.

SI

APERTURE

CARD

Also Available On
Aperture Card

9308100100 - 19

MANUFACTURE OF POLY(1,3-PHENYLENE TEREPHTHALIC ACID) COPOLYMERS

OVERALL RADICALISATION AND TOR LEVELS

RADIATION MONITOR READINGS (UNITS AS SPECIFIED) FOR GENERAL MONITORS

TIME IN MINUTES	CONTROL ROOM MONITORS						UNIT 1 SHIELD BLDG			UNIT 2 SHIELD BLDG		
	105	125	126	205	206	400	260	261	400	260	261	MIN MR/HR
	10	10	10	10	10	0.01	0.1	1000 to 1.0E+7 MR/HR	0.01 to 1.0E+4 MR/HR	0.1 to 1.0E+4 MR/HR	1.0E+3 to 1.0E+7 MR/HR	MAX MR/HR
	to 1.0E+7 CPM	to 1.0E+7 CPM	to 1.0E+7 CPM	to 1.0E+7 CPM	to 1.0E+7 CPM	0.01 to 9.9E+9 UCi/S	0.1 to 1.0E+4 UCi/S	1.0E+3 to 9.9E+9 UCi/S	0.01 to 1.0E+7 UCi/S	0.1 to 1.0E+7 UCi/S	1.0E+3 to 1.0E+7 UCi/S	UNITS
00:00	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	00:00
00:05	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	00:05
00:10	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	00:10
00:15	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	00:15
00:20	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	00:20
00:25	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	00:25
00:30	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	00:30
00:35	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	00:35
00:40	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	00:40
00:45	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	00:45
00:50	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	00:50
00:55	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	00:55
01:00	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	01:00
01:05	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	01:05
01:10	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	01:10
01:15	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	01:15
01:20	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	01:20
01:25	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	01:25
01:30	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	01:30
01:35	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	01:35
01:40	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	01:40
01:45	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	01:45
01:50	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	01:50
01:55	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	01:55
02:00	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	02:00
02:05	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	02:05
02:10	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	02:10
02:15	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	02:15
02:20	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	02:20
02:25	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	02:25
02:30	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	02:30
02:35	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	02:35
02:40	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	02:40
02:45	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	02:45
02:50	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	02:50
02:55	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	02:55
03:00	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	03:00
03:05	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	03:05
03:10	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	03:10
03:15	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E+1	1.0E-2	1.0E-1	1.0E+3	1.0E-2	1.0E+3	03:15

SEQUOYAH NUCLEAR PLANT

DRILL DATA

OVERALL RADIATION MONITOR LEVELS

PANICON WORKTOP READINGS CLINICS AS SPECIFIED) FOR CENTRAL MONITORS

SECONDARY MUCICRUST DISEASE

DIGITAL DATA

OVERALL RADIATION MONITOR LEVELS

MANUFACTURERS MONITOR BEARING LIMITS AS COEFFICIENTS AND CENCOAI MULTIBE

OVERALL RADIATION MONITOR LEVELS

SEQUOIAH NUCLEAR PLANT

DRILL DATA

OVERALL RADIATION MONITOR LEVELS

RADIATION MONITOR READINGS UNITS AS SPECIFIED FOR GENERAL MONITORS

SEGUAYA MUCIFAR PLANT

DRILL DATA

OVERALL RADIATION MONITOR LEVELS

POLYMER LETTERS EDITION

OVERALL PREDICTION MONITORING LEVELS

SANDSTROM MONITORING STUDY

OVERVIEW PUBLICATION MONITORING SERVICES

8 ADY

LIMITS AS SPECIESTHESY FOR CENEAL MORTALITY

SEQUOYAH NUCLEAR PLANT

ORIGIN DATA

OVERALL RADIATION MONITOR LEVELS

OVERALL RADIATION MONITOR LEVELS AND UNITS (UNITS AS SPECIFIED) FOR GENERAL MONITORS

RADIATION MONITOR DATA RADIATION MONITOR READINGS (UNITS AS SPECIFIED) AND CENSUS MONITOR LEVELS

OVERALL RADIATION MONITOR LEVELS

104

DRAFTS OF THE BIBLICAL WOOD BEAD AND PINE NEEDLE CROWN

SQNRM0N8.PRN
06-24-1993

sgn93 ge

SEQUOYAH NUCLEAR PLANT

DRILL DATA

OVERALL RADIATION MONITOR LEVELS

OVERALL PUBLICATION MONITORING LEVELS

END-OF-PERIOD MONITORING LEVELS

Meteorological Data for SQN 1993 Graded Exercise on June 30th will be actual meteorological data.

Environmental Radiological data will be as their meter reads for all samples.

OPERATIONS SUPPORT CENTER TASKS

Controller Assignments

OPERATIONS SUPPORT CENTER TASKS

Initial Conditions:

Cavitating Venturi for 1A-A motor driven auxiliary feedwater(AFW) pump was removed per WR 93GE01 for inspection of wall thickness based on a letter from the manufacturer. Upon removal the venturi was found to have severe cavitation damage which caused the last 6 inches of the venturi's length to be eroded well below minimum wall thickness. The cavitating venturi for 1B-B motor driven AFW pump was also removed for inspection. Upon removal it was found to have no cavitation damage. While attempting to reinstall the cavitating venturi for 1B-B AFW pump the venturi was accidentally dropped landing flange down on a structural pipe support. This resulted in a gash completely across the flange's seating surface that was about one-eighth inch deep and three-sixteenths inch wide.

Feedwater flow elements FE 3-90, FE 3-48, FE 3-35, and FE 3-103 have all been removed for steam cleaning. Steam cleaning of FE 3-35 is complete and awaiting final inspection and reinstallation. Steam cleaning of FE 3-90 is 80% complete; FE 3-48 is 10% complete. Steam cleaning of FE 3-103 has not commenced.

Sludgelancing has commenced on SG#2 and SG#4 and is about 75% complete. Sludgelancing has commenced on SG#3 and is about 10% complete. Sludgelancing has not commenced on SG#1 due to equipment problems but is expected to start this shift.

OPERATIONS SUPPORT CENTER TASKS

Task: Repair and reinstallation of 1A-A AFW cavitating venturi
and 1B-B AFW cavitating venturi

Description:

Initial TVA issued WR 93GE01 to inspect the venturis after being
Condition notified by the venturis' manufacturer, Rocky Mountain
Nuclear, that some of the material stock from which the
venturis were machined had been inadequately heat treated
and may be more prone to cavitation induced wall thinning.

02:00 One or more venturis may be reinstalled
to
03:30

Task Criticality: Task is NOT CRITICAL to the scenario. This task may
be done based on TSC/OSC priority.

Reference Drawings: Vendor Drwg. P1967-1
47W803-2
47W427-7
47W427-1 series
WR 93GE01

Controller Notes:

Simulation Notes:

No actions will actually be taken which may alter the operations of the site nor will personnel enter actual High Radiation or Contamination Areas. Actual work will only be allowed on mockups of the effected equipment. If no mockup is available, then the equipment will be physically located but verbal descriptions of actions to be taken will be given rather than performing the actual actions which would effect the site operations. Actions not effecting operations such as getting supplies and wearing protective clothing will be performed. Lead Controllers may authorize additional simulation.

Issue any messages related to this event to the players.
Read initial condition page for latest status on these venturies.

Several options exist for repairing or reinstalling these venturies.

Once any repairs or installation is completed on this venturi then notify your Lead Controller or the Exercise Coordinator informing them as to what was done.

OPERATIONS SUPPORT CENTER TASKS

Task: Cleaning and reinstallation of Feedwater flow elements FE 3-90, FE 3-48, FE 3-35, and FE 3-103.

Description:

Initial TVA issued WR 93GE02 to steam clean U-1 feedwater flow Condition elements.

02:00 One or more feedwater flow elements may be reinstalled to
03:30

Task Criticality: Task is NOT CRITICAL to the scenario. This task may be done based on TSC/OSC priority.

Reference Drawings:

Controller Notes:

Simulation Notes:

No actions will actually be taken which may alter the operations of the site nor will personnel enter actual High Radiation or Contamination Areas. Actual work will only be allowed on mockups of the effected equipment. If no mockup is available, then the equipment will be physically located but verbal descriptions of actions to be taken will be given rather than performing the actual actions which would effect the site operations. Actions not effecting operations such as getting supplies and wearing protective clothing will be performed. Lead Controllers may authorize additional simulation.

Issue any messages related to this event to the players. Read initial condition page for latest status on these flow elements.

Once any reinstallation is completed on these feedwater flow elements then notify your Lead Controller or the Exercise Coordinator informing them as to what was done.

OPERATIONS SUPPORT CENTER TASKS

Task: U-1 Steam Generator(SG) Handhole reinstallation

Description:

Initial All SGs have been drained and handholes removed in
Condition preparation for sludgelancing.

02:00 One or more SG handholes may be reinstalled
to
03:30

Task Criticality: Task is NOT CRITICAL to the scenario. This task may be done based on TSC/OSC priority.

Reference Drawings:

Controller Notes:

Simulation Notes:

No actions will actually be taken which may alter the operations of the site nor will personnel enter actual High Radiation or Contamination Areas. Actual work will only be allowed on mockups of the effected equipment. If no mockup is available, then the equipment will be physically located but verbal descriptions of actions to be taken will be given rather than performing the actual actions which would effect the site operations. Actions not effecting operations such as getting supplies and wearing protective clothing will be performed. Lead Controllers may authorize additional simulation.

Issue any messages related to this event to the players.

Once any reinstallation is completed on these handholes then notify your Lead Controller or the Exercise Coordinator informing them as to what was done.

OPERATIONS SUPPORT CENTER TASKS

Task: RHR1A-A suction piping leak on equalizing line between 1-FCV-74-3 and the room's back wall.

Description:

00:50 Leak begins on RHR system in RHR1A-A pump room between 1-FCV-74-3 and the wall. Leak rate is initially 65 to 70 gpm.

02:05 If leak has not been isolated then the leak will increase to about 105 gpm.

Task Criticality: Task is CRITICAL to the scenario. When this task is completed then the exercise may be terminated.

Reference Drawings: 47W810-1
47W432-1,2
Video Tour Pictures

Controller Notes:

Simulation Notes:



No actions will actually be taken which may alter the operations of the site nor will personnel enter actual High Radiation or Contamination Areas. Actual work will only be allowed on mockups of the effected equipment. If no mockup is available, then the equipment will be physically located but verbal descriptions of actions to be taken will be given rather than performing the actual actions which would effect the site operations. Actions not effecting operations such as getting supplies and wearing protective clothing will be performed. Lead Controllers may authorize additional simulation.

Issue any messages related to this event to the players.


A mockup will be used.

The mockup is located at the hypochlorite building. The mockup is to simulate a leak at the equalizing line upstream of 1-FCV-74-3 near valve 1-74-506. The players must discover the exact location and extent of the breach. Gaining access to the RHR1A-A pump room will be a task for the OSC team as the water will be radioactive and at about 150 degrees F. Depending upon their time of arrival there may be water on the main elevation of 653'.


Once the repairs are completed on this mockup then notify your Lead Controller or the Exercise Coordinator informing them as to what was done.



DETAIL B





DETAIL A



SEE NOTE 19-

47W432-1





SEE PLAN
EL 653.0
SHEET 1

2", See note 23

PUMP - E EI 661'-0"

Flush conn.

See note 10

PI 24-22 1-8717B

DETAIL D2

LO PT DR
MK-05

SECTION - A2-A2

E RHR PUMP 1B-B

SEE ISOMETRIC C5

DETAIL D2

Weld prep this end only
3" C.S. pipe (typ 5 places - U1 & U2
CLASS B) U2 ONLY

FOR LEAK TEST
PIPING SEE DETAIL E2
(TYP BOTH MANWAYS)

RHR sump
valve room
(Aux. Bldg)


TYP 2 pl

1 plc

See note 22

note 3631
note 11


Location I-A RHR Pump Room



I-FW-74-3

Pump

Location 1A-A Ritr Pomp Room



1-FW-74-3

INSTRUCTIONS TO PLAYERS, CONTROLLERS, AND EVALUATORS

Introduction:

A Radiological Emergency Plan (REP) exercise is conducted each year to demonstrate the ability of the emergency response organization to respond to an actual emergency and in doing so protect the safety and health of the workers and general public. This demonstration is controlled by TVA personnel and evaluated by TVA and regulatory agency personnel to determine the adequacy of the response and actions taken. The selection of personnel to control the exercise is based on the specific areas of expertise being controlled or evaluated.

A large contingent of evaluators and controllers must be utilized to conduct such a large scale endeavor and each individual must understand and follow specific instructions to ensure the successful conduct of the exercise.

The following packages contain specific instructions and rules for controllers, evaluators and players to follow while participating in the REP exercise.

INSTRUCTIONS AND RULES FOR PLANT PLAYERS

1. Remember there are two clocks, the scenario time (elapsed time) and the actual clock time. Use actual clock time when reporting events to others and in your logs.
2. Controllers run the exercise and are identified by arm bands marked "CONTROLLER." Evaluators will evaluate performance and are identified by bands marked "EVALUATOR." Evaluators MAY NOT interact or interfere with a player. Controllers will also act as evaluators to the extent their control duties allow. Visitors may be observing for what they might learn from the exercise and are identified by arm bands marked "VISITOR".
3. Identify yourself by name and function as necessary to the exercise controllers and evaluators. This will be helpful.
4. Play out all actions, as much as possible, in accordance with your emergency plan and procedures as if it were a real emergency. Unless authorized by the controller, you should not simulate your actions. It is to your advantage to exercise as many of your actual response actions as possible.

If authorized to simulate an action, tell the evaluator controller how and when you would actually do them and clearly identify your actions to the controller.

NOTE: DO NOT ENTER HIGH RADIATION AREAS OR CONTAMINATION AREAS IN THE PLANT, FOLLOW ALARA PRINCIPLES.

5. Speak out loud, identifying your key actions and decisions to the controllers and evaluators. This may seem artificial, but it will assist in the evaluation process and is to your benefit.
6. If you are in doubt, ask your controller for clarification. The controller will not prompt or coach you. The controller will normally only tell you what you would have perceived with your own senses or correct errors due to the scenario.
7. The controller periodically will issue messages or instructions designed to initiate response actions. You must accept these messages immediately. They are essential to your successful performance.
8. If the controller intervenes with your play, it is for a good reason. Obey your controller's directions at all times. This is essential to the overall success of the exercise.
9. If a situation arises where you disagree with the information provided by the controller, you may ask him to reconsider or consult with the functional area's Lead Controller. You must, however, accept his/her word as final and proceed.

INSTRUCTIONS AND RULES FOR PLANT PLAYERS
(Continued)

10. Respond to the controller's questions. Evaluators will not interact or interfere with players. You must not accept any messages or instructions from evaluators or visitors. All evaluator interactions will be with the controllers.
11. You must play as if the simulated radiological conditions provided during the exercise are actually present, in accordance with the information you have received. This will require that you wear radiation dosimeters, anti-contamination clothing, observe proper radiation protection practices, and be aware of and minimize your radiation exposure.

Controllers and evaluators are exempt from these requirements. Do not let this confuse you or cause you to act unwisely.

12. If you are entering normal nuclear station radiation areas, observe all rules and procedures. No one (not even the controllers and evaluators) is exempt from normal station radiological practices and procedures.
13. Demonstrate your knowledge of the emergency plan, emergency operations, and procedures.
14. Utilize status boards, log books, etc., as much as possible to document and record your actions, instructions, and reports to your co-players. This is very important.

15. Keep a list of items you feel will improve the emergency plan and procedures. Provide this to your Lead Controller at the player critique and he will ensure they are considered. Remember one of the main purposes of the exercise is for you, the player, to demonstrate that you are adequately prepared. Areas for improvement or lessons learned, when identified, will improve your overall emergency preparedness.

A critique of the exercise will occur after the exercise is terminated. Provide your input to your Lead Controller. This will help in the formal overall evaluation the controller will present.

16. Follow all normal industrial safety, radiological protection, and security instructions. Plant and personnel safety take precedence over any exercise requirements.
17. Please report any hazardous conditions or situations to the controller.
18. A controller should accompany you on any task you are given. If a controller is not already standing by, you should locate one and inform him of your assignment to insure you are observed and/or informed of the exercise conditions.

INSTRUCTIONS AND RULES FOR PLANT CONTROLLERS

A. Controller Duties

1. Be familiar with scenario, the data, and messages you will pass out.
2. To pass out data and messages required to guide the exercise.
3. Provide additional information to emergency responders that they may request concerning accident details as long as this information would be directly available to the responder.
4. Take actions when required to keep the scenario on course.
5. Report to your Lead Controller or the Exercise Coordinator any problems you are unable to resolve.
6. Write down any areas where you believe improvement is needed and present your comments at the post-exercise critique.

B. Instructions

1. Personnel are assigned as controllers at all key function areas to monitor and control the exercise. They will accompany radiological monitoring teams, plant health physics personnel, maintenance repair/rescue teams, and others as necessary.
2. The controller activities will be overseen by the Exercise Coordinator who will be in radio or telephone communication with plant Lead Controllers. He will be responsible for the overall conduct of the exercise scenario.
3. Messages and simulated control room data will be used to initiate, modify, and complete the events comprising the overall scenario. Selected controllers will use the message forms to place the scenario events in effect and to trigger responses from the involved emergency response organizations. Each controller will have copies of the messages controlling the portion of the exercise scenario for which he is responsible.

Controlling messages will be presented to the designated exercise participant at the time specified in the event schedule. The controller should followup with any necessary explanation of the message and answer questions to ensure that the participant understands the message.

Controllers will not initially provide information to the participants regarding scenario development or resolution of problem areas encountered. The participants are expected to obtain information through their own organization and exercise their own judgment in determining response actions and resolving problems. In the event of incorrect or incomplete responses or if the participant indicates lack of knowledge of how to proceed, the controller may redirect the participant with necessary instructions and will note the deficiency on his/her critique sheets.

INSTRUCTIONS AND RULES FOR PLANT CONTROLLERS
(continued)

4. Note that the scenario events are hypothetical. Any portions of the scenario depicting plant system operational transients are simulated events. No control room actions, reactions involving operation of plant system or effecting generation capability will be initiated. All exercise scenario messages will be prefixed and suffixed with the words: "THIS IS A DRILL." Controllers stationed at areas vital to maintaining generating capability should be especially aware and take extra precautions in issuing messages or giving instructions regarding the scenario events.
5. Selected controllers will have the time-related plant and radiological parameters of the exercise scenario for issue to the appropriate exercise participants.
6. Some exercise participants may insist that certain parts of the scenario are unrealistic. Controllers have the authority, with approval from the Lead Controllers, to clarify any questions regarding scenario content. In some cases, it may be necessary to exercise "controller's prerogative" to preserve the continuity and objectives of the exercise.
7. Scenario equipment problems not covered in the exercise events section of this manual will be handled by the controllers in the Control Room, Simulator, CECC, TSC, or OSC.
8. Players are not allowed to introduce items into the exercise or scenario.
9. Be sure to return all exercise evaluation forms to a Lead Controller who will forward them on to the Exercise Coordinator.
10. There are no specific meal breaks in the exercise. Controllers should break for meals as time permits after consulting their Lead Controller. Emergency team leaders should decide when team members may take a meal break.
11. Be sure to have a hard hat and safety glasses with you when entering the plant.

C. Rules

Do's

1. Know the overall controller organization.
2. Be aware at all times of where you are in the scenario.
3. Identify the players by name and function.
4. Identify yourself at all times to all players by wearing the arm band.
5. Identify the phone or radio you will use to maintain communications with the Lead Controller.
6. Position yourself to maximize your effectiveness in issuing messages and observing the players.
7. Be sure you understand the players' actions and the master scenario.
8. Keep the scenario on schedule by checking your timeline.

INSTRUCTIONS AND RULES FOR PLANT CONTROLLERS
(continued)

9. Issue the message on time. Make sure the players understand it.
10. Remember to call the lead controller to report on status of players' actions if off schedule or if in doubt about what to do. Call for advice if players depart significantly from the scenario script, which will create a major delay. If necessary, intervene with player action and put players back on scenario track.
11. Allow the players reasonable flexibility to do their functions and demonstrate their skill, knowledge, and initiative.
12. Attend the post-exercise critique session to provide any comments or clarification you may have.
13. Identify the player's leader. Work with them as appropriate.
14. If a real emergency occurs and this effects the players, call off your portion of the exercise and notify the lead controller immediately.
15. Be at your post at least 20 minutes prior to exercise commencement.
16. The evaluators must not issue "surprise" messages or direct "surprise" actions at the players. They must work through the controller. This is essential for the success of the exercise.
17. Controllers and evaluators do not have to follow the radiation exposure control practices for the simulated radiation levels from the emergency exercise scenario. However, the players must follow the radiation protection rules. Controllers, evaluators, and players entering normal nuclear station radiation areas must observe all normal radiation control practices.
18. Follow all normal industrial safety, radiological protection, and security instructions.
19. Report any hazardous condition to the lead controller.

Don'ts

1. Don't leave your post at key times.
2. Don't prompt the players to take action.
3. Don't coach the players.
4. Don't forget to call the lead controllers to seek advice or help, as necessary.
5. Don't allow the media or other external influences to distract the players. No interviews with players are allowed.

INSTRUCTIONS AND RULES FOR PLANT EVALUATORS

A. Instructions:

1. Message forms and simulated control room data will be used to initiate, modify, and complete the events comprising the overall scenario. Selected controllers will use the message forms to place the scenario events in effect and to trigger responses from the involved emergency response organizations. Each controller will have copies of the messages controlling the portion of the exercise scenario for which he is responsible.

Controlling messages will be presented to the designated exercise participant at the time specified in the event schedule. The controller should follow up with an explanation of the message and answer questions to ensure that the participant understands the message.

Controllers will not initially provide information to the participants regarding scenario development or resolution of problem areas encountered. The participants are expected to obtain information through their own organization and exercise their own judgment in determining response actions and resolving problems. In the event of incorrect or incomplete responses or if the participant indicates a lack of knowledge of how to proceed, the controller may prompt the participant with necessary instructions or contingency cards and will note the deficiency on his/her critique sheets.

2. Note that the scenario events are hypothetical. Any portions of the scenario depicting plant system operational transients are simulated events. No actions, involving operation of plant systems or affecting generation capability will be initiated.
3. Some exercise participants may insist that certain parts of the scenario are unrealistic. The controllers have the authority, with approval from the lead controllers, to clarify any questions regarding scenario content. In some cases, it may be necessary to exercise "controller's prerogative" to preserve the continuity and objectives of the exercise.
4. Scenario equipment problems not covered in the exercise events section of this manual will be handled by the controllers in the Control Room, Simulator, CECC, TSC, or OSC.
5. Players are not allowed to introduce items into the exercise or scenario.
6. Be sure to return all evaluation forms to a Lead Controller who will forward them on to the Exercise Director.
7. There are no specific meal breaks in the exercise. Evaluators should eat as time permits.
8. Be sure to have a hard hat and safety glasses with you when entering the plant.

INSTRUCTIONS AND RULES FOR PLANT EVALUATORS
(continued)

B. Rules

Do's

1. Know the overall scenario.
2. Know the emergency organization and the specific plant instructions governing the area you are observing.
3. Identify players by name and function when completing evaluation sheets.
4. Identify yourself at all times by wearing the arm bands provided.
5. Position yourself to maximize your effectiveness in observing the players.
6. Make notes on good and bad points of players' actions, the strengths and weaknesses, and areas for improvement. Use the Evaluator's Sheets. When completing the evaluation sheet, ask yourself the following questions in determining what was right or wrong:
 - a. Were the procedures adequate and/or correct?
 - b. Did the individual(s) use and follow the procedures?
 - c. Did the individual(s) use proper judgment if there no procedures?
 - d. Did the individual(s) respond properly based on the information provided?

In short -Concentrate on procedural adequacy, knowledge, and adherence to procedures, and player judgment.

7. Attend the post-exercise critique session to provide your comments and recommendations.
8. Be at your post at least 20 minutes prior to exercise commencement.
9. Evaluators will not issue "surprise" messages or direct "surprise" actions at the players.
10. Evaluators do not have to follow the radiation exposure control practices for the simulated radiation levels from the emergency exercise scenario. However, the players must follow the radiation protection rules. Controllers, evaluators, and players entering normal nuclear station radiation areas must observe all normal radiation control practices.
11. Follow all normal industrial safety, radiological protection, and security instructions.
12. Report any hazardous conditions or situations to the lead controller.

Don'ts

1. Don't leave your post at key times.
2. Don't prompt the players to take action.
3. Don't coach the players.
4. Don't allow yourself to distract the players.

INSTRUCTIONS AND RULES FOR PLANT VISITORS

1. The event times and scenario are confidential and should be kept confidential during the exercise. Do not discuss them with the players.
2. Visitors should not participate in the exercise nor interfere in the actions taken by the exercise players, controllers, and evaluators.
3. If you have questions, contact the controller of the location you are visiting.
4. Follow all normal industrial safety, radiological protection, and security instructions.
5. Please report any hazardous condition to the controller.

CONTROLLER CHECK LIST

A. Prior to the Exercise:

- ____ 1. Read and analyze the scenario data in your area of expertise. Determine if any changes or additions to the data are needed to insure the basic correctness of the scenario.
- ____ 2. Read the entire scenario package and be especially familiar with the objectives, narrative summary, scenario timeline, messages, data for your area, and the controller worksheets.
- ____ 3. Lead controllers, meet with the other controllers in your area several times and discuss the scenario's accuracy, completeness, and coherency. Inform the Scenario Development Team Leader of any recommended changes.
- ____ 4. Attend all Scenario Development Team/Controller meetings.
- ____ 5. Keep your scenario package updated as information changes.
- ____ 6. Do not divulge the Scenario start time or date. Do not discuss the Scenario events or timeline with people outside the Scenario Development Team.

B. During/After the Exercise:

- ____ 1. Answer and complete applicable controller worksheets.
- ____ 2. After the exercise is over, present completed controller worksheets to your lead controller prior to leaving.
- ____ 3. After the exercise is over, Lead controllers discuss any problems noted on the controller work sheets with your controllers prior to them leaving.
- ____ 4. Lead controllers review all of your controller's comments and prepare a presentation of activities for your area that contain good practices as well as areas needing improvement prior to any scheduled critique.
- ____ 5. Lead controllers attend any scheduled critique and give your presentation of activites in your area of concern.
- ____ 6. Lead controllers obtain copies of pertinent data such as log books, surveys, etc. which would be useful to the Scenario Development Team Leader in compiling the Final Exercise Report.