

## PLANT SYSTEMS

### AUXILIARY FEEDWATER PUMPS

#### LIMITING CONDITION FOR OPERATION

---

3.7.1.2 At least three steam generator auxiliary feedwater pumps shall be OPERABLE with:

- a. Two feedwater pumps capable of being powered from separate OPERABLE emergency busses, and
- b. One feedwater pump capable of being powered from an OPERABLE steam supply system.

APPLICABILITY: MODES 1, 2, and 3.

#### ACTION:

With one auxiliary feedwater pump inoperable, restore at least three auxiliary feedwater pumps (two capable of being powered from separate OPERABLE emergency busses and one capable of being powered by an OPERABLE steam supply system) to OPERABLE status within 48 hours or be in HOT SHUTDOWN within the next 12 hours.

#### SURVEILLANCE REQUIREMENTS

---

4.7.1.2 Each auxiliary feedwater pump shall be demonstrated OPERABLE:

- a. At least once per 31 days by:
  1. Starting each pump from the control room,
  2. Verifying that:
    - a) Each motor driven pump develops a discharge pressure of  $\geq 1070$  psig on recirculation flow, and
    - b) The steam turbine driven pump develops a discharge pressure of  $\geq 1000$  psig on recirculation flow.

# For repair efforts commencing 3/18/82 only, an additional 120 hour period is allowed, ending 2240 hours, 3/25/82.