

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
1750 Chestnut Street Tower II

March 15, 1982

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303



Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 1 - DOCKET
NO. 50-259 - FACILITY OPERATING LICENSE DPR-33 - REPORTABLE OCCURRENCE
REPORT BFRO-50-259/81071 - REVISION 1

This report is a supplement to my letter dated December 10, 1981 concerning
1-LIS-3-203B switch No. 2 which operated at 586.45 inches above vessel
zero. This report is submitted in accordance with Browns Ferry unit 1
Technical Specification 6.7.2.b(2).

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. A. Loper
J. A. Loper
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Records Center
Institute of Nuclear Power Operations
1820 Water Place
Atlanta, Georgia 30339

Mr. R. F. Sullivan, NRC Inspector, Browns Ferry

8204020356 820315
PDR ADOCK 05000259
S PDR

An Equal Opportunity Employer

OFFICIAL COPY

IE 22