

CONTROL BLOCK

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

1 A L B R F 3 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

R 0 LICENSE CODE 14 13 LICENSE NUMBER 21 20 LICENSE TYPE 30 57 CAT NR

454 J

REPORT SOURCE: L 0 5 0 0 0 2 9 6 7 1 1 0 7 8 1 5 0 3 1 2 8 2 0

60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND EVIDENCE CONSIDERATION	DATE	TIME	COMP	VALUE
During refueling outage, while performing SI 4.8.B.4-3. (reactor building vent				
monitoring system calibration) continuous air monitor 3-RM-90-250 failed to pass				
on gas and particulate channels. (T.S. 3.8.B-6, 3.8.B-8) There was no danger to				
the health and safety of the public. There were no previous similar events.				

SYSTEM CODE M C		CAUSE CODE E		CAUSE SUBCODE G		COMPONENT CODE I N S T R U						COMP SURCODE Y		VALVE SUBCODE Z	
EVENT YEAR 8 1		SEQUENTIAL REPORT NO 0 6 6		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO 1							
ACTION TAKEN A Z		EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0 0 0 0		ATTACHMENT SUBMITTED Y		NPRD 1 FORM SUB N		PRIME COMP. SUPPLIER L		COMPONENT MANUFACTURER N 3 0 5	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

1 1 0 Component failure. Chemical Lab started sampling program. The NMC model CRA-14BF

1 1 1 gas count rate card was replaced and the continuous air monitor was functionally

1 1 2 tested and returned to service. This is considered a random failure and no further

1 1 3 recurrence control is required.

1 1 4

FACILITY STATUS		% POWER			OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION		
1	5	H	0	0	0	NA	B	Surveillance test			
ACTIVITY CONTENT		RELEASED OF RELEASE			AMOUNT OF ACTIVITY		LOCATION OF RELEASE				
1	6	Z	Z	NA	NA						
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION					
1	7	0	0	0	Z	NA					
PERSONNEL INJURIES		NUMBER		DESCRIPTION							
1	8	0	0	0		NA					
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION							
1	9	Z				NA					
SUBJECT		PDR		PDR		NRC USE ONLY					
1	10	N	8204020505	820312	ADOCK 05000296	NA					

LER SUPPLEMENTAL INFORMATION

BFRO-50- 296 / 81066R1 Technical Specification Involved 3.8.B-6 and 3.8.B-8
Reported Under Technical Specification 6.7.2.b(2) * Date Due NRC NA
Date of Occurrence 11/7/81 Time of Occurrence 1800 Unit 3

Identification and Description of Occurrence:

CAM 3-BM-90-250 failed to pass on gas and particulate channels.

Conditions Prior to Occurrence:

Unit 1 at 99%

Unit 2 at 99%

Unit 3 in refueling outage

Action specified in the Technical Specification Surveillance Requirements met due to inoperable equipment. Describe.

Sampling program was initiated as required by technical specification 3.8.B.8.

Apparent Cause of Occurrence:

Component failure

Analysis of Occurrence:

There was no danger to the health or safety of the public, no release of activity, no damage to the plant or equipment, and no resulting significant chain of events.

Corrective Action:

The NMC model CRA-14BF gas count rate card was replaced and the continuous air monitor was functionally tested and returned to service. This is considered a random failure and no further recurrence control is required.

Failure Data:

None
Retention: Period - Lifetime; Responsibility - Document Control Supervisor

*Revision: John A. Vanner