

...ATING DATA REPORT

DOCKET NO. 50-269
 DATE 2-15-82
 COMPLETED BY J. A. Reavis
 TELEPHONE 704-373-8552

OPERATING STATUS

1. Unit Name: Oconee #1
2. Reporting Period: January, 1982
3. Licensed Thermal Power (Mwt): 2 568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 899
7. Maximum Dependable Capacity (Net MWe): 860
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>744.0</u>	<u>744.0</u>	<u>74 929.0</u>
12. Number Of Hours Reactor Was Critical	<u>173.1</u>	<u>173.1</u>	<u>51 228.4</u>
13. Reactor Reserve Shutdown Hours	<u>-</u>	<u>-</u>	<u>-</u>
14. Hours Generator On-Line	<u>112.9</u>	<u>112.9</u>	<u>48 356.1</u>
15. Unit Reserve Shutdown Hours	<u>-</u>	<u>-</u>	<u>-</u>
16. Gross Thermal Energy Generated (MWH)	<u>133 042</u>	<u>133 042</u>	<u>113 590 814</u>
17. Gross Electrical Energy Generated (MWH)	<u>39 760</u>	<u>39 760</u>	<u>39 516 110</u>
18. Net Electrical Energy Generated (MWH)	<u>23 393</u>	<u>23 393</u>	<u>37 367 569</u>
19. Unit Service Factor	<u>15.2</u>	<u>15.2</u>	<u>64.5</u>
20. Unit Availability Factor	<u>15.2</u>	<u>15.2</u>	<u>64.6</u>
21. Unit Capacity Factor (Using MDC Net)	<u>3.7</u>	<u>3.7</u>	<u>57.8</u>
22. Unit Capacity Factor (Using DER Net)	<u>3.6</u>	<u>3.6</u>	<u>56.3</u>
23. Unit Forced Outage Rate	<u>84.8</u>	<u>84.8</u>	<u>9.0</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
None

25. If Shut Down At End Of Report Period, Estimated Date of Startup: _____
26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-269
 UNIT NAME Oconee Unit 1
 DATE 2-15-82
 COMPLETED BY J. A. Reavis
 TELEPHONE 704-373-8552

REPORT MONTH January, 1982

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
1	82-01-01	F	11.95	A	3		HC	TURBIN	Moisture separator reheater drain tank high level tripped turbine/reactor.
2	82-01-01	F	6.18	A	3		HC	TURBIN	Moisture separator reheater drain tank high level tripped turbine/reactor.
3	82-01-01	F	16.60	A	3		HC	TURBIN	Moisture separator reheater drain tank high level tripped turbine/reactor.
4	82-01-02	F	21.07	A	3		HA	INSTRU	Turbine/reactor trip due to false, loss of stator coolant signal.
1-p	82-01-04	F	--	B	--		ZZ	ZZZZZZ	Holding at 40% for power escalation testing.
5	82-01-06	F	276.70	A	1		HA	TURBIN	Turbine brng. #11 exceeded high vib. limit. Shutdown for balance shot and repair generator hydrogen leak.

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance of Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

⁵
 Exhibit I - Same Source

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-269
 UNIT NAME Oconee Unit 1
 DATE 2-15-82
 COMPLETED BY J. A. Reavis
 TELEPHONE 704-373-8552

REPORT MONTH January, 1982

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
6	82-01-17	F	294.47	A	--		CH	HTEXCH	Outage extended due to leaks in the high pressure feedwater heaters 1A1 and 1A2.
7	82-01-30	F	4.13	A	1		HA	TURBIN	Removed unit from service for turbine balance shot. Reactor remained critical.

1
 F- Forced
 S- Scheduled

2
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance of Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

4
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5
 Exhibit I - Same Source

DOCKET NO. 50-269

UNIT Oconee Unit 1

DATE 2-15-82

COMPLETED BY J. A. Reavis

TELEPHONE 704-373-8552

AVERAGE DAILY UNIT POWER LEVEL

MONTH January, 1982

DAY	AVERAGE DAILY POWER LEVEL (MWe-net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-net)
1	-	17	-
2	-	18	-
3	106	19	-
4	318	20	-
5	320	21	-
6	105	22	-
7	-	23	-
8	-	24	-
9	-	25	-
10	-	26	-
11	-	27	-
12	-	28	-
13	-	29	-
14	-	30	118
15	-	31	450
16	-		

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

On this form, list the average daily unit power level in MWe-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

DOCKET NO: 50-269
UNIT: Oconee Unit 1
DATE: February 15, 1982

NARRATIVE SUMMARY

MONTH: January, 1982

Oconee 1 began the month of January at 15% power, following an extended outage for refueling, and core support assembly bolt replacement,

On January 1, a level control problem on the moisture separator reheater drain tank was the cause of three (3) trips of the turbine/reactor. Another trip occurred on January 2, due to a false loss of stator coolant signal.

Power escalation testing at the 40% level began on January 4 and was completed on January 6. On January 6, the unit was forced from service due to high vibration on turbine bearing #11.

A generator hydrogen leak and high pressure feedwater heater tube leaks extended the outage until January 30.

The reactor remained critical while the generator was removed from service on January 30 for a turbine balance shot. At the month's end, the unit had been returned to service and was increasing in power.

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 1
2. Scheduled next refueling shutdown: March, 1983
3. Scheduled restart following refueling: May, 1983
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? Yes.
If yes, what will these be? _____

Technical Specification Revision

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions? N/A.
If no, when is review scheduled? N/A

5. Scheduled date(s) for submitting proposed licensing action and supporting information: Submitted February, 1983
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures). _____

7. Number of fuel assemblies (a) in the core: 177.
(b) in the spent fuel pool: 741*
8. Present licensed fuel pool capacity: 1312*.
Size of requested or planned increase: None
9. Projected date of last refueling which can be accommodated by present licensed capacity: _____

DUKE POWER COMPANY

Date: February, 1982

Name of Contact: J. A. Reavis

*Represents total for the combined units 1 and 2

OPERATING DATA REPORT

DOCKET NO. 50-270
 DATE 2-15-82
 COMPLETED BY J. A. Reavis
 TELEPHONE 704-373-8552

OPERATING STATUS

1. Unit Name: Oconee #2
 2. Reporting Period: January, 1982
 3. Licensed Thermal Power (MWT): 2 568
 4. Nameplate Rating (Gross MWe): 934
 5. Design Electrical Rating (Net MWe): 886
 6. Maximum Dependable Capacity (Gross MWe): 899
 7. Maximum Dependable Capacity (Net MWe): 860
 8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____
 10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744.0	744.0	64 849.0
12. Number Of Hours Reactor Was Critical	0.0	0.0	46 208.4
13. Reactor Reserve Shutdown Hours	-	-	-
14. Hours Generator On-Line	0.0	0.0	45 228.4
15. Unit Reserve Shutdown Hours	-	-	-
16. Gross Thermal Energy Generated (MWH)	0.0	0.0	106 034 812
17. Gross Electrical Energy Generated (MWH)	0.0	0.0	36 076 786
18. Net Electrical Energy Generated (MWH)	-3 020	-3 020	34 229 828
19. Unit Service Factor	0.0	0.0	69.7
20. Unit Availability Factor	0.0	0.0	69.7
21. Unit Capacity Factor (Using MDC Net)	0.0	0.0	61.1
22. Unit Capacity Factor (Using DER Net)	0.0	0.0	59.6
23. Unit Forced Outage Rate	0.0	0.0	17.6

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

Refueling

25. If Shut Down At End Of Report Period, Estimated Date of Startup: April, 1982

26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

DOCKET NO. 50-270

UNIT Oconee Unit 2

DATE 2-15-82

AVERAGE DAILY UNIT POWER LEVEL

MONTH January, 1982

DAY	AVERAGE DAILY POWER LEVEL (MWe-net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-net)
1	_____ - _____	17	_____ - _____
2	_____ - _____	18	_____ - _____
3	_____ - _____	19	_____ - _____
4	_____ - _____	20	_____ - _____
5	_____ - _____	21	_____ - _____
6	_____ - _____	22	_____ - _____
7	_____ - _____	23	_____ - _____
8	_____ - _____	24	_____ - _____
9	_____ - _____	25	_____ - _____
10	_____ - _____	26	_____ - _____
11	_____ - _____	27	_____ - _____
12	_____ - _____	28	_____ - _____
13	_____ - _____	29	_____ - _____
14	_____ - _____	30	_____ - _____
15	_____ - _____	31	_____ - _____
16	_____ - _____		

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

On this form, list the average daily unit power level in MWe-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

CORRECTED COPY

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH January, 1982

DOCKET NO. 50-270
 UNIT NAME Oconee 2
 DATE 3/15/82
 COMPLETED BY J.A. Reavis
 TELEPHONE (704) 373-8552

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
1	82-01-01	S	480.00	C	--		RC	FUELXX	Scheduled refueling/inspection (10 yr. ISI) in progress.
1A	82-01-21	S	264.00	B	--		CA	VESSEL	Core support assembly bolt replacement in progress. NSM's and other maintenance.

1
 F - Forced
 S - Scheduled

2
 Reason:
 A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training & License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

3
 Method:
 1 - Manual
 2 - Manual Scram.
 3 - Automatic Scram.
 4 - Other (Explain)

4
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LIR) File (NUREG-0161)

5
 Exhibit F - Same Source

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-270
 UNIT NAME Oconee Unit 2
 DATE 2-15-82
 COMPLETED BY J. A. Reavis
 TELEPHONE 704-373-8552

REPORT MONTH January, 1982

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
1	82-01-01	S	744.00	C			RC	FUELXX	Scheduled refueling/inspection (10 yr. ISI) in progress. Core support assembly bolt replacement in progress. NSM's and other maintenance.

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

⁵
 Exhibit I - Same Source

DOCKTE NO: 50-270
UNIT: Oconee Unit 2
DATE: January 15, 1982

NARRATIVE SUMMARY

MONTH: January, 1982.

Oconee 2 began the month at shutdown for refueling and the ten-year inservice inspection, which continued throughout the month. The core support assembly bolt replacement and NSM's are in progress.

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 2
2. Scheduled next refueling shutdown: Unknown
3. Scheduled restart following refueling: Unknown
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? Yes.
If yes, what will these be? _____

Technical Specification Revision

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions? N/A.
If no, when is review scheduled? N/A.

5. Scheduled date(s) for submitting proposed licensing action and supporting information: Unknown
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures). _____
- _____
- _____
- _____
- _____

7. Number of fuel assemblies (a) in the core: 0.
(b) in the spent fuel pool: 532*.

8. Present licensed fuel pool capacity: 1312*.
Size of requested or planned increase: None.

9. Projected date of last refueling which can be accommodated by present licensed capacity: _____

DUKE POWER COMPANY

Date: February, 1982

Name of Contact: J. A. Reavis

*Represents total for the combined units 1 and 2

OPERATING DATA REPORT

DOCKET NO. 50-287
 DATE 2-15-82
 COMPLETED BY J. A. Reavis
 TELEPHONE 704-373-8552

OPERATING STATUS

1. Unit Name: Oconee #3
2. Reporting Period: January, 1982
3. Licensed Thermal Power (MWt): 2 568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 899
7. Maximum Dependable Capacity (Net MWe): 860
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report. Give Reasons:

Notes

Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>744.0</u>	<u>744.0</u>	<u>62 496.0</u>
12. Number Of Hours Reactor Was Critical	<u>744.0</u>	<u>744.0</u>	<u>46 057.9</u>
13. Reactor Reserve Shutdown Hours	<u>-</u>	<u>-</u>	<u>-</u>
14. Hours Generator On-Line	<u>744.0</u>	<u>744.0</u>	<u>45 060.1</u>
15. Unit Reserve Shutdown Hours	<u>-</u>	<u>-</u>	<u>-</u>
16. Gross Thermal Energy Generated (MWH)	<u>1 908 540</u>	<u>1 908 540</u>	<u>109 427 279</u>
17. Gross Electrical Energy Generated (MWH)	<u>659 910</u>	<u>659 910</u>	<u>37 806 724</u>
18. Net Electrical Energy Generated (MWH)	<u>633 118</u>	<u>633 118</u>	<u>35 984 594</u>
19. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>72.1</u>
20. Unit Availability Factor	<u>100.0</u>	<u>100.0</u>	<u>72.1</u>
21. Unit Capacity Factor (Using MDC Net)	<u>99.0</u>	<u>99.0</u>	<u>66.7</u>
22. Unit Capacity Factor (Using DER Net)	<u>96.1</u>	<u>96.1</u>	<u>65.0</u>
23. Unit Forced Outage Rate	<u>0.0</u>	<u>0.0</u>	<u>14.8</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):	<u>Refueling - April, 1982</u>		

25. If Shut Down At End Of Report Period, Estimated Date of Startup: _____
26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	<u> </u>	<u> </u>
INITIAL ELECTRICITY	<u> </u>	<u> </u>
COMMERCIAL OPERATION	<u> </u>	<u> </u>

DOCKET NO. 50-287UNIT Oconee Unit 3DATE 2-15-82

AVERAGE DAILY UNIT POWER LEVEL

MONTH January, 1982

DAY	AVERAGE DAILY POWER LEVEL (MWe-net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-net)
1	<u>850</u>	17	<u>850</u>
2	<u>852</u>	18	<u>850</u>
3	<u>851</u>	19	<u>851</u>
4	<u>850</u>	20	<u>853</u>
5	<u>852</u>	21	<u>851</u>
6	<u>852</u>	22	<u>847</u>
7	<u>852</u>	23	<u>831</u>
8	<u>853</u>	24	<u>847</u>
9	<u>855</u>	25	<u>849</u>
10	<u>855</u>	26	<u>849</u>
11	<u>855</u>	27	<u>850</u>
12	<u>855</u>	28	<u>851</u>
13	<u>855</u>	29	<u>850</u>
14	<u>856</u>	30	<u>852</u>
15	<u>854</u>	31	<u>854</u>
16	<u>853</u>		

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

On this form, list the average daily unit power level in MWe-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-287
 UNIT NAME Oconee Unit 3
 DATE 2-15-82
 COMPLETED BY J. A. Reavis
 TELEPHONE 704-373-8552

REPORT MONTH January, 1982

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
1-p	82-01-22	F	--	B	--		HA	TURBIN	Reactor power reduced to 86% for periodic turbine valve movement test.

¹
 F- Forced
 S- Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

⁵
 Exhibit I - Same Source

DOCKTE NO: 50-287
UNIT: Oconee Unit 3
DATE: 2-15-82

NARRATIVE SUMMARY

MONTH: January, 1982.

Oconee 3 began the month at near rated power. On January 22, the power was reduced to 86% for a periodic turbine valve movement test. After completion of the test, the power was increased to near rated power and continued the remainder of the month.

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 3
2. Scheduled next refueling shutdown: April, 1982
3. Scheduled restart following refueling: June, 1982
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? Yes.
If yes, what will these be? _____

Technical Specification Revision

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions? N/A.
If no, when is review scheduled? N/A

5. Scheduled date(s) for submitting proposed licensing action and supporting information: March, 1982
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures). _____

7. Number of fuel assemblies (a) in the core: 177.
(b) in the spent fuel pool: 361.

8. Present licensed fuel pool capacity: 474.
Size of requested or planned increase: 830.

9. Projected date of last refueling which can be accommodated by present licensed capacity: _____

DUKE POWER COMPANY

Date: February, 1982

Name of Contact: J. A. Reavis

OCONEE NUCLEAR STATION

Operating Status Report

1. Personnel Exposure

For the month of December, no individual(s) exceeded 10 percent of their allowable annual radiation dose limit.

2. The total station liquid release for December has been compared with the Technical Specifications annual value of 15 curies; the total release for December was less than 10 percent of this limit.

The total station gaseous release for December has been compared with the derived Technical Specifications annual value of 51,000 curies; the total release for December was less than 10 percent of this limit.