March 30, 1982

Docket: 50-267



Public Service Company of Colurado ATTN: Mr. O. R. Lee, Vice President Electric Production P. O. Box 840 Denver, Colorado 80201

Gentlemen:

Subject: Fort St. Vrain Unit No. 1, Radiological Emergency Exercise

This letter is to acknowledge receipt on March 22, 1982, of your letter dated March 12, 1982, and the attachment FOSAVEX-82

I request that you review 10 CFR 50, Appendix E.IV.F., which reflects exercising your emergency capabilities.

The following comments should be reflected in your Scope:

Item 4

Full demonstration of the EWA to include notification of the State, activation of the EWA, and follow-up message by the EBS.

Item 5

Definition of key emergency response personnel which should include; i.e., the fire brigade, offsite monitoring teams, onsite monitoring teams, corrective action teams and security.

The following comments should be included in your Objective:

Demonstrate that the State, local and other response organizations can alert and notify emergency response personnel.

| | 8204050069 PDR ADOCK O F | 820330 5000267 PDR | | 0 | | TE. | 35 | |
|---------|--------------------------------|--|----------|-------------|-------------|-----|-----|-------|
| OFFICE | EPA | RPB A | RPB N | DRA D | RA-BIV | 51 | 1/1 | |
| SURNAME | CAHECKHey:gb | . TWesterman | GLMadsen | . KVSeyfrit | Jacollins . | | | |
| | 3/26/82 | and the second | | | | | | ***** |
| NAC FOR | A 316 (10-60) APICA | 02.40 | OFFICIAL | RECORD (| LOPT | | | |

Part of your objectives should be to demonstrate during the off-shift that: decision making by the Shift Supervisor can be demonstrated, shift augmentation capabilities exist, that sufficient personnel can be obtained to perform onsite and offsite monitoring in a timely manner.

If you have any questions, please do not hesitate to contact me.

Sincerely, Original signed by

Juhn T. Collins

John T. Collins Regional Administrator

cc:

D. W. Warmebourg, Nuclear Production Manager
Fort St. Vrain Nuclear Station
P. O. Box 368
Platteville, Colorado 80651

J. Gham, Quality Assurance (Same Address)

bcc to DMB: (IE35)

bcc distrib. to RIV: RESIDENT INSPECTOR SECTION CHIEF STATE J. COLLINS C. HACKNEY

| | 318 (10-80) NRCM | | RECORD C | 1 | **************** |
|--------|------------------|--------|--------------|---|----------------------|
| DATE | | | | | |
| | | | | | |
| OFFICE | | ****** | | | |