

MARCH 29 1982

DMB 016

DISTRIBUTION:

Docket File

NRC PDR

L PDR

ORB#4 Rdg

DEisenhut

MFairtile

Ringram

DNeighbors

JZwolinski

OELD

AEOD

IE

ACRS-10

Gray File-2

Dockets Nos. 50-321 and 50-366



Mr. J. T. Beckham, Jr.
Vice President - Nuclear Generation
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

Dear Mr. Beckham:

SUBJECT: NUREG-0737 ITEM I.A.1.1 SHIFT TECHNICAL ADVISOR (STA) - HATCH
PLANT UNITS 1 AND 2

As required by Item I.A.1.1 of NUREG-0660 and NUREG-0737, NRR was to conduct a post-implementation review of STA training programs. Our review, based on the information furnished in your response to NUREG-0737 and your letter dated March 9, 1982, is now complete.

We based our review on a determination of whether your response met the intent of guidelines given in the NRC's September 13, 1979 and October 30, 1979 letters. These letters provided guidance concerning the technical education and training qualifications for STAs. The October 30th letter specified that the STA shall have a bachelor's degree or equivalent in a scientific or engineering discipline. The September 13th letter specified three functional areas: General Technical Education, Reactor Operations Training, and Transient and Accident Response Training.

Our review indicated that your STA training program is acceptable in meeting the intent of the guidelines set forth in the above referenced letters.

Sincerely,

*ORIGINAL SIGNED BY

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

cc: See next page

8204080080 820319
PDR ADOCK 05000321
P

ORB#4:DL C-ORB#4:DL

MFairtile

Jcto12

3/2/82:cb

3/2/82

| | | | | | | | |
|---------|-----------|------------|--|--|--|--|--|
| OFFICE | ORB#4:DL | C-ORB#4:DL | | | | | |
| SURNAME | MFairtile | Jcto12 | | | | | |
| DATE | 3/2/82:cb | 3/2/82 | | | | | |

Hatch 1/2
Georgia Power Company

50-321/366

, cc w/enclosure(s):

G. F. Trowbridge, Esq.
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Ruble A. Thomas
Vice President
P. O. Box 2625
Southern Company Services, Inc.
Birmingham, Alabama 35202

Ozen Batum
Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513

Mr. L. T. Gucwa
Georgia Power Company
Engineering Department
P. O. Box 4545
Atlanta, Georgia 30302

Mr. Max Manry
Georgia Power Company
Edwin I. Hatch Plant
P. O. Box 442
Baxley, Georgia 31513

Regional Radiation Representative
EPA Region IV
345 Courtland Street, N.E.
Atlanta, Georgia 30308

Appling County Public Library
301 City Hall Drive
Baxley, Georgia 31513

Mr. R. F. Rogers
U. S. Nuclear Regulatory Commission
Route 1, P. O. Box 279
Baxley, Georgia 31513

Mr. James P. O'Reilly, Regional
Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Charles H. Badger
Office of Planning and Budget
Room 610
270 Washington Street, S.W.
Atlanta, Georgia 30334



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

March 29, 1982

Dockets Nos. 50-321 and 50-366

Mr. J. T. Beckham, Jr.
Vice President - Nuclear Generation
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

Dear Mr. Beckham:

SUBJECT: NUREG-0737 ITEM I.A.1.1 SHIFT TECHNICAL ADVISOR (STA) - HATCH
PLANT UNITS 1 AND 2

As required by Item I.A.1.1 of NUREG-0660 and NUREG-0737, NRR was to conduct a post-implementation review of STA training programs. Our review, based on the information furnished in your response to NUREG-0737 and your letter dated March 9, 1982, is now complete.

We based our review on a determination of whether your response met the intent of guidelines given in the NRC's September 13, 1979 and October 30, 1979 letters. These letters provided guidance concerning the technical education and training qualifications for STAs. The October 30th letter specified that the STA shall have a bachelor's degree or equivalent in a scientific or engineering discipline. The September 13th letter specified three functional areas: General Technical Education, Reactor Operations Training, and Transient and Accident Response Training.

Our review indicated that your STA training program is acceptable in meeting the intent of the guidelines set forth in the above referenced letters.

Sincerely,

A handwritten signature in cursive script, reading "John F. Stolz", is written over the typed name.

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

cc: See next page