

Washington Public Power Supply System

Box 1223 Elma, Washington 98541 (206) 482-4428



Docket Numbers 50-508 and 50-509


April 1, 1982
G03-82-322

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington D. C. 20555

Subject: PROJECT NOS. 3 AND 5
INTERIM REPORT OF POTENTIAL 10CFR50.55(e)
ARTIFICIAL ENHANCEMENT OF RADIOGRAPHIC FILM (D/N #41)

Attached is a copy of an interim report provided to Region V concerning a potential 10CFR50.55(e) associated with the subject condition.

Should you have any questions or desire further information, please contact me directly.


R. S. Leddick, 760
Program Director, WNP-3

DRC/tt

Attachment

cc: J. Adams - NESCO-WO/A
D. Smithpeter - BPA-WO/A
Ebasco - New York-WO/A
WNP-3/5 Files - Richland-WO/A

IE27
S
1/1

8204090373 820401
PDR ADOCK 05000508
S PDR

VIEWING DISTRIBUTION

COMMITMENT CONTROL

ROUTING

SITE FILES

WG ALBERT/NRC-712

DR COODY-750

DE DOBSON-760

JJ DORAN-723

RB GLASSCOCK-280

CM KIM-707

DJ LAGRQU-751

DD O'SULLIVAN- Docket Numbers 50-508 and 50-509

280

March 30, 1982

RG PECK-701

G03-82-297

JJ PETERSON-710

DL QUAMME-723

JP SLUKA-707

GC SORENSEN-

440

OE TRAPP-761

U. S. Nuclear Regulatory Commission, Region V
Office of Inspection and Enforcement
1450 Maria Lane, Suite 260
Walnut Creek, California 94596-5368

Attention: Mr. T. W. Bishop
Chief, Reactor Construction Projects Branch

Subject: PROJECT NOS. 3 AND 5
INTERIM REPORT OF POTENTIAL DOSE 0.65(e)
ARTIFICIAL ENHANCEMENT OF RADIOGRAPHIC FILM (D/N #41)

Reference: Letter, G03-82-021, dated January 11, 1982, R. S.
Leddick to B. H. Faulkenberry, same subject.

The referenced letter forwarded an interim report of the subject condition and noted that a final report would be provided to your office by March 31, 1982.

Corrective action included the identification of all spools on site that had enhanced radiographic film. The affected spools were then re-radiographed. Due to a concern with radiographic technique, one of the affected spools received a third radiograph which was subsequently forwarded to AP&E, Compton, for review and acceptance. To date, results of the AP&E review have not been received. As a result, the final report will be provided by April 30, 1982.

Should you have any questions or desire further information, please contact me directly.

R. S. Leddick, 760
Program Director, WNP-3/5

DRC/tt

cc: J. Adams - NESCO
D. Smithpeter - BPA
Ebasco - New York
WNP-3/5 Files - Richland

THIS LETTER (DOES) (DOES NOT) ESTABLISH A NEW COMMITMENT

WPPSS CORRESPONDENCE NO. 603-82-297

FOR SIGNATURE OF: RS LEDDICK

3-30

OE TRAPP

JA PUZAUSKAS

FOR APPROVAL OF

SECTION

AUTHOR: DR COODY:tt