



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401
Telephone (612) 330-6071

D. E. Gilberts
Senior Vice President
Power Supply

March 25, 1982

Mr R L Spessard, Director
Division of Project and Resident Programs
Region III Office of Inspection and Enforcement
U S Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Mr Spessard:

PRAIRIE ISLAND NUCLEAR GENERATING PLANT

Docket Nos. 50-282 and 50-306

In response to your letter of February 24, 1982 which transmitted Inspection Reports 50-282/82-01 and 50-306/82-01, the following is offered:

Violation

10 CFR 50, Appendix B, Criterion V, states in part: "Activities affecting quality shall be prescribed by documented instructions, procedures, or drawings, or a type appropriate to the circumstances and shall be accomplished in accordance with these instructions, procedures, and drawings." Northern States Power Company Operational Quality Assurance Plan, Revision 6, Section 18.2, states in part: "Measures shall be established which assure that operating occurrences and events that could have a significant safety effect are investigated, reviewed, and reported as required by the Technical Specifications." Procedure 5ACD3.6 requires (Section 6.4.3) that a final investigative report be prepared and completed within 40 days and shall be reviewed within 60 days by the Operations Committee.

Contrary to the above, as of the date of the inspection which was more than 60 days after the date of the event, Final Investigative Report for Licensee Event Report No. P-RO-81-23 had not been prepared and completed.

This is a Severity Level VI violation (Supplement I).

Response

The Final Investigative Report for RO-81-23 has been completed. A system has been instituted which will remind investigators of reports that they have coming due. This system is being tested now. Full compliance will be achieved by June 1, 1982.

Yours truly,

D E Gilberts
Senior Vice President
Power Supply

cc: G Charnoff
8204120446 820407
PDR ADOCK 05000282
G PDR

MAR 29 1982

UNITED STATES NUCLEAR REGULATORY COMMISSION

NORTHERN STATES POWER COMPANY

PRAIRIE ISLAND NUCLEAR GENERATING PLANT

Docket No. 50-282

Docket No. 50-306

LETTER DATED MARCH 25, 1982
RESPONDING TO NRC LETTER DATED FEBRUARY 24, 1982
INSPECTION REPORTS 50-282/82-01 and 50-306/82-01

Northern States Power Company, a Minnesota corporation, by this letter dated March 25, 1982 hereby submits, in response to the NRC letter dated February 24, 1982, our answer to Inspection Reports 50-282/82-01 and 50-306/82-01.

This request contains no restricted or other defense information.

NORTHERN STATES POWER COMPANY

By:

D E Gilberts

D E Gilberts
Senior Vice President
Power Supply

On this 25th day of March, 19 82, before me a notary public in and for said County, personally appeared D E Gilberts, Senior Vice President Power Supply, and being first duly sworn acknowledged that he is authorized to execute this document on behalf of Northern States Power Company, that he knows the contents thereof, and that to the best of his knowledge, information and belief, the statements made in it are true and that it is not interposed for delay.

Betty J. Dean

