

Docket Nos. 50-254
50-265

Mr. L. DelGeorge
Director of Nuclear Licensing
Commonwealth Edison Company
P. O. Box 767
Chicago, Illinois 60690

Dear Mr. DelGeorge:

SUBJECT: TMI ACTION PLAN ITEMS I.A.1.3(1), I.C.5, AND I.C.6 AS
DESCRIBED IN NUREG-0737

DISTRIBUTION

Docket File
NRC PDR
L PDR
TERA
NSIC
ORB#2 Rdg
DEisenhut
OELD
AEOD
IE
ACRS-10
SNorris
RBevan
Gray File
WRoss
MGrotenhuis
RLicciardo

MAR 23 1982



RE: Quad Cities Nuclear Power Station, Unit Nos. 1 and 2

We have completed our review of your submittals concerning subject TMI Action Plan items for the Quad Cities Nuclear Power Station, Units 1 and 2. Our conclusions on each item are as follows:

Item No. I.A.1.3(1) - Shift Manning Overtime Limits

This item defined shift manning requirements for normal operation. In addition, a letter dated July 31, 1980 from D. G. Eisenhut to all power reactor licensees and applicants set forth the interim criteria for shift staffing and overtime restrictions.

By letters dated December 15, 1980 and January 30, April 1, and May 29, 1981, CECo responded to this item and described the actions taken in response to the stated requirements. The actions consisted of changes to corporate policy guidelines and administrative procedures. In addition, you took exception to certain requirements and provided justification for the exceptions.

We have reviewed the above submittals and have determined that your actions adequately address the shift manning overtime limit requirements.

We have also reviewed the exceptions noted by you and find the reasons for the exceptions to be justified. Based on this review, we find that your response to Item No. I.A.1.3(1) is acceptable.

8204120458 820323
PDR ADOCK 05000254
P PDR

Item No. I.C.5 - Feedback of Operating Experience

This item requires each licensee to prepare procedures to assure that operating information pertinent to plant safety originating both within and outside the utility organization is continually supplied to operators and other personnel and is incorporated into training and retraining programs.

CECo meets this requirement through an Operating Experience Assessment Review (OEAR) program. The OEAR program is conducted by designated personnel under the direction of the Director of Nuclear Safety. We have reviewed the OEAR program and found that it meets the published requirements for feedback of operating experience. We, therefore, conclude that your response to Item I.C.5 is acceptable.

Item I.C.6 - Verify Correct Performance of Operating Activities

This item requires review and revision, if necessary, to licensee procedures to assure that an effective system of verifying the correct performance of operating activities is provided as a means of reducing human errors and improving the quality of normal operations.

CECo responded to this item in a letter dated December 15, 1980 and described a program currently in use for verification of operating activities. You noted that the program was in accordance with guidance published in NUREG-0737 which endorsed the Draft 5, August 1980 revision to ANS 3.2, Administrative Controls and Quality Assurance for the Operational Phase of Nuclear Power Plants, as supplemented by specific provisions in the NUREG.

We have reviewed your program implementation. We find your program to be in accordance with the published guidance and conclude that your response to Item No. I.C.6 is acceptable.

Based on the results of our reviews described above, IMI Action Plan Item Nos. I.A.1.3(1), I.C.5, and I.C.6 are considered resolved.

Sincerely,

ORIGINAL SIGNED BY

Domenic Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

cc: See next page

OFFICE	ORB#2:DL <i>DBB</i>	ORB#1:DL	ORB#1:DL	ORB#1:DL	C-ORB#2:DL	
SURNAME	RBell;cf	WRoss <i>WR</i>	MGrotenhuis	RLicciardo	DVassallo	
DATE	3/23/82	3/23/82	3/23/82	3/24/82	3/23/82	

Mr. L. DelGeorge
Commonwealth Edison Company

cc:

Mr. D. R. Stichnoth
President
Iowa-Illinois Gas and
Electric Company
206 East Second Avenue
Davenport, Iowa 52801

Mr. Philip Steptoe
Isham, Lincoln & Beale
Counselors at Law
One First National Plaza, 42nd Floor
Chicago, Illinois 60603

Mr. Nick Kalivianakas
Plant Superintendent
Quad Cities Nuclear Power Station
22710 - 206th Avenue - North
Cordova, Illinois 61242

Moline Public Library
504 - 17th Street
Moline, Illinois 61265

Susan N. Sekuler
Assistant Attorney General
Environmental Control Division
188 W. Randolph Street
Suite 2315
Chicago, Illinois 60601

Resident Inspector
U. S. Nuclear Regulatory Commission
22712 206th Avenue N.
Cordova, Illinois 61242

James L. Kelley, Chairman
Atomic Safety and Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dr. Peter A. Morris
Atomic Safety and Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dr. Richard F. Foster
P.O. Box 4263
Sunriver, Oregon 97701

The Honorable Tom Corcoran
United States House of Representatives
Washington, D.C. 20515

Quad-Cities Alliance for Safe
Energy and Survival
Mr. Robert Romic
1628 Grant Street
Bettendorf, Iowa 52722

Citizens for Safe Energy
ATTN: Mr. Robert Miller
P. O. Box 23
Hillsdale, Illinois 61257

James G. Keppler
Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137