

March 22, 1982

Dockets: 50-313/82-04
50-368/82-04

Arkansas Power and Light Company
ATTN: Mr. William Cavanaugh III
Senior Vice President
Energy Supply
P. O. Box 551
Little Rock, Arkansas 72203



Gentlemen:

This refers to the inspection conducted under the Resident Inspection Program by Messrs. W. D. Johnson and L. J. Callan of this office covering the period of February 1-28, 1982, of activities authorized by NRC Facility Operating Licenses DPR-51 and NPF-6 for the Arkansas Nuclear One, Units 1 and 2, and to the discussion of the findings by the NRC inspectors with members of your staff at the conclusion of each segment of the inspection.

Areas examined during the inspection and our findings are discussed in the enclosed inspection report. Within these areas, the inspection consisted of selective examination of procedures and representative records, interviews with personnel, and observations by the inspectors.

During this inspection, it was found that certain of your activities were not conducted in full compliance with NRC requirements. Consequently, you are required to respond to this matter, in writing, in accordance with the provisions of Section 2.201 of the NRC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations. Your response should be based on the specifics contained in the Notice of Violation enclosed with this letter.

One of the violations identified during this inspection, involving a missing seismic support, was found during a follow-up inspection on a previous violation involving a seismic support. Your corrective steps taken to avoid further violations were apparently lacking in depth or thoroughness. In your response to the enclosed Notice of Violation, please include an analysis of the cause of this repetitive violation. Also include a summary of the methods which you intend to use to ensure that your corrective actions in response to violations will be thorough enough to detect and correct the root cause of the violations.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosures will be placed in the NRC Public Document Room unless you notify this office,

101

8204130343 820322
PDR ADOCK 05000313
G PDR

OFFICE	RPS-C	RPS-C	RPB2	DRP&EP	DRA	RA-RIV
SURNAME	WDJohnson/nh	REHall	WCSeidle	JEgigliardo	KVSeifrit	JCollins
DATE	3/18/82	3/18/82	3/18/82	3/18/82	3/19/82	3/20/82

511

March 22, 1982

by telephone, within 10 days of the date of this letter and submit written application to withhold information contained therein within 30 days of the date of this letter. Such application must be consistent with the requirements of 2.790(b)(1).

The responses directed by this letter and the accompanying Notice are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

"Original Signed by
W. C. SEIDLE"

W. C. Seidle, Chief
Reactor Project Branch 2

Enclosures:

1. Appendix A - Notice of Violation
2. Appendix B - NRC Inspection Reports
50-313/82-04 and 50-368/82-04

cc w/enclosures:

Arkansas Nuclear One
ATTN: J. P. O'Hanlon, General Manager
P. O. Box 608
Russellville, Arkansas 72801

bcc to DMB:(IE01)

BC
PM
AEOD
ELD
IE FILE
IE/RPRIB
NRR/DHFS
NRR/OLB
RAD ASSMT BR
RESEARCH
PDR:HQ
LPDR
NSIC

bcc distrib. by RIV:
J. T. COLLINS
RESIDENT INSPECTOR
INFO SYSTEMS
TPB
MIS
E&I
BRANCH FILE
G. VISSING, NRR
R. MARTIN, NRR
ARKANSAS STATE DEPT. HEALTH

4-11-82

OFFICE							
SURNAME							
DATE							