LICENSEE EVENT REPORT
CONTROL BLOCK: [ ] ] ] [ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 N C B E P 2 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5 6 EIGENSEE CODE 14 15 LICENSEE NUMBER 57 CAT 58
CON'T  O 1 SOURCE L GO 5 0 - 10 3 2 4 7 0 13 1 16 8 12 8 0 14 1 1 4 8 12 9  EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10  During plant operation, it was discovered that fire hose station, 2-RB-22, located
on the 20' elevation of the Reactor Building, was inoperable due to a missing
[0]4] hose nozzle. This event did not affect the health and safety of the public.
0 5
0 6
0 7
Technical Specifications 3.7.7.4a, 6.9.1.9b
SYSTEM CAUSE CODE SUBCODE COMPONENT CODE SUBCODE SUBCO
17 REPORT NUMBER   8   2   -   0   5   3   -   0   3   L   -   0   3   1   1   1   1   1   1   1   1   1
ACTION FUTURE EFFECT SHUTDOWN HOURS 22 ATTACHMENT NPRD 4 PRIME COMP. COMPONENT MANUFACTURER  C 18 Z 19 Z 20 Z 21 0 0 0 0 0 N 23 Y 24 U 25 A 1 6 7 (2)
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)  The missing hose nozzle could not be located. It is not known why the nozzle was
removed or who removed it. The nozzle, Model No. 7160, was replaced within 55 minutes
of discovering it missing and the hose station was returned to service. Plant hose
[1]3 stations are visually inspected on a monthly basis; no further action to this event is
planned.
FACILITY STATUS SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32  1 5 E 28 0 8 3 29 NA A 31 Plant Personnel Surveillance
7 8 9 10 12 13 44 45 46 80  RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) NA
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)  1 7   0   0   (37)   Z   (38)   NA
7 8 9 11 12 13 80 PERSONNEL INJURIES 80
1 8 0 0 0 0 0 0 0 0 11 12 NA NA 180
LOSS OF OR DAMAGE TO FACILITY (43) TYPE DESCRIPTION  NA  NA
PUBLICITY   8204280373   NA   See 59   NRC USE ONLY   80   NRC USE
NAME DE SPENASSO M. J. Pastva, Jr. 919-457-9521