LICENSEE EVENT REPORT
CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 N C B E P 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 57 CAT 58 5
CON'T  O 1  SOURCE L 6 0 5 0 - 0 3 2 5 7 0 3 1 9 8 2 8 0 4 1 4 8 2 9  EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10  During plant operation, routine surveillance revealed that primary containment multi-
o[3] point temperature recorder, 1-CAC-TR-1258, was printing erratically. A similar
o 4 event involving this instrument was reported in LER 1-82-2. This event did not
o s affect the health and safety of the public.
06
071
Technical Specifications 3.3.5.3, 6.9.1.9b
SYSTEM CAUSE CAUSE SUBCODE SUB
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)  [1 0] [This event occurred due to fouled electrical contacts in the recorder point select ]
relay. The relay contacts were cleaned and the recorder, Model No. 551, was returned
1 2 to service. This instrument is cleaned and inspected every three months and calibrated
1 3 every six months to ensure dependable operation.
7 8 9
FACILITY S POWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32  1 5 E 28 0 6 3 29 NA A 31 Operator Surveillance
7 8 9 10 12 13 44 45 46 80  RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)  NA
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)  NA NA NA BO  PERSONNEL INJURIES 13  PERSONNEL INJURIES 13
1 B 0 NUMBER 0 40 DESCRIPTION 41 NA NA 80
LOSS OF OR DAMAGE TO FACILITY (43) TYPE DESCRIPTION  NA  NA  80
PUBLICITY ISSUED DESCRIPTION 45 82 U 4 2 8 0 4 9 1 NA NRC USE ONLY  NRC USE ONLY  NRC USE ONLY  1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
NAME OF PREPARER M. J. Pastva, Jr. PHONE 919-457-9521