

APR 15 1982

Docket No. 99900519/82-01

Bechtel Power Corporation
Gaithersburg Power Division
ATTN: Mr. J. M. Komes
Vice President and
General Manager
15740 Shady Grove Road
Gaithersburg, MD 20760



Gentlemen:

This refers to the inspection conducted by Mr. J. R. Costello of this office on January 25-29 and February 22-26, 1982, of your facility at Gaithersburg, Maryland, and to the discussions of our findings with Mr. B. K. Kanga and members of your staff at the conclusion of the inspection.

This inspection was made as a result of a 10 CFR Part 50.55(e) and a potential construction deficiency report which covered the following: (1) valve chatter in RHR heat exchanger vent valves (Grand Gulf 1 and 2); and (2) incorrect sized cable which resulted in a failure of the control rods to scram (Grand Gulf 1 and 2). Other areas of inspection included review of Bechtel's activity in response to IE Bulletins 79-02 and 79-14.

Areas examined during this inspection and our findings are discussed in the enclosed report. Within these areas, the inspection consisted of an examination of procedures and representative records, interviews with personnel, and observations by the inspector.

Within the scope of this inspection, we found no instance where you failed to meet the commitment of your Topical Report No. BQ-TOP-1 or NRC requirements.

8205030314

IE:09
5/11

	RIV: <i>gpc</i> CI: RSS	SC: RSS	BC: VPB <i>4P</i>	D: EIS <i>5/8</i>	RA <i>RA</i>
OFFICE	JRCostello	CJHale	UPotapovs	EHJohnson	JTCollins
	4/1/82	4/2/82	4/1/82	4/1/82	4/1/82
SURNAME				<i>gpc</i>	
DATE				4/12/82	

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed report will be placed in the NRC's Public Document Room. If this report contains any information that you believe to be exempt from disclosure under 10 CFR 9.5(a)(4), it is necessary that you (a) notify this office by telephone within 10 days from the date of this letter of your intention to file a request for withholding; and (b) submit within 25 days from the date of this letter a written application to this office to withhold such information. If your receipt of this letter has been delayed such that less than 7 days are available for your review, please notify this office promptly so that a new due date may be established. Consistent with section 2.790(b)(1), any such application must be accompanied by an affidavit executed by the owner of the information which identifies the document or part sought to be withheld, and which contains a full statement of the reasons on the basis which it is claimed that the information should be withheld from public disclosure. This section further requires the statement to address with specificity the considerations listed in 10 CFR 2.790(b)(4). The information sought to be withheld shall be incorporated as far as possible into a separate part of the affidavit. If we do not hear from you in this regard within the specified periods noted above, the report will be placed in the Public Document Room.

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,
 "Original Signed by"
 U. POTAPOVS"

Uldis Potapovs, Chief
 Vendor Programs Branch

Enclosures:

1. Appendix A - Inspection Report No. 99900519/82-01
2. Appendix B - Inspection Data Sheets (16 pages)

bcc:
 IE Files
 AEOD
 QAB
 NRC:PDR
 Reg. Administrators, I, II, III, IV, V
 EHJohnson, RIV

OFFICE ▶	EHJohnson, RIV					
SURNAME ▶						
DATE ▶						