ENCLOSURE 1

DESIGN CODES, DESIGN CRITERIA, AND LOADING COMBINATIONS (SEP, III-7,B)

JERSEY CENTRAL POWER AND LIGHT COMPANY OYSTER CREEK NUCLEAR GENERATING STATION

NRC DOCKET NO. 50-255

NRC TAC NO. 41498

NRC CONTRACT NO. NRC-03-79-118

FRC PROJECT C5257 FRC ASSIGNMENT 11 FRC TASK 320

Prepared by

Franklin Research Center 20th and Race Street Philadelphia, PA 19103

Prepared for

Nuclear Regulatory Commission Washington, D.C. 20555 F. Stilwell, M. Darwish, Author: E. M. Wallo, R. Koliner, P. Noell, R. H. Hollinger FRC Group Leader: T. C. Stilwell

Lead NRC Engineer: D. Persinko

April 28, 1982

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government noany agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

> Franklin Research Center A Division of The Franklin Institute The Benjamin Franklin Parkway, Phila. Pa. 19103 (215) 448-1000

DURE 8205030319 XA)

TECHNICAL EVALUATION REPORT

DESIGN CODES, DESIGN CRITERIA, AND LOADING COMBINATIONS (SEP, III-7.B)

JERSEY CENTRAL POWER AND LIGHT COMPANY OYSTER CREEK NUCLEAR GENERATING STATION

NRC DOCKET NO. 50-255

NRC TAC NO. 41498

NRC CONTRACT NO. NRC-03-79-118

FRC PROJECT C5257 FRC ASSIGNMENT 11 FRC TASK 320

Prepared by

Franklin Research Center 20th and Race Street Philadelphia, PA 19103

Prepared for

Nuclear Regulatory Commission Washington, D.C. 20555 T. Stilwell, M. Darwish, Author: E. M. Wallo, R. Koliner, P. Noell, R. H. Hollinger FRC Group Leader: T. C. Stilwell

Lead NRC Engineer: D. Persinko

April 28, 1982

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, cr represents that its use by such third party would not infringe privately owned rights.



CONTENTS

Section	Title	Page
1	INTRODUCTION	1
2	BACKGROUND	2
3	REVIEW OBJECTIVES	3
4	SCOPE	4
5	MARGINS OF SAFETY	7
6	CHOICE OF REVIEW APPROACH	9
7	METHOD	11
	7.1 Information Retrieval	11
	7.2 Appraisal of Information Content	12
	7.3 Code Comparison Reviews	12
	7 A Assessment of the Detential Transf of Gal	12
	Changes	15
	7.4.1 Classification of Code Changes	16
	7.4.1.1 General and Conditional Classifications	
	of Code Change Impacts	17
	7.4.1.2 Code Impacts on Structural Margins	18
	7.5 Plant-Specific Code Changes	20
8	OYSTER CREEK SEISMIC CATEGORY I STRUCTURES	21
9	STRUCTURAL DESIGN CRITERIA	22
10	LOADS AND LOAD COMBINATION CRITERIA	24
	10.1 Description of Tables of Loads and Load Combinations	24

Franklin Research Center

.

.

· ·

CONTENTS (Cont.)

Section

Title

Page

	10.2	Load D	efini	ions	з.										28
	10.3	Design	Load	Tab	les, '	Comp	aris	on of	E De	sign					
		Dasis	Loads		• •	•	•	•	•	•	•	•	•	•	30
	10.4	Load C Combin	ombina ation	Crit	n Tabl teria'	les,	"Comj	paris	son .	of L	oad •				39
11	REVIEW	FINDI	NGS		•										50
	11.1	Major Code C	Findir	son.	of AIS	SC-19	63 V	5. AI	sc-	1980					52
	11.2	Major ACT 34	Pindir	igs d	DE ACI	318-	-63 1	/s.	•			Ċ	Ċ	·	54
				oue	compa	IT I SOI	1.		•	•	•	•	•	•	55
	11.3	Major (Revis	Findir ed 197	igs (of ACI Compar	: 301- :ison	-63 1	's. A	. 13.		72				59
	11.4	Major vs. Se	Findir	ITT.	E ASM	E Bal	V Co	de,	Sect	ion	VIII	, 19	62		
				,	Juba	beccit	on NE	., 19	00 0	.ode	Comp	paris	son.	•	60
12	SUMMAR	ч.	• •	•		·	·	•	•	•		•		•	66
13	RECOMM	ENDATI	ONS .	•	•	•	•	•	•	•					68
14	REFERE	NCES	• •		•	•	•	•							72
APPENDIX	A - S	CALE A YSTER	AND S	CALE	A _X C	HANGE	S DE	EMED	INA	PPRO	OPRIA	TE I	Ø		
APPENDIX	B - S	UMMARI	es of	CODE	COMP	ARISC	N FI	NDIN	GS						
APPENDIX	c - a	OMPARA	CIVE E	VALU	ATION	S AND	MOD	EL S	TUDI	ES					
APPENDIX	D - A	CI CODI	E PHIL	OSOP	HIES										
APPENDIX	I - 0	ODE CON	PARIS	ON R	EVIEW	OF T	ECHN	ICAL	DES	IGN					

BASIS DOCUMENTS DEFINING CURRENT LICENSING CRITERIA FOR SEP TOPIC III-7.B (SEPARATELY BOUND) CONTENTS (Cont.)

Section		Title
APPENDIX	II	- CODE COMPARISON REVIEW OF AISC SPECIFICATION FOR THE DESIGN, FABRICATION, AND ERECTION OF STRUCTURAL STEEL FOR BUILDINGS FOR THE YEARS 1980 VS. 1963 (SEPARATELY BOUND)
APPENDIX	III	- NOT APPLICABLE TO OYSTER CREEK PLANT
APPENDIX	IV	 CODE COMPARISON REVIEW OF CODE REQUIREMENTS FOR NUCLEAR SAFETY-RELATED CONCRETE STRUCTURES ACI 349-76 VS. BUILDING CODE REQUIREMENTS FOR REINFORCED CONCRETE ACI 318-63 (SEPARATELY BOUND)
APPENDIX	v	- COMPARISON REVIEW OF THE SPECIFICATIONS FOR STRUCTURAL CONCRETE FOR BUILDINGS, ACI 301-72 (1975 REVISION) VS. ACI 301-63 (SEPARATELY BOUND)
APPENDIX	VI	- NOT APPLICABLE TO OYSTER CREEK PLANT
APPENDIX	VII	- NOT APPLICABLE TO OYSTER CREEK PLANT
APPENDIX	VIII	- NOT APPLICABLE TO OYSTER CREEK PLANT
APPENDIX	IX	- CODE COMPARISON REVIEW OF CODE REQUIREMENTS FOR ASME B&PV CODE SECTION III, SUBSECTION NE, 1980 VS. ASME B&PV CODE SECTION VIII, 1962 (SEPARATELY BOUND)
APPENDIX	x	- NOT APPLICABLE TO OYSTER CREEK PLANT
APPENDIX	XI	- NOT APPLICABLE TO OYSTER CREEK PLANT
APPENDIX	XII	- NOT APPLICABLE TO OYSTER CREEK PLANT

v

Franklin Research Center

.

.

FOREWORD

This Technical Evaluation Report was prepared by Franklin Research Center under a contract with the U.S. Nuclear Regulatory Commission (Office of Nuclear Reactor Regulation, Division of Operating Reactors) for technical assistance in support of NRC operating reactor licensing actions. The technical evaluation was conducted in accordance with criteria established by the NRC.



.

1. INTRODUCTION

For the Seismic Category I buildings and structures at the Oyster Creek Nuclear Power Station, this report provides a comparison of the structural design codes and loading criteria used in the actual plant design against the corresponding codes and criteria currently used for licensing of new plants.

The objective of the code comparison review is to identify deviations in design criteria from current criteria, and to assess the effect of these deviations on margins of safety, as they were originally perceived and as they would be perceived today.

The work was conducted as part of the Nuclear Regulatory Commission's (NRC) Systematic Evaluation Program (SEP) and provides technical assistance for Topic III-7.B, "Design Codes, Design Criteria, and Load Combinations." The report was prepared at the Franklin Research Center under NRC Contract No. NRC-03-79-118.



TER-C5257-320

2. BACKGROUND

With the development of nuclear power, provisions addressing facilities for nuclear applications were progressively introduced into the codes and standards to which plant building and structures are designed. Because of this evolutionary development, older nuclear power plants conform to a number of different versions of these codes, some of which have since undergone considerable revision.

There has likewise been a corresponding development of other licensing criteria, resulting in similar non-uniformity in many of the requirements to which plants have been licensed. With this in mind, the NRC undertook an extensive program to evaluate the safety of 11 older plants (and eventually all plants) to a common set of criteria. The program, entitled the Systematic Evaluation Program (SEP), employs current licensing criteria (as defined by NRC's Standard Review Plan) as the common basis for these evaluations.

To make the necessary determinations, the NRC is investigating, under the SEP, 137 topics spanning a broad spectrum of safety-related issues. The work reported herein constitutes the results of part* of the investigation of one of these topics, Topic III-7.B, "Design Codes, Design Criteria, and Load Combinations."

This topic is charged with the comparison of structural design criteria in effect in the late 1950's to the late 1960's (when the SEP plants were constructed) with those in effect today. Other SEP topics also address other aspects of the integrity of plant structures. All these structurally-oriented tasks, taken together, will be used to assess the structural adequacy of the SEP plants with regard to current requirements. The determinations with respect to structural safety will then be integrated into an overall SEP evaluation encompassing the entire spectrum of safety-related topics.

*The report addresses only the Oyster Creek plant.

3. REVIEW OBJECTIVES

The broad objective of the NRC's Systematic Evaluation Program (SEP) is to reassess the safety of 11 older nuclear power plants in accordance with the intent of the requirements governing the licensing of current plants, and to provide assurance, possibly involving backfitting, that operation of these plants conforms to the general level of safety required of modern plants.

Task III-7.B of the SEP effort seeks to compare actual and current structural design criteria for the major civil engineering structures at each SEP plant site, i.e., those important to shutdown, containment, or both, and therefore designated Seismic Category I structures. The broad safety objective of SEP Task III-7.B is (when integrated with several other interfacing SEP topics) to assess the capability of all Seismic Category I structures to withstand all design conditions stipulated by the NRC, at least to a degree sufficient to assure that the nuclear power plant can be safely shut down under all circumstances.

The objective of the present effort under Task III-7.B is to provide, through code comparisons, a rational basis for making the required technical assessments, and a tool which will assist in the structural review.

Finally, the objective of this report is to present the results of Task III-7.B as they relate to the Oyster Creek Nuclear Power Station.

TER-C5257-320

4. SCOPE

In general, the scope of work required comparison of the provisions of the structural codes and standards used for the design of SEP plant Seismic Category I civil engineering structures* against the corresponding provisions governing current licensing practice. The review includes the containment and all Category I structures within and exterior to it. Explicit among the criteria to be reviewed are loads and loading combinations postulated for these structures.

The review scope consisted of the following specific tasks:

- Identify current design requirements, based on a review of NRC Regulations; 10CFR50.55a, "Codes and Standards"; and the NRC Standard Review Plan (SRP).
- Review the Structural design codes, design criteria, design and analysis procedures, and load combinations (including combinations involving seismic loads) used in the design of all Category I structures as defined in the Final Safety Analysis Report (FSAR) for each SEP plant.
- Based upon the plant-specific design codes and standards identified in Task 2 and current licensing codes and standards from Task 1, identify plant-specific deviations from current licensing criteria for design codes and criteria.
- 4. Assess the significance of the identified deviations, performing (where necessary) comparative analyses to quantify significant deviations. Such analyses may be made on typical elements (beams, columns, frames, and the like) and should be explored over a range of parameters representative of plant structures.
- 5. Prepare a Technical Evaluation Report for each SEP plant including:
 - a. comparisons of plant design codes and criteria to those currently accepted for licensing
 - b. assessment of the significance of the deviations

*In general, these are the structures normally examined in licensing reviews under Section 3.8 of the SRP (but note the list at the end of this section of structures specifically excluded from the scope of this review).

Franklin Research Center

- c. results of any comparative stress analyses performed in order to make an assessment of the significance of the code changes upon safety margins
- d. overall evaluation of the acceptability of structural codes used at each SEP plant.

A number of SEP topics examine aspects of the integrity of the structures composing SEP facilities. Several of these interface with the Task III-7.B effort as shown below:

Topic	Designation
III-1	Classification of Structures, Components, Equipment, and Systems (Seismic and Quality)
III-2	Wind and Tornado Loading
III-3.A	Effects of High Water Level on Structures
III-4	Missile Generation and Protection
III-5	Evaluation of Pipe Breaks
III-6	Seismic Design Considerations
III-7.D	Structural Integrity Tests
VI-2	Mass and Energy Release for Postulated

Because they are covered either elsewhere within the SEP review or within other NRC programs, the following matters are explicitly excluded from the scope of this review:

Mark I torus shell, supports, vents, local region of drywell at vent penetrations Reactor pressure vessel supports, steam generator supports, pump Supports Equipment supports in SRP 3.8.3 Reviewed in Generic Task A-2, A-12. Reviewed generically in Topic

Reviewed generically in Topic III-6, Generic Task A-12.

.

-5-

TER-C5257-320

Other component supports (steel and concrete)

Specific supports have been analyzed in detail in Topic III-6. (Component supports may be included later if items of concern applicable to component supports are found as a result of reviewing the structural codes.)

Testing of containment

Inservice inspection; quality control/assurance

Determination of structures that should be classified Seismic Category I

Shield walls and subcompartments inside containment

Masonry walls

Seismic analysis

Reviewed in Topic III-7.D.

Should be considered in the review only to the extent that it affects design criteria, design allowables. Aspects of inservice inspection are being reviewed in Topics III-7.A and III-3.C

Not within scope.

Reviewed in Generic Task A-2.

Reviewed generically in IE Bulletin 80-11.

Being reviewed by Lawrence Livermore Laboratory.

5. MARGINS OF SAFETY

There are several bases upon which margins of safety* may be defined and discussed.

The most often used is the margin of safety based on yield strength. This is a particularly useful concept when discussing the behavior of steels, and became ingrained into the enjineering vocabulary at the time when steel was the principal metal of engineering structures. In this usage, the margin of safety reflects the reserve capacity of a structure to withstand extra loading without experiencing an incipient permanent change of shape anywhere throughout the structure. Simultaneously, it reflects the reserve load carrying capacity existing before the structure is brought to the limit for which an engineer could be certain the computations (based on elastic behavior of the metal) applied.

This is the conventional use of the term and the meaning which engineers take as intended, unless the term is further qualified to show something else is meant. Thus, if a structure is stated to have a margin of safety of 1.0 under a given set of loads, then it will be generally understood that every load on the structure may be simultaneously doubled without encountering (anywhere) inelastic stresses or deflections. On the other hand, if (under load) a structure has no margin of safety, any increment to any load will cause the structure to experience, in a least one (and possibly more than one) location, some permanent distortion (however small) of its original shape.

Because the yield strengths of common structural steels are generally well below their ultimate strengths, the engineer knows that in most (but not all) cases, the structure possesses substantial reserve capacity--beyond his computed margin--to carry additional load.

There are other useful ways, however, to speak of safety margins and these (not the conventional one) are particularly relevant to the aims of the systematic evaluation program.

*Factors of safety (FS) are related to margins of safety (MS) through the relation, MS = FS - 1.

Franklin Research Center

TER-C5257-320

One may speak of margins of safety with <u>respect to code allowable limits</u>. This margin reflects the reserve capacity of a structure to withstand extra loading while still conforming to all criteria governing its design.

One may also speak (if it is made clear in advance that this is the intended meaning) of margins of safety <u>against actual failure</u>. Both steel and concrete structures exhibit much higher "margins of safety" on this second basis than is shown by computation of margins of safety based on code allowables.

These latter concepts of "margin of safety" are very significant to the SEP review. Indeed the basic review concept, at least as it relates to structural integrity, cannot be easily defined in any quantitative manner without considering both. The SEP review concept is predicated on the assumption that it is unrealistic to expect that plants which were built to, and were in compliance with, older codes will still conform to current criteria in all respects. The SEP review seeks to assess whether or not plants meet the "intent" of current licensing criteria as defined by the Standard Review Plan (SRP). The objective is <u>not</u> to require that older plants be brought into conformance with all SRP requirements to the letter, but rather to assess whether or not their design is sufficient to provide the general level of safety that current licensing requirements assure.

With respect to aspects of the SEP program that involve the integrity of structures, the SEP review concept can be rephrased in a somewhat more quantitative fashion in terms of these two "margins of safety." Thus, it is not expected or demanded that all structures show positive margins of safety <u>based upon code allowables</u> in meeting all current SRP requirements; but it is demanded that margins of safety <u>based upon ultimate strength</u> are not only positive, but ample. In fact, the critical judgments to be made (for SEP plants) are:

1. to what extent may current code margins be infringed upon.

 what minimum margin of safety based on ultimate strength must be assured.

The choice of method for Topic III-7.B review can be discussed in terms of these two key considerations.

6. CHOICE OF REVIEW APPROACH

The approach taken in the review process depends on which key questions (of Section 5) one chooses to emphasize and address first.

One could give primary consideration to the second. If this approach is chosen, one first sets up a minimum margin of safety (based on failure) that will be acceptable for SEP plants. This margin is to be computed in accordance with current criteria. Then one investigates structures designed in accordance with earlier code provisions, and to different loading combinations, to see if they meet the chosen SEP margin when challenged by current loading combinations and evaluated to current criteria. This approach gives the appearance of being efficient. The review proceeds from the general (the chosen minimum margin of safety) to the particular (the ability of a previously designed structure to meet the chosen margin). Moreover, issues are immediately resolved on a "go; no-go" basis. The initial step in this approach is not easy, nor are the necessary evaluations. One is dealing with highly loaded structures in regions where materials behave inelastically. Rulemaking in such areas is sure to be difficult, and likely to be highly controversial.

The alternative approach is taken in this review. It proceeds from the particular to the general, and places initial emphasis upon seeking to answer (for SEP plants) questions as to what, how many, and of what magnitude are the infringements on current criteria. No new rulemaking is involved (at least at the outset). All initial assessments are based on existing criteria.

Current and older codes are compared paragraph-by-paragraph to see the effects that code changes may have on the load carrying ability of individual elements (beams, columns, frames, and the like). It should be noted that this process, although involving judgments, is basically fact-finding -- not decisionmaking.

This kind of review is painstaking, and there is no assurance in advance that it in itself will be decisive. It may turn out, after examination of the

-9-

facts, that designs predicated upon the older criteria infringe upon current design allowables in many cases and to extensive depths. If so, such information will certainly be of value to the final safety assessment, but many unresolved questions will remain.

On the other hand, it may turn out that infringements upon current criteria are infrequent and not of great magnitude. If this is the case, many issues will have been resolved, and questions of structural integrity will be sharply focused upon a few remaining key issues. In addition, a separate file was set up to maintain past and present structural codes, NRC Regulatory Guides, Staff Position Papers, and other relevant documents (including, where available, reports from SEP tasks interfacing with the III-7.B effort).

7.2 APPRAISAL OF INFORMATION CONTENT

Most of the information sources were originally written for purposes other than those of the Task III-7.B review. Consequently, much of the information sought was embedded piecemeal in the documents furnished. These sources were searched for the relevant information that they did contain. Generally, it was found that information gaps remained (i.e., some items were not referenced at all or were not specific enough for Task III-7.B purposes). The information found was assembled and the gaps were filled through the information retrieval efforts mentioned earlier.

7.3 CODE COMPARISON REVIEWS

The codes and standards used to represent current licensing practice were selected as described in Appendix I of this report. Briefly summarized, the criteria selection corresponds to NUREG-800 (NRC's Standard Review Plan), the operative document providing guidance to NRC reviewers on licensing matters (see Reference 1).

Next, the Seismic Category I structures at the Oyster Creek Nuclear Power Station were identified (see Section 8). For these, the codes and standards which were used for actual design were likewise identified on a structure-bystructure basis (see Section 9). Each code was then paired with its counterpart which would govern design were the structure to be licensed today.

Workbooks were prepared for each code pair. The workbook format consisted of paragraph-by-corresponding paragraph photocopies of the older and the current versions laid out side-by-side on ll-by-l7-inch pages. A central column between the codes was left open to provide space for reviewer comments.

The code versions were initially screened to discover areas where the text either remained identical in both versions or had been reedited without

Franklin Research Center

-12-

7. METHOD

A brief description of the approach used to carry out SEP Topic III-7.B follows. For discussion of the work, it is convenient to divide it into six areas:

- 1. information retrieval and assembly
- 2. appraisal of information content
- code comparison reviews
- 4. code change impact assessment
- 5. plant-specific review of the relevancy of code change impacts
- 6. summarizing plant status vis-a-vis design criteria changes.

7.1 INFORMATION RETRIEVAL

6

The initial step (and to a lesser extent an ongoing task of the review) was to collect and organize necessary information. At the outset, NRC forwarded files relevant to the work. These submittals included pertinent sections of plant FSARs, Standard Review Plan (SRP) 3.8, responses to questions on Topic III-7.B previously requested of licensees by the NRC, and other relevant data and reports.

These submittals were organized into Topic III-7.B files on a plant-byplant basis. The files also contain subsequently received information, as well as other documents developed for the plant review.

A number of channels were used to gather additional information. These included information requests to NRC; letter requests for additional information sent to licensees; plant site visits*; and retrieval of representative structural drawings, design calculations, and design specifications.

^{*}A walk-through inspection of major Category I structures at the Oyster Creek Nuclear Power Station was made by SEP Topic III-7.B reviewers on May 12, 1981, and the Parsippany, NJ, Engineering Office of Jersey Central Power and Light Company was visited by team members on May 22, 1981.

changing technical content. Code paragraphs which were found to be essentially the same in both versions were so marked in the comments column.

The review then focused on the remaining portions of the codes where textual disparities existed. Pertinent comments were entered. Typical comments address either the reason the change had been introduced, the intent of the change, its impact upon safety margins, or a combination of such considerations.

As can be readily appreciated, many different circumstances arise in such evaluations--some simple, some complex. A few examples are cited and briefly discussed below.

Provisions were found where code changes liberalized requirements, i.e., less stringent criteria are in force today than were formerly required. Such changes are introduced from time to time as new information becomes available regarding the provision in question. Not infrequently, code committees are called upon to protect against failure modes where the effects are well known; but too little is yet clear concerning the actual failure mechanism and the relative importance of the contributing factors. The committee often cannot defer action until a full investigation has been completed, but must act on behalf of safety. Issues such as these are usually resolved with prudence and caution--sometimes by the adoption of a rule (based upon experience and judgment) known to be conservative enough to assure safety. Subsequent investigation may produce evidence showing the adopted rule to be overly cautious, and provide grounds for its relaxation.

On the other hand, some changes which on first view may appear to reflect a relaxation of code requirements do not in fact actually do so. Structural codes tend to be documents with interactive provisions. Sometimes apparent liberalization of a code paragraph may really reflect a general tightening of criteria, because the change is associated with stiffening of requirements elsewhere.

To cite a simple example, a newly introduced code provision may be found making it unnecessary to check thin flanged, box section beams of relatively small depth-to-width ratio for buckling. This might appear to be a relaxation of requirements; however, elsewhere the code has also introduced a require-

Franklin Research Center

ment that the designer must space end supports closely enough to preclude buckling. Thus, code requirements have been tightened, not relaxed.

Whenever it was found that code requirements had truly been relaxed, this was noted in the reviewer's comments in the code comparison review. Because liberalization of code criteria clearly cannot give rise to safety issues concerning structures built to more stringent requirements, such matters were not considered further.

On the other hand, whenever it was clear that a code change introduced more stringent criteria, the potential impact of the change on margins of safety shown for the structure was assessed. When it was felt that the change (although more restrictive) would not significantly affect safety margins, this judgment was entered as a reviewer comment. When it was clear that the code change had the potential to significantly affect the perceived margin of safety, this was noted in the comments and the paragraph flagged for further consideration.

Sometimes the effects of a code change are not apparent. Indeed, depending upon a number of factors, * the change may reflect a tightening of requirements for some structures and a liberalization for others. When doubtful or ambiguous situations were encountered in the review, the effect of the code change was explored analytically using simple models.

A variety of analytical techniques were used, depending on the situation at hand. One general approach was to select a basic structural element (a beam, a column, a frame, a slab, or the like) and analytically test it, under both the older and the current criteria. For example, a typical structural element and a simple loading were selected; the element was then designed to the older code requires is. Next, the load carrying capacity of this structure was reexamined using current code criteria. Finally, the load carrying capacities of the element, as shown by the older criteria and as

determined by the current criteria, were compared. Examples of investigations performed to assess code change impacts are found in Appendix C.

In making these studies, an attempt was made to use structural elements, model dimensions, and load magnitudes that were representative of actual structures. For studies that were parametized, an attempt was made to span the parametric range encountered in nuclear structures.

Although one must be cautious about claiming that results from simplified models may be totally applicable to the more complex situations occurring in real structures, it was falt that such examples provided reasonable guidance for making rational judgments concerning the impact of changed code provisions on perceived margins of safety.

7.4 AS SES SMENT OF THE POTENTIAL IMPACT OF CODE CHANGES

As the scope of the Task III-7.B assignment indicates, a limited objective is sought in assessing the effects of code changes on Seismic Category I structures.

The scope of this review is not set at the level of appraisal of individual, as-built structures on plant sites. Consequently, the review does not attempt to make quantitative assessments as to the structureal adequacy under current NRC criteria of specific structures at particular SEP plants.

To the contrary, the scope is confined to the comparison of former structural codes and criteria with counterpart current requirements. Correspondingly, the assessment of the impact of changes in codes and criteria is confined to what can be deduced solely from the provisions of the codes and criteria.

Although the review is therefore carried out with minimal reference to actual structures in the field, the assessments of code change impacts that can be made at the code comparison level hold considerable significance for actual structures.

-15-

In this respect, two important points should be noted:

1. The review brings sharply into focus the changes in code provisions that may give rise to concern with respect to structural margins of safety as perceived from the standpoint of the requirements that NRC now imposes upon plants currently being licensed.

The review simultaneously culls away a number of code changes that do not give rise to such concerns, but which (because they are there) would otherwise have to be addressed, on a structure-by-structure basis.

 The effects of code changes that can be determined from the level of code review are confined to potential or possible impacts on actual structures.

A review conducted at the code comparison level cannot determine whether or not potentially adverse impacts are actually realized in a given structure. The review may only warn that this may be the case.

For example, current criteria may require demonstration of structural integrity under a loading combination that includes an additional load not specified in the corresponding loading combination to which the structure was designed. If the non-considered load is large (i.e., in the order of or larger than other major loads that were included), then it is quite possible that some members in the structure would appear overloaded as viewed by current criteria. Thus a potential concern exists.

However, no determination as to actual overstress in any member can be made by code review alone. Actual margins of safety in the controlling member (and several others*) must certainly be examined before even a tentative judgment of this kind may be attempted.

In order to carry out the code review objective of identifying criteria changes that could potentially impair perceived margins of safety, the following scheme classifying code change impacts was adopted.

7.4.1 Classification of Code Changes

Where code changes involve technical content (as opposed to those which are editorial, organizational, administrative, and the like), the changes are classified according to the following scheme.

^{*}The addition of a new load can change the location of the point of highest stress.

Each such code change is classified according to its potential to alter perceived margins of safety* in structural elements to which it applies. Four categories are established:

Scale A Change - The new criteria have the potential to substantially impair margins of safety as perceived under the former criteria.

- Scale A_X Change The impact of the code change on margins of safety is not immediately apparent. Scale A_X code changes require analytical studies of model structures to assess the potential magnitude of their effect upon margins of safety.
- Scale B Change The new criteria operate to impair margins of safety but not enough to cause engineering concern about the adequacy of any structural element.
- Scale C Change The new criteria will give rise to larger margins of safety than were exhibited under the former criteria.

7.4.1.1 General and Conditional Classifications of Code Change Impacts

Scale ratings of code changes are found in two different forms in this report. For example, some are designated as "Scale A," and others as "Scale C." Others have dual designation, such as "Scale A if --- [a condition state-ment] or Scale C if --- [a second condition statement]."

In assigning scale classifications, an <u>efficient</u> design to original criteria is assumed. That is, it is postulated that (a) the provision in question controls design, and (b) the structural member to which the code provision applies was proportioned to be at (or close to) the allowable limit. The impact scale rating is assigned accordingly.

If the code change is Scale A, and it applies (in a particular structure) to a member which is not highly stressed, then this may afford excellent grounds for asserting that this particular member is adequate; but it does not thereby downgrade the ranking to, say, a Scale B change for that member. The

^{*}That is, if (all other considerations remaining the same) safety margins as computed by the older code rules were to be recomputed for an as-built structure in accordance with current code provisions, would there be a difference due only to the code change under consideration?

scale ranking is neither a function of member stress* nor a ranking of member adequacy. The scale system ranks code change impact, not individual members.

However, a number of code provisions are framed so that the allowable limit is made a function of member proportion. When this kind of a code provision is changed, the change may affect members of certain proportions one way and members of other proportions differently.

For example, assume a change in column design requirements is introduced into the code and is framed in terms of the ratio of the effective column length to its radius of gyration. The new rule acts to tighten design requirements for slender columns, but liberalizes former requirements for columns that are not slender. This change may be rated Scale A for slender columns, and simultaneously, Scale C for non-slender ones. Although some columns now appear to be Scale A columns while others appear to be Scale C columns, the distinction between them <u>resides in the code</u>, and is not a reflection of member adequacy. Clearly, it is still the code changes that are ranked; but, in this case, the code change does not happen to affect all columns in a unilateral way.

7.4.1.2 Code Impact on Structural Margins

This classification of code changes identifies both (a) changes that have the potential to significantly impair perceived margins of safety (Scale A) and (b) changes that have the potential to enhance perceived margins of safety (Scale C).

Emphasis is subsequently placed on Scale A changes, not on Scale C changes. The purpose of the code comparison review is to narrow down and bring into sharper focus the areas where structures shown adequate under former criteria may not fully comply with current criteria. Once such criteria changes have been identified, actual structures may be checked to see if the potential concern is applicable to the structure. Depending upon a number of structure-specific circumstances, it may or may not pertain.

*There are exceptions, but these are code-related, not adequacy-related.

The same thing is true of Scale C changes, i.e., those that may enhance perceived structural margins. Specific structures must be examined to see if the potential benefit is actually applicable to the structure. If it is applicable, credit may be taken for it. However, this step can only be taken at the structural level, not at the code level.

A simple example may help clarify this point. Assume a steel beam exists in a structure designed by AISC 1963 rules for the then-specified loading combination. Current criteria require inclusion of an additional load in the loading combination (Scale A change), but the current structural code permits a higher allowable load if the beam design conforms to certain stipulated proportions (Scale C change). Several circumstances are possible for beams in actual structures, as shown below.

New Load	Higher Stress Limit	Results
Maximum stress in beam under original loading conditions was low with ample margin for addi- tional load	Applicability immaterial	Beam adequate under current criteria
Maximum stress in beam under original loading condition was near former allowable limit	Beam qualifies for higher stress limit	Beam may be adequate under current criteria
Maximum stress in beam under original loading condition was near former allowable limit	Beam does not qualify for increased stress limit	Beam unlikely to be adequate under current criteria

It is clear from this example that the function of the code review is to point out code changes that might impair perceived margins of safety, and that assessment of their pertinence is best accomplished at the structure-specific level.

7.5 PLANT-SPECIFIC CODE CHANGES

There is substantial overlap among the SEP plants in the codes and standards used for structural design. Several plants, for example, followed the provisions of ACI-318, 1963 edition, in designing major concrete structures.

Thus, the initial work of comparing older and current criteria is not plant-specific. However, when the reviewed codes are packaged in sets containing only those code comparisons relevant to design of Seismic Category I structures in a particular SEP plant, the results begin to take on plantspecific character.

The code changes potentially applicable to particular structures at a particular SEP plant have then been identified. How ver, this list is almost surely overly long because the list has been prepared without reference to actual plant structures. For example, the code change list might include an item relating to recently introduced provisions for the design of slender columns, while none actually exist in any structures in that particular plant.

In-depth examination of design drawings, audit of structural analyses, and review of plant specifications were beyond the scope of the III-7.B task. Accordingly, such activities were not attempted. Occasional reference to such documents was necessary, however, to the review work. Consequently, it was possible to cull from the list some items that were obviously inappropriate to the Oyster Creek plant structures. Wherever this was done, the reason for removal was documented, but no attempt was made to remove every such item.

Code changes that may be significant for structures in general but did not appear applicable to any of the Category I structures at Oyster Creek were relegated to Appendix A. The Scale A or Scale A changes that remained are listed on a code-by-code basis in Section 11.

8. OYSTER CREEK SEISMIC CATEGORY I STRUCTURES

SEP Topic III-1 has for its objectives the classification of components, structures, and systems with respect to both quality group and seismic designation. The task force charged with this responsibility has presented its findings in Reference 5, and the following structures have been determined to be Seismic Category I:

- o Reactor building, including: Spent fuel pool Fuel storage facilities
- o Drywell, torus, and vents
- o Control room
- o Intake structure.

In addition, the following emergency electrical systems, among others, have been designated Seismic Category I:

- o Batteries
- o Diesel generator
- o Emergency buses, etc.

The diesel generator vault is not listed in this classification. Review indicates that, since it houses Category I equipment, it too is to be considered Seismic Category I. Likewise, the vent stack is treated as a Seismic Category I structure in this report. At the Oyster Creek plant, the stack is located in close proximity to other Category I systems and structures. Consequently, if stack failure is postulated, it has the potential to impair some vital function of these systems or structures. The turbine building houses two battery rooms (in different and widely separated parts of the building), the switchgear room, and the control room. The seismic classification of the turbine building was not indicated. The following structures were unlisted or were otherwise classified:

Radwaste building	Non-Seismic Category I
Screen house	Status not shown
Turbine building	Status not shown
Service building	Unlisted
Office building	Unlisted
Offgas building	Unlisted.

Franklin Research Center

-21-

9. STRUCTURAL DESIGN CRITERIA

The structural codes governing design of the major Seismic Category I structures for the Oyster Creek Nuclear Power Generating Station are detailed in the following table.

	Structure	Design Criteria	Current Criteria
1.	Drywell, torus, and vents	ASME Sect. VIII (1962) and Nuclear Code cases: 1270 N-5, 1271 N, 1272 N-5	ASME Sect. III, Div. I Subsection NE (1980)
2.	Reactor building Spent fuel pool	Concrete Structures: ACI 318-63 ACI 301-63 Steel Structures: AISC Building Code (1963)	Concrete Structures: ACI 349-76 ACI 301-72 (Rev. 75) Steel Structures: AISC Building Code (1980)
3.	Portions of the turbine building housing the control room, battery rooms, switchgear room	Same as Item 2 above	Same as Item 2 above
4.	Intake structure	Same as Item 2 above	Same as Item 2 above
5.	Diesel generator vault	Same as Item 2 above	Same as Item 2 above
6.	Ventilation Stack	ACI 505-54	ACI 349-76* (ACI-307)

^{*}Although the provisions of ACI-349 currently govern design of all Seismic Category I structures external to containment, nonconflicting provisions of ACI-307 also apply. A complete reanalysis of the stack to current criteria will be carried out within the SEP program.

REFERENCES:

.

10

Identification of original design codes:

- Primary Containment Design Report, Amendment 15 to FDSAR for the Oyster Creek Nuclear Power Plant (Identifies codes for Item 1 above)
- Burns and Roe letter of April 23, 1981 to MPR Associates (Chou to Schmidt) (Identifies codes for Items 2 through 5 above).

٤

10. LOADS AND LOAD COMBINATION CRITERIA

10.1 DESCRIPTION OF TABLES OF LOADS AND LOAD COMBINATIONS

The requirements governing loads and load combinations to be considered in the design of civil engineering structures for nuclear service have been revised since the older nuclear power plants were constructed and licensed. Such changes constitute a major aspect of the general pattern of evolving design requirements; consequently, they are singled out for special consideration in this section of this report.

The NRC Regulatory Guides and Standard Review Plans provide guidance as to what loads and load combinations must be considered. In some cases, the required loads and load combinations are also specified within the governing structural design code; other structural codes have no such provisions and take loads and load combinations as given a priori. In this report, loads and load combinations are treated within the present section whether or not the structural design codes also include them.

Later sections of this report address, paragraph by paragraph, changes in text between design codes current at the time the plant was constructed and those governing design today; however, to avoid repetition, code changes related to loads and load combinations will not be evaluated again although they may appear as provisions of the structural design codes.

To provide a compact and systematic comparison of previous and present requirements, the facts are marshalled in tabular form. Two sets of tables are used:

- 1. load tables
- 2. load combination tables.

Both sets of tables are constructed in accordance with current requirements for Seismic Category I structures, i.e., the load tables list all loads that must be considered in today's design of these structures (as enumerated in NRC's Standard Review Plan), and the load combination tables list all combinations of these loadings for which current licensing procedures require demonstration of structural integrity.

Franklin Research Center

In general, the loads and load combinations to be considered are determined by the structure under discussion. The design loads for the structure housing the emergency power diesel generator, for example, are quite different than those for the design of the containment vessel. Consequently, structures must be considered individually. Each structure usually requires a load table and load combination table appropriate to its specific design requirements.

.

The design requirements for the various civil engineering structures within a nuclear power plant are echoed in applicable sections of NRC's Standard Review Plan (SRP) 3.8. The tables in the present report correspond to, and summarize, these requirements for each structure. A note at the bottom of each table provides the reference to the applicable section of the Standard Review Plan. Section 10.2 of this report lists, for reference, the load symbols used in the charts together with their definitions.

The loads actually used for design are considered, structure by structure, and the load tables are filled in according to the following scheme:

- The list of potentially applicable loads (according to current requirements) is examined to eliminate loads which either do not occur on, or are not significant for, the structure under consideration.
- The loads included in the actual design basis are then checked against the reduced list to see if all applicable loads (according to current requirements) were actually considered during design.
- 3. Each load that was considered during design is next screened to see if it appears to correspond to current requirements. Questions such as the following are addressed: Were all the individual loads encompassed by the load category definition represented in the applied loading? Do all loads appear to match present requirements (1) in magnitude? (2) in method of application?
- 4. An annotation is made as to whether deviations from present requirements exist, either because of load omissions or because the loads do not correspond in magnitude or in other particulars.
- If a deviation is found, a judgment (in the form of a scale ranking) is made as to the potential impact of the deviation on perceived margins of safety.
- 6. Relevant notes or comments are recorded.

Franklin Research Center

ranklin institute

A Division of

Of particular importance to the Topic III-7.B review are comments indicating that the effects of certain loadings (tornado and seismic loads, in particular) are being examined under other SEP topics. In all such cases, the findings of these special SEP topics (where review in depth of the indicated loading conditions will be undertaken) will be definitive for the overall SEP effort. Consequently, no licensee investigation of such issues is required under Topic III-7.B nor is such effort within the scope of Topic III-7.B (see Section 4). Licensee participation in the resolution of such issues may, however, be requested under the scope of other SEP topics devoted to such issues.

After the load tables have been filled out, the load combination tables are compiled. Like the load tables, the load combination tables are drawn up to current requirements and the load combinations actually used in the design basis are matched against these requirements.

Current criteria require consideration during plant design of 13 load combinations for most structures, as shown in the load combination tables. These specific requirements were not in effect at the time when SEP plants were designed. Consequently, other sets of load combinations were used. In comparing actual and current criteria, an attempt was made to match each of the load combinations actually considered to its nearest counterpart under present requirements. For example, consider a plant where the safe shutdown earthquake was addressed in combination with other loads, but not in combination with the effects of a LOCA (load combination 13). The load combination tables would reflect this by showing that load case 9 was addressed, but that load case 13 was not. If six load cases were considered, only six (nearest counterpart) load cases are indicated in the table--not partial fulfillment of all 13.

For ease of comparison, the load combinations actually used are superimposed on the load combinations currently required. This is accomplished in two steps:

 Currently specified load combinations include loads sufficient for the most general cases. In particular applications, some of these are either inappropriate or insignificant. Therefore, the first step

Franklin Research Center

is to strike all loads that are not applicable to the structure under consideration from all load combinations in which they appear.

 Next, loads actually combined are indicated by encircling (in the appropriate load combinations) each load contributing to the summation considered for design.

Thus, the comparison between what was actually done and what is required today is readily apparent. If the load combinations used are in complete accord with current requirements, each load symbol on the sheet appears as either struck or encircled. Load combinations not considered and loads omitted from the load combinations stand out as unencircled items.

A scale ranking is next assigned to the load combinations; however (unlike the corresponding ranking of loads), a scale ranking is not necessarily assigned to each one. When the load combinations used for design correspond closely to current requirements, scale ratings may be assigned to all combinations. However, when the number of load combinations considered in design was substantially fewer than current criteria prescribe, it did not appear to serve any engineering purpose to rank the structure for each currently required load combination. Instead, a limited number of loading cases (usually two) were ranked.

The following considerations guided the selection of these cases:

- For purposes of the SEP review, it was not believed necessary to require an extensive reanalysis of structures under all load combinations currently specified.
- SEP plants have been in full power operation for a number of years. During this time, they have experienced a wide spectrum of operating and upset conditions. There is no evidence that major Seismic Category I structures lack integrity under these operating conditions.
- The most severe load combinations occur under emergency and accident conditions. These are also the conditions a sociated with the greatest consequences to public health and safety.
- 4. If demonstration of structural adequacy under the most severe load combinations currently specified for emergency and accident conditions is provided, a reasonable inference can be drawn that the structure is also adequate to sustain the less severe loadings associated with less severe consequences.

The scale rankings assigned to loads and load combinations in tables are intended as an appraisal of plant status, with respect to demonstration of compliance with current design criteria, based on information available to the NRC prior to the inception of the SEP review. A number of structurally related SEP topics review some loads and load combinations in detail based upon current calculational methods. In order that a consistent basis for the tables be maintained, they are based upon load combinations considered in the original design of the facility or, in the case of facility modifications, they are based upon the combinations used in the design of the modification. Loads that were not included in the original design or that have increased in magnitude and have not been specifically addressed in another SEP topic should be addressed by the Licensee.

10.2 LOAD DEFINITIONS

D Dead loads or their related internal moments and forces (such as permanent equipment loads).

E or Eo Loads generated by the operating basis earthquake.

E' or Ess Loads generated by the safe shutdown earthquake.

- F Loads resulting from the application of pre-stress.
- H Hydrostatic loads under operating conditions.
- H_a Hydrostatic loads generated under accident conditions, such as post-accident internal flooding. (F_L is sometimes used by others* to designate post-LOCA internal flooding.)
- L Live loads or their related internal moments and forces (such as movable equipment loads).
- Pa Pressure load generated by accident conditions (such as those generated by the postulated pipe break accident).
- P_{O} or P_{V} Loads resulting from pressure due to normal operating conditions.

*See, for example, SRP 3.8.2.

Franklin Research Center A Division of The Franklin Institute

- Ps All pressure loads which are caused by the actuation of safety relief valve discharge including pool swell and subsequent hydrodynamic loads.
- R_a or R_r Pipe reactions under accident conditions (such as those generated by thermal transients associated with an accident).
 - R_O Pipe reactions during startup, normal operating, or shutdown conditions, based on the critical transient or steady-state condition.
 - R_S All pipe reaction loads which are generated by the discharge of safety relief valves.
 - T_a Thermal loads under accident conditions (such as those generated by a postulated pipe break accident).
 - To Thermal effects and loads during startup, normal operating, or shutdown conditions, based on the most critical transient or steady-state condition.
 - T_S All thermal loads which are generated by the discharge of safety relief valves.
 - W Loads generated by the design wind specified for the plant.
- W' or Wt Loads generated by the design tornado specified for the plant. Tornado loads include loads due to tornado wind pressure, tornadocreated differential pressure, and tornado-generated missiles.
 - Y_j Equivalent static load on the structure generated by the impingement of the fluid jet from the broken pipe during the design basis accident.
 - Ym Missile impact equivalent static load on the structure generated by or during the design basis accident, such as pipe whipping.
 - Yr Equivalent static load on the structure generated by the reaction on the broken pipe during the design basis accident.

The load combination charts correspond to loading cases and load definitions as specified in the appropriate SRP. Each chart is associated with a specific SRP as identified in the notes accompanying the chart. Guidance with respect to the specific loads which must be considered in forming each load combination is provided by the referenced SRP. All SRPs are prepared to a standard format; consequently, subsection 3 of each plan always contains the appropriate load definitions and load combination guidance.

.

×

10.3 DESIGN LOAD TABLES

"COMPARISON OF DESIGN BASIS LOADS"

.
COMPARISON OF DESIGN BASIS LOADS

STRUCTURE:

DRYWELL (steel)

PLANT: OYSTER CREEK

	Current Design Basis Loads	Is Load Applicable To This Structure	Is Load Included In Plant Design Basis?	SEP Topic Reviewing This Locd	Does Load Magnitude Correspond To Present Criteria?	Does Deviation Exist In Load Basis?	Code Impact Scale Ranking	Comments
Gravity	D L	Yes Yes	Yes Yes		Yes Yes	No No		
Pressure	F H Po Pa	No Yes Yes Yes	Yes ^{3.} Yes Yes No	VI-2.D, III-7.B	* No *	* Yes * Yes	* c *	1.
Thermal	T _o T _a Ts	Yes Yes Tes	No No No	VI-2.D, III-7.B		Yes * Yes	B * 6.	4. 4. 4.
Pipe 6 Mech.	R _o R _a R _S	Yes Yes Yes	Yes Yes No	_	No No	Yes Yes Yes		2. 2.
Environmental	E' E W' W	Yes Yes No No	Yes Yes 	III-6 III-6 III-2, III-4.A III-2, III-4.A	:	:	A _x *	
Impulse	Yr Yj Ym	Yes Yes Yes	Yes ⁵ . No	III-5.A III-5.A III-5.A	:	:	• •	

Comments

* To be determined per results of SEP topics. Scale ranking shown for SEP topic items are independent judgments, based on information in the FSAR or other original design documents.

1. Design pressure was used i.e., $P_0 = P_d = 62$ psig

2. Vent thrust only.

- Flooding condition reported to have been investigated but it was considered only as an independent load (FSAR containment report).
- 4. No indication of thermal consideration in CB & I calculations except metal properties are taken at temp.
- Not analytically considered. However, a sample plate, locally loaded in a static testing machine, sustained 3-inch deformation without cracking or rupture.
- 6. Reviewed in generic Task A-7, effects of hydrodynamic loads, Mark I containment.

STRUCTURE :

REACTOR BUILDING

PLANT: OYSTER CREEK

	Current Design Basis Loads	Is Load Applicable To This Structure	Is Load Included In Plant Design Basis?	SEP Topic Reviewing This Load	Does Load Magnitude Correspond To Present Criteria?	Does Deviation Exist In Load Basis?	Code Impact Scale Ranking	Comments
Gravity	D L	Yes Yes	Yes Yes	=	Yes Yes	No No	 A _x	3.
Pressure	F H Pa	No Yes Yes	Yes No	III-3.A II ⁻ -5.B	-	:	:	
Thermal	T _o T _a	Neglig. Yes	No No	III-5.B		Yes *	3 *	1.
Pipe \$ Mech.	R _o R _a	Yes Yes	No No		No No	Yes Yes	B A_	2.
Environmental	2 2 2 2 2 2	Yes Yes Yes Yes	Yes Yes Yes Yes	III-6 III-6 III-2, III-4.A III-2, III-4.A	•4.	:	* * ^Ax	
Impulse	Yr Yj Ym	Yes Yes Yes	No No No	III-5.B III-5.B III-5.B	:	:	:	

Ref.; SRP(1981) Section 3.8.4

Comments

* To be determined per results of SEP topics. Scale ranking shown for SEP topic items are independent judgments, based on information in the FSAR or other original design documents.

- 1. Ordinary thermal stress in concrete structures are commonly neglected.
- Some pipes and supports typical of installation are likely to have experienced major transients (e.g. turbine trip).
- 3. Roof loads have increased per SEP Topic II-2.A and may increase per SEP Topic II-3.B for parapet roofs.
- 4. Attachment B of Amendment II states; metal siding can withstand 150 MPH winds but cannot provide protection from tornado missiles.

Franklin Research Center

STRUCTURE: SPENT FUEL POOL (Concrete)

PLANT: OYSTER CREEK

.

	Current Design Basis Loads	Is Load Applicable To This Structure	Is Load Included In Plant Design Basis?	SEP Topic Reviewing This Load	Does Load Magnitude Correspond To Present Criteria?	Does Deviation Exist In Load Basis?	Code Impact Scale Ranking	Comments
Gravity	D L	Yes Yes	Yes Yes	=	Yes Yes	No No		
Pressure	F H Pa	No Yes No	Yes	III-3.A III-5.B	-	:		
Thermal	T _o T _a	Negl. Yes	· Yes1.	 III-5.B		-		
Pipe 6 Mech.	R _o R _a	No No		_	-	_		
Environmental	E' E W' W	Yes Yes Yes ² No	Yes Yes No	III-6 III-6 III-2, III-4.A III-2, III-4.A	:	:	:	4.
Impulse	Yr Yj Ym			III-5.B III-5.B III-5.B		: : :	:	3. 3. 3.

Ref.; SRP(1981) Section 3.8.4

Comments

٠

* To be determined per results of SEP topics. Scale ranking shown for SEP topic items are independent judgments, based on information in the FSAR or other original design documents.

- Thermal load from cask drop accident is referenced in Jersey Central Power & Light Co's. Answer to Question 5, Rev 1 to ADD.2 to Supplement 1 of Am. 78.
- 2. Applicable only since steel structure over spent pool is not tornado resistant.

3. Pipe break external to containment is evaluated in SEP Topic III-5.3.

 SEP Topic III-2 will determine whether or not pool exposure to possible tornado effects is an allowable spent fuel pool load.

STRUCTURE: CONTROL ROOM & CONTINGENT PARTS OF TURBINE BUILDING

PLANT: OYSTER CREEK

	Current Design Basis Loads	Is Load Applicable To This Structure	Is Load Included In Plant Design Basis?	SEP Topic Reviewing This Load	Does Load Magnitude Correspond To Present Criteria?	Does Deviation Exist In Load Basis?	Code Impact Scale Ranking	Comments
Gravity	D L	Yes Yes	Yes Yes		Yes Yes	No No	 A _x	2.
Pressure	F H P _a	No No Yes ¹		III-3.A III-5.B	 :	:	:	
Thermal	T _o T _a	Neglig. Yes ¹	No No	III-5.B		Yes *	-	
Pipe 6 Mech.	R _o R _a	No No	_			-	_	
Envi ronmental	ย" ย ม" ม	Yes Yes Yes Yes	Yes Yes Yes Yes	III-6 III-6 III-2, III-4.A III-2, III-4.A	:	:	^A x * ^A x *	
Impulse	Yr Yj Ym		-	III-5.B III-5.B III-5.B	•	:	:	

Ref.; SRP(1981) Section 3.8.4

Comments

* To be determined per results of SEP topics. Scale ranking shown for SEP topic items are independent judgments, based on information in the FSAR or other original design documents.

1. Not a structural concern but might affect control room habitability.

2. Roof loads have increased per SEP Topic II-2.A and may increase per SEP Topic II-3.B for parapet roofs.

Franklin Research Center

PLANT: OYSTER CREEK

STRUCTURE: BATTERY, SWITCHGEAR ROOMS AND CONTINGENT PARTS OF TURBINE BUILDING

	Current Design Basis Loads	Is Load Applicable To This Structure	Is Load Included In Plant Design Basis?	SEP Topic Reviewing This Load	Does Load Magnitude Correspond To Present Criteria?	Does Deviation Exist In Load Basis?	Code Impact Scale Ranking	Comments
Gravity	D L	Yes Yes	Yes Yes	_	Yes Yes	No No		
Pressure	F H P _a			III-3.A III-5.B		:		
The rma?	T _o T _a	Negl.	No No			Yes *		
Pipe 6 Mech.	R _o R _a	No	_	_		_		
Environmental	2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	Yes Yes	Yes Yes	III-6 III-6 III-2, III-4.A III-2, III-4.A	:	:	A _x •	
Iapulse	۲ ۲ ۳ ۳			III-5.8 III-5.8 III-5.8		:		

Ref.; SRP(1981) Section 3.8.4

Comments

* To be determined per results of SEP topics. Scale ranking shown for SEP topic items are independent judgments, based on information in the FSAR or other original design documents.

Franklin Research Center

PLANT: OYSTER CREEK

	Current Design Basis Loads	Is Load Applicable To This Structure	Is Load Included In Plant Design Basis?	SEP Topic Reviewing This Load	Does Load Magnitude Correspond To Present Criteria?	Does Deviation Exist In Load Basis?	Code Impact Scale Ranking	Comments
Gravity	D L	Yes Yes	Yes Yes	=	Yes Yes	No No	-	
Pressure	F H Pa	No Yes No	Yes	III-3.A III-5.B		:		
Thermal	T _o T _a	Negl. No	No	 III-5.8	-	-		
Pipe 6 Mech.	R _o R _a	Yes No	-		_		_	
Environmental	т. 19 19 19 19 19 19 19 19 19 19 19 19 19	Yes Yes Yes Negl.	Yes Yes Yes	'II-6 III-6 III-2, III-4.A III-2, III-4.A	• • •		A _x * A _x *	
Impulse	Yr Yj Ym	No No No	-	III-5.B III-5.B III-5.B	:	•	-	

Ref.; SRP(1981) Section 3.8.4

Comments

- * To be determined per results of SEP topics. Scale ranking shown for SEP topic items are independent judgments, based on information in the FSAR or other original design documents.
 - Attachment B of Amendment 11 to FSAR states; intake structure can withstand 300 MPH wind but does not provide missile protection.

Franklin Research Center

STRUCTURE :

INTAKE STRUCTURE

STRUCTURE: DIESEL GENERATOR VAULT (HOUSING CLASS I EQUIPMENT)

PLANT: OYSTER CREEK

	Current Design Basis Loads	Is Load Applicable To This Structure	Is Load Included In Plant Design Basis?	SEP Topic Reviewing This Load	Does Load Magnitude Correspond To Present Criteria?	Does Deviation Exist In Load Basis?	Code Impact Scale Ranking	Comments
Gravity	D L	Yes Yes	Yes Yes	_	Yes Yes	No No		1.
Pressure	F H Pa	No Yes No		III-3.A III-5.B	 :	:	-	
Thermal	T _o T _a	No No	=	 III-5.B		-	=	
Pipe 6 Mech.	R _o R _a	No No	-	_		_		
Environmental	E' E W'	Yes Yes Yes Yes	Yes Yes No Yes	III-6 III-6 III-2, III-4.A III-2, III-4.A	÷	: .	^x * ^x	
Inpulse	ي ي ي ي	No No No		III-5.B III-5.B III-5.B	:			

Ref.; SRP(1981) Section 3.8.4

Comments

* To be determined per results of SEP topics. Scale ranking shown for SEP topic items are independent judgments, based on information in the FSAR or other original design documents.

1. Roof load have increased per SEP Topic II-2.A and may increase per SEP Topic II-3.A for parapet roofs.

STRUCTURE :

VENTILATION STACK

COMPARISON OF DESIGN BASIS LOADS

PLANT: OYSTER CREEK

	Current Design Basis Loads	Is Load Applicable To This Structure	Is Load Included In Plant Design Basis?	SEP Topic Reviewing This Load	Does Load Magnitude Correspond To Present Criteria?	Does Deviation Exist In Load Basis?	Code Impact Scale Ranking	Comments
Gravity	D L	Yes Yes	Yes Yes	=	=	=	_	
Pressure	F H Pa	No No No	No No No	III-3.A III-5.B	 :	:		
Thermal	T _o T _a	Yes No	Yes No	Ш-5.В		-	B 	1.
Pipe 6 Mech.	R o R a	No No	_	=	_	-		
Environmental	е* е w* w	Yes Yes Yes Yes	Yes Yes No Yes	III-6 III-6 III-2, III-4.A III-2, III-4.A	:	:	* * *	2. 2.
Impulse	Yr Yj Ym	No No No		III-5.8 III-5.8 III-5.8	:	· ·		

Ref.; SRP(1981) Section 3.8.4

Comments

* To be determined per results of SEP topics. Scale ranking shown for SEP topic items are independent judgments, based on information in the FSAR or other original design documents.

- 1. Stack design is based on 100°F maximum temperature gradient as per Attachment F Docket 50-219.
- Maximum wind velocity considered is 100 MPR as per Attachment F Docket 50-219 and maximum wind velocity the stack can withstand is 180 MPH as per Attachment B Docket 50-219.

Franklin Research Center

10.4 LOAD COMBINATION TABLES

"COMPARISON OF LOADING COMBINATION CRITERIA"



4

COMPARISON C LOADING COMBINATION CRITERIA

PLAN	T: OYSTER	C-368				DRYWELL			
	Combined Loading Cases	Gravity Dead, Live	Thermal	Pressure	Mechanical	Natural Phenomena	Impulsive Loading	Scale Ranking]
1 4	1	D + L	To	Po	R				1
Leve	2	D + L	Ts	Ps	R				
lce	3	D + L	Ta	Pa	Ra				
Serv	4	D + L	T _a + T _s	P _s + P _s	R _a + R _s	Ш., ;			
vel B	1	D + L	Ta	F	Ra	E			1
e Le	2	0+0	To	6	(P.)2.	E.	1.1.1		7.
rvic	3	D+L	Ts	Ps	R _s	E			
s	4	D+L	T _a + T _g	P _a + P _s	R _a + R _g				
el c	1	D+L	Ta	Pa	Ra	E'			
Lev	2	D+L	To	Po	Ro	Ε'		(* 23) (* 24)	
Service	3	D + L	T _a + T _s	P _a + P _s	R _a + R _s	Ε'			
	1	D + L	Ta	Pa	Ra	Ε'	Yr+Yj+Ym		1
Level D	2.	D+C	T _a + T _s	(Pa)+ Ps	(R_3)+ R, 2.	(E') 5.	Yr+Yj+Ym	^A x	7.,
Service							() 3., 4.		
Post - LOCA Flooding	1	D + L		(Pr-1)		Ε		A _x	8.

STRUCTURE

Ref.: SRP Section 3.8.2 Steel Containment

Notes

- Encircled loads are those actually considered in the design per FSAR. When load factors different from those currently required were used, the factor used is also encircled.
- 2. Vent thrust due to 35 psi pipe cap force considered; but no other pipe reactions were investigated.
- 3. Y, considered independently of other loads.
- Static load tests showed ring supported plate could be dimpled 3 inches by load applied over 20-inch dia. area without fracture
- 5. Static g-loads used in load combinations.
- 6. Design pressure 62 psi used for Pa.
- 7. Only primary membrane stresses were computed for this load combination.
- 8. For purposes of the SEP Review, demonstration that structural integrity is maintained for load cases indicated above (per current criteria) may be considered as providing reasonable assurance that this structure meets the intent of current design criteria.

A Division of The Franklin Institute

CONCRETI	COMPARISON OF E STRUCTURES OYSTER CREEK	LOADING COMBI	NATION CR	ITERIA	STRUCTURE REACTOR BU	: JILDING (CONC	RETE)
Combined Loading Cases	Gravity Dead, Live	Thermal	Pressure	Mechanical	Natural Phenomena	Impulsive Loading	Scale Ranking
1	1.40 + 1.7L						
2	1.40+1.70				1.90		-
3	1.40+1.70			1	1.70		
4	.75 (1.4D + 1.7L)	.75 x 1.7 %		.75 x 1.7 R			
5	.75 (1.4D + 1.7L)	.75 x 1.7 %		.75 x 1.7 R	.75 x 1.9E		
6	.75 (1.4D + 1.7L)	.75 x 1.7 %		.75 x 1.7 R	.75 x 1.7W		
7	1.2D				1.9E		
8	1.2D				1.7W		
9	D+C	X		R _o	E		
10	D + L	de'		Ro	We		4
11	D + L	та	1.5 P	Ra			-
12	D + L	Ta	1.25 Pa	Ra	1.25E	Y _r + Y _j + Y _m	
13	D + L	T.	Pa	Ra	E,	Y _r + Y _j + Y _m	A _x

Ref.: SRP (1981) Sect. 3.8.4 Otear Catages I structures (concrete)

- Notes
- Ultimate strength method required by ACI-349 (1977).
 Methods used in design { working stress ~ consequently no load factors were used
 - 3. Loads deemed inapplicable or negligible struck from loading combinations.
 - 4. Encircled loads are those actually considered in the design. When load factors different from those currently required were used, the factor used is also encircled.
 - 5. Snow load coefficients in accordance with ANSI A58.1 may be used, or provisions of UBC Section 2311 (j) invoked.
 - 6. For purposes of the SEP Review, demonstration that structural integrity is main-tained for load cases 10, 13 (per current criteria) may be considered as providing reasonable assurance that this structure meets the intent of current design criteria.

Franklin Research Center

in and

ę,

%

1.

-42-

COMPARISON OF STRESS LIMITS

FOR

STEEL CONTAINMENT STRUCTURES

8)
Franklin A Dhrean of	/
Research I	
Center	

=

PLANT

OYSTER CREEK

ī	£.			
1	۲	-	۰	
•	٦,			
		L		
		۰		

SERVICE	CURRENT CRITERIA {REF.: TABLE NE - 3221-1, ASME SECTION	111, 1980)	DESIGN CRITERIA (REF.: FSAR-ALLOWABLE STRESSES-PRIMARY CONTAINMENT, TABLE V-3-2		
	CRITERIA	VALUE, ps1	CRITERIA		VALUE, ps1
x	$ \begin{array}{cccc} P_{u} & 1.0 & S \\ P_{L} & 1.5 & S \\ P_{L} + P_{b} & 1.5 & S \\ P_{L} + P_{b} + Q & 3.0 & S \\ (See note 6) & & & \\ \end{array} $	mc 19,300 mc 3,950 mc 28,950 m1 67,500			
В	$ \begin{array}{c} P_{m} & 1.0 \text{ s} \\ P_{L} & 1.5 \text{ s} \\ P_{L} + P_{b} & 1.5 \text{ s} \\ P_{L} + P_{b} + Q & 3.0 \text{ s} \\ (\text{See note 6}) \end{array} $	mc 19,300 28,950 mc 28,950 m3 67,500	P_{m} $P_{L} + P_{b}$ $P_{L} + P_{b} + Q$	1.15 1.5(1.15) 3.05	19,250 28,875 52,500
¢	$P_{m} = \frac{1.2 \text{ S}_{mc} \text{ or } 1.0 \text{ S}}{1.8 \text{ S}_{mc} \text{ or } 1.5 \text{ S}}$ $P_{L} = \frac{1.8 \text{ S}_{mc} \text{ or } 1.5 \text{ S}}{1.8 \text{ S}_{mc} \text{ or } 1.5 \text{ S}}$ $P_{L} + P_{b} = \frac{1.8 \text{ S}_{mc} \text{ or } 1.5 \text{ S}}{1.8 \text{ S}_{mc} \text{ or } 1.5 \text{ S}}$ $(See notes 3, 4 \text{ 8} 6)$	y 38,000 y 57,000 y 57,000			
D	P_{m} 1.0 S P_{L} 1.5 S $P_{L} + P_{b}$ 1.5 S (See notes 2, 5 8 6)	f 41,650 f 62,475 f 62,475	Pm (see note 8)	Sy	38,000
POST- FLOODING CONDITION	$\begin{array}{cccc} P_{m} & 1.2 & P_{mc} & \text{or } 1.0 & \text{S} \\ P_{L} & 1.8 & \text{S}_{mc} & \text{or } 1.5 & \text{S} \\ P_{L} + P_{b} & 1.8 & \text{S}_{mc} & \text{or } 1.5 & \text{S} \\ P_{L} + P_{b} & 1.8 & \text{S}_{mc} & \text{or } 1.5 & \text{S} \\ P_{L} + P_{b} + Q & 3.0 & \text{S} \\ (\text{See notes } 4 & 6) & \end{array}$	38,000 57,000 57,000 67,500			

SHEL	L MATERIAL
SPEC. NO. A212	GRADE: B (see note 7.)
VIELD STRESS (Sy)	- 38,000 ps1
ULT. STRENGTH (Su) - 70,000 ps1
CURRENT	Smc = 19,300 ps1
PRIMARY	Smc = 22,500 ps1
STRESS INTENSITY	m1 @ 300 oF
LIMIT	(See note 1)
DESIGN PRIMARY MEMBRANE STRESS LIMIT	s 17,500 ps1 e 300 ° _F

NOTES: 1. NOTE THAT CURRENT PRIMARY STRESS INTENSITY LIMITS PRESUME (AMONG OTHER CODE QUALITY CONTROLS) MODERN COMPUTERIZED METHODS OF ANALYSIS. CONSEQUENTLY, CAUTION SHOULD BE OBSERVED IN MAKING DIRECT COMPARISONS WITH DESIGN STRESS LIMITS APPROPRIATE FOR LESS MODERN ANALYTICAL PROCEDURES.

2. THE COMPARABLE CURRENT CRITERIA ASSUMING ELASTIC METHODS WERE USED FOR THE ORIGINAL DESIGN ANALYSIS. 3. VALUES SHOWN PERTAIN TO INTEGRAL AND CONTINUOUS STRUCTURES ONLY.

4. THE LARGER OF THE TWO LIMITS IS APPLICABLE. 5. 54 IS 85% OF THE GENERAL PRIMARY MEMBRANE ALLOWABLE PERMITTED IN APPENDIX F OF SECTION III, ASME CODE.

5. IN ALL INSTANCES FATIGUE AND BUCKLING CRITERIA MUST ALSO BE SATISFIED. 7. IN ALCORDANCE WI.H ASME BAPV CODE SECTION III, DIVISION 1, SUBSECTION NE, SUBPARA. NE 2121, THIS MATERIAL IS NOT LISTED AMONG THOSE CURRENTLY PERMITTED. REF.: APPENDICES TABLE I-10.1 "CURRENT" STRESS VALUES LISTED ARE DERIVED USING Smc * 1.1 X 1/4 X S., and S. @ 300°F FROM TABLE N-421 ASME B&PV CODE SECTION III, CLASS A. (1965) mc 8. STRESS EXCEEDING YIELD PERMITTED, IF CALCULATIONS SHOW ENERGY ABSORPTION CAPACITY ADEQUATE (REF. PG. V-3-2 OF FSAR).

CONCRET	COMPARISON OF E STRUCTURES OYSTER CREEK	STRUCTURE: SPENT FUEL POOL CONCRETE					
Combined Loading Cases	Gravity Dead, Live	Thermal	Pressure	Mechanical	Natural Phenomena	Impulsive Loading	Scale Ranking
1	1.4D + 1.7L						
2	1.4D + 1.7L				1.9E		
3	1.4D + 1.7L				1.7%		
4	.75 (1.4D + 1.7L)	.75 x 1.7 %		.75 x 1.7 %			
5	.75 (1.40+1.70	.75 x 1.7 %		.75 x 1.7 %	.75 x 1.90)	
6	.75 (1.4D + 1.7L)	.75 x 1.7 %		.75 x 1.7 %	.75 x 1.7%		
7	1.2D				1.9E		
8	1.2D				1.74		
9	D+L	×.		8	E		
10	D + L	×.		R	We		A.
11	D + L	3	1.5 R	X			
12	D + L	z	1.25 R	3	1.25E	Y _r + Y _j + Y _m	
13	D + L	3	8	*	Ε'	Y, + Yj + Ym	A _x

Notes

1. Ultimate strength method required by ACI-349 (1977).

- Methods used in design { working stress ~ consequently no load factors were used.
- 3. Loads deemed inapplicable or negligible struck from loading combinations.
- Encircled loads are those actually considered in the design. When load factors different from those currently required were used, the factor used is also encircled.
- 5. Licensee states criteria and loading cases for Spent Fuel Pool correspond to Table I-A-4 of Am. 22.
- 6. For purposes of the SEP Review, demonstration that structural integrity is maintained for load case 10, 13 (per current criteria) may be considered as providing reasonable assurance that this structure meets the intent of current design criteria.

COMPARISON OF LOADING COMBINATION CRITERIA STEEL STRUCTURES (Elastic Analysis) PLANT: OYSTER CREEK					STRUCTURE: REACTOR BUILDING (STEEL)			
Combined Loading Cases	Gravity Dead, Live	Thermal	Pressure	Mechanical	Natural Phenomena	Impulsive Loading	Scale	
1	D + L							
2	D+C	1.40			E			
3	D+L				۲			
4	D + L	×.		*			1	
5	D + L	X		8	E			
6	D+L	A.		*	W			
7	D+C	×		*	E			
8	D + L	×.		*	WE		A _x	
9	D + L	Ta	Pa	*				
10	D + L	Ta	Pa	×	Е	Y _j + Y _r + Y _a		
11	D + L	Ta	P.a.	*	E'	Y _j + Y _r + Y	A _x	

Ref: SRP (1981) SECT. 3.8.4 Other Category I structures (steel)

Notes

- Encircled loads are those actually considered in the design. When load factors are different from those currently required were used, the factor used is also encircled.
- For cases where the load combination reduces to D + L + W, assessment of structural adequacy will be made within SEP Topics III-2 5 III-4.A.
- Snow load coefficients in accordance with ANSI A58.1 may be used, or provisions of UBC Section 2311 (j) invoked.
- 5. For purposes of the SEP Review, demonstration that structural integrity is maintained for load cases 8, 11 (per current criteria) may be considered as providing reasonable assurance that this structure meets the intent of current design criteria.

STRUCTURE :

CONCRETI	E STRUCTURES OYSTER CREEK	BATTERY, SWI CONTINGENT P	ART OF TURBI	S AND NE BLDG.			
Combined Loading Cases	Gravity Dead, Live	Thermal	Pressure	Mechanical	Natural Phenomena	Impulsive Loading	Scale Rankin
1	1.4D + 1.7L						
2	1.40+1.70				1.9C		
3	1.4D + 1.7L				1.7₩		
4	.75 (1.4D + 1.7L)	.75 x 1.7 %		.75 x 1.7 %			
5	.75 (1.4D + 1.7L)	.75 x 1.7 %		.75 x 1.7 %	.75 x 1.9E		
6	.75 (1.4D + 1.7L)	.75 x 1.7 %		.75 x 1.7 %	.75 x 1.7W		
7	1.2D				1.9E		
8	1.2D				1.7W		
9	D+C	st.		*a	E		
10	D + L	4ª		×.	×		
11	D + L	TA	1.5 P _a	×.			
12	D + L	Ta	1.25 P _a	×,	1.25E	Y _r + Y _j + Y _a	
13	D + L	Ta	P _a	*	E'	Y _r + Y _j + Y _n	A _x

Ref.: SRP (1981) Sect. 3.8.4 Other Category I structures (concrete)

COMPARISON OF LOADING COMBINATION CRITERIA

1. Ultimate strength method required by ACI-349 (1977). Notes

- Methods used in design { working stress
 Loads deemed incomplicable
 Loads deemed incomplicable
- 3. Loads deemed inapplicable or negligible struck from loading combinations.
- 4. Encircled loads are those actually considered in the design. When load factors different from those currently required were used, the factor used is also encircled.
- 5. For purposes of the SEP Review, demonstration that structural integrity is maintained for load case 13 (per current criteria) may be considered as providing is onable assurance that this structure meets the intent of current design criteria.

Franklin Research Center A Division of The Franklin Institute

CONCRETI	COMPARISON OF STRUCTURES OYSTER CREEK	STRUCTURE CONTROL ROO PARTS OF TU	M AND CONTINURBINE BUILDI	GENT			
Combined Loading Cases	Gravity Dead, Live	Thermal	Pressure	Mechanical	Natural Phenomena	Impulsive Loading	Scale Ranking
1	1.4D + 1.7L						
2	1.40+1.70				1.9Ē		
3	1.4D + 1.7L				1.7W		
4	.75 (1.4D + 1.7L)	.75 x 1.7 %		.75 x 1.7 %			
5	.75 (1.4D + 1.7L)	.75 x 1.7 %		.75 x 1.7 %	.75 x 1.9E		
6	.75 (1.40+1.70	.75 x 1.7 %		.75 x 1.7 %	.75 x 1.7)	
7	1.2D				1.9E		
8	1.2D				1.7W		
9	D+C	XX		*	E		
10	D + L	AND .		80	W _E		A
11	D + L	Ta	1.5 P_a	*			
12	D + L	Ta	1.25 Pa	*	1.25E	Y _r + Y _j + Y _m	
13	D + L	Ta	Pa	*	Ε'	Y _r + Y _j + Y _m	A _x .

Notes

1. Ultimate strength method required by ACI-349 (1977).

- 2. Methods used in design { working stress ~ consequently no load factors were used
- 3. Loads deemed inapplicable or negligible struck from loading combinations.
- 4. Encircled loads are those actually considered in the design. When load factors different from those currently required were used, the factor used is also encircled.
- For cases where the load combination reduces to D + L + W_t, assessment of structural adequacy will be made within SEP Topics II-2 & II-4.A.
- Snow load coefficients in accordance with ANSI A58.1 may be used, or provisions of UBC Section 2311 (j) invoked.
- 7. For purposes of the SEP Review, demonstration that structural integrity is maintained for load cases 10, 13 (per current criteria) may be considered as providing reasonable assurance that this structure meets the intent of current design criteria.

COMPARISON OF LOADING COMBINATION CRITERIA CONCRETE STRUCTURES PLANT: OYSTER CREEK						: DIESEL GEN DUSING CLASS EQUIPMENT)	NERATOR
Combined Loading Cases	Gravity Dead, Live	Thermal	Pressure	Mechanical	Natural Phenomena	Impulsive Loading	Scale Ranking
1	1.4D + 1.7L						
2	1.40+1.10				1.9E		
3	1.4D + 1.7L				1.7₩		
4	.75 (1.4D + 1.7L)	.75 x 1.7 %		.75 x 1.7 %			
5	.75 (1.4D + 1.7L)	.75 x 1.7 %		.75 x 1.7 %	.75 x 1.9E		
6	.75 (1.40+ 1.70	.75 x 1.7 x		.75 x 1.7 %	.75 x 1.7)	
7	1.2D				1.9E		
8	1.2D				1.7W		
9	D+C	se la		85	E	1.000	•
10	D + L	**		80	w _e		A _x
11	D + L	X	1.5 %	8			
12	D + L	**	1.25 %	*	1+85E	x + x + x	
13	D + L	×	2ª	×	E'	× + × + ×	•

Notes

- Ultimate strength method required by ACI-349 (1977).
 - 2. Methods used in design { working stress < consequently no load factors were used
 - 3. Loads deemed inapplicable or negligible struck from loading combinations.
 - Encircled loads are those actually considered in the design. When load factors different from those currently required were used, the factor used is also encircled.
 - 5. For cases where the load combination reduces to D+L+W, assessment of structural. adequacy will be made within SEP Topics III-2 & III-4.A
 - Snow load coefficients in accordance with ANSI A58.1 may be used, or provisions of UBC Section 2311 (j) invoked.
 - 7. For purposes of the SEP Review, demonstration that structural integrity is maintained for load case 10 (per current crieeria) may be considered as providing reasonable assurance that this structure meets the intent of current design criteria.

Franklin Research Center

CONCRET	COMPARISON OF E STRUCTURES OYSTER CREEK	STRUCTURE: INTAKE STRUCTURE					
Combined Loading Cases	Gravity Dead, Live	Thermal	Pressure	Mechanical	Natural Phenomena	Impulsive Loading	Scale Ranking
1	1.4D + 1.7L						
2	1.4D + 1.7L				1.9E		
3	1.4D + 1.7L		-		1.7%		
4	.75 (1.4D + 1.7L)	.75 x 1.7 %		.75 x 1.7 %			
5	.75 (1. 1 + 1. 1)	.75 x 1.7 %		.75 x 1.7 %	.75 x 1.9€)	
6	.75 (1.40+ 1.70	.75 x 1.7 %		.75 x 1.7 %	.75 x 1.7)	
7	1.2D				1.9E		
8	1.2D				1.7₩		
9	©+C	××		*	E		-
10	D + L	×.		×5	W _E		Ax
11	D + L	X	1.5 K	8			1
12	D + L	×.	1.25 -R	*	1.25E	** + * + *	-
13	D + L	×	(Ha+H)	*	ε'	* + * + *	5. A _x

Notes

1. Ultimate strength method required by ACI-349 (1977).

2. Methods used in design { working stress ~ consequently no load factors were used

3. Loads deemed inapplicable or negligible struck from loading combinations.

- Encircled loads are those actually considered in the design. When load factors different from those currently required were used, the factor used is also encircled.
- 5. Reduces to combination considered in another SEP Topic.
- 6. For purposes of the SEP Review, demonstration that structural integrity is maintained for load cases 10, 13 (per current criteria) may be considered as providing reasonable assurance that this structure meets the intent of current design criteria.

Franklin Research Center

11. REVIEW FINDINGS

The most important findings of the review are summarized in this section in tabular form.

The major structural codes used for design of Seismic Category I buildings and structures for the Oyster Creek Nuclear Power Station were:

- AISC, "Specification for Design, Fabrication, and Erection of Structural Steel for Buildings," 1963
- 2. ACI 318-63, "Building Code Requirements for Reinforced Concrete," 1963
- ACI 301-63, "Suggested Specifications for Structural Concrete for Buildings," 1963
- ASME Boiler and Pressure Vessel Code, Section VIII, "Unfired Pressure Vessels," 1962.

Each of these design codes has been compared with the corresponding structural code governing current licensing criteria. Tables follow, in the order listed above, summarizing important results of these comparisons for each code.

These tables provide:

- identification by paragraph number (both of the original code and of its current counterpart) of code provisions where Scale A or Scale A_x deviations exist.
- identification of structural elements to which each such provision may apply.

Some listed provisions may apply only to elements that do not exist in the Oyster Creek structures. When it could be determined that this was the case, such provisions were struck from the list. Any provisions that appeared to be inapplicable for other reasons also were eliminated. Items so removed are listed in Appendix A to this report.

Access to further information concerning code provision changes is provided by additional appendixes. Each pair of codes (the design and the current ones) has a tabular summary within the report (Appendix B) which lists all code changes by scale ranking.

-50-

Franklin Research Center

COMPARISON OF LOADING COMBINATION CRITERIA CONCRETE STRUCTURES PLANT: OYSTER CREEK						STRUCTURE: VENTILATION STACK		
Combined Loading Cases	Gravity Dead, Live	Thermal	Pressure	Mechanical	Natural Phenomena	Impulsive Loading	Scale Rankin	
1	1.4D + 1.7L							
2	1.4D + 1.7L				1.9E			
3	1.4D + 1.7L				1.7W			
4	.75 (1.4D + 1.7L)	.75 x 1.7 T _o		.75 x 1.7%				
5	.75 (1.4D + 1.7L)	.75 x 1.7 T _o		.75 x 1.7 %	.75 x 1.9E			
6	.75 (1.4D + 1.7L)	.75 x 1.7 T _o		.75 x 1.7 %	.75 x 1.7W			
7	1.2D				1.9E			
8	1.2D				1.7W			
9	D+L	E)		8	E		*	
10	D+L	5		*	We		•	
11	D + L	**	1.5 %	*				
12	D + L	×	1.25 %	×	1	x + x + x		
13	D + L	Y.	8	*	E'	x + x + x		

Notes

1. Ultimate strength method required by ACI-349 (1977).

- Methods used in design { working stress ~ consequently no load factors were used
 Loads deemed inapplicable or negligible struck from loading combinations.
- 4. Encircled loads are those actually considered in the design. When load factors different from those currently required were used, the factor used is also encircled.
- 5. The principal loads on the stack are = D, E, E, W & W. Reanalysis of all ventilation stacks for these loadings is being carried out within the SEP Program.

In addition, a separately bound appendix exists for each code pair. The appendix provides:

- full texts of each revised provision in both the former and current versions
- 2. comme ts or conclusions, or both, relevant to the code change
- 3. the scale ranking of the change.

۰.

*

11.1 MAJOR FINDINGS OF AISC-1963 VS. AISC-1980 CODE COMPARISON

MAJOR FINDINGS OF AISC 1963 VS. AISC 1980 CODE COMPARISON

(Summary of Code Changes with the Potential to Significantly Degrade Perceived Margin of Safety)

Scale A

×

Reference Subsect	ced ion		
AISC 1980	AISC 1963	Structural Elements Potentially Affected	Comments
1.5.1.2.2		Beam end connection where the top flange is coped and subject to shear, or failure by shear along a plane through fasteners or by a combination of shear along a plane through fasteners plus tension along a perpendicular plane	See case study 1 for details.
1.9.1.2 and Appendix C	1.9.1	Slender compression unstiff- ened elements subject to axial compression or compression due to bending when actual width-to-thickness ratio exceeds the values specified in subsection 1.9.1.2	New provisions added in the 1980 Code, Appendix C See case study 10 for details.
1.14.2.2	-	Axially loaded tension members where the load is transmitted by bolts or rivets through some but not all of the cross-sectional elements of the members	New requirement added in the 1980 Code
1.15.5.2 1.15.5.3 1.15.5.4		Restrained members when flange or moment connection plates for end connections of beams and girders are welded to the flange of I or H shaped columns	New requirement added in the 1980 Code

. .

к.

Scale A (Cont.)

Refere	enced ction		
AISC 1980	AISC 1963	Structural Elements Potentially Affected	Comments
			Scale
2.9	2.8	Lateral bracing of members to resist lateral and	A 0.0 < M/Mp < 1.0 C 0.0 > M/Mp > -1.0

torsional displacement

See case study 7 for details.



11.2 MAJOR FINDINGS OF ACI 318-63 VS. ACI 349-76 CODE COMPARISON



.

.

.

.

MAJOR FINDINGS OF ACI 318-63 VS. ACI 349-76 CODE COMPARISON

(Summary of Code Changes with the Potential to Significantly Degrade Perceived Margin of Safety)

Scale A

Referenced Subsection			
ACI 349-76	ACI 318-63	Structural Elements Potentially Affected	Comments
7.10.3	805	Columns designed for stress reversals with variation of stress from $f_{\rm Y}$ in compression to 1/2 $f_{\rm Y}$ in tension	Splices of the main reinforcement in such columns must be reasonably limited to provide for adequate ductility under all loading conditions.
11.13		Short brackets and corbels which are primary load-carrying members	As this provision is new, any existing corbels or brackets may not meet these criteria and failure of such elements could be non-ductile type failure. Structural integrity may be seriously endangered if the design fails to fulfill these requirements.
11.15		Applies to any elements loaded in shear where it is inappropriate to consider shear as a measure of diagonal tension and the loading could induce direct shear type cracks.	Structural integrity may be seriously endangered if the design fails to ful- fill these require- ments.

-56-

MAJOR FINDINGS OF ACI 318-63 VS. ACI 349-76 CODE COMPARISON

(Summary of Code Changes with the Potential to Significantly Degrade Perceived Margin of Safety)

Scale A (Cont.)

1

Referenced Subsection			
ACI	ACI	Structural Elements	
349-76	318-63	Potentially Affected	Comments
11.16		All structural walls - those which are primary load carrying, e.g., shear walls and those which serve to provide protection from impacts of missile- type objects.	Guidelines for these kinds of wall loads were not provided by older codes; there- fore, structural integrity may be seriously endangered if the design fails to fulfill these requirements.
Appendix A		All elements subject to time-dependent and position-dependent temperature variations and restrained so that thermal strains will result in thermal stresses.	For structures sub- ject to effects of pipe break, espe- cially jet impinge- ment, thermal stresses may be sig- nificant (Scale A). For structures not subject to effects of pipe break acci- dent, thermal stresses are unlikely to be significant

MAJOR FINDINGS OF ACI 318-63 VS. ACI 349-76 CODE COMPARISON

(Summary of Code Changes with the Potential to Significantly Degrade Perceived Margin of Safety)

Scale A (Cont.)

Referen	iced		
ACI	ACI	Structural Elements	
349-76	318-63	Potentially Affected	Comments
Appendix B		All steel embedments used to transmit loads from attachments into the rein-	New appendix; fore, consider

thereable review of older designs is warranted. Since stress analysis associated with these conditions is highly dependent on definition of failure planes and allowable stress for these special conditions, past practice varied with designers' opinions. Stresses may vary significantly from those thought to exist under previous design procedures.

11.3 MAJOR FINDINGS OF ACI 301-63 VS. ACI 301-72 (REVISED 1975) COMPARISON

No Scale A or $A_{\mathbf{X}}$ changes were found in the ACI 301 comparison.



4

*

11.4 MAJOR FINDINGS OF ASME B&PV CODE COMPARISON, SECTION VIII, 1962 VS. SECTION III, SUBSECTION NE, 1980



MAJOR FINDINGS OF ASME B&PV CODE COMPARISON, SECTION VIII, 1962 VS. SECTION III, SUBSECTION NE, 1980

(Summary of Code Changes with the Potential to Significantly Degrade Perceived Margin of Safety)

Scale A

.

Referenced Subsection			
Sec. III 1980	Sec. VIII 1962	Structural Elements Potentially Affected	Comments
NE-3112.4	UG-23	Vessels of materials no longer listed as Code acceptable	Section III, 1980 Code references materials identical to those referenced in Section VIII, 1962 Code. However, several materials which were referenced in Section VIII, 1962 are no longer given in Section III, 1980. Verification of
			the allowable stress values and validation of the materials used are required.
	UG-25 (d)	Vessels containing telltale holes	The removal of this pro- vision from Section III, 1962 Code, bans the use of telltale holes, par- ticularly since the only non-destructive test methods are recommended in Section XI of the Code, Rules for Inservice Inspection. Moreover, a more recent version of Section VIII specifically excludes using telltale holes when using lethal substances.
NE-3131		Containment shells designed by formula	Section VIII, 1962 Code calls for the design of the vessel by formula, while Section III, 1980 Code requires that the

MAJOR FINDINGS OF ASME B&PV CODE COMPARISON, SECTION VIII, 1962 VS. SECTION III, SUBSECTION NE, 1980

(Summary of Code Changes with the Potential to Significantly Degrade Perceived Margin of Safety)

Scale A (Cont.)

Refe	renced	
Sec. III	Sec. VIII	Structural Elements
1980	1962	Potentially Affected

Comments

NE-3131 Cont. rules of Subsection NE-3200 (Design by Analysis) be satisfied. In the absence of substantial thermal or mechanical loads other than pressure, the rules of "Design by Formula" may be used (substantial loads are those loads which cumulatively result in stresses which exceed 10% of the primary stresses induced by the design pressure, such stresses being defined as maximum principal stresses). The Scale rating for a Containment Shell where substantial thermal or mechanical loads other than pressure are absent, is Scale B. Otherwise it is Scale A.

NE-3133.5(a) UG-29

Stiffening rings for cylindrical shells subject to external pressure The requirements of the 1980 Code for defining the minimum moment of inertia of the stiffening ring as compared to the requirements of the 1962 Code may result in a lower margin of safety.

Scale

Is'	>	1.28	Is	С
Is'	>	1.22	Is	В
Is'	<	1.22	Is	A

.

MAJOR FINDINGS OF ASME B&PV CODE COMPARISON, SECTION VIII, 1962 VS. SECTION III, SUBSECTION NE, 1980

(Summary of Code Changes with the Potential to Significantly Degrade Perceived Margin of Safety)

Scale A (Cont.)

Referenced

÷

Subsection				
Sec. III Sec. VIII		Structural Elements		
1980		Potential? Affected	Comments	
NE-	UG-29		where Is is the minimum	
3133.5(a)			required moment of inertia	
Cont.			of the stiffening ring about	
			its neutral axis parallel to the axis of the shell. I _s '	
			is the moment of inertia of the combined ring-shell	
			section about its neutral axis parallel to the axis of the	
			shell. The width of shell	
			to Is' shall not be greater	
			than 1.1 $\sqrt{D_0/T}$.	
NE-3133.5(b)		Different materials used for the shell and the	This new insert in Section III of the 1980 Code	
		stiffening rings	requires using the material	
			chart which gives the larger value of the factor A. This	
			may result in a larger	
			stiffening ring section needed	
			to meet the requirements of the Code.	
			Scale A for ring-stiffened	
			shells where (1) the ring and	
			the shell are of different	
			materials and, in addition,	
			(2) the "factor A" (as	
			computed by the procedures of NE-3133.5) for the two	
			materials differs by more than 6%; otherwise Scale B.	
Fig.	Fig.	Vessels with a reducer	The effect of the change in	
3324.11	UG-36(d)	section with "reversed"	the requirements of the code	
(a) (6) -1		curvature	code on the margin of safety depends on the Br/t ratio	
			The races	

1

MAJOR FINDINGS OF ASME B&PV CODE COMPARISON, SECTION VIII, 1962 VS. SECTION III, SUBSECTION NE, 1980

(Summary of Code Changes with the Potential to Significantly Degrade Perceived Margin of Safety)

Scale A (Cont.)

-

1

0

Refere	enced			
Sec. II 1980	1962	Structural Elements Potentially Affected	Commen	ts
Fig. 3324.11	Fig. UG-36(d)		Limitations	Scale
(a) (6) -1 (Cont.)			$\frac{R_{\rm L}}{t} > 24$ $\frac{R_{\rm L}}{t} < 23$	C A
			where	
			R _L = radius of th end of the r t = shell thickn	e large educer ess
NE-3327.1		Vessels with positive locking devices - Quick actuating closures	New requirements 1980 Code	in the
NE-3327.4		Pressure indicating devices for vessels having quick actuating closures	Safety-related pr requires that the indicating device visible from the operating area	ovision pressure be
NE-3331(b)) UG-36	Openings and reinforce- ments Provisions for fatigue analysis	Requirements for analysis of vesse parts which are i service are provi Section III, 1980 No specific guida given in Section 1962 Code.	fatigue ls or n cyclic ded in Code. nce was VIII,
NE-3334.1 NE-3334.2	UG-40(b) UG-40(c)	Reinforcement for openings along and normal to vessel wall	New requirements 1980 Code limit t forcement measure the midsurface of nominal wall thic and normal to the wall	in the the rein- d along the kness vessel

Franklin Research Center

MAJOR FINDINGS OF ASME B&PV CODE COMPARISON, SECTION VIII, 1962 VS. SECTION III, SUBSECTION NE, 1980

(Summary of Code Changes with the Potential to Significantly Degrade Perceived Margin of Safety)

Scale A (Cont.)

.

Referenced Subsection				
Sec. III 1980	Sec. VIII 1962	Structural Elements Potentially Affected	Comments	
NE-3365(f)		Bellows expansion joints over 6 inches in diameter	Provisions regarding the internal sleeve design (for sizes over 6-inch diameter) and flow velocity limitations (for all sizes) are introduced in the 1980 Code.	
NE-3365.2		Bellows	New design requirements specified in the 1980 Code	



12. SUMMARY

The table that follows provides a summary of the status of the findings from the Task III-7.B criteria comparison review of structural codes and loading requirements for Category I structures at the Oyster Creek Nuclear Power Station.

The first and second columns of the table show the extent to which all Category I structures external to containment comply with current design criteria codes. The first column applies to the concrete portion of these structures; the second column applies to the portions which are of steel frame construction. The third column applies to concrete structures with regard to original and current specifications for structural concrete. The fourth column applies only to the containment building, including its liner.

The salient feature of this table is the limited number of code change impacts requiring a Scale A ranking. Consequently, resolution, at the structural level, of potential concerns with respect to changes in structural code requirements appears, at least for the Oyster Creek plant, to be an effort of tractable size.


SUMMARY

NUMBER	OF	DDE	CHANGE	IN	APACTS	FOR	
OYSTER	CREE	EK CA	TEGORY	I	STRUCT	URES	

SCALE RANKING TOTAL CHANGES FOUND		ACI 318.63 VS. ACI 349-76	AISC 1963 VS. AISC 1980	ACI 301-63 VS. ACI 301-72 (Rev. 1975)	ASME B&PV CODES SECTION VIII,1962 VS. SECTION III Subsec. NE, 1980
		82	33	37	27
quire	A or A Not Applicable to OYSTER CREEK	Not ble to CREEK 2 + 4* 14		.4 0	3*
ot Re her stiga	В	63	10	21	9
Do N Furt Inve	с	7	4	16	3
To Be Further Investigated	А	6	5	0	12
	A _x	0	0	0	0

SCALE RATINGS:

.

Scale A Change - The new criteria have the potential to substantially impair margins of safety as perceived under the former criteria.

- Scale A_X Change The impact of the code change on margins of safety is not immediately apparent. Scale A_X code changes require analytical studies of model structures to assess the potential magnitude of their effect upon margins of safety.
- Scale C Change The new criteria will give rise to larget margins of safety than were exhibited under the ferm r criteria.

*These changes are related to specified loads and load combinations. Loading criteria changes are separately considered elsewhere.

4

13. RECOMMENDATIONS

Potential concerns with respect to the ability of Seismic Category I buildings and structures in SEP plants to conform to current structural criteria are raised by the review at the code comparison level. These must ultimately be resolved by examination of individual as-built structures.

It is recommended that Jersey Central Power and Light Company be requested to take three actions:

- Review individually all Seismic Category I structures at the Oyster Creek plant to see if any of the structural elements listed in the following table occur in their designs. These are the structural elements for which a potential exists for margins of safety to be less than originally computed, due to criteria changes since plant design and construction. For structures which do incorporate these features, assess the actual impact of the associated code changes on margins of safety.
- 2. Reexamine the margins of safety of Seismic Category I structures under loads and load combinations which correspond to current criteria. Only those load combinations assigned a Scale A or Scale A_x rating in Section 10 of this report need be considered in this review. If the load combination includes individual loads which have themselves been ranked A or A_x , indicating that they do not conform to current criteria, update such loads.

Full reanalysis of these structures is not necessarily required. Simple hand computations or appropriate modifications of existing results can qualify as acceptable means of demonstrating structural adequacy.

 Review Appendix A of this report to confirm that all items listed there have no impact on safety margins at the Oyster Creek plant.

LIST OF STRUCTURAL ELEMENTS TO BE EXAMINED

Structural Elements to be Co	de Change Affec	ting These Elements		
Examined	New Code	Old Code	Scale	
Compression Elements	AISC 1980	AISC 1963		
With width-to-thickness ratio higher than speci- fied in 1.9.1.2	1.9.1.2 and Appendix C	1.9.1	A	
Tension Members	AISC 1980	AISC 1963		
When load is transmitted by bolts or rivets	1.14.2.2	•	A	
Connections	AISC 1980	AISC 1963		
 Beam ends with top flange coped, if subject to shear 	1.5.1.2.2		A	
 Connections carrying moment or restrained member connection 	1.15.5.2 1.15.5.3 1.15.5.4	-	A	
Members Designed to Operate in an Invlastic Regime	AISC 1980	AISC 1963		
Spacing of lateral bracing	2.9	2.8	A	
Short Brackets and Corbels having a shear span-to- depth ratio of unity or less	ACI 349-76 11.13	ACI 318-63	A	
<u>Shear Walls</u> used as primary load-carrying members	ACI 349-76 11.16	ACI 318-63	A	
Precast Concrete Structural Elements, where shear is not a measure of diagonal tension	ACI 349-76 11.15	ACI 318-63	A	

*Double dash (--) indicates that older code had no provisions.

,

.

.

.

LIST OF STRUCTURAL ELEMENTS TO BE EXAMINED (Cont.)

Sti	Examined Cod	de Change Affect New Code	ing These Elements Old Code	Scale
Cor	ncrete Regions Subject to The Temperatures	ACI 349-76	ACI 318-63	
Tir pos ten	me-dependent and sition-dependent mperature variations	Appendix A		A
Col Rei	lumns with Spliced	ACI 349-76	ACI 318-63	
str fy 1/2	tess reversals; in compression to 2 fy in tension	7.10.3	805	A
<u>Ste</u> tra	eel Embedments used to insmit load to concrete	ACI 349-76 Appendix B	ACI 318-63	A
Cor	tainment Vessels			
1.	Containment vessels of materials no longer listed as code acceptable	ASME Sec. III, NE-3112.4	ASME Sec. VIII, UG-23	A
2.	Containment vessels containing telltale holes	ASME Sec. III,	ASME Sec. VIII, 1962 UG-25(d)	A
3.	Containment vessels designed by formula and subject to substantial loads	ASME Sec. III, NE-3131	ASME Sec. VIII,	A
4.	Stiffening rings for cylindrical shells subject to external pressure	ASME Sec. III, NE-3133.5(a)	ASME Sec. VIII, UG-29	A
5.	Different materials used for the shell and stiffening rings	ASME Sec. III, NE-3133.5(b)	ASME Sec. VIII,	A
6.	Vessels with reducer section with "reversed" curvature when RL/t < 23	ASME Sec. III, Fig. 3324.11 (a) (6)-1	ASME Sec. VIII, Fig. UG-36(d)	A
7.	Vessels with positive locking devices - Quick actuating closures	ASME Sec. III, NE-3327.1	ASME Sec. VIII,	A

Franklin Research Center

LIST OF STRUCTURAL ELEMENTS TO BE EXAMINED (Cont.)

Str	uctural Elements to be Co	de Change Affect	ing These Elements	
	Examined	New Code	Old Code	Scale
8.	Pressure indicating devices for vessels having quick actuating closures	ASME Sec. III, NE-3327.4	ASME Sec. VIII,	A
She	11 Openings and Attachments			
1.	Openings and reinforcements Provisions for fatigue analysis	ASME Sec. III, NE-3331(b)	ASME Sec. VIII, UG-36	A
2.	Reinforcement for openings	ASME Sec. III, NE-3334.1 NE-3334.2	ASME Sec. VIII, UG-40(b) UG-40(c)	A
3.	Bellows expansion joints, over 6 inches in diameter	ASME Sec. III, NE-3365(f)	ASME Sec. VIII,	A
4.	Bellows - New design requirements	ASME Sec. III, NE-3365.2	ASME Sec. VIII,	A

٠

.

14. REFERENCES

- Standard Review Plan NRC, July 1981 NUREG-0800 (Formerly NUREG-75/087), Rev. 1
- AISC Specification for Design, Fabrication, and Erection of Structural Steel for Buildings American Institute of Steel Construction, Inc., New York, NY 1963
- "Building Code Requirements for Reinforced Concrete" American Concrete Institute, Detroit, MI, 1963 ACI 318-63
- ASME Boiler and Pressure Vessel Code, Section VIII "Unfired Pressure Vessels" The American Society of Mechanical Engineers, New York, NY, 1962
- Codes and Standards for Category I Structures, Attachment E Oyster Creek Nuclear Generating Station December 1979 Docket No. 50-219
- 6. Appendix I to Technical Evaluation Report, "Design Codes, Design Criteria, and Loading Combinations" Contains List of Basic Documents Defining Current Licensing Criteria for SEP Topic III-7.B Franklin Research Center, 1981 TER-C5257-327

APPENDIX A

.

SCALE A AND SCALE A CHANGES DEEMED INAPPROPRIATE TO OYSTER CREEK PLANT



APPENDIX A-1

AISC 1963 VS. AISC 1980 CODE COMPARISON

(SCALE A AND SCALE A CHANGES DEEMED INAPPROPRIATE TO OYSTER CREEK OR CODE CHANGES RELATED TO LOADS OR LOAD COMBINATIONS AND THEREFORE TREATED ELSEWHERE)

. *

ø

TER-C5257-320

8

.

AISC 1963 VS. AISC 1980 CODE COMPARISON

Referenced Subsection				
AISC 1980	AISC 1963	Structural Elements Potentially Affected		Comments
1.5.1.1	1.5.1.1	Structural members under tension, except for pin connected members		Structural steel used in Oyster Creek Cat. I structures is A-36. Thus, Fy < 0.83 Fu Therefore, Scale C for Oyster Creek.
			and the second second	

Limitations	Scale

$F_y \leq 0.833$	Fu			С
0.833 Fu <	Fy	< 0.875	Fu	В
Fy 20.875	Fu			A

2.4	2.3	Sler	nderness	ratio	
lst	lst	for	columns.	Must	satisfy:
Para.	Para.				

$$\frac{1}{r} - \frac{\langle \sqrt{2\pi^2 E}}{F_y}$$

			Scale
Fy	< 40 ks	si	C
40	< Fy <	44 ksi	В
Fy	244 ks	si	A

2.7 2.6

Flanges of rolled W, M, or S shapes and similar built-up single-web shapes subject to compression

Scale

Scale C

Scale C

for Oyster Creek. See case study 4 for details.

for Oyster Creek.

See case study

6 for details.

Fy	<	36	ksi		C
36	<	Fy	< 38	ksi	В
Fy	2	38	ksi		A

A-1.2

applicable

AISC 1963 VS. AISC 1980 CODE COMPARISON

Referen	ced ion		
AISC 1980	AISC 1963	Structural Elements Potentially Affected	Comments
1.5.1.4.1 Subpara. 6	1.5.1.4.1	Box-shaped members (subject to bending) of rectangular cross section whose depth is not more than 6 times its width and whose flange thickness is not more than 2 times the web thickness New requirement in the 1980 Code	Box-shaped mem- bers not found to be used in Oyster Creek Cat. I structures; therefore, not applicable
1.5.1.4.1 Subpara. 7	1.5.1.4.1	Hollow circular sections subject to bending New requirement in the 1980 Code	Hollow circular sections not found to be used in Oyster Creek Cat. I struc- tures; therefore, not applicable
1.5.1.4.4		Lateral support requirements for box sections whose depth is larger than 6 times their width New requirement in the 1980 Code	Box section members not found to be used in Oyster Creek Cat. I structures; therefore; not applicable
1.5.2.2	1.7	Rivets, bolts, and threaded parts subject to 20,000 cycles or more	Cat. I struc- tures are not subject to such cyclic loading; therefore, not applicable
l.7 and Appendix B	1.7	Members and connections subject to 20,000 cycles or more	Cat. I struc- tures are not subject to such cyclic loading; therefore, not

.

.

.

AISC 1963 VS. AISC 1980 CODE COMPARISON

Referenced			
AISC 1980	AISC 1963	Structural Elements Potentially Affected	Comments
1.9.2.3 and Appendix C		Circular tubular elements subject to axial compression	New requirements added to the 1980 Code
			Circular tubular elements are not found to be used in Oyster Creek Cat. I struc- tures; there- fore, not appli- cable
1.10.6	1.10.6	Hybrid girder - reduction in flange stress	Structural material used is A-36 steel. No hybrid girder found in the reactor building; therefore, not applicable
1.11.4	1.11.4	Shear connectors in composite beams	Shear connectors are not found to be used in the reactor building; therefore, not applicable
1.11.5	-	Composite beams or girders with formed steel deck	Composite beams or girders with formed steel decks are not found to be used in the reactor building; therefore, not applicable
1.13.3		Roof surface not provided with sufficient slope towards	

points of free drainage or

Franklin Research Center

A-1.4

AISC 1963 VS. AISC 1980 CODE COMPARISON

Referenced Subsection			
AISC	AISC	Structural Elements	
1980	1963	Potentially Affected	Comments
1.13.3		adequate individual drains to	
(Cont.)		prevent the accumulation of rain water (ponding)	
Appendix D		Web tapered members	New requirement

Web tapered Meb tapered Meb tapered Mebers are not found to be used

in Oyster Creek Cat. I structures; therefore, not applicable

TER-C5257-320

APPENDIX A-2

ACI 318-63 VS. ACI 349-76 CODE COMPARISON

(SCALE A AND SCALE A CHANGES DEEMED INAPPROPRIATE TO OYSTER CREEK OR CODE CHANGES RELATED TO LOADS OR LOAD COMBINATIONS AND THEREFORE TREATED ELSEWHERE)



4

TER-C5257-320

ACI 318-63 VS. ACI 349-76 CODE COMPARISON

Referenced Section			
ACI 349-76	ACI 318-63	Structural Elements Potentially Affected	Comments
Chapter 9 9.1, 9.2, & 9.3 most	Chapter 1	5 All primary load-carrying members or elements of the structural system are potentially affected.	
specifi- cally		Definition of new loads not normally used in design of traditional build- ings and redefinition of load factors and capacity reduction factors have altered the traditional analysis requirements.*	
10.1 and 10.10		All primary load-carrying members	
		Design loads here refer to Chapter 9 load combinations.*	
11.1		All primary load-carrying members	
		Design loads here refer to Chapter 9 load combinations.*	
18.1.4 and		Prestressed concrete elements	No prestressed
18.4.2		New loadings here refer to Chapter 9 load combinations.*	primary contain- ment; therefore, not applicable.
Chapter 19		Shell structures with thickness equal to or greater than 12 in	No shell struc- ture except primary
		This chapter is completely new; therefore, shell structures designed by the general criteria of older codes may not satisfy all aspects of this chapter. This chapter also refers to Chapter 9 load provisions.*	containment; therefore, not applicable.

*Special treatment of loads and load combinations is addressed in other sections of the report.

ACI 318-63 VS. ACI 349-76 CODE COMPAR SON

Refere	enced
Secti	ion
ACI	ACI

318-63

Stru	ctura	1 Elei	ments
Pote	ntial	ly Af:	fected

Comments

Appendix --C

349-76

All elements whose failure under impulsive and impactive loads must be precluded

New appendix; therefore, consideration and review of older designs is considered important. Since stress analysis associated with these conditions is highly dependent on definition of failure planes and allowable stress for these special conditions, past practice varied with designers' opinions. Stresses may vary significantly from those thought to exist under previous design procedures.*

TER-C5257-320

APPENDIX A-3

ACI 301-63 VS. ACI 301-72 (REVISED 1975)

No Scale A or $A_{\rm X}$ changes were found in the ACI 301 comparison.

×

TER-C5257-320

APPENDIX A-4

ASME B&PV CODE COMPARISON SECTION VIII, 1962, VS. SECTION III, SUBSECTION NE, 1980

(SCALE A AND SCALE A CHANGES DEEMED INAPPROPRIATE TO OYSTER CREEK OR CODE CHANGES RELATED TO LOAD COMBINATIONS AND THEREFORE TREATED ELSEWHERE)

÷.

A-4.1

ASME B&PV CODE COMPARISON SECTION VIII, 1962, VS. SECTION III, SUBSECTION NE, 1980

Referenced Section			
Section III 1980	Section VIII 1962	Structural Elements Potentially Affected	Comments
NE-3111	UG-22	Loading as applied to load-carrying compo- nents*	Section III, 1980 Code, specifies new loads to be considered in designing the vessel. These are: o dynamic head of liquids o snow loads and vibration loads o reaction to steam and water jet impingement
NE-3112.2		Design temperature as applied to the vessel and its components*	The effect of heating the vessel by external or internal heat generation is to be considered in establishing the vessel design temperature
NE-3112.3		Design mechanical loads as applied to the vessel and its compo- nents*	In computations involving design pressure and design temperature, the values of dead loads and any hydro- static loads coincident with design pressure (designated as design mechanical loads) should be used

*Special treatment of load and load combinations is addressed in other sections of the report.

Franklin Research Center

APPENDIX B

.

SUMMARIES OF CODE COMPARISON FINDINGS



.

APPENDIX B-1 AISC 1963 VS. AISC 1980 SUMMARY OF CODE COMPARISON

*

.

Scale A

Referenced				
AISC 1980	AISC 1963	Structural Elements Potentially Affected	Comments	
1.5.1.1	1.5.1.1	Structural members under tension, except for pin connected members	<u>Limitations</u>	Scale
			$F_y \le 0.833 F_u$ 0.833 $F_u \le F_y \le 0.875 F_u$ $F_y \ge 0.875 F_u$	C B A
1.5.1.2.2	-	Beam end connection where the top flange is coped and subject to shear, failure by shear along a plane through fasteners, or shear and tension along and perpendicular to a plane through fasteners	See case study 1 for details.	
1.5.1.4.1 Subpara. 6	1.5.1.4.1	Box-shaped members (subject to bending) of rectangular cross section whose depth is not more than 6 times their width and whose flat thickness is not more that 2 times the web thickness	ect New requirement in the ar 1980 Code ange an s	
1.5.1.4.1 Subpara. 7	1.5.1.4.1	Hollow circular sections subject to bending	New requirement in the 1980 Code	
1.5.1.4.4		Lateral support requireme for box sections whose de is larger than 6 times th width	ents New requirement in the epth 1980 Code meir	
1.5.2.2	1.7	Rivets, bolts, and threaded parts subject to 20,000 cycles or more	Change in the require- ments	

Scale A (Cont.)

.

Referenced Subsection			
AISC 1980	AISC 1963	Structural Elements Potentially Affected	Comments
l.7 and Appendix B	1.7	Members and connections subject to 20,000 cycles or more	Change in the require- ments
1.9.1.2 and Appendix C	1.9.1	Slender compression unstiff- ened elements subject to axial compression or compression due to bending when actual width-to-thickness ratio exceeds the values specified in subsection 1.9.1.2	New provisions added in the 1980 Code, Appendix C. See case study 10 for details.
1.9.2.3 and Appendix C		Circular tubular elements subject to axial compression	New requirements added in the 1980 Code
1.10.6	1.10.0	Hybrid girder - reduction in flange stress	New requirement added in the 1980 Code. Hybrid girders were not covered in the 1963 Code. See case study 9 for details.
1.11.4	1.11.4	Shear connectors in composite beams	New requirements added in the 1980 Code regard- ing the distribution of shear connectors (eqn. 1.11-7). The diameter and spacing of the shear connectors are also introduced.
1.11.5		Composite beams or girders with formed steel deck	New requirements added in the 1980 Code
1.15.5.2 1.15.5.3 1.15.5.4		Restrained members when flange or moment connection plates for end connections of beams and girders are welded to the flange of I or H shaped columns	New requirement added in the 1980 Code

Franklin Research Center

.

.

Scale A (Cont.)

Referenced Subsection				
AISC	AISC	Structural Elements		
1980	1963	Potentially Affected	Comments	
1.13.3		Roof surface not provided with sufficient slope towards points of free drain- age or adequate individual drains to prevent the accumulation of rain water (ponding)		
1.14.2.2		Axially loaded tension members where the load is transmitted by bolts or rivets through some but not all of the cross-sectional elements of the members	New requirement added in the 1980 Code	
2.4 1st Para.	2.3 1st Para.	Slenderness ratio for columns must satisfy	See case study 4 for details.	Scale
		$\frac{1}{r} \leq \sqrt{\frac{2\pi^2 E}{F_y}}$	$F_{y} \leq 40 \text{ ksi}$ $40 < F_{y} < 44 \text{ ksi}$ $F_{y} \geq 44 \text{ ksi}$	C B A
2.7	2.6	Flanges of rolled W, M, or S shapes and similar built-up single-web shapes	See case study 6 for details.	Scale
		subject to compression	$F_y \leq 36$ ksi 36 < $F_y < 38$ ksi $F_y \geq 38$ ksi	C B A
2.9	2.8	Lateral bracing of members to resist lateral and torsional displacement	See case study 7 for details.	
Appendix D		Web Capered members	New requirements added in the 1980 Code	

Scale B

.

Referenced Subsection			
AISC 1980	AISC 1963	Structural Elements Potentially Affected	Comments
1.9.2.2	1.9.2	Flanges of square and rectangular box sections of uniform thickness, of stiffened elements, when subject to axial compres- sion or to uniform compres- sion due to bending	The 1980 Code limit on width-to-thickness ratio of flanges is slightly more stringent than that of the 1963 Code.
1.10.1		flybrid girders	Hybrid girders were not covered in the 1963 Code. Application of the new requirement could not be much different from other rational method.
1.11.4	1.11.4	Flat soffit concrete slabs, using rotary kiln produced aggregates conforming to ASTM C330	Lightweight concrete is not permitted in nuclear plants as structural members (Ref. ACI-349).
1.13.2		Beams and girders supporting large floor areas free of partitions or other source of damping, where transient vibration due to pedestrian traffic might not be acceptable	Lightweight construction not applicable to nuclear structures which are designed for greater loads
1.14.6.1.3		Flare type groove welds when flush to the surface of the solid section of the bar	
1.16.4.2	1.16.4	Fasteners, minimum spacing, requirements between fasteners	
1.16.5	1.16.5	Structural joints, edge distances of holes for bolts and rivets	

B-1.5

÷.

Scale B (Cont.)

Referenced Subsection				
AISC	AISC	Structural Elements		
1980	1963	Potentially Affected	Comments	
1.15.5.5		Connections having high shear in the column web	New insert in the 1980 Code	
2.3.1 2.3.2		Sraced and unbraced multi- story frame - instability effect	Instability effect on short buildings will have negligible effect.	
2.4	2.3	Members subject to combined axial and bending moments	Procedure used in the 1963 Code for the interaction analysis is replaced by a different	

procedure. See case study 8 for details.

Franklin Research Center

Scale C

.

Referen	nced		
AISC 1980	AISC 1963	Structural Elements Potentially Affected	Comments
1.3.3	1.3.3	Support girders and their connections - pendart operated traveling cranes	
		The 1963 Code requires 25% increase in live loads to allow for impact as applied to traveling cranes, while the 1980 Code requires 10% increase.	The 1963 Code require- ment is more stringent, and, therefore, conservative.
1.5.1.5.3	1.5.2.2	Bolts and rivets - projected area - in shear connections $F_p = 1.5 F_u$ (1980 Code) $F_p = 1.35 F_y$ (1963 Code)	Results using 1963 Code are conservative.
1.10.5.3	1.10.5.3	Stiffeners in girders - spacing between stiffeners at end panels, at panels containing large holes, and at panels adjacent to panels containing large holes	New design concept added in 1980 Code giving less stringent require- ments. See case study 5 for details.
1.11.4	1.11.4	Continuous composite beams, where longitudinal reinforc- ing steel is considered to act compositely with the steel beam in the negative moment regions	New requirement added in the 1980 Code



APPENDIX B-2 ACI 318-63 VS. ACI 349-76 SUMMARY OF CODE COMPARISON



.

.

.

.

Scale A

Referenced Section			
ACI	ACI	Structural Elements	
349-76	318-63	Potentially Affected	Comments
7.10.3	805	Columns designed for stress reversals with variation of stress from f_y in compression to $1/2 f_y$ in tension	Splices of the main rein- forcement in such columns must be reasonably limited to provide for adequate ductility under all loading conditions.
Chapter 9 9.1, 9.2, & 9.3 most specifically	Chapter 15	All primary load-carrying members or elements of the structural system are potentially affected	Definition of new loads not normally used in design of traditional buildings and redefini- tion of load factors and capacity reduction factors has altered the traditional analysis requirements.*
10.1 and 10.10	-	All primary load-carrying members	Design loads here refer to Chapter 9 load combinations.*
11.1		All primary load-carrying members	Design loads here refer to Chapter 9 load combinations.*
11.13	-	Short brackets and corbels which are primary load- carrying members	As this provision is new, any existing corbels or brackets may not meet these criteria and failure of such elements could be non-ductile type failure. Structural integrity

*Special treatment of load and loading combinations is addressed in other sections of the report.

Scale A (Cont.)

.

Refere	nced		
ACI 349-76	ACI 318-63	Structural Elements Potentially Affected	Comments
11.13 (Cont.)			may be seriously endangered if the design fails to fulfill these requirements.
11.15	-	Applies to any elements loaded in shear where it is inappropriate to consider shear as a measure of diagonal tension and the loading could induce direct shear-type cracks	Structural integrity may be seriously endangered if the design fails to fulfill these requirements.
11,16		All structural walls - those which are primary load carrying, e.g., shear walls and those which serve to provide protec- tion from impacts of missile-type objects	Guidelines for these kinds of wall loads were not provided by older codes; therefore, struc- tural integrity may be seriously endangered if the design fails to fulfill these require- ments.
18.1.4 and 18.4.2	-	Prestressed concrete elements	New load combinations here refer to Chapter 9 load combinations.*
Chapter 19	-	Shell structures with thickness equal to or greater than 12 inches	This chapter is com- pletely new; therefore, shell structures designed by the general criteria of older codes may not satisfy all aspects of this chapter.

*Special treatment of loads and loading combinations is addressed in other sections of the report.

5

.

Scale A (Cont.)

Referenced Section			
ACI	ACI	Structural Elements	
349-76	318-63	Potentially Affected	Comments
Chapter 19 (Cont.)			Additionally, this chapter refers to Chapter 9 provisions.
Appendix A		All elements subject to time-dependent and position-dependent temperature variations and which are restrained such that thermal strains will result in thermal stresses	New appendix; older Code did not give specific guidelines on temperature limits for concrete. The possible effects of strength loss in concrete at high temperatures should be assessed.
Appendix B		All steel embedments used to transmit loads from attachments into the reinforced concrete structures	New appendix; therefore, considerable review of older designs is warranted.**
Appendix C	-	All elements whose failure under impulsive and impactive loads must be precluded	New appendix; therefore, considerations and review of older designs is considered important.**

**Since stress analysis associated with these conditions is highly dependent on definition of failure planes and allowable stress for these special conditions, past practice varied with designers' opinions. Stresses may vary significantly from those thought to exist under previous design procedures.

Scale B

.

Referenced Section			
ACI	ACI	Structural Elements	
349-76	318-63	Potentially Affected	Comments
1.3.2	103(b)	Ambient temperature control for concrete inspection - upper limit reduced 5° (from 100°F to 95°F) applies to all structural	Tighter control to ensure adequate control of curing environment for cast-in-place concrete.
		concrete	
1.5		Requirement of a "Quality Assurance Program" is new. Applies to all structural concrete	Previous codes required inspection but not the establishment of a quality assurance program.
Chapter 3	Chapter 4	Any elements containing steel with f _Y > 60,000 psi or lightweight concrete	Use of lightweight con- crete in a nuclear plant not likely. Elements containing steel with $f_y > 60,000$ psi may have inadequate ductility or excessive deflections at service loads.
3.2	402	Cement	This serves to clarify intent of previous code.
3.3	403	Aggregate	Eliminated reference to lightweight aggregate.
3.3.1	403	Any structural concrete covered by ACI 349-76 and expected to provide for radiation shielding in addition to structural capacity	Controls of ASTM C637, "Standard Specifications for Aggregates for Radiation Shielding Concrete," closely parallel those for ASTM C33, "Standard Specifi- cation for Concrete

B-2.5

Aggregates."

.

÷

Scale B (Cont.)

Section			
ACI 349-76	ACI 318-63	Structural Elements Potentially Affected	Comments
3.3.3	403	Aggregate	To ensure adequate control.
3.4.2	404	Water for concrete	Improve quality control measures.
3.5	405	Metal reinforcement	Removed all reference to steel with $f_y > 60,000$ psi.
3.6	406, 407 & 408	Concrete admixtures	Added requirements to improve quality control.
4.1 and 4.2	501 & 502	Concrete proportioning	Proportioning logic improved to account for statistical variation and statistical quality control.
4.3	504	Evaluation and acceptance of concrete	Added provision to allow for design specified strength at age > 28 days to be used. Not considered to be a problem, since large cross sections will allow concrete in place to continue to hydrate.
5.7	607	Curing of very large concrete elements and control of hydration temperature	Attention to this is required because of the thicker elements en- countered in nuclear- related structures.
6.3.3	-	All structural elements with embedded piping containing high tempera- ture materials in excess	Previous codes did not address the problem of long periods of exposure to high temperature and

Franklin Research Center

B-2.6

Scale B (Cont.)

,

.

Referenced			
ACI 349-76	ACI 318-63	Structural Elements Potentially Affected	Comments
6.3.3 (Cont.)		of 150°F, or 200°F in localized areas not insulated from the concrete	did not provide for reduction in design allowables to account for strength reduction at high (>150°F) temperatures.
7.5, 7.6, & 7.8	805	Members with spliced reinforcing steel	Sections on splicing and tie requirements amplified to better control strength at splice locations and provide ductility.
7.9	805	Members containing deformed wire fabric	New sections to define requirements for this new material.
7.10 & 7.11	-	Connection of primary load-carrying members and at splices in column steel	To ensure adequate ductility.
7.12.3 7.12.4		Lateral ties in columns	To provide for adequate ductility.
7.13.1 through 7.13.3		Reinforcement in exposed concrete	New requirements to conform with the expected large thick- nesses in nuclear related structures.
8.6		Continuous nonprestressed flexural members.	Allowance for redistri- bution of negative moments has been redefined as a function of the steel percentage.
9.5.1.1		Reinforced concrete members subject to bending - deflection limits	Allows for more stringent controls on deflection in special cases.

.

۰

Scale B (Cont.)

Comments
mments in r 3 summary.
m thickness lly would not l this type of ure.
s serviceability, rength.
ate and long time tions generally not al in structures ed for very large coadings; however, by ultimate es more attention to tion controls.
ol of camber, both al and long time in ton to service load tion, requires more tion for designs by ate strength.
limit on B of yould correspond to of 8,000 psi. No ete of this strength y to be found in a ar structure.
s on axial design for these members in terms of design ions.

Franklin Research Center

B-2.8

Scale B (Cont.)

.

Referenced Section			
ACI	ACI	Structural Elements	
349-76	318-63	Potentially Affected	Comments
10.6.1 10.6.2 10.6.3 10.6.4	1508	Beams and one-way slabs	Changes in distribution of reinforcement for crack control.
10.6.5		Beams	New insert
10.11.1 10.11.2 10.11.3 10.11.4 10.11.5 10.11.5.1 10.11.5.2 10.11.6 10.11.7 10.12	915 916	Compression members, slenderness effects	For slender columns, moment magnification concept replaces the so- called strength reduc- tion concept but for the limits stated in ACI 318-63 both methods yield equal accuracy and both are acceptable methods.
10.15.1 10.15.2 10.15.3 10.15.4 10.15.5 10.15.6	1404-1406	Composite compression members	New items - no way to compare; ACI 318-63 con- tained only working stress method of design for these members.
10.17	-	Massive concrete members, more than 48 in thick	New item - no comparison.

٠

.

Scale B (Cont.)

Referenced Section			
ACI 349-76	ACI 318-63	Structural Elements Potentially Affected	Comments
11.2.1		Concrete flexural members	For nonprestressed members, concept of minimum area of shear reinforcement is new. For prestressed members, Eqn. 11-2 is the same as in ACI 318-63. Requirement of minimum shear reinforcement provides for ductility and restrains inclined crack growth in the event of unexpected loading.
11.7 through 11.8.6		Nonprestressed members	Detailed provisions for this load combination. were not part of ACI 318-63. These new sections provide a conservative logic which requires that the steel needed for torsion be added to that required for transverse shear, which is consistent with the logic of ACI 318-63. This is not considered to be critical, as ACI 318-63 required the designer to consider torsional stresses; assuming that some rational method was used to account for torsion, no problem is expected to arise.
Scale B (Cont.)

.

*

Referenced Section			
ACI	ACI	Structural Elements	
349-76	318-63	Potentially Affected	Comments
11.9 through 11.9.6		Deep beams	Special provisions for shear stresses in deep beams is new. The minimum steel requirements are similar to the ACI 318-63 requirements of using the wall steel limits. Deep beams designed under previous ACI 318-63 criterion were reinforced as walls at the minimum and therefore no unreinforced section would have resulted.
11.10 through 11.10.7		Slabs and footings	New provision for shear reinforcement in slabs or footings for the two- way action condition and new controls where shear head reinforcement is used. Logic consistent with ACI 318-63 for these conditions and change is not considered major.

B-2.11

•

.

Scale B (Cont.)

Referenced Section			
ACI 349-76	ACI 318-63	Structural Elements Potentially Affected	Comments
11.11.1	1707	Slabs and footings	The change which deletes the old requirement that steel be considered as only 50% effective and allows concrete to carry 1/2 the allowable for two-way action is new. Also deleted was the requirement that shear reinforcement not be considered effective in slabs less than 10 in thick. Change is based on recent research which indicates that such reinforcement works even in thin slabs.
11.11.2 through 11.11.2.5		Slabs	Details for the design of shearhead is new. ACI 318-63 had no provisions for shearhead design. The requirements in this section for slabs and footings are not likely to have been used in older plant designs. If such devices were used, it is assumed a rational design method was used.
11.12		Openings in slabs and footings	Modification for inclusion of shearhead design. See above conclusion.

Scale B (Cont.)

Referenced Section			
ACI	ACI	Structural Elements	
349-76	318-63	Potentially Affected	Comments
11.13.1 11.13.2		Columns	No problem anticipated since previous code required design consideration by some analysis.
Chapter 12		Reinforcement	Development length con- cept replaces bond stress concept in ACI 318-63. The various l _d lengths in this chapter are based entirely on ACI 318-63 permissible bond stresses. There is essentially no difference in the final design results in a design under the new code compared to ACI 318-63.
12.1.6 through 12.1.6.3	918(C)	Reinforcement	Modified with minimum added to ACI 318-63, 918(C).
12.2.2 12.2.3		Reinforcement	New insert in ACI 349-76.
12.4		Reinforcement of special members	New insert. Gives emphasis to special member consideration.
12.8.1 12.8.2		Standard hooks	Based on ACI 318-63 bond stress allowables in general; therefore, no major change.

Scale B (Cont.)

Referenced Section			
ACI ACI		Structural Elements	
349-76	318-63	Potentially Affected	Comments
12.10.1 12.10.2(b)		Wire fabric	New insert. Use of such reinforce- ment not likely in Category I structures for nuclear plants.
12.11.2	-	Wire fabric	New insert. Mainly applies to pre- cast prestressed members.
12.13.1.4		Wire fabric	New insert. Use of this material for stirrups not likely in heavy members of a nuclear plant.
13.5	-	Slab reinforcement	New details on slab reinforcement intended to produce better crack control and maintain
			Past practice was not inconsistent with this in general.
14.2		Walls with loads in the Kern area of the thickness	Change of the order of the empirical equation (14-1) makes the solution compatible with Chapter 10 for walls with loads in the Kern area of the thickness.

Scale B (Cont.)

Referenced Section			
ACI 349-76	ACI 318-63	Structural Elements Potentially Affected	Comments
15.5		Footings - shear and development of rein- forcement	Changes here are in- tended to be compatible with change in concept of checking bar devel- opment instead of nominal bond stress con- sistent with Chapter 12.
15.9	-	Minimum thickness of plain footing on piles	Reference to minimum thickness of plain foot- ing on piles which was in ACI 318-63 was removed entirely.
16.2		Design considerations for a structure behaving monolithically or not, as well as for joints and bearings.	New but consistent with the intent of previous code.
17.5.3	2505	Horizontal shear stress in any segment	Use of Nominal Average Shear Stress equation (17-1) replaces the theoretical elastic equation (25-1) of ACI 318-63. It provides for easier computation for the designer.
18.4.1	-	Concrete immediately after prestress transfer	Change allows more tension, thus is less con- servative but not considered a problem.



1

٠

Scale B (Cont.)

Section			
ACI	ACI	Structural Elements	
349-76	318-63	Potentially Affected	Comments
18.5	2606	Tendons (steel)	Augmented to include yield and ultimate in the jacking force requirement.
18.7.1		Bonded and unbonded members	Eqn. 18-4 is based on more recent test data.
18.9.1 18.9.2 18.9.3	-	Two-way flat plates (solid slabs) having minimum bonded reinforcement	Intended primarily for control of cracking.
18.11.3 18.11.4	-	Bonded reinforcement at supports	New to allow for consideration of the redistribution of negative moments in the design.
18.13 18.14 18.15 18.16.1	-	Prestressed compression members under combined axial load and bending. Unbonded tendons. Post tensioning ducts. Grout for bonded tendons.	New to emphasize details particular to prestressed members not previously addressed in the codes in detail.
18.16.2		Proportions of grouting materials	Expanded definition of how grout properties may be determined.
18.16.4	-	Grouting temperature	Expanded definition of temperature controls when grouting.

Franklin Research Center

B-2.16

Scale C

.

Section			
ACI	ACI	Structural Elements	
349-76	318-63	Potentially Affected	Comments
7.13.4		Reinforcement in flexural slabs	
10.8.1 10.8.2 10.8.3	912	Compression members, limiting dimensions	Minimum size limitations are deleted in newer Code, giving the designer more freedom in cross sectional dimensioning.
10.14	2306	Bearing - sections controlled by design bearing stresses	ACI 318-63 is more conservative, allowing a stress of $1.9(0.25 \text{ f'}_{C}) =$ $0.475 \text{ f'}_{C} < 0.6 \text{ f'}_{C}$
11.2.5	1706	Reinforcement concrete mem- bers without prestressing	Allowance of spirals as shear reinforcement is new. Requirement, where shear stress exceeds $6\phi/f'_{C}$, of 2 lines of web reinforcment was removed.
13.0 to end	-	Two-way slabs with multiple square or rec- tangular panels	Slabs designed by the previous criteria of ACI 318-63 are generally the same or more conservative.
13.4.1.5		Equivalent column flexi- bility stiffness and attached torsional members	Previous code did not consider the effect of stiffness of members normal to the plane of the equivalent frame.
17.5.4 17.5.5	-	Permissible horizontal shear stress for any surface, ties provided or not provided	Nominal increase in allowable shear stress under new code.

APPENDIX B-3

ACI 301-63 VS. ACI 301-72 (REVISED 1975)

SUMMARY OF CODE COMPARISON



*

.

Scale B

Section			
ACI 301-72	ACI 301-63	Structural Elements Potentially Affected	Comments
3.8.2.1 3.8.2.3	309Б	Lower strength concrete can be proportioned when "working stress concrete" is used	ACI 301-72 (Rev. 1975) bases proportioning of concrete mixes on the specified strength plus a value determined from the standard deviation of test cylinder strength results. ACI 301-63 bases proportioning for "working stress concrete" on the specified strength plus 15 percent with no mention of standard deviation. High standard deviations in cylinder test results could require more than 15 percent under ACI 301-72 (Rev. 1975)
3.8.2.2 3.8.2.3	309d	Mix proportions could give lower strength concrete	ACI 301-72 (Rev. 1975) requires more strength tests than ACI 301-63 for evalua- tion of strength and bases the strength to be achieved on the standard deviation of strength test results.
17.3.2.3	1704d	Lower strength concrete could have been used	ACI 301-72 (Rev. 1975) requires core samples to have an average strength at least 85 percent of the specified strength with no single result less than 75 percent of the specified strength. ACI 301-63 simply requires "strength adequate for the intended purpose." If "adequate for the intended purpose" is less than 85 percent of the specified strength, lower strength concrete could be used.

B-3.2

Scale B (Cont.)

Section			
ACI 301-72	ACI 301-63	Structural Elements Potentially Affected	Comments
17.2	1702a 1703a	Lower strength concrete could have been used	ACI 301-72 (Rev. 1975) specifies that that no individual strength test result shall fall below the specified strength by more than 500 psi. ACI 301-63 specifies that either 20 percent (1702a) or 10 percent (1703a) of the strength tests can be below the specified strength. Just how far below is not noted.
15.2.6.1	1502b1	Weaker tendon bond possible	ACI 301-72 (Rev. 1975) requires fine aggregate in grout when sheath is more than four times the tendon area. ACI 301-63 requires fine sand addition at five times the tendon area.
15.2.2.1 15.2.2.2 15.2.2.3	1502el	Prestressing may not be as good	ACI 301-72 (Rev. 1975) gives considerably more detail for bonded and unbonded tendon anchorages and couplings. ACI 301-63 does not seem to address unbonded tendons.
8.4.3	804b	Cure of concrete may not be as good	ACI-301-72 (Rev. 1975) provides for better control of placing temperature. This will give better initial cure.
8.2.2.4	80254	Concrete may be more nonuniform when placed	ACI 301-72 (Rev. 1975) provides for a maximum slump loss. This gives better control of the character- istics of the placed concrete.

•

.

Scale B (Cont.)

1.10

Section			
ACI 301-72	ACI 301-63	Structural Elements Potentially Affected	Comments
8.3.2	803b	Weaker columns and walls possible	ACI 301-72 (Rev. 1975) provides for a longer setting time for concrete in columns and walls before placing concrete in supported elements.
5.5.2		Poor bonding of reinforce- ment to concrete possible	ACI 301-72 (Rev. 1975) provides for cleaning of reinforcement. ACI 301-63 has no corresponding section.
5.2.5.3		Reinforcement may not be as good	ACI 301-72 (Rev. 1975) provides for use of welded deformed steel wire fabric for reinforcement. ACI 301-63 has no corresponding section.
5.2.5.1 5.2.5.2	503a	Reinforcement may not be as good when welded steel wire fabric is used	ACI 301-72 (Rev. 1975) provides a maximum spacing of 12 in for welded intersec- tion in the direction of principal reinforcement.
5.2.1		Reinforcement may not have reserve strength and ductility	ACI 301-72 (Rev. 1975) has more stringent yield requirements.
4.6.3	406c	Floors may crack	ACI 301-72 (Rev. 1975) provides for placement of reshores directly under shores above, while ACI 301-63 states that reshores shall be placed "in approximately the same pattern."

Franklin Research Center

Scale B (Cont).

Referenced Section			
ACI 301-72	ACI 301-63	Structural Elements Potentially Affected	Comments
4.6.2		Concrete may sag or be lower in strength	ACI 301-72 (Rev. 1975) provides for reshoring no later than the end of the working day when stripping occurs.
4.6.4		Concrete may sag or be lower in strength	ACI 301-72 (Rev. 1975) provides for load distribu- tion by reshoring in multistory buildings.
4.2.13		Low strength possible if reinforcing steel is distorted	ACI 301-72 (Rev. 1975) requires that equipment runways not rest on reinforc- ing steel.
3.8.5	-	Possible to have lower strength floors	ACI 301-72 (Rev. 1975) places tighter control on the concrete for floors.
3.7.2 3.4.4		Embedments may corrode and lower concrete strength	ACI 301-72 (Rev. 1975) requires that it be demonstrated that mix water does not contain a deleterious amount of chloride ion.
3.4.2 3.4.3	-	Possible lower strength	ACI 301-72 (Rev. 1975) places tighter control on water- cement ratios for watertight structures and structures exposed to chemically aggressive solutions.
1.2	-	Possible damage to green or underage concrete resulting in lower strength	ACI 301-72 (Rev. 1975) provides for limits on loading of emplaced concrete.

Scale C

Referenced			
ACI 301-72	ACI 301-63	Structural Elements Potentially Affected	Comments
3.5	305	Better strength resulting from better placement and consolidation	ACI 301-63 gives a minimum slump requirement. ACI 301-72 (Rev. 1975) omits minimum slump which could lead to difficulty in placement and/or consolida- tion of very low slump concrete. A tolerance of 1 in above maximum slump is allowed provided the average slump does not exceed maximum. Generally the placed concrete could be less uniform and of lower strength.
3.6	306b	Better strength resulting from better placement and consolidation	ACI 301-63 provides for use of single mix design with maximum nominal aggregate size suited to the most critical condition of concreting. ACI 301-72 (Rev. 1975) allows waiver of size requirement if the architect-engineer believes the concrete can be placed and consolidated.
3.8.2.1	309Ь	Higher strength from better proportioning	ACI 301-63 bases propor- tioning for "ultimate strength" concrete on the specified strength plus 25%. ACI 301-72 (Rev. 1975) bases proportioning on the specified strength plus a value determined from the standard deviation of test cylinder strengths. The requirement to exceed the specified strength by 25% gives higher strengths than the standard deviation method.

Franklin Research Center

B-3.6

Scale C (Cont.)

.

Referenced Section			
ACI 301-72	ACI 301-63	Structural Elements Potentially Affected	Comments
4.4.2.2	404c	Better bond to reinforce- ment gives better strength	ACI 301-63 provides that form coating be applied prior to placing reinforcing steel. ACI 301-72 (Rev. 1975) omits this requirement. If form coating contacts the rein- forcement, no bond will develop.
4.5.5	405Ь	Better strength and less chance of cracking or sagging	ACI 301-63 provides for keeping forms in place until the 28-day strength is attained. ACI 301-72 (Rev. 1975) provides for removal of forms when specified removal strength is reached.
4.6.2	406b	Better strength and less chance of cracking or sagging	Same as above but applied to reshoring.
4.7.1	407a	Better strength by curing longer in forms	ACI 301-63 provides for cylinder field cure under most unfavorable conditions prevailing for any part of structure. ACI 301-72 (Rev. 1975) provides only that the cylinders be cured along with the concrete they represent. Cure of cylinders could give higher strength than the

Franklin Research Center

in-place concrete and forms could be removed too soon.

Scale C (Cont.)

Referenced Section			
ACI 301-72	ACI 301-63	Structural Elements Potentially Affected	Comments
5.2.2.1 5.2.2.2		Better strength, less chance of cracked rein- forcing bars	ACI 301-72 (Rev. 1975) has less stringent bending requirement for reinforcing bars than does ACI 318-63.
5.5.4 5.5.5	505b	Better strength from reinforcement	ACI 301-63 provides for more overlap in welded wire fabric.
12.2.3	1201d	Better strength from better cure of concrete	ACI 301-63 provides for final curing for 7 days with air temperature above 50°F. ACI 301-72 (Rev. 1975) provides for curing for 7 days and compressive strength of test cylinders to be 70 percent of specified strength. This could allow termination of cure too soon.
14.4.1	1404	Better strength resulting from better uniformity	ACI 301-63 provides for a maximum slump of 2 in. ACI 301-72 (Rev. 1975) gives a tolerance on the maximum slump which could lead to nonuniformity in the concrete in place.
15.2.1.1	1502-c1b	Higher strength from higher yield prestressing bars	ACI 301-63 requires higher yield stress than does ACI 301-72 (Rev. 1975)
15.2.1.2	1502-c2	Higher strength from better prestressing steel	ACI 301-63 requires that stress curves from the production lot of steel be furnished. ACI 301-72 (Rev. 1975) requires that a typical stress-strain curve be submitted. The use of the typical curve may miss lower strength material.

B-3.8

Scale C (Cont.)

Referenced Section			
ACI 301-72	ACI 301-63	Structural Elements Potentially Affected	Comments
16.3.4.3	1602-4c	Better strength resulting from better cylinder tests	ACI 301-63 requires 3 cylinders to be tested at 28 days; if a cylinder is damaged, the strength is based on the average of two. ACI 301-72 (Rev. 1975) requires only two 28-day cylinders; if one is damaged, the strength is based on the one survivor.
16.3.4.4	1602-4d	Better strength, less chance of substandard concrete	ACI 301-63 requires that less than 100 yd ³ of any class of concrete placed in any one day be represented by 5 tests. ACI 301-72 (Rev. 1975) allows strength tests to be waived on less than 50 yd ³ .
17.3.2.3	1704d	Better strength could be developed	ACI 301-6. requires core strengths "adequate for the intended purposes." ACI 301-72 (Rev. 1975) requires an average strength at least 85 percent of the specified strength with no single result less than 75 percent of the specified strength. If "adequate for the intended purpose" is higher than 85 percent of the specified strength, the concrete is stronger.



APPENDIX B-4

ASME B&PV CODE, SECTION VIII, 1962 VS. ASME B&PV CODE, SECTION III, SUBSECTION NE, 1980 SUMMARY OF CODE COMPARISON



5

.

Scale A

Referenc	ed Section		
Section III 1980	Section VIII 1962	Structural Elements Potentially Affected	Comments
NE-3111	UG-22	Loading as applied to load carrying compo- nents*	Section III, 1980 Code specifies new loads to be considered in designing the vessel. These are: o Dynamic head of liquids o Snow loads and vibration loads o Reaction to steam and
			water jet impingement
NE-3112.2		Design temperature as applied to the vessel and its components*	The effect of heating the vessel by external or internal heat generation is to be considered in establishing the vessel design temperature.
NE-3112.3		Design mechanical loads as applied to the vessel and its compo- nents*	In computations involving design pressure and design temperature, the values of dead loads and any hydro- static loads coincident with design pressure (designated as design mechanical loads) should be used.
NE-3112.4	UG-23	Vessels of materials no longer listed as Code acceptable	Section III, 1980 Code references materials which are identical to those referenced in Section VIII, 1962 Code. However, several materials which were referenced in Section VIII, 1962 are no longer given in Section III, 1980.

*Special treatment of load .nd load combinations is addressed in other sections of the report.

Scale A (Cont.)

.

Section III 1980	Section VIII 1962	Structural Elements Potentially Affected	Comments
NE-3112.4 (Cont.)			Verification of the allow- able stress values and validation of the materials used are required.
	UG-25 (d)	Vessels containing telltale holes	The removal of this provi- sion from Section III, 1962 Code, bans the use of telltale holes, particularly since the only non- destructive test methods are recommended in Section XI of the Code, Rules for Inservice Inspection. Moreover, the more recent version of Section VIII specifically excludes using telltale holes when using lethal substances.
NE-3131		Containment shells designed by formula	Section VIII, 1962 Code calls for the design of vessels by formula, while Section III, 1980 Code requires that the rules of Subsection NE-3200 (Design by Analysis) be satisfied. In the absence of substan- tial thermal or mechanical loads other than pressure, the rules of "Design by Formula" may be used (substantial loads are those loads which cumulatively result in stresses which exceed 10% of the primary stresses induced by the design pressure, such stresses being defined as maximum

B-4.3

Scale A (Cont.)

Reference	ed Section		
Section III 1980	Section VIII 1962	Structural Elements Potentially Affected	Comments
NE-3131 (Cont.)			The scale rating for containment shells where substantial thermal or mechanical loads other than pressure are absent is Scale B; otherwise it is Scale A.
NE-3133.5(a)	UG-29	Stiffening rings for cylindrical shells subject to external pressure	The requirements of the 1980 Code for defining the minimum moment of inertia of the stiffening ring as compared to the require- ments of the 1962 Code may result in a lower margin of safety.

Scale

I's	>	1.28	Is	с
I's	>	1.22	Is	в
I's	<	1.22	Is	A
when	PA			

Is is the minimum required moment of inertia of the stiffening ring about its neutral axis parallel to the axis of the shell. Is' is the moment of inertia of the combined ring-shell section about its neutral axis parallel to the axis of the shell. The width of shell which is taken as contributing to Is' shall not be greater than $1.1 \sqrt{D_0/T}$.

Scale A (Cont.)

Reference	d Section		
Section III 1980	Section VIII 1962	Structural Elements Potentially Affected	Comments
NE-3133.5(b)		Different materials used for the shell and the stiffening rings	This new insert in Section III of the 1980 Code requires using the material chart which gives the larger value of the factor A. This may result in a larger stiffening ring section needed to meet the requirements of the code.
			Scale A for ring-stiffened shells where (1) the ring and the shell are of different materials and, in addition, (2) the "factor A" (as computed by the procedure of NE-3133.5) for the two materials differs by more than 6%; otherwise Scale B.
Fig. 3324.11 (a)(6)-1	Fig. UG-36(d)	Vessels with a reducer section with "reversed" curvature	The effect of the change in the requirements of the code on the margin of safety depends on the R_L/t ratio
			Limitations Scale
			$\begin{array}{c} R_{L}/t > 24 & C\\ R_{L}/t < 23 & A \end{array}$
			where
			R _L = radius of the large end of the reducer
			t = shell thickness

.

×.

Scale A (Cont.)

Referenced Section			
Section III 1980	Section VIII 1962	Structural Elements Potentially Affected	Comments
NE-3327.1		Vessels with positive locking devices - quick actuating closures	New requirements in the 1980 Code
NE-3327.4		Pressure indicating devices for vessels having quick actuating closures	Safety related provision requires that the pressure indicating device be visible from the operating area.
NE-3331(b)	UG-36	Openings and reinforce- ments Provisions for fatigue analysis*	Requirements for fatigue analysis of vessels or parts which are in cyclic service are provided in Section III, 1980 Code. No specific guidance was given in Section VIII, 1962 Code.
NE-3334.1 NE-3334.2	UG-40 (b) UG-40 (c)	Reinforcement for openings along and normal to vessel wall	New requirements in the 1980 Code limit the rein- forcement measured along the midsurface of the nominal wall thickness and normal to the vessel wall.
NE-3365(f)		Bellows expansion joints over 6 inches in diameter	Provisions regarding the internal sleeve design (for sizes over 6-inch diameter) and flow velocity limita- tions (for all sizes) are introduced in the 1980 Code.
NE-3365.2		Bellows	New design requirements specified in the 1980 Code.

*Special treatment of load and load combinations is addressed in other sections of the report.

.

i.

Scale B (Cont.)

Refer	enced Section		
Section I 1980	II Section VIII 1962	Structural Elements Potentially Affected	Comments
NE-3328		Combination units	This new insert gives the design requirements for pressure vessels consisting of more than one independent pressure chamber. These requirements are standard practice for designing such vessels.
NE-3335	UG-40	Reinforcement in nozzles and vessel walls	These new provisions in Section III, 1980 Code detail specific requirements which are usually considered in good design practice.
NE3365		Bellows expansion joint - general requirements	This new section provides specific requirements usually considered in the design and selection of bellows.
NE-3367		Closures on small penetrations	This new insert gives details used in common practice. However, compliance with the standards listed in Table NE-3132-1 is covered in SEP Topic III.1.
NE-3700		Electrical and mechanical penetration assemblies	Provisions usually adopted in standard engineering design of such assemblies.

Scale B

.

Referenced Section			
Section III 1980	Section VIII 1962	Structural Elements Potentially Affected	Comments
NE-3133.1	UG-28	Components under external pressure	The design rules as given in Section VIII, 1962 are nearby identical to those specified in Section III, 1980. The differences will have little effect on the margin of safety.
NE-3133.6		Cylinders under axial compression	This new requirement is based on standard methods of analysis which do not differ much from those previously used in the analysis of cylinders under compressive loads.
NE-3324.8(c)		Torispherical heads made of materials having minimum tensile strength exceeding 80 ksi	The allowable stress for such a material should not exceed 22 ksi at room temperature as specified in the 1980 Code. Allowable stresses for the materials specified on the 1962 Code could be slightly higher, giving somewhat less conservative results.
NE-3324.12		Nozzles	The specified requirements imposed on the wall thickness of the nozzles or other connections are considered to be within the limitations of standard practice.

Scale C

. .

Referenced Section			
Section III 1980	Section VIII 1962	Structural Elements Potentially Affected	Comments
NE-3332.2	UG-37(b)	Area of reinforcement - vessels under internal pressure	The introduction of the correction factor F in Section III, 1980 Code will render the applicable equation to be the same or less conservative.
NE-3325.2(b)	UG-34(c)	Flat unstayed heads, covers, and blind flanges	The applicable revised equation (2) will have a minor effect in the calculation of the thickness.
NE-3362(b)	UG-42	Bolted flanges and studded connections	The requirements for length of stud engagement are relaxed in Section III, 1980 Code.

APPENDIX C

.

COMPARATIVE EVALUATIONS AND MODEL STUDIES



	Project	C5257	and a second state	Page C- 2
A Division of The Franklin Institute The Benjamin Franklin Park-ay, Phila, Pa 19103	By MD	Date 047, '81	Ch'k'd Date	Rev. Date
CASE ST	UDY _1-			
The allowable stress for	structural st	il subject	t'to sheep	
is specified in section	1.5.1.2 0(the Also	code	
both in the 1963 and	1980 editi	m1 05	cour	
F. = 0.40 F.	(1)	based on th	e sectional are	ea.
However, in the 1920 G	de a new see	tion 15.1	resisting shear	r
introduced stating the	t,			
"At beam end connec	tions where t	he top fla	nge is coped	
and in similar situa	tions where f	silver mi	ght. occur	,
by shear along a pla	me through	the faster	ners, or by a	
Combination of shear	along a plan	e through	h the fastene	~
plus tension along a	perpendicular	plane o	n the area	
effective in resisting t	Earing faile	re: Fr:	= 0.30 F	
where the effective ,	area is the	minimum	net failure	
Surface, bounded by	the bolt R	der."	'	
Referring to the 1980 G	mmentary and	Fig. C.I	.5.1.2	
The connection allowed	ble capacit	j in the t	earing failu	re
mode can be taken	as		0.	
0.30 Av Fu +	- 0.50 At 1		(2)	
where Ar and At are	the net sheer	r and me	t tension	
areas respectively.				
In order to evaluate +	the effect of	the code	change.	
3 sets of each; Mater	al beam size	t coefficient	ients for	
web tear out (Take	le 1-6 page 4	- 11 of the	AISC Steel	1.22.24
Manual) were use	d. 19	~		
The result, obtained	by using equ	tions (1) +	z) above	
indicate that the	1980 Code	gives les	s conservati	~
results as shown on	the following	ng tabulat	ion.	
Therefore, Scale	_ A _	V	in di C	

Eranklin Passarch Contar	Project	C5257	1.5		Page C-	3
A Division of The Franklin Insutute The Benjaman Franklin Parkway, Phila, Pa. 19103	By D	Date 007, '31	Ch'k'd	Date 10/81	Rev.	Date

BEAM END CONNECTION WHERE TOP FLANGE IS COPED, CASE STUDY -1-

FY,PSI	FU, PSI	9,IM	C1	C2	ALLONABL	E LOAD, LB	PCT.
					1963 CODE	1980 CODF	
36000.	60000.	12.00	1.00	0.74	172800.	104400.	40.
36000.	60000.	12.00	1.50	0.74	172800.	134400.	22.
36000.	60000.	24.00	1.00	0.74	345600.	104400.	70.
36000.	60000.	24.00	1.00	2.48	345600.	206900.	40.
36000.	50000.	24.00	1.50	0.74	345600.	134400.	61.
36000.	60000.	24.00	1.50	2.48	345600.	238800.	31.
36000.	60000.	24.00	2.25	0.74	345600.	179400.	42.
36000.	60000.	24.00	2.25	2.18	345600.	283800.	18.
36000.	60000.	36.00	1.00	2.43	510400.	208800.	50.
36000.	60000.	36.00	1.00	4.81	518400.	348600.	33.
36000.	60000.	36.00	1.50	2.48	518400.	236900.	54.
36000.	60000.	36.00	1.50	4.81	518400.	378600.	27.
36000.	60000.	36.00	2.25	2.40	516400.	283800.	45.
36000.	60000.	36.00	2.25	4.81	518400.	423600.	18.
50000.	70000.	12.00	1.00	0.74	240000	121300.	49.
50000.	70000.	12.00	1.50	0.74	240000.	156800.	35.
50000.	70000.	12.00	2.25	0.74	240000.	209300.	13.
50000.	70000.	24.00	1.00	0.74	480000	121800.	75.
50000.	70000.	24.00	1.00	2.45	480000	243600.	49.
50000-	70000.	24.00	1.50	0.74	480000	156800.	67.
50090.	70000.	24.00	1.50	2.48	480000	278600-	47.
50000.	70000.	24.00	2.25	0.74	480000	204300.	56.
50000.	70000	24.00	2 25	2 48	480000	231100	31
50000.	70000	36.00	1.00	2.48	720000	243500	54.
50000-	70000.	36.00	1.00	4.81	720000	405700	44
50000.	70000	36.00	1 50	2 49	720000	278600	61
50000	70000	36.00	1 50	A 91	720000	210000.	20
50000	20000	36.00	2 35	2 49	720000.	231100.	57.
50000	70000.	36.00	2.25	4 91	720000.	101200	34.
65000	80000	12.00	1.00	4.71	720000.	494200.	51.
65000	80000.	12.00	1.00	0.74	312000.	139200.	33.
65000	80000	12.00	2.30	0.74	312000.	179200.	13.
65000.	80000.	24.00	2.73	0.74	312000.	130200.	23.
65000.	80000.	24.00	1.00	0.14	624000.	139200.	10.
65000.	80000.	24.00	1.00	2.48	624000.	278400.	>>.
65000.	80000.	24.00	1.50	0.14	624000.	1/4200.	/1.
65000.	80000.	24.00	1.50	2.48	624000.	318400.	49.
65000.	80000.	24.00	2.25	0.14	624000.	239200.	62.
65000.	80000.	24.00	2.25	2.48	624000.	378400.	39.
65000.	80000.	36.00	1.00	1.40	936000.	278400.	70.
65000.	80000.	36.00	1.00	4.81	936000.	464800.	50.
65000.	80000.	36.00	1.50	2.48	936000.	318400.	66.
65000.	80000.	30.00	1.50	4.81	936000.	504800.	46.
65000.	P0000.	36.00	2.25	2.48	936000.	378400.	00.
65000.	80000.	36.00	2.25	4.81	936000.	564800.	40.

NOTES:

1- ALLOWABLE LOADS ARE GIVEN PER INCH OF WEB THICKNESS 2- PCT= PERCENT OF THE REDUCTION OF PERCEIVED MARGIN OF SAFETY

Tinne	Project	C5257		Page C= 4
A Division of The Franklin Institute The Benjaman Franklin Parkway, Phila, Pa. 19103	BY RK/MD	Date 10/81	Ch'k'd Date	Rev. Date
CASE S COMPARING SHORT COLUM BY 318-53 AND 349-76	TUDY 2	25 [#]	$A_{g} = 625$ $\frac{x.01}{6.25}$ $4 - #11 = 6$	IN ² = P IN ² 5.24 IN ²
	Ľ	1 S. J. J.	CLOSE TO	1% Fg
SHORT COLUMNS SEC. 1403 @ (AND 1402 AC	I 318-63)			
P= .85 [(Ag (.25 f2 + fs. Pg)]		$f_{s} = 3,000$ $f_{s} = .4 \times 40$	±1 PS1 ,000 = 16,000	PSI)
= .85 [625 IN2 (.25 (3,00	0) + 16,000 (.01)	x	
= .85 [625 (750 + 160)] =	483,000	SERVICE L	(040)	
BY 349-76 SEC. 10.3.6				
$P_{u} = \phi \cdot 80[.85 f_{c}^{2}(A_{g} - A_{st})]$	+ fy Ast]			
= .7(.8)[(.85)(3,000)(62	5-6.24)+40	,000(6.24)]	
56 [1578,000 + 24	9,600]= <u>1,</u>	023.000 (ULT. LOAD)	
USING LOAD FACTORS C	DF D.L.=1 Z = 1.55			
THEN SERVICE LOAD =	1,023,0	00 = 660	000	
INCREASE OF	483 x	00 % = <u>36.</u>	6 %	
CONCLUSION: FOR SHORT MUCH MOR	COLUMNS"	THE PREVIOU	us codes w	1225

Execution Descents Constant	Project C5257	Page C- 5
A Division of The Franklin Institute The Benjamun Franklin Parkway, Phila, Pa. 19103	By Date Ch'k'd Di RK/MD 10/31 2010 10	ate Rev. Date
CAS Sample Comparis (Ultimate) ar	SE STUDY -3- son Between Strength nd Alternate (Working Stre	ess) Designs
Sample Section 50'' $57''$ $57'''$ $57'''$ $57''$ $57''$ $57''$ $57''$ $57''$ $57'$	<u>Allowable Stresses</u> Concrete: 3000 lb/ in^2 (fc = 3.000, $fc = 1350$, Reinforcing steel: Grade 40 ($fy = 40.000$ lb/ in^2 , $fs = 20$ to bars = 12.66 in^2	jrade n=9) 1,000 (b/in2)
I. By <u>Strength</u> $f = \frac{12.66}{18 \times 57} = .0$ $q = .01234 \left(\frac{40}{3}\right)$	Design (There is a limit 1234 But a "reasonable" is half of this.))=.1645	of .0278, design
Mu = .9 [(18") 23.45	(57")² (3 K/in²)(.1645)(15 50 "K	59(.1645)]=
Assuming L.	$L = D.L$, $U = \frac{1.4 + 1.7}{2} =$	1.55(D+L)
The moment ther moment of =	n is equivalent to a 's 23,450 ' \times /1.55 = 15,130 'K	ervice"

Franklin Research Conter	Project	C5257			Page C-	6
A Division of The Franklin Institute The Jenjamin Franklin Parkway, Phila, Pa. 19103	BY RK/MD	Date 10/31	Ch'k'd	Date [2]ξ]	Rev.	Date
		^с				
I. BY Alternate	Design					
	1.1.1.1					
Finding the location	on of the	e neutral	axis	×(=	Kd)	
$18 \times (\frac{1}{2}) = 9($	12.66) (57-	- ×)				
solving, x = Kd	= 21.27"					
the r	noment a	rm = jd = 1	57 - 21	- 27 =	49.91	
Then $M_{c} = \frac{1}{2} (1.35)$	· K/in2)(18".)(21.27°)	(49.91	") = 1	2,900"	k
and $M_s = 12.66$ m	2(20 K/m2))(49.91")	= 12,	640 **	<	
			<	Gover	ms)	

TL Comparison:

 $\frac{15,130^{*K} - 12,640^{*K}}{12,640^{*K}} \times 100\% = 19.7\% \text{ ADVANTAGE}$

Conclusion	1	For Rectang	ular	Beams,	
		The working s	Stress	Designs	
	C	commonly used	when	following the	earlier
		ACI 318 codes) wer	e considera	bly more
		conservative.			1

Examplelia Passarah Canton	Project C5257					Page C = 7	
A Division of The Franklin Institute The Benjamen Franklin Parkwey, Phila, Pa. 19103	BY D	Date SEPT. 31	Ch'k'd	Date 13/2/	Rev.	Date	

CASE STUDY -4 -

Ref AISC 1980 CODE

Subsection 2.4 Columns

"In the plane of bending of columns which would develop a plastic himge at ultimate loading, the slenderness ratio f shall not exceed Cc, "

where $C_{e} = \sqrt{\frac{2\pi^{2}E}{Fy}}$ $E = 29 \times 10^{3} \text{ KSI}$ $F_{y} = \text{ yield Stress}$ Therefore $\frac{l}{r} \leq \frac{756.6}{\sqrt{Fy}}$

Ref AISC 1963 Code

Subsection 2.3 Columns

" In the plane of bending of columns which would develop a plastic hinge at ultimate loading, the slenderness ratio shall not exced 120, ... "

$$\frac{l}{r} \leq 120$$

Franklin Research Center	Project C5257					8
A Division of The Franklin Institute	By	Date	Ch'k'd	Date	Rev.	Date
The Benjaman Franklin Parkway, Phila, Pa. 19103	MD	SEPT. 31	Em D.	10/21		

which of the two codes is the more restrictive on l/r ratio depends on the yield strength of the steel used for the columns.

1) Both codes give $\frac{l}{r} = 120$ when

 $C_{c} = \frac{756.6}{\sqrt{F_{3}}} = 120$

then,

2) The 1980 Code is 5% more conservative when

$$\frac{l}{r} = 114 = \frac{756.6}{JFy}$$

then, $Fy = 44$ KSI

Conclusion:

Scale

Franklin Bassarah Canton	Project	C5257			Page C-	. 9
A Division of The Franklin Institute The Benjamin Parkway, Phila, Pa. 19103	BY MD	Date SEPT 31	Ch'k'd	Date 10/21	Rev.	Date

CASE STUDY -5-

Ref Alsc 1980 Code

Subsection 1.10.5.3

" In girders designed on the basis of tension field action, the spacing between stiffeners at end panels, at panels containing large holes, and at panels adjacent to panels containing large holes shall be such that fu does not exceed the value given " below

$$F_V = \frac{F_y}{289} C_V \leq 0.4 F_y$$

Where

$$C_{V} = \frac{45000 \, k}{F_{y} (h/t)^{2}} \quad \text{when } C_{V} \leq 0.8$$

$$R = 4 + \frac{5.34}{(a/h)^{2}} \quad \text{when } a/h \leq 1.0$$

$$= 5.34 + \frac{4}{(a/h)^{2}} \quad \text{when } a/h > 1.0$$

Franklin Persearch Center	Project	C5257			Page C-	. 10
A Division of The Franklin Institute The Benjamin Franklin Parlivery Phila. Pa. 19103	BY	Date SEPT. 81	Ch'k'd	Date 13/81	Rev.	Date

Ref AISC 1963 Code

Subsection 1.10.5.3

" The spacing between stiffeners at end panels and panels containing large holes shall be such that the smaller panel dimension a or h shall not exceed

11000t "

Franklin Research Center	Project	C5257			Page C-	11
A Division of The Franklin Institute The Benjamen Frankin Parkway, Phila. Pa 19103	BY	Date SEP T. 81	Ch'k'd	Date 19/21	Rev.	Date

÷.



from 1.10.5.3 1963 Code

a or h $\Rightarrow \frac{11000t}{\sqrt{fr}} = \frac{11000 \times 3/8}{\sqrt{9.06 \times 1000}} = 43$ in

Which is the distance from the end of the girder to the first transverse stiffemer.

By considering the tension field action as specified TM 1980 Code subsection 1.10.7.3 for = 9.06 KS1 $\frac{h}{t} = \frac{68}{.375} = 181$ $\notin \frac{a}{h} = \frac{42}{.68} = .618$ $k = 4 + \frac{5.34}{(a/h)^2} = 4 + \frac{5.34}{(.618)^2} = 17.98$ $C_{v} = \frac{45000 fk}{Fy} (-fk/t)^2 = \frac{45000 \times 17.98}{36 (.181)^2} = .686$ $F_{v} = \frac{F_{v}}{F_{y}} C_{v} \leq .4F_{y}$ $= \frac{36}{2.89} \times .686 = 8.54 \times 51 \notin \text{ from table 10.36 the}$ Allowable shear stress ≈ 8.6 Ksi (checks computed Value) however, lower than f_{v} of 9.06 Ksi \therefore Scale B for this example
Franklin Research Center	Project C5257					12
A Division of The Franklin Institute	By	Date	Ch'k'd	Date	Rev.	Date
The Benjamen Franklin Parkway, Phila. Pa. 19103	MD	SEPT. 'BI	8.11.1.	13/21		

Remarks

The following two figures show FV VS. A/Tfor various values of A/H and Fy. By knowing the shear stress FV or FV' the A/T value can be abtained and compared with the design A/T. Thus comparison should be examined on a case by case basis.





	Project	Project C5257				
A Division of The Franklin Institute The Benjamin Franklin Parkway, Phila, Pa. 19103	av ND	Date SEPT. '81	Ch'k'd Date	Rev.	Date	
CASE STUD	Y -6-					
Ref AISC 1980	Code					
Section 2.7						

rolled W, M, or S shapes and similar built-up single-web shapes that would be subjected to compression involving hinge rotation under ultimate loading shall not exceed the following values:"

> The width - thickness ratio of similarly compressed flange plates in box sections and cover plates shall not exceed 190/JFz "



×31	-
F4	6/t
36	31.7
50	26.9
75	22
(00)	19

	Project C5257				Page	16	
A Division of The Franklin Institute The Benjaman Frenklin Perkwey, Phila, Pe. 19103	By MD	SEP	Date T. '81	Ch'k'd	Date 10/51	Rev.	Dat
				p-n-x			
			* 1. T				
"The death - this	Vare		1.2				
aepin - Inic	kness rat	to of	webs	of			
shall ant around	ted to p	lastic	Denda	Pang			
Simil not exceed	••••						
$d/t = \frac{412}{12}(1 - 1)$	1.4 P) (when -	P 40	.27			
Vry	1.9		3	-			
		ty.	a/.	£			
For = = 0.0		36	68.	7			
5		75	47.	6			
		100	41.	2	an a		
$d/t = \frac{251}{E}$ whe	n f >	0.27					
113	123						
	-3	Fy	d/t				
		36	42.	8			
		50	36 .	3			
		75	30				
		100	25.7	7			
		100	25.7	7			

TING	Project	Project C5257		
A Division of The Franklin Institute The Benjamin Franklin Parkway, Phila, Pa 19103	By MD	Date SEPT. '81	Ch'k'd Date E.M. J 13/81	Rev. Da
Ref AISC (963 Section 2.6	Code			
" Projecting el to compression under ultime thickness ro following: bf	ement, the m involvi ate loading atio no q $2t_f \leq 8$	at would be ng plastic h shall have greater than 5 Rolled 2 Box Sec	subjected inge rotatio width - the Shapes stions	M
"The depth and girde bending " formula $43 \leq d/$	r webs s is give ∕w ≤ 70	ratio of b ubjected to n by the f 0-100 P	plastic ollowing	
Remarks				
The 1963 Co for A36 of the two code If the struct having high	ode take Fy = 36 k es are t cture was her yield,	into account isi or less he same for designed usin the design	material (note that Fy=36). g material might not	

.

 $F_{y} \leq 36 \text{ Ks1} \bigcirc$ $36 \langle F_{y} \langle 38 \text{ Ks1} \bigcirc$ $F_{y} \geq 38 \text{ Ks1} \bigcirc$

Franklin Research Center	Project	C5257			Page C-	18
A Division of The Franklin Institute The Benjamin Franklin Parkway, Phila, Pa. 19103	BY D	SEPT. 81	Ch'k'd	Date 10/81	Rev.	Date

CASE STUDY -7-

Ref Alsc 1980 Code Section 2.9 Lateral Bracing

" Members shall be adequately braced to resist lateral and torsional displacements The laterally unsupported distance, lcr, ... shall not exceed the value determined from "

$$\frac{lcr}{r_{y}} = \frac{1375}{F_{y}} + 25 \quad \text{when} \quad 1.0 > \frac{M}{M_{p}} > -0.5$$

or $\frac{lcr}{r_{y}} = \frac{1375}{F_{y}} \quad \text{when} \quad -0.5 \ge \frac{M}{M_{p}} > -1.0$

lcr/ry	Fy= 36 KSI	50	75	100
1>M, >5	63.2	52.5	43 3	38.75
5 M 7-1.0	38.2	27.5	18.3	13.75

example

C

× -

Franklin Provention	Project	C5257	1998 - 19 4 -	Page C= 19
A Division of The Franklin Institute The Benjaman Franklin Parkway, Phila, Pa. 19103	ву МО	Date SEPT. 181	Cr.'k'd Date E.M.W. 10/21	Rey, De
Ref AISC 1963	Code			
Section 2.8 L	-ateral B	racing		
When the mor	ment de	finition is		
the formula	for for	/ru become	:	
	10,	.,9		
$35 < \frac{ler}{r_y} = 6c$	+ 40 2	1p		
example M lcr				
Mp Ty				
0 60				
5 40		8		
······				
CONSLUSIONS				
The figure w	hich follo	ws (lor/	vs. M/	10)
indicates that for	A-36 steel	(Feseksi) Scale	σ ,	·F -
0 < Mp <		<u> </u>		

Note: The summary is based on material with Fy=36, other material should be examined on a case by case basis.

	Project	Project C5257				Page C- 20		
A Division of The Franklin Institute The Benjamen Franklin Parkway, Phila, Pa. 19103	By D	SEPT	Date	Ch'k'd	Date 12,81	Rev.	Dat	
The Benjamin Franklin Parkway, Phila. Pa. 19103	MD	SEPT	81	Emil.	12,81			
Lor 1								
J 100		1						
qa	•	Limit	Using					
30	-/		963 00	0E				
70-	/ .	y = 36 KSI						
60		4=50 KSI						
50		4= 75 KSI						
35 - 50								
-15 0	, .5	1	M	- 				
				()p				
	Sec.							

Enaldia Paranah Canta	Project C5257			Page C- 21	
A Division of The Franklin Institute The Benjamin Franklin Parkway, Phila, Pa. 19103	BYRA	SEPT 81	Ch'k'd Date EM. W. 10/81	Rev.	Dat
<u>CASE</u> STU Comparison of Se	JDY -	- <u>8-</u> 3, Colum	ms (AISC)	. 1963)
with Section 2.4	, Colu	umns (Alsc	, 1980)		
AISC 1963		AISC	1980		
1. Stenderness ratio for in continuos frames wh sideway is not prevented, limited by Formula (20) $\frac{2P}{Py} + \frac{l}{70r} \leq 1.0$ This limits stenderness Ratio $\frac{l}{r} \leq 70$ and a load not to exceed 0.3 for $\frac{l}{r} = 0$. Also lim by Formula (26) given	columns lere , Ts)) axial 5 Py nited below.	 Slender Columns i frames when not prevente to only 70 by Formulas (2.9-1b) f not to as given 	rness rati in continu re Sidesw ed, not li 0. But 5 (2.9 - 10 given below exceed C below	o for os ay is imited limite a) and w and ce,	ed d
2. For columns in brace frames the maximum axial load P shall n exceed 0.6 Py.	ced N ot	2. The axi columns 7 not to ex	al load in braced aceed 0.84	in frame: 5 Py	s

(See Case Study 4 also, for Slenderness ratio)

	Project		Page		
A Division of The Franklin Institute The Benjamin Franklin Parkway, Phila, Pa. 19103	BYRA	Date SEPT '81	Ch'k'd Date	Rev.	Date
 3. a) Slenderness ratio \$\overline{\overline{1}}\$ not to exceed 12 b) The allowable laterally unsupported distance \$\overline{1}\$ co = (60 - 40 \overline{\overline{1}\$} co) ry, Formula(26) But Ler \$\overline{3}\$ c) \$\overline{1}\$ not to exceed \$\overline{3}\$ not to exceed \$\overline{3}\$ to any case 	35ry 3 b d ft le r) An l vi 3c.	a. a Slend $rac{l}{r}$ not to here $Cc =$ d for Fc the later stance lcr $rac{r}{Fy} +$ $rac{r}{Fy} +$ $rac{r}{Fy}$	erness rati exceed C $\sqrt{\frac{2\pi^2 E}{Fy}}$ Fy = 36 K C = 126. rally unsupp not to e 25 (2.9 $1.0 > \frac{M}{Mp} > 1.0$ (2.9 - 1.0) to exceed case.	o si, 1 ported exceed -1a) -0.5 -1b) 200 in	

A Division of The Franklin Institute	Q.,	Project C5257				
	RA	SEPT 81	Ch'k'd Date	Rev.	Da	
	신상					
4(a) Interaction formulas -	for 4.1	Interaction f	ormulas	are		
single curvature are		En la Can				
$M \in B - G(P) \leq 1.0$		P Cm M	-2)			
$M_P = 0 q (P_y) = 1.0$	-	$\frac{1}{Pcr} + \frac{Cm}{(1-\frac{P}{P})}$	-) Mm = 1.1	0		
M = MP		re				
and Formula (23)	.2 0	and Formula	(2.4-3)			
$\frac{M}{Mp} \leq 1.0 - H(\frac{M}{Py}) - J(\frac{1}{2})$	/py)	Py + 1.18 Mp	≤ 1.0; M	≤ Mp		
Values of B, G, H and	JV	here Par =	1.7 A Fa			
listed in tables as a		Pe =	23 A Fé			
function of slenderness ro and Fu	utio		12			
		a given by	(1.5-1)	and		
(b) Interaction formulas for		M = Ma /	Section 1.	6.1		
double curvature are		vim - i-ip (veak direct	iton)		
M 4 Ma fr P/2 4 au	5	= [107	-(2/2) TEV	Ta		
M (1) P + P / P) (P	- I	L 1.01	3160	JMps	= M	
Mp = 1.18 -1.18 (1/Py) = 1.0		(unbrace	d in weak	direct	10	
for P/py 2 0.15	100					
and Formula (22)	0	.) For single	curvature			
$\frac{M_{P}}{M_{P}} \leq B - G\left(\frac{P}{P_{V}}\right) \leq 1.0$;	0.6 5 For daub	$Cm \leq 1.0$			
M 4 M-	D	0.4 5	Cm = 0.6	ure		

Eranklin Passarah Castar	Project	C5257		Page C- 24
A Division of The Franklin Institute The Benjaman Franklin Parkway, Phila, Pa 19103	RA	SEPT'81	Ch'k'd Date	Rev. Date
For comparison of these P/py Vs M/mp are of 30,70 and 100 with Fy = 36 ksi has for our purposes Sey Single curvature (0.6 s Curvature (0.4 & Cm & For frames with sid graphs of P/py Vs two types of colum	specifica drawn fo Typic been tak parate gr = Cm ≤ 1 0.6) c lesway (M/Mp 14	tions, gray r slender al Column ien as an aphs are a .0) and a ases. (m = 0.85 are draw WF 150 an	phs of ness ratio 14 WF 150 example drawn for double) allowed n for d 12 WF G	
with Fy = 36 Ksi, in the weak direction It can be infe	Columns 1.	assumed to	o be brace	ed .
in all cases, the of allowable axial 0.5 Py to 0.75 Py allowed) and 0.6 Columns. But the in both codes is curvature we notic (2.4-2) line for	major c load, wi for un Py to accept almost ce for Cm=1.0	thange Ts hange Ts hich is m braced coll o.85 Py for able design same. For $\frac{Kl}{r} = 30$ Ts b	the limit icreased f umns (Sid r braced n region or single the Foi elow, the	rom esway
formula (23) line, and for $\frac{kl}{r} = 100$, is above the form $\frac{kl}{r} = 30$ 1980 cod while for $\frac{kl}{r} = 100$, <u>conservative</u> . This best as a B	but for the form mula (23 e being 1963 change change	$\frac{kl}{r} = 70,$ $ula (2.4 - 2)$ $line.$ $more \ Con$ $code \ seen$ $can \ thus$	they ove for Cm thus for servative, ns to be be classi	r lap = 1.0 <u>more</u> ified













$100000 \text{ fraction of the Fraction matrix fraction in the field of the field of$	Franklin Passarch Contor	Project	C5257			Page C-	. 31
$\begin{aligned} y + y + y + y + y + y + y + y + y + y $	A Division of The Franklin Institute The Benjamon Franklin Parkway, Phila, Pa. 19103	BYRA	Date SEPT'81	Ch'k'd	Date 12/21	Rev.	Date
$y_{y} = 16 \text{ km} \qquad \frac{41}{p} \neq 10 (2.5 \text{ cm}) \qquad 190 \text{ Code}$ $\frac{190 \text{ Code}}{p_{y}^{2}} \qquad 190 \text{ Code}$ $\frac{190 \text{ Code}}{p_{y}^{2}} \qquad 190 \text{ Code}$ $\frac{190 \text{ Code}}{p_{y}^{2}} = 1.0 + 1.18(P/Py) \pm 1.0 \qquad (1 + 1) \frac{p}{p_{x}} + \frac{Q}{(1 + \frac{Q}{p_{y}})} + \frac{1}{p_{y}} + \frac{Q}{p_{y}}}{p_{y}^{2}} \qquad (2 + 1) \frac{p}{p_{y}} + \frac{Q}{(1 + \frac{Q}{p_{y}})} + \frac{1}{p_{y}} + \frac{Q}{p_{y}}}{p_{y}^{2}}$ $Pormale (2) \frac{M}{p_{y}} = 1.0 - 8(P/Py) \pm 1.0 \qquad (1 + 1) \frac{p}{p_{y}} + \frac{1}{118m_{y}} \pm 1.0, \text{ M} \pm m_{y}}{p_{y}^{2}} \qquad (2 + 1) \frac{p}{p_{y}} + \frac{1}{118m_{y}} \pm 1.0, \text{ M} \pm m_{y}}{p_{y}^{2}}$ $Pormale (2) \frac{M}{p_{y}} = 1.0 - 8(P/Py) - 1(P/Py)^{2}$ $Pormale (2) \frac{M}{p_{y}} = \frac{1}{p_{y}} + $							
$F_{y} = 16 \text{ kell} \qquad \frac{11}{y} = 30 + 12 \text{ error} 3$ $\frac{1380 \text{ Code}}{1380 \text{ Code}}$ Fermula (21) $H = H_{y}$ when $P/P_{y} \leq 0.15$ $\frac{H_{y}}{H_{y}} \leq 1.16 + 1.18(P/P_{y}) \leq 1.0$ $(2.4-3)$ $\frac{1}{y} = \frac{1}{y} + \frac{1}{(1 + \frac{1}{y})} \frac{1}{y} = 1.0$ $C_{g} = 0.35$ Fermula (22) $\frac{H}{H_{y}} \leq \frac{1}{y} = 0 + R(P/P_{y}) = 1.0$ $H = \frac{H}{H_{y}} + \frac{H}{1.18K_{y}} \leq 1.0, \text{ M} \leq W_{y}$ Fermula (23) $\frac{H}{H_{y}} \leq 1.0 - R(P/P_{y}) = 1/(P/P_{y})^{2}$ Therewise (23) $\frac{H}{H_{y}} \leq 1.0 - R(P/P_{y}) = 1/(P/P_{y})^{2}$ $\frac{1}{M_{y}} = \frac{1}{M_{y}} + \frac{H}{M_{y}} = \frac{1}{M_{y}} + \frac{H}{M_{y}} = \frac{1}{M_{y}} + \frac{H}{M_{y}} = \frac{1}{M_{y}} + \frac{H}{M_{y}} = \frac{1}{M_{y}} = \frac{1}{M_{y}} + \frac{H}{M_{y}} = \frac{1}{M_{y}} + \frac{H}{M_{y}} = \frac{1}{M_{y}} + \frac{H}{M_{y}} = \frac{1}{M_{y}} + \frac{H}{M_{y}} = \frac{1}{M_{y}} = \frac{1}{M_{y}} + \frac{H}{M_{y}} = \frac{1}{M_{y}} + \frac{H}{M_{y}} = \frac{1}{M_{y}} = \frac{1}{M_{y}} + \frac{H}{M_{y}} = \frac{1}{M_{y}} = \frac{1}{M_{y}} = \frac{1}{M_{y}} + \frac{H}{M_{y}} = \frac{1}{M_{y}} = \frac{1}{M_$							
1952 Code $1950 Code$ $100 Code$ 100	$F_{\gamma} = 36 \text{ ksi} \qquad \frac{k1}{r} = 30$) 12 w# +5	SIDESWAY ALLOWED				
Formula (21) $H = H_{y}$ when $P/P_{y} \le 0.15$ $\frac{H_{y}}{H_{y}} \le 1.18 - 1.18(P/P_{y}) \le 1.0$ $H \le H_{y}$ Formula (22) $\frac{H}{H_{y}} \le 8-C(P/P_{y}) \le 1.0$ $H \le H_{y}$ (2.4-3) $\frac{P}{P_{y}} + \frac{C_{y}H}{1.1845_{y}} \le 1.0, H \le H_{y}$ Formula (23) $\frac{H}{H_{y}} \le 1.0 - R(P/P_{y}) = 1(P/P_{y})^{2}$ THIOL EXAMPLE $\frac{199}{H_{y}} = \frac{1}{2} (0.9 + 10^{-10})$ $\frac{1993}{H_{y}} = \frac{1}{2} (0.0 + 10^{-10})$ $\frac{1993}{H_{y}} = \frac{1}$	1963 Code		1980 Code				
$\frac{1}{N_{p}} \leq 1.13 + 1.18(P/Py) \leq 1.0$ $\frac{1}{P_{p}} \leq \frac{1}{P_{p}} + \frac{1}{(1 - \frac{p}{P_{p}})N_{p}} \leq 1.0$ $\frac{1}{N_{p}} \leq \frac{1}{P_{p}} + \frac{1}{N_{p}} = 1.0, \text{ M} \leq N_{p}$ Formula (22) $\frac{N}{N_{p}} \leq \frac{1}{P_{p}} + \frac{1}{2} + \frac{N}{1.18N_{p}} \leq 1.0, \text{ M} \leq N_{p}$ Formula (23) $\frac{N}{N_{p}} \leq 1.0 + \frac{1}{2}(P/Py) - \frac{1}{2}(P/Py)^{2}$ $\frac{10}{N_{p}} = \frac{1}{1.0 + \frac{1}{2}(P/Py)} = \frac{1}{2}(P/Py)^{2}$ $\frac{10}{N_{p}} = \frac{1}{N_{p}} = \frac$	Formula (21) $M = M_p$ when $P/Py \le 0.15$		с_м		1.5		
Formula (22) $\frac{H}{N} \leq B - G(P/Fyr) \leq 1.0$ $H \leq H_p$ Formula (23) $\frac{H}{N_p} \leq 1.0 - H(P/Fyr) - J(P/Fyr)^2$ TIPICAL DELAPTIS $M \leq M$ $M \leq M$ $M \leq M$ $M \leq M$ 1963 Code Also Imposes the Following Limit $\frac{2P}{F_y} + \frac{1}{10y} \leq 1.0$ Formula (20) $\frac{2P}{F_y} + \frac{1}{10y} \leq 1.0$ Formula (20) $\frac{1963}{1963} - \frac{100}{100} - \frac{100}$	$\frac{M}{M_p} \le 1.18 - 1.18(P/Py) \le 1$.0 (2.4-2) P	$\frac{1}{(1-\frac{p}{p})N_p} \leq 1.0$	c =0.8	5		
Formula (23) $\frac{M}{M_p} \leq 1.0 - H(P/Py) - 2(P/Py)^2$ TITICAL EXAMPLES $M \leq M_p$ $M \leq$	Formula (22) $\frac{M}{M_p} \leq B-G(P/Py) \leq 1.0$	(2.4-3) <u>P</u>	<u> </u>				
Formula (23) $\frac{M}{H_2} \leq 1.0 - B(F/Py) = J(F/Py)^2$ TTPICAL EXAMPLES $\int \int $	M ≤ Mp	y y	1.18Mp = 1.0, A =	ζ.			
TTICAL EXAPLISE $\int_{\mathbf{x}} \int_{\mathbf{x}} \int_$	Formula (23) H < 1.0 - H(P/Py) - J(P/Py)) ²					
TIFICAL EXAMPLES $ \int_{X} \int_{$	- en	M < M.					
$\frac{2}{2} - \frac{1}{2}$	TYPICAL EXAMPLES						
$P_{p_{Y}}$ P_{q} $P_{p_{Y}}$ P_{q} $P_{p_{Y}}$ P_{q} P_{q	Y -						
$F_{py} = 4$ $F_{py} = 4$ $1963 \text{ Code Also Imposes the Following Limit \frac{2P}{P_y} + \frac{1}{70y} \leq 1.0 \text{ Formula (20)} 1963 \text{ Code Limit \frac{2P}{P_y} + \frac{1}{70y} \leq 1.0 \text{ Formula (20)} 1963 \text{ Code Limit 1963 \text{ Code Limit } 1963 Code Limit$							
$\frac{7}{P_{Y}} = \frac{4.4}{1963} \text{ Code Also Imposes the Following Limit}$ $\frac{2P}{P_{Y}} + \frac{1}{10Y} \leq 1.0 \text{ Formula (20)}$ $\frac{2P}{P_{Y}} + \frac{1}{10Y} \leq 1.0 \text{ Formula (20)}$ $\frac{1}{1963} \text{ Code Limit}$ $\frac{2P}{P_{Y}} + \frac{1}{10Y} \leq 1.0 \text{ Formula (20)}$ $\frac{1}{1963} \frac{1}{1963} $	1.0						
$\frac{27}{P_y} + \frac{1}{70y} \leq 1.0 \text{Formula (20)}$	7/py 0.9	1963 Code Als	o Imposes the Follow	ing Limit			
0.7 0.6 0.7 0.4 0.4 0.4 0.4 0.4 0.4 0.4 0.4	0.5 1480 CODE LIMIT	$\frac{2P}{P_y} + \frac{1}{70\gamma}$	<1.0 Formula (20)				
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	M1 54		1				
0.4 0.4 0.3 0.4 0.4 0.4 0.4 0.4 0.4 0.4 0.4		Ser Con	1				
0.4 0.3 0.4 0.4 0.4 0.4 0.4 0.5 0.5 0.7 0.5 0.9 1.0 1.0 1.0 1.0 1.0 1.0 1.0 1.0	**5 -	N.	1				
0 01 0.2 4.3 6.4 6.7 0.6 0.7 0.8 0.9 1.0	0.4-	/					
04 0.2 4.3 4.4 A.T 0.6 0.7 0.8 0.9 1.0	03- 1963 COOP LIMIT		The				
0 04 0.2 1.3 1.4 2.5 0.6 0.7 0.8 0.9 1.0	ar -) is				
0 01 0.2 1.3 1.4 5.5 0.6 0.7 0.8 0.9 1.0	04 -		1				
	0 04 0.2 1.3 1.4	0.5 0.6 0.7	0.8 0.9 1.0				

	Project	C5257	Page C- 32
A Division of The Franklin Institute The Benjamin Franklin Parkway, Phila, Pa. 19103	BYRA	SEPT'81 Ch'k'd	Date Rev. Dat 19/21
$F_y = 36 \text{ kml} \frac{\text{kl}}{\tau}$	• 30 14 wF 150	SIDESWAY ALLOWED	
1963 Code	14	1980 Code	
$\frac{M}{M_{p}} \le 1.18 - 1.18(P/Py)$) <u>≤</u> 1.0 (2.4-2)	<u>p</u> _ C_M ≤ 1.0	
Formula (22) H < B-G(F/Py) < 1.0		$\int_{e}^{p} cr \left(1 - \frac{p}{p}\right) M_{p}$	C ₃ =0.85
^р н <u>≤</u> н _р	(2.4-3)	$\frac{\frac{p}{p}}{\frac{p}{y}} + \frac{M}{1.18M_p} \leq 1.0, \ M \leq M_p$	
Formula (23) $\frac{M}{M_p} \le 1.0 - H(P/Py) - J$	(P/Py) ²	4	
TYPICAL EXAMPLES	JA TT		
	¥¥	7	
P 10	-		
-P.4	1963 Code	Also Imposes the Following L	imit
0.5 HOTO CODE UMIT	$\frac{2P}{P_y} + \frac{1}{7}$	1.0 Formula (20)	
04	A		
	1. 2. 4. 1.		
.+-			
N3 1963 CODE LIMIT		eff-	
al-		and the second	
		· \	
0	19 15 16	0.7 0.8 0.9 (.)	

English Research Contes	Project	C5257			Page C-	33
A Division of The Franklin Institute The Benjamen Franklin Parkway, Phila, Pa. 19103	BYRA	OLT 81	Ch'k'd	Date 11/81	Rev.	Date

CASE STUDY -9-

Comparison of AISC - 1980 Section 1.10.6 with AISC - 1963 Section 1.10.6, Reduction in Flange Stress, Hybrid Girders only.

The only change between the two codes is the introduction of Formula (1.10-6) for case of hybrid girder, in the 1980 code. Formula (1.10-5) of 1980 Code with Fb in Ksi is identical to Formula (12) of 1963 with Fb in Psi. Hybrid girder designed in 1963 would be designed in accordance with Formula (12) which is identical to (1.10-5) in 1980 Code. But a hybrid girder designed in accordance with 1980 has to conform to both Formulas (1.10-5) and (1.10-6). For Fb=25 Ksi and 50 ksi, we draw graphs of reduction Factor (Fb) Vs. Area of web to Area of Flange ratio Fb (Aw/Af), using Formulas (1.10-5) and (1-10-6) for given x = 0.3, 0.6, and 0.9 and for given h/t natios (162, 172 & 182, for Fb=25/si and 117, 127 & 137 for Fb=50 Ksi). We find in all six cases depending on Aw/Af ratio for x = 0.45, Formula (1.10-6) in the 19.80 code is quite conservative.

Unit MultiplePreserve Center Main Method \mathbb{P}_{RA} Oct \mathbb{P}_{S1} <th>Use the second of the Franklin InstanceBut for 0.45 < $d \le 0.75$, Formula (1.10-6)or formula (1.10-5)or formula (1.10-5)compared to each other depending on h/t ratiofor given Fb. But for $d > 0.75$, in anycase, Formula (1.10-5)case, Formula (1.10-5)thus we can make the following judgmenton them.OLD Formulasa) Formula (12), 1963 CodeFb \le Fb $[1.0-0.0005 \ Am}{Ar}(\frac{h}{t} - \frac{24000}{1Fb})]$with Fb Th Psi.b) Formula (1.10-5)b) Formula (1.10-5)in the fb Th Rsi.b) Formula (1.10-5)in the fb Th Rsi.b) Formula (1.10-5)in the fb Th Rsi.b) Formula (1.10-5)in the fb Th Rsi.New FormulaIn the fb Th Rsi.In the fb</th> <th>TINT</th> <th>Project</th> <th>C5257</th> <th></th> <th>Pa</th> <th>6- 34</th>	Use the second of the Franklin InstanceBut for 0.45 < $d \le 0.75$, Formula (1.10-6)or formula (1.10-5)or formula (1.10-5)compared to each other depending on h/t ratiofor given Fb. But for $d > 0.75$, in anycase, Formula (1.10-5)case, Formula (1.10-5)thus we can make the following judgmenton them.OLD Formulasa) Formula (12), 1963 CodeFb \le Fb $[1.0-0.0005 \ Am}{Ar}(\frac{h}{t} - \frac{24000}{1Fb})]$ with Fb Th Psi.b) Formula (1.10-5)b) Formula (1.10-5)in the fb Th Rsi.b) Formula (1.10-5)in the fb Th Rsi.b) Formula (1.10-5)in the fb Th Rsi.b) Formula (1.10-5)in the fb Th Rsi.New FormulaIn the fb Th Rsi.In the fb	TINT	Project	C5257		Pa	6- 34
But for 0.45 < $d \le 0.75$, Formula (1.10-6) or Formula (1.10-5) could be conservative as compared to each other depending on h/t ratio for given Fb. But for $d \ge 0.75$, in any case, Formula (1.10-5) is more conservative. Thus we can make the following Judgment on them.	But for $0.45 \le d \le 0.75$, Formula $(1.10-6)$ or Formula $(1.10-5)$ could be conservative as compared to each other depending on h/t ratio for given Fb. But for $d \ge 0.75$, in any case, Formula $(1.10-5)$ is more conservative. Thus we can make the following Judgment on them.	A Division of The Franklin Institute The Benjamin Franklin Parkway, Phila, Pa. 19103	RA	OCT'81	Chikid Emai II	Date Re	ev. Dat
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	$\frac{OLD \text{formulas}}{Fb \leq Fb [1.0 - 0.0005 \frac{Aw}{Af}(\frac{h}{t} - \frac{24000}{\sqrt{Fb}})]} \qquad \qquad$	But for 0.45 < d & or Formula (1.10-5. compared to each or for given Fb. Bu case, Formula (1.1 Thus we can mak on them.	ther dep to -5) is the the	Formula be conser ending or d > 0.75 more co following	CI.10- vative h h/t mservativ Judgm	6) as ratio any le. ent	
b) Formula (1.10-5) 1980 code $F_{b} \leq F_{b} [1.0 - 0.0005 \frac{AW}{Af} (\frac{h}{t} - \frac{760}{\sqrt{F_{b}}})],$ with Fb in Ksi $A_{f} = \frac{760}{\sqrt{F_{b}}} $	b) Formula (1.10-5) 1980 code $F_{b} \leq F_{b} [1.0 - 0.0005 \frac{Aw}{Af} (\frac{h}{t} - \frac{760}{1F_{b}})],$ with F_{b} in K_{si} <u>New Formula</u> Formula (1.10-6) 1980 code	<u>OLD</u> Formulas a) Formula (12), 1963 Cod $F_6 \leq F_6 [1.0 - 0.0005]$	e 4w (는 - 24 17	<u>۳</u>	2 0.45 and	50	cale A
	New Formula (1.10-6) 1980 code 0.75 B	b) Formula (1.10-5) 1980 Fé 5 Fb [1.0 - 0.0005 With Fb in Ksi	$\frac{Aw}{Af}\left(\frac{h}{t}\right)$	<u>76</u> ℃〕,	Awy ro	atio	

.





÷

an de la companya de la comp









Esaldia Research Contra	Project	C5257	- 27		Page C-	41
A Division of The Franklin Institute The Benjamen Franklin Parkwey, Phila. Pa. 19103	BV RA	SEPT'8)	Ch'k'd	Date 10/81	Rev.	Date
A Division of The Franklin Institute The Benjamen Franklin Parkway, Phila, Pa. 19103	RA	SEPT'81	Em.D.	10/81		
	A Discourse of a lot of the second					A second s

Comparison of Section (1.9.1.2) and Appendix C (AISC 1980) with Section 1.9.1 (AISC, 1963); width-thickness ratio of unstiffened elements Subject to axial compression and compression due to bending.

In both sections the limit of width thickness ratio is given for the following various cases.

- CASE I : single angle Struts ; double angle struts with separators
- CASE II: Struts comprising double angles in contact; angles or plates projecting from girders, columns, or other compression members; compression flanges of beams; Stiffeners on plate girders

CASE II : Stems of tees

In AISC, 1980, according to the specifications for the above cases, when compression members exceed the allowable widththickness ratio, the allowable stresses are reduced by a factor based on formulas given in appendix C which depends on yield stress (Fy) and the width - thickness ratio.

Eraphilia Bassarah Contor	Project	C5257			Page C-	42
A Division of The Franklin Institute The Benjamin Franklin Parkway, Phila., Pa. 19103	BY	SEPT'81	Ch'k'd	Date 12/21	Rev.	Date

But according to AISC, 1963 Specifications, When compression members exceed the allowable width - thickness ratio, the member is acceptable if it satisfies the allowable stress requirements with a portion of width ie. effective width meets stress requirements.

For the case study, two values of Fy 36 ksi and 50 ksi are chosen. For the two values for typical angle section and T sections given in AISC Manual graphs flave been plotted for Reduction Factor <u>VS</u> Width - thickness ratio. Reduction Factor for AISC, 1980 Cade is based on formulas given in appendix C and for AISC, 1963, reduction factor is the ratio of effective width to actual width of the section.

Based on the graphs, the change for case I and Case II at higher width/thickness ratio would be a <u>C</u> change, as Specifications were more conservative in 1963 code. But for Case III the change in Specification is <u>A</u> change as it is more conservative in 1980 code, at higher width - thickness ratio.







ï

•






Franklin Bassach Contas	Project	Project C5257				Page C- 49		
A Division of The Franklin Institute The Benjamen Franklin Parkway, Phila, Pa. 19103	RA	Date DCT 8!	Ch'k'd	Date 11/81	Rev.	Date		

CASE STUDY -11 -

Comparison of AISC 1980 Section 1.11.4 with Alsc 1963 Section 1.11.4; Shear connectors for composite beams, where longitudinal reinforcing steel acts with beam .

According to AISC 1980, Formula (1.11-5)

Vh = Asr Fyr/2 (1.11-5)

is given for continuous composite beam where longitudinal reinforcing steel is considered to act compositely with the steel beam in the negative moment regions, to calculate the total horizontal shear to be resisted by shear connectors between an interior support and each adjacent point of contraflexure.

whereas in AISC 1963 specifications, the total horizontal shear to be resisted between the point of maximum positive moment and each end or a point of contraflexure in continuous beams is given as the smaller value of Formula (18) and (19)

VI-	0.85	fé Ac	(
vn-	0.00	2	(18)

and $V_h = \frac{A_s F_y}{7}$ (19)

Franklin Pasaarch Contar	Project	C5257			Page C-	50
A Division of The Franklin Institute The Benjamen Franklin Parkway, Phila, Pa. 19103	BYRA	Date XT'81	Ch'k'd	Date 11/21	Rev.	Date

There is no separate formula for negative moment region in AISC, 1963. The above formulas are the same in AISC, 1980; Formula (1.11-3) and (1.11-4) for the positive moment region. Moreover in AISC, 1963, there is no consideration of reinforcing steel in concrete acting compositely with the steel beam in negative moment regions.

This implies that in computing the section modulus at the points of negative bending, reinforcement parallel to the steel. beam, and lying within the effective width of stab may be included according to AISC, 1980. But it is not allowed to include reinforcing steel in computing the section modulus for the above case as per the specifications of Alsc. 1963. Thus design criteria is being liberalized in AISC 1980. Since the quantification of this liberal criteria is unknown. this change can best be classified as C. Any Composite beam designed as per AISC 1963 specifications will show more moment capacity when calculated according to AISC. 1980 Specifications.

Proj	Project	Project . C5257				51
A Division of The Franklin Institute The Benjaman Franklin Parkway, Phila, Pa. 19103	By CM.V.	Date 10/81	Ch'k'd RK/MD	Date	Rev.	Date

CASE STUDY -12-

The allowable peripheral Shear Stress (punching Shear Stress) as stated in the B & PV ASME Code Section II Div. Z, 1980 (ACI 359-80) Para. CC-3421.6 is limited to Uc where Ue shall be calculated as the weighted average of Uch and Ucm

$$U_{ch} = 4 \int f_{e}^{\prime} \int I + \left(\frac{f_{m}}{4 \int f_{e}^{\prime}} \right)$$

$$U_{cm} = 4 \int f_{e}^{\prime} \int I + \left(\frac{f_{h}}{4 \int f_{e}^{\prime}} \right)$$

The ACI 318-63 Code Section 1707 states that the Ultimate Shear Strength Uu shall not exceed $U_c = 4 \sqrt{f_c}$.

Comparing the above two cases the following is concluded;

When :

5

Scale

Membrane stresses are compressive
 318-63 is more conservative (C)
 Membrane stresses are tensile
 318-63 is less conservative (A)

Franklin Dansah C		Project C5257				Page C-	Page	
A Divis	Iklin Research Center	By mai	Date	Ch'k'd	Date	Rev.	Date	
The Benja	men Franklin Parkway, Phila, Pa. 19103	5. 11100.	10/21	RK/MD	10/31	L		
				Sci	ale			
3.	Membrane stresse	es are	zero					
	318-63 is	identic	al	No r	ating			
4.	Membrane Stress	ec are	apposite					
	in sign	its are	oppositie					
	318-63 Could	be less	con servat	ive	(A))		
	경망 귀엽 감영 것이다.							

Franklin Research Center	Project	C5257			Page C-	53
A Division of The Franklin Institute The Benscren Franklin Parkwey, Phile. Pa 19103	BY S.M.W.	Date 10/21	Ch'k'd RK/MD	Date	Rev.	Date

CASE STUDY -13-

The B & PV ASME Code Section II Division 2 1980 (ACI 359-80) Para. CC-3421.7 states + the shear stress taken by the concrete resulting from pure torsion shall not exceed Vet where

$$U_{ct} = 6 \int \overline{f_c} \sqrt{1 + \frac{f_h + f_m}{6 \int \overline{f_c}'}} + \frac{f_m f_h}{(6 \int \overline{f_c}')^2}$$

While the ACI 318-63 Code Section 1707 limits the ultimate Shear Strength Un to

 $V_c = 4 \int f_c$

From the above two cases the following is concluded;

when :

Scale

- 1. Membrane stresses are compressive 318-63 is more conservative (C)
- 2. Membrane stresses are tensile 318-63 is less conservative (A)

Franklin Research Center	Project	C5257			Page C-	54
A Division of The Franklin Institute The Benjamen Franklin Parkway, Phila, Pa. 19103	BYEANW	Date 10/21	Ch'k'd	Date 10/ 31	Rev.	Date

3

Scale

- 3. Membrane stresses are zero 318-63 is more conservative (C)
- 4. Membrane stresses are opposite in sign 318-63 could be less conservative (A)

APPENDIX D

.

ACI CODE PHILOSOPHIES



ACI CODE PHILOSOPHIES

The American Concrete Institute (ACI) Building Code Requirements for Reinforced Concrete delineate two philosophies of design which have long been in use: the so-called working stress method, which was in general acceptance and predominant use from early in this century to the early 1960's, and the ultimate strength method, which has been rapidly replacing working stress since about 1963.

Working Stress Method

The working stress method of design is referred to as the "alternate design method" by the most recent ACI code. By this method, the designer proportions structural elements so that internal stresses, which result from the action of service loads* and are computed by the principles of elastic mechanics, do not exceed allowable stress values prescribed by the code.

The allowable stresses as prescribed by the ACI code are set such that the stresses under service load conditions will be within the elastic range of behavior for the materials involved. As a result of this, the assumption of straight line stress-strain behavior applies reasonably for properly designed structural members. The member forces used in design by this method are those which result from an elastic analysis of the structure under the action of the service loads.

Ultimate Strength Design

The ultimate strength method is referred to as the "strength method" in the most recent ACI code. By this method, the proportioning of the members is based on the total theoretical strength of the member, satisfying equilibrium and compatibility of stress and strain, at failure. This theoretical strength is modified by capacity reduction factors which attempt to assess the variations to be encountered in material, construction tolerances, and calculation approximation.

^{*}Service loads are defined as those loads which are assumed to occur during the service life of the structure.

Strength Reduction Factor

In the present code, the capacity reduction factor (ϕ) varies for the type of member and is considered to account for the relative seriousness of the member failure as regards the overall integrity of the structure.

Load Factors

Also, by this method, the designer increases the service loads by applying appropriate load factors to obtain the ultimate design loads in an attempt to assess the possibility that the service loads may be exceeded in the life of the structure. The member forces used to proportion members by this method are based on an elastic analysis of the structure under the action of the ultimate design loads.

Importance of Ductility

A critical factor involved in the logic of ultimate strength design is the need to control the mode of failure. The present ACI code, where possible, has incorporated a philosophy of achieving ductility in reinforced concrete designs. Ductility in a structural member is the ability to maintain load carrying capacity while significant, large deformations occur. Ductility in members is a desired quality in structures. It permits significant redistribution of internal loads allowing the structure to readjust its load resistance pattern as critical sections or members approach their limiting capacity. This deformation results in cracking and deflections which provide a means of warning in advance of catastrophic collapse. Under conditions of loading where energy must be absorbed by the structure, member ductility becomes very important.

This concern for preserving ductility appears in the present code in many ways and has guided the changes in code requirements over the recent decades. Where research results have confirmed analysis and intuition, the code has provided for limiting steel percentages, reinforcing details, and controls-all directed at guaranteeing ductility. In those aspects of design where ductility cannot be achieved or insured, the code has required added strength to insure potential failure at the more ductile sections of structures.

Franklin Research Center

Examples of this are evident in the more conservative capacity reduction factors for columns and in the special provisions required for seismic design.

Strength and Serviceability in Design

.

There are many reasons for the recent trend in reinforced concrete codes toward ultimate strength rather than working stress concepts. Research in reinforced concrete has indicated that the strain distributions predicted by working stress computations in general do not exist in the members under load. There are many reasons for this lack of agreement. Concrete is a brittle, non-linear material in its stress-strain behavior, exhibiting a down trend beyond its ultimate stress and characterized by a tensile stress-strain curve which in all its features is approximately on the order of one tenth smaller than its compressive stress-strain curve.

Time-dependent shrinkage and creep strains are often of significant magnitude at service load levels and are difficult to assess by working stress methods. While ultimate strength methods do not eliminate these factors, they become less significant at ultimate load levels. In addition, ultimate strength methods allow for more reasonable approximations to the non-linear concrete stress-strain behavior.

In the analyses of structures, the designer must, by necessity, make certain assumptions which serve to idealize the structures. The primary assumptions are that the structure behaves in a linearly elastic manner, and that the idealized member stiffness is constant throughout each member and constant in time.

Working stress logic does not lend itself well to accounting for variations in stiffness caused by cracking and variations in material properties with time. Although the ultimate strength method in the present code requires an elastic structural analysis to determine member forces for design, it recognizes these limitations and, in concept, anticipates the redistribution resulting from ductile deformation at the most critically stressed sections and in fact proportions members so that redistribution will occur.

D-3

In addition to strength, a design must satisfy serviceability requirements. In some designs, serviceability factors (such as excessive deflection, cracking, or vibration at service load) may prove to be more important than strength. Computations of the various serviceability factors are generally at service load levels; therefore, the present code uses elastic concepts in its controls of serviceability.

Factors of Safety

Factors of safety* are subjects of serious concern in this review. For working stress, the definition of the factor of safety is often considered to be the ratio of yield stress to service load stress. This definition becomes suspect or even incorrect where nonlinear response is involved. For ultimate strength, one definition of factors of safety is the ratio of the load that would cause collapse to the service or working load. As presented in the present code, a factor of safety is included for a variety of reasons, each of which is important but has no direct interrelation with the other.

The present ACI code has divided the provisions for safety into two factors; the overload factors and the capacity reduction factors (considered separately by the code) are both provisions to insure adequate safety but for distinctly different reasons. The code provisions imply that the total theoretical strength to be designed for is the ratio of the overload factor (U) over the capacity reduction factor (ϕ). The present ACI code has assigned values to the above factors such that the ratio U/ ϕ ranges from about 1.5 to 2.4 for reinforced concrete structural elements.

*Factors of safety (FS) are related to margins of safety (MS) through the relation, MS = FS - 1.

Franklin Research Center